

Recommended Practice for Oil and Gas Producing and Gas Processing Plant Operations Involving Hydrogen Sulfide

API RECOMMENDED PRACTICE 55
SECOND EDITION, FEBRUARY 1995

REAFFIRMED, JANUARY 2013



AMERICAN PETROLEUM INSTITUTE

Recommended Practice for Oil and Gas Producing and Gas Processing Plant Operations Involving Hydrogen Sulfide

Upstream Segment

API RECOMMENDED PRACTICE 55
SECOND EDITION, FEBRUARY 1995

REAFFIRMED, JANUARY 2013



AMERICAN PETROLEUM INSTITUTE

SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication date as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Authoring Department [telephone (214) 953-1101]. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API *standard*. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the director of the Exploration and Production Department, American Petroleum Institute, 700 North Pearl, Suite 1840, Dallas, Texas 75201. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

CONTENTS

	Page
0 INTRODUCTION	1
1 SCOPE	1
2 REFERENCES	1
2.1 Standards	1
2.2 Regulations	2
2.3 Other References	3
2.4 Bibliography	3
2.5 Acronyms and Abbreviations.....	4
3 DEFINITIONS	4
3.1 Acceptable Ceiling Concentration	4
3.2 Breathing Zone.....	4
3.3 Continuous Hydrogen Sulfide Monitoring Equipment	4
3.4 Emergency Response Planning Guide—Level 2 (ERPG-2)	4
3.5 Enclosed Facility	4
3.6 Essential Personnel	4
3.7 Gas Detection Instrument	5
3.8 Hydrogen Sulfide	5
3.9 Immediately Dangerous to Life and Health (IDLH)	5
3.10 Inadequately Ventilated	5
3.11 Length-of-stain Detector	5
3.12 Permissible Exposure Limit (PEL)	5
3.13 Shall	5
3.14 Shelter-in-place	5
3.15 Should	5
3.16 Sulfur Dioxide	5
3.17 Threshold Limit Value (TLV)	5
4 APPLICABILITY	5
4.1 Personnel and Equipment Protection	5
4.2 Legal Requirements	6
4.3 Hazard Communication (Worker Right-to-know)	6
4.4 <i>Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA) and Superfund Amendments and Reauthorization Act (SARA) Title III (Emergency Planning and Community Right-to-know</i>	6
4.5 Hazardous Waste Operations and Emergency Response (HAZWOPER)	7
5 PERSONNEL TRAINING	7
5.1 Introduction	7
5.2 Minimum Training	7
5.3 Additional Training for Onsite Supervisory Personnel	7
5.4 Refresher Training	7
5.5 Training Visitors and Other Non-regularly Assigned Personnel	7
5.6 Hydrogen Sulfide Safety Instructors.....	8
5.7 Safety Review	8
5.8 Supplemental Training.....	8
5.9 Records	8
5.10 Other Personnel Considerations.....	8

5.10.1	Enclosed Facilities and Confined Space Entry.....	8
5.10.2	Respiratory Problems	8
5.10.3	Perforated Eardrums	8
6	PERSONNEL PROTECTIVE EQUIPMENT	8
6.1	Introduction	8
6.2	Stationary Hydrogen Sulfide Monitoring Systems	8
6.3	Portable Detection Equipment	9
6.4	Breathing (Respiratory Protection) Equipment	9
6.4.1	Storage and Maintenance	9
6.4.2	Face Piece Restrictions.....	10
6.4.3	Air Supply	10
6.4.4	Compressors.....	10
6.4.5	Breathing Equipment Use	10
6.5	Standby Rescue Personnel	10
6.6	Rescue Equipment	10
6.7	Wind Direction Indicators	10
6.8	Warning Signs	11
7	CONTINGENCY PLANNING INCLUDING EMERGENCY PROCEDURES	11
7.1	Introduction	11
7.2	Scope	11
7.3	Availability of Plan	11
7.4	Plan Information	11
7.5	Responsibilities of Personnel.....	11
7.6	Immediate Action Plan	12
7.7	Emergency Telephone Lists.....	12
7.8	Training and Drills.....	12
7.9	Updating Provisions.....	13
8	DESIGN AND CONSTRUCTION PRACTICES	13
8.1	Design Guidelines	13
8.1.1	Process and Mechanical Considerations	13
8.1.2	Design Considerations	13
8.1.3	Materials Considerations.....	13
8.1.4	Materials Selection.....	13
8.1.5	Site Selection.....	14
8.1.6	Warning Method.....	14
8.2	Construction Guidelines	14
8.2.1	Fabrication and Joining System Components.....	14
8.2.2	Qualification of Personnel.....	14
8.2.3	Handling and Storage of Equipment.....	14
8.2.4	Inspection	14
8.2.5	Repairs.....	14
8.3	Electrical Design Considerations	14
9	OPERATING PRACTICES	15
9.1	Introduction	15
9.2	Emergency Procedures	15
9.3	Test Procedures	15
9.4	Safe Work Practices	15
9.5	Leak Detection.....	15
9.6	Safe Work Permits	15
9.7	Valves, Connections, and Gauges	15
9.8	Artificial Lift Wells.....	15

9.9	Flowing Wells	15
9.10	Flow/Gathering Lines	15
9.11	Pressure Vessels	15
9.12	Pressure Relief and Normally Venting Devices	16
9.13	Storage Tanks	16
9.14	Flare Systems	16
9.15	Monitoring Equipment—Maintenance, Testing, and Calibration.....	16
9.16	Corrosion Monitoring	16
9.17	Confined Space Entry	16
9.18	Enclosed Facility Entry	16
9.19	Iron Sulfide Precautions.....	16
9.20	Drilling Operations	16
9.21	Safety Precautions for Sampling and Tank Gauging Operations.....	17
9.22	Facilities Abandonment—Surface Equipment.....	17
9.23	Well Abandonment	17
9.24	Contingency Plan Revisions	17
10	GUIDELINES FOR EVALUATION AND SELECTION OF CONTINUOUS HYDROGEN SULFIDE MONITORING EQUIPMENT	17
10.1	Introduction	17
10.2	General	17
10.3	Construction Characteristics	18
10.3.1	Portability	18
10.3.2	Power Supply, Portable Monitoring Equipment.....	18
10.3.3	Readout	18
10.3.4	Recorder Output	18
10.3.5	Simplicity of Operation.....	18
10.3.6	Instruction Manuals.....	18
10.3.7	Electrical Approval.....	18
10.3.8	Ruggedness	18
10.3.9	Calibration Equipment	18
10.3.10	Zero and Span Adjustments	18
10.3.11	Alarm Systems	18
10.3.12	Testing Alarm Circuitry.....	19
10.3.13	Remote Sampling	19
10.3.14	Equipment Trouble (Malfunction) Alarm	19
10.3.15	Detection Range Indication.....	19
10.4	Performance Guidelines.....	19
10.4.1	Accuracy.....	19
10.4.2	Zero Drift	19
10.4.3	Warm-up Time	19
10.4.4	Response Time	19
10.4.5	Operating Humidity Range	19
10.4.6	Operating Temperature Range	19
10.4.7	Interferences	19
10.4.8	Functional Field Test.....	19
10.4.9	Air Velocity	19
10.4.10	Electromagnetic Interference (EMI)	20
11	OFFSHORE OPERATIONS	20
11.1	Introduction	20
11.2	Uniqueness of Offshore Operations	20
11.3	Federal Regulatory Requirements	20
11.4	Contingency Planning	20

11.5 Simultaneous Operations	20
12 OPERATIONS INVOLVING ENCLOSED FACILITIES	20
12.1 Introduction	20
12.2 Uniqueness of Operations Involving Enclosed Facilities	20
12.3 Design Consideration	21
12.4 Fixed Hydrogen Sulfide Monitoring Systems	21
12.5 Personnel Protection Techniques	21
12.6 Warning Signs	22
13 GAS PROCESSING PLANT OPERATIONS	22
13.1 Introduction	22
13.2 General Considerations	22
13.3 Gas Conditioning Facilities	22
13.4 Materials of Construction	22
13.5 Corrosion Monitoring	22
13.6 Leak Detection	22
13.7 Contingency Planning	23
APPENDIX A—PHYSICAL PROPERTIES AND PHYSIOLOGICAL EFFECTS OF HYDROGEN SULFIDE	25
APPENDIX B—PHYSICAL PROPERTIES AND PHYSIOLOGICAL EFFECTS OF SULFUR DIOXIDE	29
APPENDIX C—A SCREENING APPROACH TO DISPERSION OF HYDROGEN SULFIDE	31
APPENDIX D—DEFINITION OF A SOUR ENVIRONMENT	39
Figures	
C-1—Radius of Hydrogen Sulfide Exposure Continuous Daytime Hydrogen Sulfide Releases	32
C-2—Radius of Hydrogen Sulfide Exposure Continuous Nighttime Hydrogen Sulfide Releases	32
C-3—Radius of Hydrogen Sulfide Exposure Instantaneous Daytime Hydrogen Sulfide Releases	33
C-4—Radius of Hydrogen Sulfide Exposure Instantaneous Nighttime Hydrogen Sulfide Releases	33
D-1—Sour Gas Systems	40
D-2—Sour Multiphase Systems	40
Tables	
A-1—Hydrogen Sulfide	27
A-2—Summary of Occupational Exposure Values for Hydrogen Sulfide	28
B-1—Sulfur Dioxide	30
B-2—Summary of Occupational Exposure Values for Sulfur Dioxide	30
C-1—Linear Regression Coefficients for Mathematical Predictions of ROE as a Function of Downwind Hydrogen Sulfide Concentration and Release Quantity/Rate	31

FOREWORD

These recommended practices were prepared by the API Subcommittee on Production Operations Involving Hydrogen Sulfide. This standard is under the administration of the American Petroleum Institute Exploration & Production Department's Executive Committee on Drilling & Production Practices.

It is intended that these voluntary recommended practices serve as a guide to promote and maintain integrity of oil and/or gas producing and gas processing facilities in the interests of public safety, personnel safety, and protection of the environment. Users of this publication are reminded that constantly developing technology, specific company requirements and policy, and specialized or limited operations do not permit coverage of all possible operations, practices, or alternatives. This standard is not so comprehensive as to present *all* of the recommended practices for oil and gas well producing operations and gas processing plant operations involving hydrogen sulfide. Alternative operating procedures and/or equipment are available and routinely used to meet or exceed recommended practices or performance levels set forth herein. Recommendations presented in this publication are based on industry experience and expertise involving a wide range of operating locations and conditions. Recommendations presented in this publication are not intended to inhibit developing technology and equipment improvements or improved operating procedures. This publication, or portions thereof, cannot be substituted for qualified technical/operations analysis and judgment to fit a specific situation.

There may be federal, state, or local statutes, rules, or regulations requiring oil and gas producing and gas processing operations to be conducted in a safe or environmentally sound manner. Organizations and individuals using this standard are cautioned that requirements of federal, state, or local laws and regulations are constantly evolving. These requirements should be reviewed to determine whether the practices recommended herein and the operations being planned or conducted are consistent with current laws and regulations.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet (MSDS).

Provisions of these voluntary recommended practices include use of the verbs "shall" and "should", whichever is deemed most applicable for the specific situation. For purposes of this publication, the following definitions are applicable.

Shall: Indicates the "recommended practice(s)" has universal applicability to that specific activity.

Should: Denotes a "recommended practice(s)" 1) where a safe comparable alternative practice(s) is available; 2) that may be impractical under certain circumstances; or 3) that may be unnecessary under certain circumstances.

Suggested revisions to these recommended practices are invited and should be submitted in writing to: Director, Exploration & Production Department, American Petroleum Institute, 700 North Pearl Street, Suite 1840, Dallas, Texas 75201-2845.

Recommended Practices for Oil and Gas Producing and Gas Processing Plant Operations Involving Hydrogen Sulfide

0 Introduction

The petroleum industry, through many years of research and operating experience, has developed guidelines for safe operations under conditions involving hydrogen sulfide. Continuing industry efforts, which include planning, prudent selection and layout of equipment, prudent selection of materials, operating and emergency procedures, specialized safety equipment, and appropriate personnel training are all necessary to ensure successful and safe operations. Effective response to emergencies requires prior planning. *Good engineering practice (engineering and administrative controls) dictates that producing and gas processing systems be designed to minimize exposure of personnel and the public to hydrogen sulfide and sulfur dioxide.*

1 Scope

Recommendations set forth in this publication apply to oil and gas producing and gas processing plant operations conducted with hydrogen sulfide present in the fluids being handled. The presence of hydrogen sulfide in these operations also presents the possibility of exposure to sulfur dioxide from the combustion of hydrogen sulfide. *Refer to Section 4 for applicability of this standard.*

2 References

2.1 STANDARDS

The following standards contain provisions which, through reference in this text, constitute provisions of this standard. All standards are subject to revision, and users are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below.

ACGIH¹

1. *Threshold Limit Values and Biological Exposure Indices (1993-94).*

ANSI²

2. B31.3 *Chemical Plant and Petroleum Refining Piping.*
3. B31.4 *Liquid Petroleum Transportation Piping Systems.*
4. B31.8 *Gas Transmission and Distribution Piping Systems.*
5. CGA G-7.1 *Breathing Air, Grade D.*
6. ISEA 102 *Standard for Gas Detector Tube Units—Short Term Type for Toxic Gases and Vapors in Working Environments.*
7. Z88.2 *Practices for Respiratory Protection.*

API³

8. BUL E1 *Bulletin on the Generic Hazardous Chemical Category List and Inventory for the Oil and Gas Exploration & Production Industry.*
9. BUL E2 *Bulletin on Management of Naturally Occurring Radioactive Materials (NORM) in Oil and Gas Production.*
10. BUL E3 *Well Abandonment and Inactive Well Practices for U.S. Exploration and Production Operations.*
11. BUL E4 *Release Reporting for the Oil and Gas Exploration and Production Industry as Required by the CWA, CERCLA, and SARA Title III.*
12. RP12R1 *Recommended Practice for Setting, Maintenance, Inspection, Operation, and Repair of Tanks in Production Service.*
13. RP14C *Recommended Practice for Analysis, Design, Installation, and Testing of Basic Surface Safety Systems for Offshore Production Platforms.*
14. RP49 *Recommended Practice for Drilling and Drill Stem Testing Operations Involving Hydrogen Sulfide.*
15. RP500 *Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities.*
16. API 510 *Pressure Vessel Inspection Code: Maintenance Inspection, Rating, Repair, and Alteration.*
17. RP576 *Inspection of Pressure Relieving Devices.*
18. RP750 *Management of Process Hazards.*
19. STD 1104 *Welding of Pipelines and Related Facilities.*
20. PUBL 2217A *Guidelines for Work in Inert Confined Spaces in the Petroleum Industry.*

ASME⁴

21. *Boiler & Pressure Vessel Code.*

¹American Conference of Governmental Industrial Hygienists, 1330 Kemper Drive, Cincinnati, OH 45240.

²American National Standards Institute, 1430 Broadway, New York, N.Y. 10018.

³American Petroleum Institute, Publications & Distribution Section, 1220 L Street NW, Washington, D.C. 20005.

⁴American Society of Mechanical Engineers, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300.

- EPA⁵
22. EPA/600/8-86/026A *Health Assessment Document for Hydrogen Sulfide.*
- ISA⁶
23. S12.15, Part I *Performance Requirements for Hydrogen Sulfide Detection Instruments.*
24. RP12.15, Part II *Installation, Operation, and Maintenance of Hydrogen Sulfide Detection Instruments.*
- NACE⁷
25. MR0175-94 *Standard Material Requirements Sulfide Stress Cracking Resistant Metallic Materials for Oilfield Equipment.*
- National Response Team⁸
26. NRT-1 *Hazardous Materials Emergency Planning Guide.*
27. *Technical Guidance for Hazards Analysis, Emergency Planning for Extremely Hazardous Substances.*
- NFPA⁹
28. NFPA 70 *National Electrical Code.*
29. NFPA 496 *Purged and Pressurized Enclosures for Electrical Equipment in Hazardous (Classified) Locations.*
- NIOSH¹⁰
30. NIOSH 74-111 *Criteria for a Recommended Standard for Occupational Exposure to Sulfur Dioxide (GPO No. 017-033-00029).*
31. NIOSH 77-158 *Criteria for a Recommended Standard for Occupational Exposure to Hydrogen Sulfide (GPO No. 017-033-00217-7).*
32. DHHS 85-114 *NIOSH Pocket Guide to Chemical Hazards.*
- PACE¹¹
33. Report 85-5 *Review of Ambient Hydrogen Sulfide Standards in Canada.*

2.2 REGULATIONS

The following regulations are referenced in this standard. All regulations are subject to revision, and users should determine the latest version to ensure compliance.

Bureau of Mines (DOI)¹²

34. 30 CFR Chapter 1, Subchapter B, Part II, Subpart H *Respiratory Protection Devices.*

Coast Guard (DOT)¹³

35. 33 CFR Parts 140, 143, and 146 *Emergency Evacuation Plans for Manned OCS Facilities.*
36. 54 FR 21566, May 18, 1989 *Emergency Evacuation Plans for Manned OCS Facilities.*

DOT¹⁴

37. 49 CFR Part 178, Subpart C *Shipping Container Specifications.*

EPA⁵

38. 40 CFR Part 264, Subpart D *Contingency Plans and Emergency Procedures.*
39. 40 CFR Part 302 *Designation, Reportable Quantities, and Notification.*
40. 40 CFR Part 355 *Emergency Planning and Notification.*
41. 40 CFR Part 370 *Hazardous Chemical Reporting: Community Right-to-Know.*

MMS (DOI)¹⁵

42. 30 CFR Parts 250 & 256 *Oil, Gas, and Sulphur Operations in the Outer Continental Shelf.*
43. 53 FR 10596-10777, April 1, 1988 *Oil, Gas, and Sulphur Operations in the Outer Continental Shelf.*
44. MMS-OCS-1 *Safety Requirements for Drilling Operations in a Hydrogen Sulfide Environment, Outer Continental Shelf. (February 1976).*

⁵Environmental Protection Agency, available from U.S. Government Printing Office, Washington, D.C. 20402.

⁶Instrument Society of America, Box 12277, Research Triangle Park, NC 27709.

⁷National Association of Corrosion Engineers, NACE International, Box 218340, Houston, Texas 77218-8340.

⁸National Response Team, National Oil and Hazardous Substances Contingency Plan GWDR/12, 2100 Second Street SW, Washington, D.C. 20593.

⁹National Fire Protection Association, 60 Batterymarch Park, Quincy, MA 02269.

¹⁰National Institute for Occupational Safety and Health (U.S. Department of Health, Education, and Welfare), available from U.S. Government Printing Office, Washington, D.C. 20402.

¹¹Petroleum Association for Conservation of the Canadian Environment, 12002-275 Slater Street, Ottawa, Ontario, Canada L1P-5H9.

¹²Bureau of Mines, U.S. Department of Interior, available from U.S. Government Printing Office, Washington, D.C. 20402.

¹³Coast Guard, U.S. Department of Transportation, available from U.S. Government Printing Office, Washington, D.C. 20402.

¹⁴U.S. Department of Transportation, available from U.S. Government Printing Office, Washington, D.C. 20402.

¹⁵Minerals Management Service, U.S. Department of Interior, 381 Elden Street, Herndon, VA 22070-4817. Available from U.S. Government Printing Office, Washington, D.C. 20402.

45. 47 FR 28888, July 1, 1982 *Safety Requirements for Drilling Operations in a Hydrogen Sulfide Environment, Outer Continental Shelf. (July 1, 1982).*
- OSHA¹⁶
46. 29 CFR Part 1910.38 *Employee Emergency Plan and Fire Prevention Plans.*
47. 29 CFR Part 1910.119 *Process Safety Management of Highly Hazardous Chemicals.*
48. 29 CFR Part 1910.120 *Hazardous Waste Operations and Emergency Response.*
49. 54 FR Part 9294, March 6, 1989 *Hazardous Waste Operations and Emergency Response.*
50. 29 CFR Part 1910.134 *Respiratory Protection Standard.*
51. 29 CFR Part 1910.146 *Permit-required Confined Spaces.*
52. 29 CFR Part 1910.1000 *Toxic and Hazardous Substances (Air Contaminants).*
53. 54 FR 2332, January 19, 1989 *Air Contaminants.*
54. 58 FR 35338, June 30, 1993 *Air Contaminants.*
55. 29 CFR Part 1910.1200 *Hazard Communication Standard.*
- Pipeline Ruptures”, Department of Mechanical Engineering, University of Alberta, Edmonton, Canada.
62. Jann, P. R., “Evaluation of Sheltering In Place”, *Journal of Loss Prevention in the Process Industry*, Vol. 2, No. 1, Jan. 1989, pp 33-38.
63. MacFarlane, D. R. and Ewing, T. F., “Acute Health Effects From Accidental Releases of High Toxic Hazard Chemicals”, *Journal of Loss Prevention in the Process Industry*, Vol. 3, No. 1, January 1990, pp 167-176.
64. Wilson, D. J., “Stay Indoors or Evacuate to Avoid Exposure to Toxic Gas?”, *Emergency Preparedness Digest*, Ottawa, Canada, January-March 1987, pp 19-24.
65. Davies, P. C. and Purdy, G., “Toxic Gas Risk Assessments—The Effects of Being Indoors”, North Western Branch Papers 1986 No. 1, Institution of Chemical Engineers, Health and Safety Executive, Major Hazards Assessment Unit, St. Annes House, Stanly Precinct, Bootle, Merseyside, England.
66. Glickman, T.S. and Ujrhara, A. M., “Protective Action Decision Making in Toxic Vapor Cloud Emergencies”, Center for Risk Management, Resources for the Future, Washington, D. C. 20036.
67. Wilson, D. J., “Variation of Indoor Shelter Effectiveness Caused by Air Leakage Variability of Houses in Canada and the USA”, US EPA/FEMA Conference on Effective Use of In-place Sheltering as a Potential Option to Evacuation During Chemical Release Emergencies, Emmitsburg, MD, November 30-December 1, 1988.

2.3 OTHER REFERENCES

56. Poda, George A., “Hydrogen Sulfide Can Be Handled Safely”, *Archives of Environmental Health*, Vol. 12, 795-800, June 1966.
57. Ronk, Richard and White, M. K., “Hydrogen Sulfide and the Probabilities of Inhalation Through a Tympanic Membrane Defect”, *Journal of Occupational Medicine*, Vol. 25, No. 5, 337-340, May 1985.
58. *Synopsis of Boiler & Pressure Vessel Laws, Rules, and Regulations by States, Cities, Counties, and Provinces (United States and Canada)*, available from Uniform Boiler and Pressure Vessel Laws Society, P. O. Box 1521, Oceanside, New York, NY 11572.
59. Pasquill, F., *Atmospheric Diffusion*, Second Edition, John Wiley & Sons, New York, NY, 1947.
60. Slade, D. H., *Metrology and Atomic Energy* NTIS-TID 24190 (1968), National Technical Information Service (NTIS), U.S. Department of Commerce, Springfield, VA 22161.
61. Wilson, D. J., “Release and Dispersion of Gas from

2.4 BIBLIOGRAPHY

The following publications contain information related to this subject:

- API RP14F *Recommended Practice for Design and Installation of Electrical Systems for Offshore Production Platforms.*
- API RP54 *Recommended Practices for Occupational Safety for Oil and Gas Well Drilling and Servicing Operations.*
- Recommended Standard for Occupational Exposure to Hydrogen Sulfide*, National Institute for Occupational Safety and Health, 125 Baker Drive, Morgantown, WV.
- Texas Railroad Commission Rule 36: *Oil, Gas, and Geothermal Resources Operations in Hydrogen Sulfide Areas*, Texas Railroad Commission, Austin, TX.
- Public Health Service Publication 999-AP-26, *Workbook on Atmospheric Dispersion Estimates*, D. Bruce Tanner, available from U.S. Department of Health, Education, and Welfare, Cincinnati, OH.

¹⁶Occupational Safety & Health Administration (U.S. Department of Labor), available from U.S. Government Printing Office, Washington, D.C. 20402.

GPA 2145-85 *Physical Constants of Paraffin Hydrocarbons and Other Components of Natural Gas*, available from Gas Processors Association, 6526 E. 60th Street, Tulsa, OK 74145.

2.5 ACRONYMS AND ABBREVIATIONS

The following acronyms and abbreviations are used in this publication:

ACC	Acceptable Ceiling Concentration
ACGIH	American Conference of Governmental Industrial Hygienists
ANSI	American National Standards Institute
API	American Petroleum Institute
ASME	American Society of Mechanical Engineers
ASTM	American Society for Testing and Materials
CERCLA	<i>Comprehensive Environmental Response, Compensation, and Liability Act</i>
CFR	<i>Code of Federal Regulations</i>
CWA	<i>Clean Water Act</i>
DC	Direct Current
DOI	U. S. Department of Interior
DOL	U. S. Department of Labor
DOT	U. S. Department of Transportation
EMI	Electromagnetic Interference
EPA	Environmental Protection Agency
ERPG	<i>Emergency Response Planning Guide</i>
FR	<i>Federal Register</i>
HAZWOPER	Hazardous Waste Operations and Emergency Response
IDLH	Immediately Dangerous to Life or Health
ISA	Instrument Society of America
LEL	Lower Explosive Limit
LEPC	Local Emergency Planning Committee
MMS	Minerals Management Service
MSDS	Material Safety Data Sheet
NACE	National Association of Corrosion Engineers
NFPA	National Fire Protection Association
NIOSH	National Institute for Occupational Safety and Health
NORM	Naturally Occurring Radioactive Material
NRTL	National Recognized Testing Laboratory
NTIS	National Technical Information Service
OCS	Outer Continental Shelf
OSHA	Occupational Safety and Health Administration

PEL	Permissible Exposure Limit
PG	Pasquill-Gifford
RCRA	<i>Resource Conservation & Recovery Act</i>
REL	Recommended Exposure Level
RFI	Radio Frequency Interference
ROE	Radius of Exposure
RP	<i>Recommended Practice</i>
RQ	Reportable Quantity
SARA	<i>Superfund Amendments and Reauthorization Act</i>
SCF	Standard Cubic Foot
SSC	Sulfide Stress Cracking
STEL	Short Term Exposure Level
TLV	Threshold Limit Value
TPQ	Threshold Planning Quantity
WPS	Welding Procedure Specification

3 Definitions

For the purposes of this standard, the following definitions are applicable.

3.1 acceptable ceiling concentration: (ACC). The designated level of an air contaminant to which an employee may be exposed at any time during an 8-hour shift, except for a specified time period and up to a specified concentration not exceeding the "acceptable maximum peak concentration" above the acceptable ceiling concentration for an 8-hour shift. Refer to 29 *CFR* 1910.1000 and Appendix A, Par. A.2.

3.2 breathing zone: A hemisphere forward of the shoulders with a radius of 6 to 9 inches. Refer to OSHA Instruction CPL 2-2.20A, March 30, 1984; amended by CPL 2-20A CH-1, October 29, 1984.

3.3 continuous hydrogen sulfide monitoring equipment: Equipment capable of continuously measuring and displaying the concentration of hydrogen sulfide in ambient air.

3.4 emergency response planning guide—level 2: (ERPG-2). The maximum airborne concentration below which it is believed that nearly all individuals could be exposed for up to one hour without experiencing or developing irreversible or other serious health effects or symptoms that could impair an individual's ability to take protective actions. Refer to *Technical Guidance for Hazards Analysis; Emergency Planning for Extremely Hazardous Substances*.

3.5 enclosed facility: A three-dimensional space enclosed by more than two-thirds ($\frac{2}{3}$) of the possible projected plane surface and of sufficient size to allow the entry of personnel. For a typical building, this would require that more than two-thirds of the walls, ceiling, and floor be present. Refer to *API Recommended Practice 500*.

3.6 essential personnel: Those individuals required to

provide proper and prudent safe operations activities and those required to effect control of the hazardous hydrogen sulfide or sulfur dioxide conditions.

3.7 gas detection instrument: An assembly of electrical, mechanical, and chemical components designed to sense and respond continuously to the presence of chemical gases in atmospheric mixtures.

3.8 hydrogen sulfide: Chemical formula is H₂S. A flammable, toxic gas that is heavier than air and sometimes found in fluids encountered in oil and gas producing and gas processing operations. *Inhalation at certain concentrations can lead to injury or death.* Refer to Appendix A.

3.9 immediately dangerous to life and health: (IDLH). An atmospheric concentration of any toxic, corrosive, or asphyxiant substance that poses an immediate threat to life or would cause irreversible or delayed adverse health effects or would interfere with an individual's ability to escape from a dangerous atmosphere. The National Institute for Occupational Safety & Health (NIOSH) considers 300 ppm and 100 ppm to be the IDLH concentrations for hydrogen sulfide and sulfur dioxide, respectively. *API Publication 2217A* specifies an oxygen content of less than 19.5% as oxygen deficient and an oxygen content of less than 16% is considered IDLH.

3.10 inadequately ventilated: Ventilation (natural or artificial) that is *not* sufficient to prevent the accumulation of significant quantities of hydrogen sulfide-air mixtures in excess of 10 ppm.

3.11 length-of-stain detector: A specially designed pump and colorimetric indicator tube detector (length-of-stain), with a supply of detector tubes, that operates by using the pump to pull a known volume of air or gas through a detector tube. The tubes contain chemical reagents that are designed to detect the presence and display the concentration of hydrogen sulfide or sulfur dioxide in the sample. The length of the resultant color band in the tube indicates an instantaneous quantitative concentration of the specific chemical in the sample.

3.12 permissible exposure limit: (PEL). The designated level of any airborne contaminant to which an employee may be exposed. The PEL may be expressed as an eight-hour time weighted average (TWA), a ceiling value, a short term exposure level (STEL), or a skin designation. PELs are subject to change and users should check the latest version of *29 Code of Federal Regulations Part 1910.1000* for compliance.

3.13 shall: Indicates the "recommended practice(s)" has universal applicability to that specific activity.

3.14 shelter-in-place: The concept of providing the public additional protection by having residents stay indoors until emergency evacuators arrive or the emergency is over. Refer to references 62, 63, 64, 65, 66, and 67.

3.15 should: Denotes a "recommended practice(s)" 1) where a safe comparable alternative practice(s) is available; 2) that may be impractical under certain circumstances; or 3) that may be unnecessary under certain circumstances.

3.16 sulfur dioxide: Chemical formula is SO₂. A toxic product of combustion of hydrogen sulfide. This gas is heavier than air. *Inhalation at certain concentrations can lead to injury or death.* Refer to Appendix B.

3.17 threshold limit value: (TLV). The maximum airborne concentration of a substance to which, it is believed that, nearly all workers may be repeatedly exposed day after day without adverse effects, as determined by the responsible committees of the American Conference of Governmental Industrial Hygienists (ACGIH). Refer to *"Threshold Limit Values and Biological Indices"*. "TLV" is a trademarked term of ACGIH. TLVs are subject to change and users should check the latest edition of the foretated reference.

4 Applicability

4.1 PERSONNEL AND EQUIPMENT PROTECTION

In oil and gas producing operations and gas processing plant operations, severity of the environment shall be assessed. As a minimum, the following measures shall be implemented:

a. Personnel protection should be provided if the work area concentration of hydrogen sulfide (refer to Par. 3.8) exceeds 10 ppm eight-hour time weighted average (TWA) or 15 ppm as a short term exposure level (STEL) averaged over 15 minutes (refer to Appendix A); or the work area concentration of sulfur dioxide (refer to Par. 3.16) exceeds 2 ppm as an eight-hour TWA or 5 ppm as a STEL averaged over 15 minutes (refer to Appendix B). Personnel safety provisions of this publication do not apply when:

1. the atmospheric concentration of hydrogen sulfide could not exceed 10 ppm (by volume), or
2. the atmospheric concentration of sulfur dioxide could not exceed 2 ppm (by volume).

b. Equipment and materials shall be selected on the basis of resistance to sulfide stress cracking and corrosion. Refer to Section 8, "Design and Construction Practices", Appendix D, and *NACE Standard MR0175* for recommendations for selection of equipment and materials. The equipment and materials provisions of this publication do not apply when the partial pressure of hydrogen sulfide in the gas could not exceed 0.05 psia or 10 psia in the gas phase of sour crude systems (refer to Appendix D, Par. D.1.1.2).

Some conditions may require extensive personnel safety measures but only the use of conventional equipment and materials; other conditions may require the use of special equipment and materials but only minimal personnel safety

measures; still other conditions may require both.

Throughout this publication, "trigger levels" for various actions are used to ensure safety of employees and the public. These trigger levels have been established considering threshold limit values (TLVs—refer to Par. 3.17). These TLVs are subject to change and users should check the latest edition of *Threshold Limit Values and Biological Exposure Indices* and the latest revision of *29 Code of Federal Regulations* Part 1910.1000, "Toxic and Hazardous Substances", for compliance.

In 1989, the U. S. Department of Labor, Occupational Safety and Health Administration (OSHA) issued updated permissible exposure limits (PELs) for several hundred chemicals, including revised PELs for hydrogen sulfide (10 ppm as an eight-hour TWA or 15 ppm STEL averaged over 15 minutes) and sulfur dioxide [2 ppm as an eight-hour TWA or 5 ppm STEL averaged over 15 minutes (refer to *54 Federal Register (FR)* 2333, January 19, 1989]. A federal court set aside the OSHA 1989 rule (refer to *58 Federal Register* 35338, June 30, 1993).

The American Conference of Governmental Industrial Hygienists (ACGIH) recommends a hydrogen sulfide TLV of 10 ppm (eight-hour TWA) and a STEL of 15 ppm averaged over 15 minutes and recommends 2 ppm as an eight-hour TWA TLV and 5 ppm as a STEL averaged over 15 minutes for sulfur dioxide (refer to *Threshold Limit Values for Chemical Substances and Biological Exposure Indices*).

In the interest of safety and health, this standard recommends use of the ACGIH TLVs (refer to *Threshold Limit Values for Chemical Substances and Biological Exposure Indices 1993-94*) as trigger levels for employee safety (refer to Appendices A and B). Some states have adopted these levels as requirements for personal safety.

Individual employers may set their own trigger levels after review and due consideration of site specific conditions, various regulatory requirements, and material safety data sheet (MSDS) information. Users should check the current status of OSHA PELs, OSHA acceptable ceiling concentrations (ACCs), ACGIH TLVs, and applicable regulatory requirements concerning substances of interest.

4.2 LEGAL REQUIREMENTS

This publication presents recommended practices and precautions deemed pertinent to protect personnel and the public from exposure to potentially hazardous concentrations of hydrogen sulfide and sulfur dioxide. These recommended practices recognize that owners, operators, contractors, and their employees have separate responsibilities that may be contractual in nature. It is not the intent of these recommended practices to alter the contractual relationship(s) between the parties. Some of the practices recommended herein are mandatory by local, state, or federal laws, rules, and regulations. Because of the functional and geographical diversity of these requirements, no attempt has been made in

these recommended practices to designate which are optional and which are required. Furthermore, even if all the practices recommended herein are followed, there still may be existing or future legally imposed laws or regulations which would not be met. *In the event of any omission or conflict between these recommended practices and legally required action(s) the requirements of laws and regulations must control.* Some of the federal regulations pertinent to safe production operations involving hydrogen sulfide are listed in Section 2, "References". Users of this publication shall review these regulations and other federal, state, and local laws to assure appropriate compliance in their specific operations.

4.3 HAZARD COMMUNICATION (WORKER RIGHT-TO-KNOW)

This publication contains important information that is intended as a guide but may not comply in all respects with OSHA's Hazard Communication Standard. Appropriate counsel should be sought to assure compliance with hazard communication requirements for the specific operations. Refer to OSHA rules on hazard communication in *29 Code of Federal Regulations* Part 1910.1200, "Hazard Communication Standard" (*52 Federal Register (FR)* 31877-31886, August 24, 1987).

4.4 COMPREHENSIVE ENVIRONMENTAL RESPONSE, COMPENSATION, AND LIABILITY ACT (CERCLA) AND SUPERFUND AMENDMENTS AND REAUTHORIZATION ACT (SARA) TITLE III (EMERGENCY PLANNING AND COMMUNITY RIGHT-TO-KNOW)

Environmental Protection Agency (EPA) regulations implementing Title III of the *Superfund Amendments and Reauthorization Act of 1986* (SARA Title III) set threshold levels (threshold planning quantities, i.e., TPQs) for emergency planning at a local level. Both SARA Title III and CERCLA set reportable quantities (RQs) for reporting releases to the environment. The TPQ for both hydrogen sulfide and sulfur dioxide is 500 pounds; RQs for release reporting are 100 pounds for hydrogen sulfide and 1 pound for sulfur dioxide. TPQs and RQs (trigger levels) and the regulations requiring response plans and release reports under both SARA Title III and CERCLA are set forth in *40 Code of Federal Regulations* Part 302, and *40 Code of Federal Regulations* Part 355. Refer to *API Bulletin E-4* for guidance on release reporting requirements. "Trigger levels" for response plan and release reporting requirements are subject to change and users shall check the latest revisions for compliance. SARA Title III also requires submission of periodic and annual reports of information to state and local officials on the presence of hazardous chemicals at production

and gas processing facilities. Those regulations are set forth in 40 *Code of Federal Regulations* Part 370, and API has published suggested generic reporting forms (refer to *API Bulletin E-1*) that are acceptable to EPA. Appropriate guidance should be sought to assure compliance with these programs for the specific operations.

4.5 HAZARDOUS WASTE OPERATIONS AND EMERGENCY RESPONSE (HAZWOPER)

OSHA's standard, 29 *Code of Federal Regulations* Part 1910.120, sets requirements for safety and health protection of employees involved in cleanup operations at uncontrolled hazardous waste sites being performed under government mandate; certain hazardous waste treatment, storage, and disposal operations conducted under the *Resource Conservation and Recovery Act* (RCRA); and emergency response to incidents involving hazardous substances. Appropriate guidance should be sought to assure compliance with 29 *Code of Federal Regulations* Part 1910.120 requirements for the specific operations (refer to 54 *Federal Register* 9294-9336, March 6, 1989).

5 Personnel Training

5.1 INTRODUCTION

Operators of oil and gas producing and gas processing operations involving hydrogen sulfide shall alert personnel (including employees, service companies, and contractors) of the possibility of hydrogen sulfide atmospheric concentrations greater than 10 ppm and sulfur dioxide atmospheric concentrations greater than 2 ppm that may be encountered in the performance of their work. All personnel working in an area where concentrations of hydrogen sulfide or sulfur dioxide may exceed the levels stipulated in Par. 4.1.a should be provided with training prior to beginning the work assignment. All employers, whether operator, contractor, or subcontractor, shall be responsible for training and instruction of their own employees. Personnel assigned to work in areas where they may be exposed to hydrogen sulfide or sulfur dioxide shall be trained by a hydrogen sulfide safety instructor, as defined in Par. 5.6.

5.2 MINIMUM TRAINING

The value of training and periodic drills in all oil and gas producing and gas processing plant operations cannot be over emphasized. The uniqueness or complexity of a specific facility or operation will determine the extent of the training (e.g., SARA Title III and HAZWOPER; refer to Pars. 4.4 and 4.5) deemed necessary for the assigned personnel. However, the following elements are considered a minimum level of training for regularly assigned personnel:

- a. The hazards, characteristics, and properties of hydrogen

sulfide and sulfur dioxide (refer to Appendices A and B).

- b. Sources of hydrogen sulfide and sulfur dioxide.
- c. Proper use of hydrogen sulfide and sulfur dioxide detection methods used at the workplace.
- d. Recognition of and proper response to the warning signals for hydrogen sulfide and sulfur dioxide detection systems used at the workplace.
- e. Symptoms of hydrogen sulfide exposure (refer to Appendix A); symptoms of sulfur dioxide exposure (refer to Appendix B).
- f. Rescue techniques and first aid to victims of hydrogen sulfide and sulfur dioxide exposure.
- g. Proper use and maintenance of breathing equipment for working in a hydrogen sulfide and sulfur dioxide atmosphere (theory and hands-on practice, with demonstrated proficiency). Refer to 29 *Code of Federal Regulations* Part 1910.134.
- h. Workplace practices and relevant maintenance procedures that have been established to protect personnel from the hazards of hydrogen sulfide and sulfur dioxide.
- i. Wind direction awareness and routes of egress (refer to Par. 6.7).
- j. Confined space and enclosed facility entry procedures (if applicable).
- k. Emergency response procedures that have been established for the facility. Refer to Section 7, "Contingency Planning Including Emergency Procedures".
- l. Locations and use of safety equipment.
- m. Locations of emergency assembly areas, if so designated.

5.3 ADDITIONAL TRAINING FOR ONSITE SUPERVISORY PERSONNEL

Those personnel assigned supervising responsibilities at the site shall have additional training in the following elements:

- a. Supervisor responsibilities of the contingency plan (refer to Section 7).
- b. Effects of hydrogen sulfide on components of the hydrogen sulfide handling system (i.e., corrosion, embrittlement, etc.).

5.4 REFRESHER TRAINING

A formal recurring training program shall be implemented to maintain proficiency in the elements listed in Pars. 5.2 and 5.3, as appropriate.

5.5 TRAINING VISITORS AND OTHER NON-REGULARLY ASSIGNED PERSONNEL

Prior to entering a potentially hazardous area, visitors and other non-regularly assigned personnel shall be briefed on route(s) of egress, emergency assembly area(s), applicable warning signals, and how to respond in the event of an emergency, including use of personal protective equipment, if re-

quired. These personnel may be allowed in potentially hazardous areas only in the presence of trained personnel, after being briefed on emergency action and evacuation procedures. In the event of an emergency, these personnel shall be immediately evacuated or immediately supplied with proper personal protective equipment.

5.6 HYDROGEN SULFIDE SAFETY INSTRUCTORS

Hydrogen sulfide safety instructors are persons who have successfully completed a course in hydrogen sulfide instructor training from an institution or organization offering such courses, or have received equivalent instruction from a company-designated hydrogen sulfide safety instructor/trainer, or have had equivalent instructor/trainer experience. A recurring training program shall be implemented to maintain proficiency of the hydrogen sulfide safety instructor.

5.7 SAFETY REVIEW

Before any persons unfamiliar with the job site enter the location, they shall, as a minimum, be briefed on emergency evacuation procedures.

5.8 SUPPLEMENTAL TRAINING

Training should be a continuing educational program for personnel (including personnel engaged in maintenance and repair work) whose work may involve exposure to hydrogen sulfide or sulfur dioxide. Effective ongoing training will ensure that personnel have current knowledge of potential job hazards, procedures for dealing with confined space entry, procedures for enclosed facilities work, relevant maintenance procedures, and cleanup methods. Depending on the nature of the programs, certain appropriate training aids may be very useful. These aids may include, but are not limited to, films, manuals, and industry publications or documents (refer to Section 2 "References"). Guest speakers, demonstrations, and consultants are also recommended.

5.9 RECORDS

Dates, instructors, attendees, and subjects for all personnel training sessions shall be documented and appropriate records should be retained for a minimum of one year.

5.10 OTHER PERSONNEL CONSIDERATIONS

5.10.1 Enclosed Facilities and Confined Space Entry

Refer to 29 *Code of Federal Regulations* Part 1910.146 for OSHA's confined space entry regulations. Refer to Section 12, "Operations Involving Enclosed Facilities", for some topics that may be used in training personnel for enclosed facilities work. Refer to Pars. 9.17 and 9.18 for further precau-

tionary information on entry into confined spaces (including vessels) and enclosed facilities.

5.10.2 Respiratory Problems

Personnel with known physiological or psychological conditions which impair normal respiration shall not be assigned to jobs involving potential exposure to a hydrogen sulfide or sulfur dioxide environment if use of the breathing equipment or exposure will complicate their respiratory problems. Refer to OSHA's Respiratory Protection Standard (29 *Code of Federal Regulations* Part 1910.134).

Note: Personnel assigned job-related tasks requiring routine use of breathing equipment shall have a periodic review to determine their physiological and psychological adequacy for use of this equipment (refer to 29 *Code of Federal Regulations* Part 1910.134 and ANSI Z88.2).

5.10.3 Perforated Eardrums

There are differences of opinion¹⁷ in the medical community about whether a person with a perforated eardrum can become overexposed to a toxic substance via the ear even when wearing properly functioning breathing apparatus (refer to Par. 6.4). Refer to Appendix A.

6 Personnel Protective Equipment

6.1 INTRODUCTION

Section 6 discusses some personnel protective equipment that can be used in oil and gas well producing and gas processing plant operations where the work atmosphere concentration of hydrogen sulfide could exceed 10 ppm or sulfur dioxide atmospheric concentration could exceed 2 ppm (refer to Par. 4.1 and Appendices A and B). Having personnel protective equipment available is not enough; training personnel in the selection, use, inspection, and maintenance of the equipment is essential.

6.2 STATIONARY HYDROGEN SULFIDE MONITORING SYSTEMS

Stationary hydrogen sulfide atmospheric monitoring systems used in oil and gas producing and gas processing plant operations shall include visual or audible alarm(s), located where the alarm can be seen or heard throughout the work area. The batteries of direct current (DC) systems should be checked daily during operation unless an automatic low voltage alarm is provided. Instrument Society of America publications, *ISA-S12.15*, Part I, and *ISA-RP12.15*, Part II, contain equipment performance requirements and

¹⁷Note: Compare Poda, George A., "Hydrogen Sulfide Can Be Handled Safely"⁵⁵, *Archives of Environmental Health*, Vol. 112, 795-800, June 1966, and Ronk, Richard and White, M. K., "Hydrogen Sulfide and the Probabilities of Inhalation Through a Tympanic Membrane Defect"⁵⁶, *Journal of Occupational Medicine*, Vol. 25, No. 5, 337-340, May 1985.

recommendations for installation, operation, and maintenance of hydrogen sulfide monitoring and detection instruments, respectively. Refer to Section 10 for additional details regarding evaluation and selection of hydrogen sulfide monitoring equipment.

6.3 PORTABLE DETECTION EQUIPMENT

If the atmospheric concentration of hydrogen sulfide could reach or exceed those levels stipulated in Par. 6.1, portable hydrogen sulfide detection instruments¹⁸ shall be available. Refer to Section 10 for details regarding evaluation, selection, maintenance, and use of hydrogen sulfide detection equipment. In those instances where the hydrogen sulfide atmospheric concentration may exceed the measurement range of the detection instruments in use, a pump and colorimetric indicator tube detector¹⁹ (length-of-stain), with a supply of detector tubes, shall be available to take instantaneous "grab" samples to determine hydrogen sulfide concentrations in enclosed facilities, storage tanks, vessels, etc.

If sulfur dioxide levels could reach or exceed those stipulated in Par. 6.1 (e.g., during flaring or other operations producing sulfur dioxide), either portable sulfur dioxide detection instruments or length-of-stain detectors, with a supply of detector tubes, shall be available for determining the sulfur dioxide concentration in the area and to monitor areas impacted by sulfur dioxide gas when fluids containing hydrogen sulfide are burned. Personnel shall wear appropriate personal breathing equipment (refer to Par. 6.4) unless it is established that the work area atmosphere is safe.

6.4 BREATHING (RESPIRATORY PROTECTION) EQUIPMENT

Site specific contingency plans shall be prepared to specify the quantity and location of breathing equipment to be available. Respirators shall meet the requirements of OSHA's Respiratory Protection Standard (refer to 29 *Code of Federal Regulations* Part 1910.134) and be approved under procedures outlined in *ANSI Z88.2*. All breathing air cylinders shall meet U.S. Department of Transportation (DOT) or other appropriate regulatory requirements (refer to 30 *Code of Federal Regulations*, Part 1910.134, Chapter 1, Subchapter B, Part II, Subpart H, Par. 11.80 and 49 *Code of Federal Regulations* Part 178, Subpart C). The following types of breathing equipment with full face piece meet these

¹⁸A gas detection instrument is an assembly of electrical, mechanical, and chemical components designed to sense and respond continuously to the presence of chemical gases (hydrogen sulfide or sulfur dioxide) in atmospheric mixtures.

¹⁹A pump and colorimetric indicator tube detector (length-of-stain), with a supply of detector tubes, is an assembly of specially designed pump and detector tubes that operates by using the pump to pull a known volume of air or gas through a detector tube. The tubes contain chemical reagents that are designed to detect the presence and display the concentration of hydrogen sulfide or sulfur dioxide in the sample. The length of the resultant color band in the tube indicates an instantaneous quantitative concentration of the specific chemical in the sample.

requirements and should be used where the work area atmospheric concentration exceeds 10 ppm for hydrogen sulfide or 2 ppm for sulfur dioxide:

- a. Self-contained, positive-pressure/pressure-demand breathing equipment that provides respiratory protection in any atmospheric concentration of hydrogen sulfide or sulfur dioxide.
- b. Positive-pressure/pressure-demand air-line breathing equipment coupled with a self-contained breathing apparatus equipped with a low pressure warning alarm and rated for fifteen minutes (minimum). This equipment permits the wearer to move from one work area to another.
- c. Positive-pressure/pressure-demand, air-line breathing equipment, with an auxiliary self-contained air supply (rated for a minimum of 5 minutes). This type unit can be used for entry as long as the air line is connected to a source of breathing air. *The auxiliary self-contained air supply (rated for less than 15 minutes) is suitable only for escape or self-rescue use.*

Notes:

1. Personnel assigned job-related tasks requiring routine use of breathing equipment shall have a periodic review to determine their physiological and psychological adequacy for use of this equipment (refer to *ANSI Z 88.2* and 29 *Code of Federal Regulations* Part 1910.134).
2. Positive-pressure/pressure-demand, air-line or self-contained breathing apparatus, as appropriate, with full face piece shall be worn by personnel exposed to atmospheres containing concentrations of hydrogen sulfide or sulfur dioxide above OSHA's ACCs and PELs for air contaminants (refer to 29 *Code of Federal Regulations* Part 1910.1000).

CAUTION: Gas mask canister type breathing and demand type (negative pressure) equipment shall not be used in oil and gas producing and gas processing plant operations when a hydrogen sulfide or sulfur dioxide environment could be encountered.

6.4.1 Storage and Maintenance

Personal breathing equipment shall be strategically located so that this equipment is quickly and easily available to essential personnel. Essential personnel are those required to provide proper and prudent safe operations activities and those required to effect control of the hazardous hydrogen sulfide or sulfur dioxide conditions (refer to Par. 7.5). Additional breathing equipment may be required by site specific contingency plans (refer to Section 7). Breathing equipment shall be maintained and stored in a convenient, clean, and sanitary location, in accordance with OSHA's Respiratory Protection Standard (refer to 29 *Code of Federal Regulations* Part 1910.134). All breathing equipment shall be checked before and after each use and inspected at least monthly to ensure that it is maintained in satisfactory condition. A record of the monthly inspections, including dates and findings, shall be retained [refer to 29 *Code of Federal Regulations* 1910.134(f)]. These records should be retained for a minimum of twelve (12) months and longer if dictated by company policy. Equipment needing repair shall be appro-

priately tagged and removed from equipment stock until it is suitably repaired or replaced. Proper storage, maintenance, handling, and inspection is essential to the integrity of personal breathing equipment. Personnel with assigned breathing equipment should be instructed in proper maintenance of this equipment, or other steps shall be taken to ensure its integrity. NIOSH, OSHA, and manufacturer's recommendations shall be followed.

6.4.2 Face Piece Restrictions

Full face piece breathing equipment meeting requirements of Par. 6.4 should be used where the work area atmosphere concentration exceeds 10 ppm for hydrogen sulfide or 2 ppm for sulfur dioxide. Personnel shall not wear eyeglasses with temple bars that extend through the sealing edge of the face piece. Using approved adapters, corrective prescription lenses may be mounted inside the breathing apparatus face piece.

As of this writing, U. S. Department of Labor (OSHA) does not permit wearing contacts when using respirator breathing equipment [refer to *29 Code of Federal Regulations* Part 1910.134(e)(5)(ii)]. OSHA has investigated the prohibition of contact lenses used under respirator breathing equipment and issued a field memorandum (February 8, 1989, Thomas Shepich, Director, Directorate of Compliance Programs) stating their intent to modify the rule and issuing an interim enforcement policy as follows:

- a. Violations of the Respiratory Protection Standard (*29 Code of Federal Regulations* Part 1910.134) involving the use of gas permeable and soft contact lenses shall continue to be documented in the case file and recorded as de minimis; citations shall not be issued.
- b. Evidence indicating any negative effect(s) associated with the use of contact lenses with respirator breathing equipment should be provided to U. S. Department of Labor (DOL), Occupational Safety and Health Administration (OSHA), Directorate for Compliance Programs, Washington, D. C. 20210. Benefits associated with the use of contact lenses with respirator breathing equipment would be useful to OSHA. The issue of use of non-gas-permeable hard contact lenses will be resolved in OSHA's revision of *29 Code of Federal Regulations* Part 1910.134.

Note: Companies should review available information and provide employee guidance regarding the use of contact lenses under respirator breathing equipment.

Personnel shall not wear facial hair that may prevent proper sealing of the face mask. Personnel shall be satisfied that a face seal can be obtained with the assigned equipment or randomly selected unassigned equipment before they use the equipment. If a seal cannot be obtained, either satisfactory equipment must be provided or the individual shall be disqualified from working in areas where hazardous conditions are anticipated or existent.

6.4.3 Air Supply

Breathing air quality shall meet requirements set forth in OSHA's Respiratory Protection Standard, *29 Code of Federal Regulations* Part 1910.134, and shall at least meet Grade D requirements as described in *ANSI CGA G-7.1*.

6.4.4 Compressors

All breathing air compressors used shall meet the requirements set forth in *29 Code of Federal Regulations* Part 1910.134 of OSHA's Respiratory Protection Standard. The air intake for such compressors must be located in a contaminant-free area that is unclassified by *API RP500*, Section B. Inlet air for such compressors shall be monitored when conditions arise which permit possible contamination of the inlet air by toxic, flammable, or combustible gases.

6.4.5 Breathing Equipment Use

Personnel shall use breathing equipment prior to entering an area where OSHA ACCs and PELs for hydrogen sulfide and sulfur dioxide, respectively, are exceeded (refer to Par. 4.1, Appendices A and B, and *29 Code of Federal Regulations* Part 1910.1000, Subpart Z, Table Z.1) until either the area is made or tested safe or they return to a safe area. *Breathing equipment shall be put on in a safe area prior to either beginning a rescue operation or entering a hazardous environment.*

6.5 STANDBY RESCUE PERSONNEL

When personnel work in locations with hydrogen sulfide or sulfur dioxide concentrations considered immediately dangerous to life or health (IDLH) (refer to Appendices A and B) in the working breathing zone, a standby rescue person trained in rescue techniques and with suitable rescue equipment, including appropriate breathing apparatus (refer to Par. 6.4), shall be provided.

6.6 RESCUE EQUIPMENT

At locations with hydrogen sulfide, sulfur dioxide, or oxygen concentration considered immediately dangerous to life or health (IDLH), suitable rescue equipment [for example, appropriate breathing equipment, lifeline(s), and harness(es)] shall be provided. Types of rescue equipment required will vary and will depend on the type of job and work being performed. Appropriate counsel with qualified health and safety professional personnel should be effected to determine what rescue equipment should be available for site-specific job and work conditions.

6.7 WIND DIRECTION INDICATORS

Consideration should be given to locating windsocks, streamers, flags, or other suitable devices for indicating wind

direction at the producing or gas processing site. These devices shall be readily visible to personnel on or approaching the work location.

Note: Regulatory requirements for wind direction indicators shall be observed.

6.8 WARNING SIGNS

Legible warning signs, such as "HYDROGEN SULFIDE OPERATIONS—ENTER ONLY WHEN MONITORING SHOWS THE AREA TO BE SAFE" or "RESPIRATORY PROTECTION EQUIPMENT MUST BE WORN BEYOND THIS POINT," should be prominently posted at appropriate locations (e.g., entrance points) for facilities where produced fluids containing hydrogen sulfide (refer to Par. 4.1 for applicability) are being processed or handled.

Note: Regulatory requirements for sign posting shall be observed.

7 Contingency Planning Including Emergency Procedures

7.1 INTRODUCTION

Operators shall evaluate existing and new operations involving hydrogen sulfide and sulfur dioxide to determine if contingency plans, special emergency procedures, and/or training are required. The evaluation process shall identify potential emergencies and their impact on operating personnel and the general public. The contingency plan, if required, shall conform to all applicable local, state, and federal regulations regarding notifications, precautions, evacuations, and other requirements (refer to 40 *Code of Federal Regulations* Part 264, Subpart D; 29 *Code of Federal Regulations* Part 1910.120; and 29 *Code of Federal Regulations* Part 1910.38 for EPA and OSHA requirements, respectively, for contingency plans and emergency procedures).

7.2 SCOPE

The contingency plan should contain emergency response procedures that provide an organized immediate action plan for alerting and protecting operating personnel and the public. Contingency plans should be site specific for the facility operations and should consider the severity and extent of the anticipated atmospheric hydrogen sulfide and sulfur dioxide concentrations. Contingency plans should consider the dispersion characteristics of hydrogen sulfide and sulfur dioxide (refer to Appendix C or other recognized dispersion modelling techniques). Contingency plans should contain provisions for all applicable items listed in this section. (Refer to *Hazardous Materials Emergency Planning Guide, NRT-1*, and *Technical Guidance For Hazards Analysis*. In addition to the contingency plan, Sections 302 and 303 of the *Superfund Amendments and Reauthorization Act of 1986* (SARA Title III) can require a facility operator to name a facility emer-

gency coordinator to work with a local emergency planning committee (LEPC) in the development of an emergency response plan (refer to 40 *Code of Federal Regulations* Part 355).

7.3 AVAILABILITY OF PLAN

The contingency plan shall be available to all personnel responsible for implementation, regardless of their normal location assignment.

7.4 PLAN INFORMATION

Contingency plans should contain, but not be limited to, information on the following subjects, as appropriate:

- a. Emergency Procedures:
 1. Responsibilities of personnel (refer to Par. 7.5).
 2. Immediate action plan (refer to Par. 7.6).
 3. Telephone numbers and communication methods (refer to Par. 7.7).
 4. Locations of nearby residences, businesses, parks, schools, churches, roads, medical facilities, etc.
 5. Evacuation routes and road block locations.
 6. Safety equipment and supplies available (e.g., number and location of breathing equipment).
- b. Characteristics of Hydrogen Sulfide and Sulfur Dioxide:
 1. Refer to Appendix A for hydrogen sulfide characteristics.
 2. Refer to Appendix B for sulfur dioxide characteristics.
- c. Facility Description, Maps, and Drawings:
 1. Plants.
 2. Water injection stations.
 3. Wells, tank batteries, gas conditioning facilities, flow-lines.
 4. Compression facilities.
- d. Training and Drills (refer to Par. 7.8):
 1. Responsibilities and duties of essential personnel.
 2. On-site or classroom (tabletop) drills.
 3. Informing nearby residents on protective measures in emergency situations, as appropriate.
 4. Training and attendance documentation.
 5. Briefing of public officials on issues such as evacuation or *shelter-in-place*²⁰ plans.

7.5 RESPONSIBILITIES OF PERSONNEL

The contingency plan shall outline responsibilities and duties of all essential personnel. Visitors and other non-essential personnel should be prohibited from remaining in or entering an area contaminated by hydrogen sulfide exceeding an atmospheric concentration of 10 ppm or a concentra-

²⁰Shelter-in-place refers to the concept of providing the public additional protection by having residents stay indoors until emergency evacuators arrive or the emergency is over (refer to References 62, 63, 64, 65, 66, and 67).

tion of sulfur dioxide exceeding 2 ppm in the atmosphere (refer to Par. 4.1 and Appendices A and B).

7.6 IMMEDIATE ACTION PLAN

Each contingency plan should contain a condensed "Immediate Action Plan" to be followed by designated personnel any time they receive notice of a potentially hazardous hydrogen sulfide or sulfur dioxide discharge. For the protection of personnel (including the general public) and abatement of the discharge, this "Immediate Action Plan" should include, but not be limited to, the following provisions:

- a. Alert and account for facility personnel.
 1. Move away from the hydrogen sulfide or sulfur dioxide source and get out of the affected area.
 2. Don proper personal breathing equipment.
 3. Alert other affected personnel.
 4. Assist personnel in distress.
 5. Proceed to the designated emergency assembly area.
 6. Account for on-site personnel.
- b. Take immediate measures to control the present or potential hydrogen sulfide or sulfur dioxide discharge and to eliminate possible ignition sources. Emergency shutdown procedures should be initiated as deemed necessary to correct or control the specific situation. When the required action cannot be accomplished in time to prevent exposing operating personnel or the public to hazardous concentrations of hydrogen sulfide or sulfur dioxide, proceed to the following steps, as appropriate for the site specific conditions.
- c. Alert the public (directly or through appropriate government agencies) that may be subjected to an atmosphere exposure exceeding 30 ppm²¹ of hydrogen sulfide or 10²¹ ppm of sulfur dioxide.
- d. Initiate evacuation operations.
- e. Contact the first available designated supervisor on the call list (refer to Par. 7.4.a). Notify the supervisor of circumstances and whether or not immediate assistance is needed. The supervisor should notify (or arrange for notification of) other supervisors and other appropriate personnel (including public officials) on the call list.
- f. Make recommendations to public officials regarding blocking unauthorized access to the unsafe area and assist as appropriate.
- g. Make recommendations to public officials regarding evacuating the public and assist as appropriate.
- h. Notify, as required, state and local officials and the National Response Center to comply with release reporting re-

²¹Emergency Response Planning Guide Level 2 (ERPG-2), refer to Reference 27. ERPG-2 is defined as the maximum airborne concentration below which it is believed that nearly all individuals could be exposed for up to one hour without experiencing or developing irreversible or other serious health effects or symptoms that could impair an individual's ability to take protective action.

quirements (i.e., 40 Code of Federal Regulations Parts 302 and 355) (refer to Par. 4.4).

- i. Monitor the ambient air in the area of exposure (after following abatement measures) to determine when it is safe for re-entry.

Note: This sequence (Par. 7.6) should be altered to fit the prevailing situation. Certain actions, especially those dealing with the public, should be coordinated with public officials.

7.7 EMERGENCY TELEPHONE LISTS

A list of emergency telephone numbers should be prepared and maintained as a part of the contingency plan, considering the need to contact any of the following:

- a. Emergency Services
 1. Ambulances
 2. Hospitals
 3. Medical personnel (e.g., doctors)
 4. Helicopter services
 5. Veterinarians
- b. Government Agencies and Contacts
 1. Local Emergency Planning Committee
 2. National Response Center
 3. State Emergency Response Commission
 4. State and Local Law Enforcement Agencies
 5. Civil Defense
 6. Fire Departments
 7. Other applicable government agencies.
- c. Operator and Contractors
 1. Operator personnel
 2. Contractor personnel
 3. Applicable service companies
- d. Public

7.8 TRAINING AND DRILLS

The value of training and drills in emergency response procedures for oil and gas operations involving hydrogen sulfide or sulfur dioxide cannot be over emphasized. All personnel identified in the plan shall have appropriate training. It is important that the training conveys a full appreciation of the importance of each role and the effect that each person has on implementing an effective emergency response.

Exercises or drills that simulate an emergency in which personnel perform or demonstrate their duties are important tools that can convey the importance of contingency plans and result in their being kept current. The exercise can be a tabletop or classroom discussion; or can be a realistic drill in which equipment is deployed, communication equipment is tested, and "victims" are sent to hospital facilities with simulated injuries. Public officials should be informed of (and preferably involved in) these exercises. After a plan is tested, it should be revised and retested until those responsible for the plan are confident the plan is operational. Refer to *NRT-1: Hazardous Materials Emergency Planning Guide*.

7.9 UPDATING PROVISIONS

A contingency plan shall be periodically reviewed and updated any time its provisions or coverage change (refer to Par. 9.24).

8 Design and Construction Practices

8.1 DESIGN GUIDELINES

Recommendations presented in Section 8 apply to producing and gas processing plant operations where the fluids handled contain sufficient hydrogen sulfide to be within the scope of *NACE Standard MR0175*. *NACE Standard MR0175* may also be a useful reference when designing and constructing other facilities handling hydrogen sulfide. Refer to Appendix D for information on defining a sour environment. All pressure vessels should be designed and constructed in accordance with *ASME Boiler and Pressure Vessel Code* [refer to *Synopsis of Boiler and Pressure Vessel Laws, Rules, and Regulations by States, Cities, Counties, and Provinces (United States and Canada)*]. All piping systems should be designed and constructed in accordance with applicable provisions of *ANSI B31.3*, *ANSI B31.4*, OR *ANSI B31.8*.

Manufactured equipment shall be designed, constructed, tested, and approved to meet or exceed system requirements for hydrogen sulfide service and should be installed in compliance with applicable codes and industry-accepted standards.

8.1.1 Process and Mechanical Considerations

Factors to be considered in facility design include, but are not limited to, the hydrogen sulfide concentration and impact of atmospheric and operating temperatures, system pressures, pH and water content of system fluids, mechanical stresses imposed on system components, operating and physical strength changes of system components resulting from corrosion and scale deposits, and conditions peculiar to individual processes that could be of a detrimental nature to the system.

8.1.2 Design Considerations

To minimize internal corrosion, piping and vessels should be designed and installed in such a way that areas of insufficient flow (including dead-end piping) are eliminated. Where this cannot be accomplished, provisions should be made for draining of accumulated fluids. Drain systems for hydrogen sulfide laden fluids should be designed to prevent migration of hydrogen sulfide from one point in the facility to another.

8.1.3 Materials Considerations

When exposed to an environment containing hydrogen

sulfide, many materials may suddenly fail in a brittle manner. Failure occurs by a form of embrittlement known as sulfide stress cracking (SSC). Susceptibility of a given material to sulfide stress cracking increases as strength and tensile stress (residual or applied) increase. Material hardness frequently is used as an indirect measure of strength and sometimes is referenced as a limiting parameter. The failure of certain producing and gas processing plant equipment components used in the sulfide stress cracking regime could result in the uncontrolled release of hydrogen sulfide to the atmosphere. Such components should be made from sulfide stress cracking resistant materials (refer to Par. 8.1.4).

8.1.4 Materials Selection

Metallic materials satisfactory for use in hydrogen sulfide environments and the conditions under which they should be used are described in *NACE Standard MR0175*. The latest revision of this standard should be consulted when selecting materials for use in hydrogen sulfide environments. The provisions of *NACE Standard MR0175* should be considered minimum standards, with the equipment user free to apply more stringent specifications. The material requirements of *NACE Standard MR0175* offer resistance to sulfide stress cracking (SSC); however, other forms of corrosion and modes of failure (such as pitting, hydrogen-induced cracking, and chloride cracking) should be considered in the design and operation of equipment. Control of failures by mechanisms other than SSC should be mitigated by chemical inhibition, material selection, and environmental controls (refer to *NACE Standard MR0175*, Par. 1.1). Appendix D includes excerpts from *NACE Standard MR0175*, providing the definition of a sour environment and graphs that may be used to determine when sulfide stress cracking resistant materials should be used. Users of this publication should check the latest edition of *NACE Standard MR0175* for revisions to the defining criteria for a sour environment.

8.1.4.1 Manufacturer certification of compliance with *NACE Standard MR0175* for equipment intended for hydrogen sulfide service may be required by the user, depending on severity of the service. Adequate quality assurance procedures should be followed to verify compliance by the manufacturer for the original equipment and for any subsequent equipment modifications.

8.1.4.2 Materials not covered in *NACE Standard MR0175* that have been qualified for hydrogen sulfide environment service by the user or manufacturer, using recognized and acceptable testing procedures, may be used. A written agreement between the manufacturer and user may be appropriate. Recognized and acceptable testing procedures are those that demonstrate that the material(s) performs as well as or superior to similar material(s) set forth in *NACE Standard MR0175*, using laboratory procedures or procedures for which testing has been completed under actual or simulated

environmental conditions. The suitability of materials must be supported by appropriate documentation that should include a complete description of the materials, processing, and testing procedure. Laboratory, field, or other environmental testing results or service performance should be recorded in writing. Full documentation supporting the suitability of the material(s) for the selected service should be maintained by the user, manufacturer, or both. Materials use is subject to compliance with applicable regulations.

8.1.5 Site Selection

In selecting a facility site, consideration should be given to taking advantage of the prevailing wind direction, climatic conditions, terrain, transportation routes, and the proximity of populated or public areas. Site selection should consider maintenance of clear entrance and exit routes and should minimize existence of confined spaces. Applicable regulatory requirements concerning location, spacing, and height of flares or vent stacks shall be considered in site selection.

8.1.6 Warning Method

Facility design should incorporate a means to provide a warning of a hazardous upset or condition. Devices and equipment such as hydrogen sulfide monitoring equipment, hazardous warning equipment (audible or visual), and process monitoring devices (such as pressure and flow rate sensors) should be considered. The operator should specify, and the design should consider, the physical and environmental conditions that will be present at the installation site.

8.2 CONSTRUCTION GUIDELINES

Construction of facilities within the scope described in Paragraph 8.1 should be conducted in accordance with the following recommendations, as applicable.

8.2.1 Fabrication and Joining System Components

Welding rods of proper composition and size, applied at recommended temperature and rate, should be used to join pipe and system components by welding. Preheating, post-heating, stress relieving, and hardness control requirements should be in accordance with a welding procedure specification (WPS). Proper bolting and gasket materials should be selected in accordance with *NACE Standard MR0175*. Proper alignment should be maintained for all piping, and all system components should be adequately supported to reduce stresses.

8.2.2 Qualification of Personnel

Fabrication of system components and joining of pipe should be done by experienced and qualified workers. Piping

system welders should have passed a performance qualification test in accordance with Section IX, *ASME Boiler and Pressure Vessel Code* or *API Standard 1104*. Qualification under *API Standard 1104* will satisfy U. S. Department of Transportation (DOT) requirements for pipelines. Welders shall be permitted only to weld on materials, and to use only procedures, for which they are currently qualified.

8.2.3 Handling and Storage of Equipment

Materials and equipment used in facility construction, reconstruction, repair, or in routine maintenance should be stored and handled in a manner that will not jeopardize their integrity. Where equipment storage is required or where use after installation is delayed, adequate precautionary measures against corrosion, fouling, deterioration, and other harmful effects should be employed. Reliable warehouse control methods shall be employed to assure that material and equipment unsuitable for hydrogen sulfide service is not inadvertently used in hydrogen sulfide service.

8.2.4 Inspection

Pressure-containing components should be thoroughly cleaned and pressure tested in accordance with applicable construction codes. Welded connections should be tested by non-destructive tests (such as ultrasonic or radiographic methods). Final facility inspection should be conducted by knowledgeable personnel to determine that the completed facility complies with design specifications and material records and that markings indicate materials used are suitable for the intended service. Refer to *API 510* and *API Recommended Practice 12R1*.

8.2.5 Repairs

Equipment or systems damaged or worn to the extent that their safety and reliability are doubtful shall not be placed or retained in service. Vessel, piping, and equipment repairs shall be made by qualified and, where required, certified personnel in accordance with applicable codes and good work practices. Only compatible materials, suitable for use in the existing hydrogen sulfide environment shall be used to repair or replace equipment for use in this service. Refer to *API 510*.

8.3 ELECTRICAL DESIGN CONSIDERATIONS

In addition to being toxic, hydrogen sulfide is flammable at concentrations of 4.3 to 46 percent (by volume) in air. Electrical equipment installed in areas subject to exposure to a methane-hydrogen sulfide mixture composed of 25% or more (by volume) of hydrogen sulfide should be suitable for Class I, Group C classified areas (refer to Par. 3.5, "National Electric Code Grouping of Atmospheric Mixtures," in *API Recommended Practice 500*).

9 Operating Practices

9.1 INTRODUCTION

Section 9 discusses operating practices that should be followed to provide integrity of equipment and continuity of work practices in operations involving the design and handling of materials in hydrogen sulfide service (refer to Par. 4.1 and applicable regulatory requirements). Each equipment installation or work procedure should be reviewed and observed as often as necessary to detect when changes may be needed in operating practices or equipment. *Water injection and other enhanced recovery operations may result in the introduction of bacteria that can cause water soluble hydrogen sulfide to develop over time and be present in produced fluids.*

9.2 EMERGENCY PROCEDURES

Emergency operating and shutdown procedures shall be posted or readily available to operating personnel.

9.3 TEST PROCEDURES

Tests of the gas phase of produced fluids shall be conducted periodically to determine the hydrogen sulfide concentration. Procedures should be established and routine operational tests should be conducted periodically for hydrogen sulfide detection and monitoring equipment and alarm devices, forced air ventilation systems, and similar safety devices. Results of these tests should be recorded.

9.4 SAFE WORK PRACTICES

Safe operating procedures should be developed for performing operations and maintenance (e.g., tank gauging, water line blowdown, line repair, valve replacement, and sampling) so hazards due to the release of hydrogen sulfide can be avoided. A safety review of the work should be performed prior to beginning any maintenance or operating work activities requiring personnel to be in areas that could contain concentrations of hydrogen sulfide or sulfur dioxide exceeding the levels stipulated in Par. 4.1. Legible warning signs, such as "HYDROGEN SULFIDE OPERATIONS—ENTER ONLY WHEN MONITORING SHOWS THE AREA TO BE SAFE" or "RESPIRATORY PROTECTION MUST BE WORN BEYOND THIS POINT", should be prominently posted in the area where produced fluids containing hydrogen sulfide (refer to Par. 4.1 for applicability) are being handled or processed.

Note: Regulatory requirements for sign posting shall be observed.

9.5 LEAK DETECTION

In produced fluids handling systems containing hydrogen sulfide in concentrations capable of causing atmosphere con-

centrations in excess of 10 ppm, monitoring techniques or procedures (for example, visual observation, soap bubble test, portable detection equipment, fixed monitoring equipment) should be employed to detect leaks. Particular attention should be given to enclosed facilities (refer to Section 12).

9.6 SAFE WORK PERMITS

For activities without previously established operating procedures, special safety review documentation (e.g., hot work permits and check-off lists) outlining specific safety precautions with specific authorization should be used. Documentation should include personnel protective equipment required; equipment that should be properly blinded, blanked, or disconnected; equipment and piping that should be properly vented; procedures for excavation of buried lines in processing areas; etc.

9.7 VALVES, CONNECTIONS, AND GAUGES

Valves, flanges, gauges, connections, and other components should be observed for evidence of needed inspection, repair, or maintenance. The cause of equipment failure should be investigated and determined. If failure is caused by exposure to hydrogen sulfide, alternate methods or equipment should be considered.

9.8 ARTIFICIAL LIFT WELLS

Artificial lift wells should be observed for any change in operating conditions that could cause leaks or failures. Significant changes in wellhead pressure, gas-oil-water ratios, flow rates, and similar parameters should be evaluated to prevent leaks or failures.

9.9 FLOWING WELLS

Annuli of flowing wells should be tested at regular intervals for any pressure changes. Such pressure changes may indicate a downhole failure of the packer, tubing, or casing. Changes in fluid volumes or ratios, fluid corrosiveness, and surface pressures should be evaluated to determine the need for corrective measures.

9.10 FLOW/GATHERING LINES

Flow line and gathering line right-of-ways should be observed for conditions conducive to pipeline failures, such as those caused by excavation, construction, trespassing, or surface erosion.

9.11 PRESSURE VESSELS

Relief valves and other applicable components on pressure vessels shall be tested according to regulatory requirements or company policy. Refer to *API 510* and *API*

Recommended Practice 576.

9.12 PRESSURE RELIEF AND NORMALLY VENTING DEVICES

The discharge of pressure relief and normally venting devices should be located away from work areas and designed to maximize dispersion and minimize personnel exposure to hydrogen sulfide. Refer to Par. 8.1.4 for considerations for materials applications in hydrogen sulfide service.

9.13 STORAGE TANKS

Produced liquids storage tanks should be observed for needed repairs or maintenance. The tank thief hatch seals, inspection and clean-out plate seals, vent line back-pressure valves, etc., should be serviced or replaced as appropriate. Refer to *API Recommended Practice 12R1*.

9.14 FLARE SYSTEMS

Ignition devices for flare systems handling hydrogen sulfide in hazardous concentrations should be inspected and serviced regularly to ensure proper operation.

9.15 MONITORING EQUIPMENT— MAINTENANCE, TESTING, AND CALIBRATION

Monitoring equipment used to detect occupational exposure levels of hydrogen sulfide shall be serviced and tested at intervals recommended by the manufacturer, and possibly more frequently under extreme humidity, temperature, dust, or other adverse environmental operating conditions. The monitoring equipment should be calibrated by qualified individuals at intervals frequent enough to enable the user to determine an acceptable calibration schedule. The equipment should be calibrated once every three (3) months, at intervals not exceeding 100 days. Refer to *ISA Recommended Practice 12.15*, the equipment manufacturer's instruction manual, and Section 10.

9.16 CORROSION MONITORING

A corrosion monitoring program should be established to detect and mitigate internal and external corrosion activity that can affect equipment in hydrogen sulfide service.

9.17 CONFINED SPACE ENTRY

Enclosures with known or potential hydrogen sulfide hazards and restricted means of entrance and exit deserve special attention. These enclosures are not normally occupied by people nor well ventilated. Examples of such enclosures in the oil and gas producing and gas processing plant industries may include tanks, cellars, process vessels, tank trucks, temporary and permanent pits and trenches, and barges. A con-

finied space entry permit shall be required for entry into a confined space. A confined space entry permit should as a minimum:

- a. identify the job site.
- b. indicate the date and duration of the permit.
- c. specify testing requirements and other conditions to safely perform the job.
- d. ensure that sufficient monitoring is conducted to ascertain that the hydrogen sulfide, oxygen,²² or hydrocarbon concentrations do not become a health or fire hazard, and
- e. bear the approval specified in the operator's procedure.

As an alternate to foregoing Par. 9.17, Item d, proper personal protective breathing equipment may be worn during the work operation; however, sufficient monitoring of the enclosure atmosphere shall be performed to ensure that it is free of an ignitable mixture of hydrocarbons. Refer to OSHA's Confined Space Entry Standard (29 Code of Federal Regulations Part 1910.146)

9.18 ENCLOSED FACILITY ENTRY

Personnel shall use extreme caution before entering enclosed facilities such as buildings housing oil, gas, or produced water processing and handling equipment containing hazardous concentrations of hydrogen sulfide. Personnel shall either establish that entry without personal protective breathing (respiratory protection) apparatus will be safe or shall wear protective breathing equipment. Refer to Section 12 for additional details and precautions.

9.19 IRON SULFIDE PRECAUTIONS

Iron sulfide, a reaction product of hydrogen sulfide and iron or spent iron sponge (a treating material), when exposed to air, can autoignite (spontaneous combustion) and burn. Iron sulfide, when exposed to air, should be kept wet until it can be disposed of in accordance with applicable regulations. Iron sulfide scale can accumulate on inside surfaces of vessels and on filter elements used in amine systems and become an autoignition hazard if exposed to atmospheric oxygen. One of the products of burning iron sulfide is sulfur dioxide; proper safety procedures must be effected to deal with this toxic substance.

9.20 DRILLING OPERATIONS

Refer to *API Recommended Practice 49* for recommended procedures for drilling and drill stem testing operations involving hydrogen sulfide.

²² *API PUBL 2217A: Guidelines for Work in Confined Spaces in the Petroleum Industry* specifies an oxygen content of less than 19.5% as oxygen deficient and an oxygen content of less than 16% is considered immediately dangerous to life and health (IDLH).

9.21 SAFETY PRECAUTIONS FOR SAMPLING AND TANK GAUGING OPERATIONS

When it is known or suspected that the system to be sampled or gauged may contain hydrogen sulfide, special precautions shall be observed. Production tanks shall be tested to determine their hydrogen sulfide content (refer to Par. 9.3). Tests should also be conducted within the normal worker breathing zone to determine if the levels stipulated in Par 4.1 may be exceeded and if engineering controls, administrative procedures, or personal protective breathing equipment (refer to Par. 6.4) may be required for sampling or tank gauging operations. The tests should be conducted under operating and atmospheric conditions to determine the maximum hydrogen sulfide exposure level.

If the hydrogen sulfide level in the worker breathing zone exceeds IDLH level (300 ppm), in addition to appropriate personal protective breathing equipment (refer to Par. 6.4), rescue precautions and procedures (refer to Pars. 6.5 and 6.6) shall be utilized.

9.22 FACILITIES ABANDONMENT—SURFACE EQUIPMENT

Precautions should be taken to ensure that hazardous quantities of hydrogen sulfide do not remain in abandoned surface equipment, including buried pipelines and flow lines. Pipelines and flow lines left in place should be purged, bullplugged, or otherwise capped. Vessels should be flushed with water, purged, drained, and left open to the atmosphere. Precautions should be taken to prevent an iron sulfide fire (refer to Par. 9.19).

CAUTION: Prior to abandonment, vessels should be checked for the presence of naturally occurring radioactive material (NORM) and appropriate safety and handling procedures should be exercised. Refer to *API Bulletin E-2* for guidance on management of NORM.

9.23 WELL ABANDONMENT

The following recommended practices are not intended to supersede federal, state, or local regulations for well abandonment. Where not covered by applicable regulations, the practices and well conditions should be considered in planning and effecting permanent well abandonment. It is recommended that cement be set across formations that are known to produce or could produce hydrogen sulfide in hazardous concentrations. Refer to *API Bulletin E-3* for guidance and procedures for plugging and abandoning wells.

9.24 CONTINGENCY PLAN REVISIONS

Operating personnel should be observant for changes that would make reconsiderations and possible revisions advisable in contingency plan coverage, location(s) of monitoring equipment, and location(s) of lease equipment. Some

changes that should be observed and considered are new residences or residential areas, stores, businesses, parks, schools, or roads; changes in well operations; and changes in lease facilities. Refer to Section 7 for suggested procedures for planning and implementing contingency plans and emergency procedures.

10 Guidelines for Evaluation and Selection of Continuous Hydrogen Sulfide Monitoring Equipment

10.1 INTRODUCTION

Section 10 is provided to make users of hydrogen sulfide monitoring equipment aware of some equipment limitations and certain desirable features of such equipment. There are a number of detection principles and analytical procedures available for monitoring the concentration of hydrogen sulfide in ambient air where the potential exists for exposure to levels that may be hazardous to health. These guidelines are intended to aid in the selection and application of continuous monitoring equipment for use in production operations involving hydrogen sulfide. The term "continuous hydrogen sulfide monitoring equipment" as used herein is defined as equipment capable of continuously measuring and displaying the concentration of hydrogen sulfide in ambient air. Section 10 is not applicable to personnel monitoring badges or length-of-stain or color-comparison type detector devices (refer to *ANSI/ISEA 102*).

10.2 GENERAL

All monitors, both portable and stationary, shall be designed on sound engineering and scientific principles and constructed of materials suitable for the application. Their design and construction should allow for ease of maintenance and repair. Instruments should be verified by a national recognized testing laboratory (NRTL) as meeting the minimum performance requirements of *ISA-S12.15*, Part I. Equipment should be installed, operated, and maintained in accordance with *ISA Recommended Practice 12.15*, Part II.

It generally is recommended (and frequently required) that electrical controls for safety systems such as hydrogen sulfide monitoring equipment and other gas detector systems be installed normally-energized ("fail-safe"). This means that power is supplied continuously during normal operations to devices which provide alarm(s) and corrective action if concentrations corresponding to specific alarm set points are reached. Under these conditions, interruption of power due to either deliberate safety device actuation or loss of power will initiate corrective action. It is desirable to provide a test means that will allow the system to be tested (and calibrated) without shutting in producing or gas processing plant operations (or other corrective action), but it should be evident to operating personnel that the system is in the test (bypass) mode.

To better ensure proper application, it is recommended that an environmental and application checklist (similar to the example shown in Appendix 1, *ISA Recommended Practice 12.15*, Part II) be provided to prospective vendors by the user.

10.3 CONSTRUCTION CHARACTERISTICS

The following construction and useability characteristics are desirable for hydrogen sulfide monitoring equipment.

10.3.1 Portability

Portable monitors, including all required parts and accessories, should weigh a maximum of ten (10) pounds and have a maximum volume of one (1) cubic foot.

10.3.2 Power Supply, Portable Monitoring Equipment

Portable hydrogen sulfide monitoring equipment is defined as self-contained, battery-operated, carryable or transportable instruments capable of operating within specifications from integral batteries for a period of eight hours minimum, including a 15 minute period of maximum load conditions (with alarms, lights, etc. activated), while exposed to clean air at a nominal temperature of 14°F (-10°C). Applications requiring in excess of eight hours of continuous operation or operation at lower temperatures should be specified by the end user.

10.3.3 Readout

Monitors should provide a direct readout of hydrogen sulfide concentration in parts per million (ppm) by volume.

10.3.4 Recorder Output

For certain applications, it may be desirable for monitors to provide an output signal (e.g., 4-20 ma) proportional to hydrogen sulfide concentration for use in connection with recorders or for other purposes.

10.3.5 Simplicity of Operation

Monitoring and detection equipment should be readily operable by personnel without scientific background or training in instrumentation.

10.3.6 Instruction Manuals

An instruction manual should be provided by the manufacturer with each instrument. The instruction manual should contain complete operating instructions, including procedures for startup, warm-up time, zero checks, calibration, alarm setting and testing, preventive maintenance, performance checks, and trouble-shooting. Monitors with rechargeable power supplies should be furnished with in-

structions for charging, storing, and maintaining the power supply. Information also should be included regarding instrument recovery time after the exposure of sensor(s) to hydrogen sulfide. The manufacturer should provide response time data and a list of interfering, desensitizing, or contaminating substances or water vapor concentrations known to the instrument manufacturer which may adversely affect proper operation and performance of the instrument (refer to Par. 10.4.7). Instruction manuals should include wiring diagrams and estimates of the life expectancy of all consumables. The manual should include a complete parts list suitable for identification of all replaceable parts and sources for procurement of these parts.

10.3.7 Electrical Approval

Any portion of a stationary hydrogen sulfide monitoring instrument intended for installation or use in a hazardous (classified) location and all portable monitoring instruments shall be approved for use in such a hazardous (classified) location and marked accordingly. Refer to *NFPA 70*, Article 500-3, FPN No. 2.

10.3.8 Ruggedness

Portable monitoring units should be sufficiently rugged to withstand routine transporting, handling, and use in the field environment, as specified by the user. Refer to *ISA-S12.15* for details of a recommended "drop test" to evaluate portable unit ruggedness and a "vibration test" to evaluate ruggedness of fixed and portable monitors.

10.3.9 Calibration Equipment

All accessories required to calibrate the instruments should be made available by the manufacturer. The life expectancy and any special handling required of any hydrogen sulfide test concentrations should be provided by the supplier.

10.3.10 Zero and Span Adjustments

Zero and span adjustment controls should be readily accessible for field adjustment, and the monitor design should include provisions to apply zero and calibration gases to the sensor(s) in a non-laboratory environment. All accessories for calibration and zero should be made available with the monitor and should be useable under field conditions.

10.3.11 Alarm Systems

Fixed monitors shall have provisions for external alarms. Portable monitor units should contain integral audible, visual, or physical presentation (e.g., vibrator signal) alarms as specified by the user. Hydrogen sulfide alarms should be unique to the location.

10.3.12 Testing Alarm Circuitry

Provisions should be included for the testing of alarms and alarm outputs. The test procedure should be included in the equipment instruction manual.

10.3.13 Remote Sampling

A remote sampling accessory (such as a probe) may be desirable for use with a portable monitoring unit.

CAUTION: Optional probe attachments for portable monitoring units, which allow the user to manually draw samples from remote locations, inherently prevent continuous monitoring of the immediate local environment. Users should consult the manufacturer's instruction manual to determine the proper number of bulb strokes required to draw samples when non-continuous monitoring attachments are used. The remote sampling attachment should be removed after use to restore the instrument to the normal continuous monitoring mode.

10.3.14 Equipment Trouble (Malfunction) Alarm

A trouble (malfunction) signal (indicator or output) should be provided for all monitors.

10.3.15 Detection Range Indication

The range(s) of detection should be conspicuously marked on the instrument.

10.4 PERFORMANCE GUIDELINES

The following recommended performance parameters are applicable to fixed and portable hydrogen sulfide monitoring equipment.

10.4.1 Accuracy

Instruments should meet requirements of the accuracy test specified in *ISA-S12.15*, Part I. Users are cautioned that the class of instruments suitable for field use are not "laboratory-grade" instruments, and *an equivalent degree of precision should not be expected.*

10.4.2 Zero Drift

Instruments should meet the requirements of the "Long-term Stability Test" specified in *ISA-S12.15*, Part I. Excessive zero drift is undesirable and can require instrument calibration at unreasonably short intervals.

10.4.3 Warm-up Time

The minimum warm-up time when power is first applied should be stated in the equipment instruction manual. A monitor ready-status indicator is a desirable feature.

10.4.4 Response Time

ISA-S12.15, Part I specifies monitoring equipment minimum response time to input step changes. The toxicity of hydrogen sulfide requires that monitoring equipment have rapid response time to alert personnel of potentially dangerous concentrations. Hence, response time of monitoring equipment is an important parameter for consideration in evaluation and selection of such equipment.

10.4.5 Operating Humidity Range

Monitoring equipment should meet the "Humidity Variation Test" specified in *ISA-S12.15*, Part I. Users should advise equipment manufacturers of the humidity ranges expected for specific equipment applications.

10.4.6 Operating Temperature Range

Monitoring equipment should be suitable for viable use in an ambient temperature range of 14°F to 122°F (-10°C to 50°C). Applications requiring equipment exposure to temperatures outside this range should be specified by the user.

10.4.7 Interferences

A list of interfering, desensitizing, and contaminating substances (e.g., carbon monoxide, sulfur dioxide, aromatic mercaptans, methanol, oxides of nitrogen, aldehydes, carbon sulfide, monoethanolamine, carbon dioxide, benzene, and methane) known by the manufacturer should be listed in the equipment instruction manual. Also, water vapor concentrations which may adversely affect proper equipment operation should be included in the instruction manual.

CAUTION: Monitoring and detector equipment and sensors should be protected from exposure to liquid spray or wash down. Such exposure can affect equipment performance and reliability.

10.4.8 Functional Field Test

Functional field testing of monitoring equipment should be conducted under "as installed" or "as used" conditions. All instrument and system accessories normally used with this equipment should be installed and operated during functional field tests. Functional field tests may include, but are not limited to, exposing the sensor to a sample containing sufficient hydrogen sulfide to cause response of the system. Functional field testing *does not* necessarily include zero and span adjustments. The hydrogen sulfide concentration used in functional field testing of monitoring equipment should not exceed the maximum operating range of the equipment being tested.

10.4.9 Air Velocity

Monitoring equipment should meet the "Air Velocity Variation Test" specified in *ISA-S12.15*, Part I. Accessories are

often available and may be desirable for use with detector equipment installed in areas of high air velocity.

10.4.10 Electromagnetic Interference (EMI)

Some monitoring equipment may be susceptible to electromagnetic interference (EMI), particularly radio frequency interference (RFI). Caution should be taken when using monitoring equipment in close proximity to a radio transmitter or other EMI generators. Refer to *ISA-S12.15*, Part I, Sections 9.5 and 11.6.

11 Offshore Operations

11.1 INTRODUCTION

Section 11 presents some additional recommendations that are needed offshore due to the uniqueness of offshore operations. Many recommendations in other sections of this publication also are applicable to offshore operations. Refer to Appendix F, "Toxic Gases", *API Recommended Practice 14C*.

11.2 UNIQUENESS OF OFFSHORE OPERATIONS

Problems that might be considered minor in onshore operations can be more critical in offshore operations. This is due to the remoteness of offshore operations, compactness of facilities, limited escape and evacuation routes, and sophisticated escape and evacuation equipment.

11.3 FEDERAL REGULATORY REQUIREMENTS

Refer to 30 *Code of Federal Regulations* Parts 250 and 256 for Minerals Management Service, U. S. Department of Interior (DOI) requirements for Outer Continental Shelf (OCS) oil and gas producing operations involving hydrogen sulfide. These regulations include requirements for training personnel involved in OCS oil and gas producing operations and for hydrogen sulfide contingency plans for OCS oil and gas producing operations.

11.4 CONTINGENCY PLANNING

Where potentially hazardous atmospheric concentration of hydrogen sulfide could occur offshore, contingency planning is particularly essential due to the uniqueness of facilities as discussed in Par. 11.2. Although the recommendations for contingency planning presented in Section 7 are applicable to offshore operations, there are additional items that should be addressed. These include, but are not limited to, the following:

a. **Training.** All personnel shall be familiar with the location and use of emergency escape equipment and routes. Personnel regularly assigned to offshore facilities shall be trained in the requirements of Par. 5.2, as well as be proficient in the

use of oxygen resuscitation equipment.

b. **Evacuation Procedures.** The U. S. Coast Guard's (Department of Transportation) requirements for emergency evacuation plans for manned Outer Continental Shelf facilities are contained in 33 *Code of Federal Regulations* Parts 140, 143, and 146 (refer to 54 *Federal Register*, May 18, 1989, 21566). Surface and/or air transportation to the site should be available since it may be necessary to evacuate visitors and other non-essential personnel and to bring in specialists or equipment if a hazardous hydrogen sulfide condition is suspected or does occur. Monitoring for combustible gases (primarily methane) and hydrogen sulfide should be provided to avoid unnecessarily exposing personnel and equipment to the dangers of a fire, explosion, or hazardous concentration during transport or transfer operations. If a hazardous hydrogen sulfide condition is known or suspected to be imminent, boats and helicopters should approach the site from an upwind direction, when possible.

Proper personal protective breathing equipment must be provided for helicopter and boat crew members and all passengers. Evacuation routes and debarking procedures shall be well planned and posted. Evacuation drills shall be regularly performed.

11.5 SIMULTANEOUS OPERATIONS

Particular emphasis must be given to coordination between drilling, well servicing, producing, and construction operations when two or more of these activities are conducted simultaneously. An individual shall be designated to be the person-in-charge for simultaneous operations, and the chain of command shall be communicated to all applicable personnel.

12 Operations Involving Enclosed Facilities

12.1 INTRODUCTION

Section 12 presents some additional recommendations that are unique to oil and gas producing and gas processing plant operations in enclosed facilities²³ and involving hydrogen sulfide (refer to Par. 4.1). An enclosed facility may be as simple as a single piece of equipment within an enclosure or as complicated as complex onshore or offshore enclosed facilities located in cold climates.

12.2 UNIQUENESS OF OPERATIONS INVOLVING ENCLOSED FACILITIES

The uniqueness of oil and gas producing and gas processing plant operations in enclosed facilities is due to the potential that escaping quantities of hydrocarbon gases containing hydrogen sulfide can be contained in an enclosed space²³, particularly if ventilation is inadequate. This space may be entered by personnel. A small leak of product containing hy-

drogen sulfide gas that would normally dissipate as it escaped can be contained in the enclosed space surrounding the leak and increase the hazard to entering personnel unless adequate ventilation is provided to reduce the hazard.

12.3 DESIGN CONSIDERATION

The design and construction practices of Section 8 generally apply to enclosed facilities, but there are areas of design that should be considered due to the unique operating situations they present. Additional design considerations for enclosed facilities can include, but are not limited to, the following:

- a. Means to prevent flammable liquids and gases from coming into contact with surfaces hot enough to cause ignition. The autoignition temperature for natural gas is approximately 900°F (482°C). The autoignition temperature for other natural gas mixtures ranges from 700°F to 900°F (371°C to 482°C). The autoignition temperature for hydrogen sulfide is approximately 500°F (260°C).
- b. Ventilation.
- c. Onsite respiratory protection equipment.
- d. Electrical equipment (possibly Group C versus Group D equipment required). Refer to Par. 3.5, "National Electrical Code Grouping of Atmospheric Mixtures", of *API Recommended Practice 500*.
- e. Emergency relief and depressuring devices and their discharge points.
- f. Hydrocarbon vents from diaphragm valves, machinery, and regulators.
- g. Compressor depressuring and blowdown lines.
- h. Floor drains.
- i. Process drains, manual and automatic.
- j. Vents from gas conditioning equipment (glycol and amine).
- k. Hydrogen sulfide monitoring system.

12.4 FIXED HYDROGEN SULFIDE MONITORING SYSTEM

In many locations where personnel enter frequently, on a regular basis, or occupy enclosed facilities for relatively long periods of time, fixed hydrogen sulfide monitoring systems (with adequate alarms) can enhance safety. In some locations, an alternative to fixed monitoring systems may be implementation of personnel entry procedures (refer to Pars. 9.18 and 12.5).

Fixed hydrogen sulfide monitoring systems should be installed in facilities containing process equipment (vessels,

machinery, etc.) handling gases or fluids containing hydrogen sulfide when a release of these gases or fluids is capable of causing atmospheres with hydrogen sulfide in concentrations exceeding 10 ppm when the locations are both:

- a. an enclosed area (room, building, or space) as defined by Par. 12.1 and *API Recommended Practice 500*.
- b. inadequately ventilated. [*Inadequately ventilated* is defined as ventilation (natural or artificial) which is *not* sufficient to prevent the accumulation of significant quantities of hydrogen sulfide-air mixtures in concentrations exceeding 10 ppm]. Adequacy of ventilation should be assessed on a site-specific basis.

Fixed monitoring systems shall contain audible alarm devices (and visual alarm devices in high noise areas, refer to Par. 10.3.11) activated by hydrogen sulfide concentrations at preset levels (not to exceed 10 ppm), as required to alert personnel. Hydrogen sulfide monitoring equipment should be calibrated in accordance with Par. 9.15.

It is recognized in specific instances that a fixed combustible gas detection system may detect the existence of a potentially hazardous atmospheric condition before a fixed hydrogen sulfide monitoring system that is set to alarm at 10 ppm of hydrogen sulfide would be activated. For example, in a release of a 300 ppm hydrogen sulfide in methane mixture, a combustible gas detector set to alarm at 20% lower explosive limit (LEL) would activate and sound an alarm at a hydrogen sulfide concentration of approximately 3 ppm.

In such instances, a regular testing program should be established to monitor content of the process stream to ensure that the concentration of hydrogen sulfide has not increased. If an increase in the hydrogen sulfide concentration is confirmed, the user should verify adequacy of the detection system in use. This verification should consider all variable criteria that will affect performance of the detection equipment as well as factors that could increase the concentration of hydrogen sulfide in the work atmosphere should a malfunction or equipment failure occur.

CAUTION: This option is limited in its scope and should be used only when all applicable limitations and site specific parameters have been duly considered.

Fixed monitoring systems are also desirable to monitor the air intake for enclosed areas when the air is used for makeup or for pressurizing the enclosed facilities (refer to *NFPA 496*).

12.5 PERSONNEL PROTECTION TECHNIQUES

A method of protecting personnel from exposure to atmospheric concentrations of hydrogen sulfide exceeding 10 ppm should be provided in all enclosed facilities containing process equipment (vessels, machinery, etc.) handling hydrogen sulfide bearing fluids and capable of causing hydrogen sulfide atmospheric concentrations in excess of 10 ppm. Acceptable methods include:

²³An enclosed facility (room, building, or space) is defined as a three-dimensional space enclosed by more than two-thirds ($2/3$) of the possible projected plane surface and of sufficient size to allow the entry of personnel. For a typical building, this would require that more than two-thirds ($2/3$) of the walls, ceiling, and/or floor be present. Refer to *API Recommended Practice 500*.

- a. Requiring personnel to wear proper protective breathing apparatus (refer to Par. 6.4) before entering and when in the facility.
- b. Installing fixed hydrogen sulfide monitoring equipment (refer to Par. 6.2, Section 10, and Par. 12.4).
- c. Properly ventilating the facility to maintain hydrogen sulfide concentrations in the work atmosphere less than 10 ppm, confirmed by monitoring with a fixed hydrogen sulfide monitoring system. Recirculation of air is allowed, but recirculated air streams should be monitored with fixed monitoring systems to alarm when concentrations of hydrogen sulfide exceed 10 ppm in the recirculated air.
- d. Testing the facility before entry and continuously while in the facility, using portable hydrogen sulfide detection equipment (refer to Par. 6.3), to ensure that hydrogen sulfide concentration in the work area atmosphere does not exceed 10 ppm.

Note: Personnel shall either establish that entry without protective breathing (respiratory protection) equipment will be safe or shall wear appropriate personal protective breathing equipment (refer to Par. 6.4).

12.6 WARNING SIGNS

Legible warning signs, such as "HYDROGEN SULFIDE OPERATIONS—ENTER ONLY WHEN MONITORING SHOWS THE AREA TO BE SAFE" or "RESPIRATORY PROTECTION EQUIPMENT MUST BE WORN BEYOND THIS POINT", shall be prominently posted outside all access doorways leading into enclosed facilities where produced fluids or gases containing hydrogen sulfide (refer to Par. 4.1 for applicability) are being processed or handled.

Note: Regulatory requirements for sign posting shall be observed.

13 Gas Processing Plant Operations

13.1 INTRODUCTION

Section 13 presents some additional recommendations that are unique to gas processing plant operations involving hydrogen sulfide (refer to Par. 4.1.). Some recommendations in other sections of this publication also are applicable to gas processing plant operations.

13.2 GENERAL CONSIDERATIONS

Gas processing plant operations typically include more complex processes than field operations (e.g., gas conditioning facilities). Some differences include:

- a. potentially higher volumes of gas containing hydrogen sulfide,
- b. potentially higher concentrations of hydrogen sulfide,
- c. generally a greater number of personnel and more equipment, and
- d. the assignment of personnel on a more regular basis.

These differences often require special considerations to ensure safe operations involving activities such as vessel and

line openings and confined space entry. When such activities are to take place, a coordinating meeting between operations, maintenance, contractor, and other involved parties should be held to ensure that facility personnel are aware of the activities involved, their effect(s) on plant operations, and the necessary safety precautions that are to be followed.

13.3 GAS CONDITIONING FACILITIES

Many gas treating and sulfur recovery processes are employed in gas processing plants. These processes can be classified into chemical reaction, physical solution, and adsorption processes, and can be further subdivided into regenerable and non-regenerable processes. Regenerable type processes include amine solvents, hot potassium carbonate, molecular sieve, and chelants. Non-regenerable type processes include iron sponge, caustic scrubbers, metal oxides, direct oxidation, and various other sulfur recovery processes. Because most of these methods result in a concentrated hydrogen sulfide stream or reaction product, operators shall be familiar with the various chemical and physical characteristics of the process(es) at the particular facility. The amount of hydrogen sulfide in residence within a process may be sufficient to require implementation of requirements contained in 29 Code of Federal Regulations Part 1910.119.

13.4 MATERIALS OF CONSTRUCTION

The failure of gas processing plant equipment components can permit the uncontrolled release of hydrogen sulfide to the atmosphere. Those equipment components in the sulfide stress cracking regime should be made from sulfide stress cracking resistant materials (refer to Par. 8.1.3).

13.5 CORROSION MONITORING

A corrosion monitoring program should be established to minimize internal and external corrosion activity which can affect equipment in hydrogen sulfide service.

13.6 LEAK DETECTION

In gas or liquid handling systems containing hydrogen sulfide in concentrations capable of causing atmospheric concentrations of 10 ppm or more of hydrogen sulfide, monitoring techniques or procedures (for example, visual observation, soap bubble test, portable detectors, or fixed monitoring equipment) should be employed to detect leaks. Particular attention should be given to enclosed facilities, such as control rooms, compressor buildings, cellars, and sumps (refer to Section 12). Regularly scheduled inspection of equipment for leaks, such as pump seals, is recommended. Results should be retained for a minimum of one year as a part of the facility or equipment operating and maintenance records. Fixed hydrogen sulfide ambient air monitoring systems are recommended (refer to Section 10 and Appendix C)

in gas processing plants located near populated areas to facilitate early detection and necessary warning to the general public.

13.7 CONTINGENCY PLANNING

Contingency plans for gas processing plant facilities shall cover plant personnel and the general public that could be

exposed to a release of hydrogen sulfide (refer to Appendix B of *API Recommended Practice 750*. Operating personnel must be familiar with emergency plant shutdown procedures, rescue operations, notification procedures, briefing areas, and locations of emergency equipment (refer to Section 7). Visitors shall be briefed on the physical layout of the gas processing facility, applicable warning signals, and how to respond in the event of an emergency.

APPENDIX A—PHYSICAL PROPERTIES AND PHYSIOLOGICAL EFFECTS OF HYDROGEN SULFIDE

A.1 Physical Data

Chemical Name: Hydrogen Sulfide

CAS Number: 7783-06-4

Synonyms: Sulfureted hydrogen, hydrosulfuric acid, dihydrogen sulfide.

Chemical Family: Inorganic sulfide.

Chemical Formula: H₂S.

Normal Physical State: Colorless gas, slightly heavier than air. Vapor density (specific gravity) at 59°F (15°C) and 1 atmosphere = 1.189.

Autoignition Temperature: 500°F (260°C).

Boiling Point: -76.4°F (-60.2°C).

Melting Point: -117.2°F (-82.9°C).

Flammable Limits: 4.3 - 46 percent vapor by volume in air.

Solubility: Soluble in water and oil; solubility decreases as the fluid temperature increases.

Combustibility: Burns with a blue flame to produce sulfur dioxide (SO₂). Refer to Appendix B.

Odor and Warning Properties: Hydrogen sulfide has an extremely unpleasant odor, characteristic of rotten eggs, and is easily detected at low concentrations. However, due to rapid onset of olfactory fatigue and paralysis (inability to smell) ODOR *SHALL NOT* BE USED AS A WARNING MEASURE.

A.2 Exposure Limits

The Occupational Safety and Health Administration (OSHA) has established 20 ppm by volume as an acceptable ceiling concentration (ACC) and 50 ppm by volume as an acceptable maximum peak above the ACC for an 8-hour shift for hydrogen sulfide (refer to 29 *Code of Federal Regulations* Part 1910.1000, Subpart Z, Table Z-2). The American Conference of Governmental Industrial Hygienists (ACGIH) recommends a Threshold Limit Value (TLV)⁽¹⁾ of 10 ppm (eight-hour TWA) and a short term exposure limit (STEL) of 15 ppm averaged over fifteen minutes. Exposure at the STEL should not be repeated more than four times per day with at least sixty minutes between successive exposures in this range. For Outer Continental Shelf (OCS) oil and gas producing operations, exposure levels exceeding 20 ppm instantaneous exposure require use of personal protective breathing equipment pursuant to U. S. Department of Interior, Minerals Management Service Final Rule, 30 *Code of Federal Regulations* Part 250.67, as published at 53 *Federal Register*

⁽¹⁾“TLV” is a trademarked term of the American Conference of Governmental Industrial Hygienists (ACGIH). Refer to *Threshold Limit Values and Biological Exposure Indices* and companion documents available from ACGIH, 1330 Kemper Meadow Drive, Cincinnati, OH 45240 (check latest edition).

10596-10777, April 1, 1988⁽²⁾. The *NIOSH Recommended Standard for Occupational Exposure to Hydrogen Sulfide* should be consulted for additional detailed information. Refer to Table A-2 for additional information on exposure values. CHECK WITH THE EMPLOYER CONCERNING EXPOSURE LIMITS FOR PARTICULAR CIRCUMSTANCES.

A.3 Physiological Effects

INHALATION AT CERTAIN CONCENTRATIONS CAN LEAD TO INJURY OR DEATH (refer to Table A-1). Hydrogen sulfide is an extremely toxic, flammable gas that may be encountered in the production and processing of gas well gas, high-sulfur-content crude oil, crude oil fractions, associated gas, and waters. Since hydrogen sulfide is heavier than air, it can collect in low places. It is colorless and has a foul, rotten-egg odor. In low concentrations, it is detectable by its characteristic odor. However, smell cannot be relied on to forewarn of dangerous concentrations because exposure to high concentrations (greater than 100 ppm) of the gas rapidly paralyzes the sense of smell due to paralysis of the olfactory nerve. A longer exposure to lower concentrations has a similar desensitizing effect on the sense of smell. IT SHOULD BE WELL UNDERSTOOD THAT THE SENSE OF SMELL WILL BE RENDERED INEFFECTIVE BY HYDROGEN SULFIDE, WHICH CAN RESULT IN AN INDIVIDUAL FAILING TO RECOGNIZE THE PRESENCE OF DANGEROUSLY HIGH CONCENTRATIONS. Excess exposure to hydrogen sulfide causes death by poisoning the respiratory system *at the cellular level*. There is some indication that the presence of alcohol in the blood aggravates the effects of hydrogen sulfide in acute poisoning cases. Even at low concentrations (10-50 ppm) hydrogen sulfide is irritating to the eyes and respiratory tract. Closely repeated short-term exposures at low concentrations may lead to irritation of the eyes, nose, and throat. Symptoms from repeated exposures to low concentrations usually disappear after not being exposed for a period of time. Repeated exposures to low concentrations that do not produce effects initially may eventually lead to irritation if the exposures are frequent.

A.4 Respiratory Protection

The National Institute for Occupational Safety and Health (NIOSH) has examined the criteria for respirator tests and sources of respirator leakage and recommends that positive pressure, either supplied-air or self-contained breathing apparatus, as appropriate, with a full face piece be worn by

⁽²⁾Available from Superintendent of Documents, U. S. Government Printing Office, Washington, DC 20402.

anyone exposed to atmosphere containing hydrogen sulfide concentrations above OSHA's ACC (refer to 29 *Code of Federal Regulations* Part 1910.1000, Subpart Z, Table Z-2) Refer to Par. 6.4 for proper breathing equipment recommendations for oil and gas producing and gas processing plant operations involving hydrogen sulfide.

Note: There are differences of opinion in the medical community about whether a person with a perforated eardrum can become overexposed to a toxic substance via the ear, even when wearing proper personal breathing apparatus, and whether they should be excluded from work in a hydrogen sulfide environment⁽³⁾. Theoretical calculations by Richard Ronk and M. K. White⁽³⁾ have led the authors to conclude that tympanic membrane (eardrum) defects do not significantly compromise respiratory protection against hydrogen sulfide and that individuals with perforated tympanic membranes should not be excluded from work in a hydrogen sulfide environment. The validity of these calculations is supported by the absence of case reports of hydrogen sulfide poisoning due to tympanic membrane defect.

Ronk and White⁽³⁾ also concluded that wearers of positive-pressure, either supplied-air or self-contained personal breathing apparatus, with a full face piece, as recommended by the National Institute for Occupational Safety and Health (NIOSH), who have a tympanic membrane defect and a concurrent tympanomaxillary shunt or a patulous eustachian tube (the tube remains open) may experience the sensation of outward air flow which can

be annoying.

In 1982, the Minerals Management Service (MMS), U. S. Department of Interior, amended requirements of the Outer Continental Shelf (OCS) Hydrogen Sulfide Standard, *MMS-OCS-1*, "Safety Requirements for Drilling Operations in a Hydrogen Sulfide Environment, Outer Continental Shelf", Section 5.2, February 1976. MMS rescinded the requirement for personnel eardrum examinations and rescinded the prohibition against persons with perforated eardrums working in a hydrogen sulfide environment (refer to 47 *Federal Register* 28888-28890, July 1, 1982).

The U. S. Occupational Safety and Health Administration may address this subject in future revision of its Respiratory Protection Standard (29 *Code of Federal Regulations* Part 1910.134).

⁽³⁾Compare Poda, George A., "Hydrogen Sulfide Can Be Handled Safely", *Archives of Environmental Health*, Vol. 12, 795-800, June 1966, and Ronk, Richard and White, M. K., "Hydrogen Sulfide and the Probabilities of Inhalation Through Tympanic Membrane Defect", *Journal of Occupational Medicine*, Vol. 25, No. 5, 337-340, May 1985.

Table A-1—Hydrogen Sulfide

Concentration in Air				Typical Characteristics Regarding Hydrogen Sulfide Exposure ⁽⁵⁾
Percent by Volume	Parts Per Million By Volume	Grains Per 100 Std. Cubic Feet	Milligrams Per Cubic Meter ⁽⁴⁾	
0.000013	0.13 ⁽⁶⁾	0.008 ⁽⁶⁾	0.18 ⁽⁶⁾	Obvious and unpleasant odor generally at 0.13 ppm and quite noticeable at 4.6 ppm. As the concentration increases, the sense of smell fatigues and the gas can no longer be detected by odor. ⁽⁶⁾
0.001	10	0.63	14.41	Unpleasant odor. Possible eye irritation. ACGIH recommended Threshold Limit Value (TLV) [®] (eight-hour TWA). ⁽⁷⁾
0.0015	15	0.94	21.61	ACGIH STEL averaged over 15 minutes. ⁽⁷⁾
0.002	20	1.26	28.83	Burning sensation in eyes and irritation of the respiratory tract after one hour or more exposure. OSHA ACC (refer to 29 Code of Federal Regulations Part 1910.1000, Subpart Z, Table Z-2).
0.005	50	3.15	72.07	Loss of sense of smell after about 15 or more minutes exposure. Exposure over one hour may lead to headache, dizziness, and /or staggering. Pulmonary edema reported following extended exposure to greater than 50 ppm. ⁽⁸⁾ Exposure at 50 ppm or greater can cause serious eye irritation or damage.
0.01	100	6.30	144.14	Coughing, eye irritation, loss of sense of smell after 3 to 15 minutes. Altered respiration, pain in eyes, and drowsiness after 15 to 20 minutes, followed by throat irritation after one hour. Prolonged exposure results in a gradual increase in the severity of these symptoms.
0.03	300	18.90	432.40	Marked conjunctivitis and respiratory tract irritation. Note: Concentration considered immediately dangerous to life or health (IDLH) ⁽⁹⁾ (refer to DHHS No. 85-114, NIOSH Pocket Guide to Chemical Hazards. ⁽¹⁰⁾
0.05	500	31.49	720.49	Unconsciousness after short exposure, cessation of breathing if not treated quickly. Dizziness, loss of sense of reasoning and balance. Victims need prompt artificial ventilation and /or cardiopulmonary resuscitation (CPR) techniques.
0.07	700	44.08	1008.55	Unconscious quickly. Breathing will stop and death will result if not rescued promptly. Artificial ventilation and /or cardiopulmonary resuscitation (CPR) is needed immediately.
0.10+	1000+	62.98+	1440.98+	Unconsciousness at once. Permanent brain damage or death may result. Rescue promptly and apply artificial ventilation and /or cardiopulmonary resuscitation (CPR).

Note: Data in Table A-1 are approximate values for guidance. There are published data that show slightly different values.

⁽⁴⁾Based on 1% hydrogen sulfide = 629.77 gr/100 SCF @ 14.696 psia and 59°F (101.325 KPa and 15°C).

⁽⁵⁾Hydrogen sulfide has physiological effects on humans. These effects vary from person to person. FOR ADDITIONAL INFORMATION, CONSULT WITH THE EMPLOYER AND RESEARCH THE MATERIAL SAFETY DATA SHEETS (MSDS).

⁽⁶⁾There are wide variations in reported odor thresholds for hydrogen sulfide. A U.S. Environmental Protection Agency draft report states a range for the odor threshold of 0.1-0.2 ppm (refer to Review Draft: *Health Assessment Document for Hydrogen Sulfide*, EPA/600/8-86/026A, August 1986). A Petroleum Association for Conservation of the Canadian Environment (PACE) report, *Review of Ambient Hydrogen Sulfide Standards in Canada*, No. 85-5, December 1985, cites an odor threshold range of 0.005-0.05 ppm from the National Resource Council of Canada (1981) at Table 3.1 (page 3-

10). The PACE document also cites reports of wider ranges of odor threshold from 0.0005-1.4 ppm at Table 4.1 (page 4-4).

⁽⁷⁾"TLV" is a trademarked term of the American Conference of Governmental Industrial Hygienists (ACGIH). Refer to *Threshold Limit Values and Biological Indices* and companion documents available from ACGIH, 1330 Kemper Meadow Drive, Cincinnati, Ohio 45240 (check latest edition).

⁽⁸⁾EPA Draft Review Document, supra Note (6), page 1-2.

⁽⁹⁾IDLH means an atmospheric concentration of any toxic, corrosive, or asphyxiant substance that poses an immediate threat to life or would cause irreversible or delayed adverse health effects or would interfere with an individual's ability to escape from a dangerous atmosphere (refer to 29 Code of Federal Regulations Part 1910.120). NIOSH considers 300 ppm or more to be the IDLH concentration for hydrogen sulfide (refer to *NIOSH Pocket Guide to Chemical Hazards*).

⁽¹⁰⁾Available from Superintendent of Documents, U. S. Government Printing Office, Washington, D. C. 20402.

Table A-2—Summary of Occupational Exposure Values for Hydrogen Sulfide

OSHA ACCs ⁽¹¹⁾		ACGIH TLVs ⁽¹²⁾				NIOSH RELs ⁽¹³⁾					
ACC		Maximum Peak Above ACC For 8-hours		TWA		STEL		TWA		CEIL(C)	
ppm	mg/m ³	ppm	mg/m ³	ppm	mg/m ³	ppm	mg/m ³	ppm	mg/m ³	ppm	mg/m ³
20	29	50	72	10	14	15	21	N/A	N/A	C10	C15

ACC Acceptable Ceiling Concentration.

TLVs Threshold Limit Values.

RELs Recommended Exposure Limits.

TWA Eight-hour Time Weighted Average (refer to specific reference document for different methods of weighting used).

STEL Short Term Exposure Limit averaged over a period of 15 minutes.

N/A Not Applicable.

CEIL(C) NIOSH Ceiling Exposure Limit averaged over a period of 10 minutes.

⁽¹¹⁾Refer to 29 Code of Federal Regulations Part 1910.1000, Subpart Z, Table Z-2.

⁽¹²⁾Refer to *Threshold Limit Values and Biological Exposure Indices, 1993-94*.

⁽¹³⁾Refer to *NIOSH 77-158: Criteria for a Recommended Standard for Occupational Exposure to Hydrogen Sulfide*.

APPENDIX B—PHYSICAL PROPERTIES AND PHYSIOLOGICAL EFFECTS OF SULFUR DIOXIDE

B.1 Physical Data

Chemical Name: Sulfur Dioxide.

CAS Number: 7446-09-05.

Synonyms: Sulfurous anhydride, sulfurous oxide.

Chemical Family: Inorganic.

Chemical Formula: SO₂.

Normal Physical State: Colorless gas appreciably heavier than air. Vapor density (specific gravity) at 32°F (0°C) and 1 atmosphere = 2.26.

Boiling Point: 14°F (-10.0°C).

Flammable Limits: Non-flammable (produced from burning hydrogen sulfide).

Solubility: Readily soluble in water and oil; solubility decreases as the fluid temperature increases.

Odor and Warning Properties: Sulfur dioxide has a pungent odor associated with burning sulfur. It produces a suffocating effect and produces sulfurous acid on membranes of the nose and throat.

B.2 Exposure Limits

The Occupational Safety and Health Administration (OSHA) has established a permissible exposure limit (PEL) of 5 ppm as an 8-hour TWA for sulfur dioxide (refer to 29 *Code of Federal Regulations* Part 1910.1000, Subpart Z, Table Z-1. The American Conference of Governmental Industrial Hygienists (ACGIH) recommends 2 ppm as an eight-hour TWA Threshold Limit Value (TLV)⁽¹⁴⁾ and 5 ppm as a STEL averaged over 15 minutes for sulfur dioxide.⁽¹⁴⁾ Refer to Table B-2 for additional information on exposure values. CHECK WITH THE EMPLOYER CONCERNING EXPOSURE LIMITS FOR PARTICULAR CIRCUMSTANCES.

B.3 Physiological Effects

B.3.1 ACUTE TOXICITY

INHALATION AT CERTAIN CONCENTRATIONS CAN LEAD TO INJURY OR DEATH (refer to Table B-1). Exposure to concentrations below 20 ppm can cause eye irritation, throat irritation, respiratory tract irritation, chest constriction, and some nausea. Exposure to concentrations above 20 ppm can result in marked coughing, sneezing, eye irritation, and chest constriction. Exposure to 50 ppm causes irritation to the nose and throat, running nose, coughing, reflex broncho-constriction with possible increase in bronchial mucous secretion, and increased pulmonary resistance to air

⁽¹⁴⁾"TLV" is a trademarked term of the American Conference of Governmental Industrial Hygienists (ACGIH). Refer to *Threshold Limit Values and Biological Exposure Indices* and companion documents available from ACGIH, 1330 Kemper Meadow Drive, Cincinnati, OH 45240 (check latest edition).

flow (breathing congestion) occurs promptly. This atmosphere (50 ppm or more) will not be tolerated by most persons for more than 15 minutes. Some reported acute reactions of exposure to high concentrations include, but are not limited to, inflammation of the eyes, nausea, vomiting, abdominal pain, and sore throat. These symptoms are sometimes followed by bronchitis, pneumonia, and /or complaints of weakness for a period of weeks.

B.3.2 CHRONIC TOXICITY

It has been reported that prolonged exposures to sulfur dioxide may lead to increased risk of chronic nasopharyngitis, alteration in sense of smell and taste, shortness of breath on exertion, and a higher frequency of respiratory tract infections compared to unexposed persons. It has also been postulated that sulfur dioxide in the work environment "possibly enhances" the suspected carcinogenic (cancer) effect of arsenic or other cancer agents⁽¹⁵⁾. No definite evidence is available regarding co-carcinogenesis or promotion of cancer by sulfur dioxide exposure. A few persons apparently have or develop a hypersusceptibility to sulfur dioxide. Decrements in pulmonary function tests have been noted after both acute and chronic exposures.

B.3.3 EXPOSURE RISKS

It is not yet clear what concentrations of low level exposure or lengths of exposure increase the risks, nor by how much the risks are increased. Sulfur dioxide exposures should be minimized. Smoking by persons exposed to sulfur dioxide should be strongly discouraged.

Note: Any pre-existing chronic respiratory impairment must be considered in regard to job placement since these conditions can be aggravated by exposure to sulfur dioxide.

B.4 Respiratory Protection

The National Institute for Occupational Safety and Health (NIOSH) has examined the criteria for respirator tests and sources of respirator leakage and recommends that positive pressure, either supplied-air or self-contained personal breathing apparatus, as appropriate, with a full face piece be worn by anyone exposed to atmosphere containing sulfur dioxide concentrations above OSHA's permissible exposure limit (PEL) (refer to 29 *Code of Federal Regulations* Part 1910.1000, Subpart Z, Table Z-1). Refer to Par. 6.4 for proper breathing equipment recommendations for oil and gas producing and gas processing operations involving sulfur dioxide.

⁽¹⁵⁾*Criteria for a Recommended Standard for Occupational Exposure to Sulfur Dioxide*, NIOSH, 1974, P. 26. Refer also to the 1977 edition.

Table B-1—Sulfur Dioxide

Concentration in Air				Typical Characteristics Regarding Hydrogen Sulfide Exposure ⁽¹⁷⁾
Percent by Volume	Parts Per Million By Volume	Grains Per 100 Std. Cubic Feet	Milligrams Per Cubic Meter ⁽¹⁶⁾	
0.0001	1	0.12	2.71	Pungent odor, may cause respiratory changes.
0.0002	2	0.24	5.42	ACGIH TLV [®] ⁽¹⁸⁾ , and NIOSH REL.
0.0005	5	0.59	13.50	Burning eyes, breathing irritation, and minor throat irritation. Note: OSHA PEL (refer to 29 CFR 1910.1000, Table Z-1; ACGIH and NIOSH STEL as averaged over 15 minutes.
0.0012	12	1.42	32.49	Throat-irritating cough, constriction in chest, watering eyes, and nausea.
0.010	100	12.0	271.00	Concentration considered immediately dangerous to life or health (IDLH). ⁽¹⁹⁾ Refer to <i>DHHS No. 85-114, NIOSH Pocket Guide to Chemical Hazards.</i> ⁽²⁰⁾
0.015	150	17.76	406.35	Extreme irritation. Can be tolerated for only a few minutes.
0.05	500	59.2	1354.50	Causes a sense of suffocation, even with the first breath. Rescue promptly and apply artificial ventilation and/or cardiopulmonary resuscitation (CPR) techniques.
0.10	1000	118.4	2708.99	Death may result unless rescued promptly. Artificial ventilation and/or cardiopulmonary resuscitation (CPR) techniques should be immediately applied.

Note: Data in Table B-1 are approximate values for guidance. There are published data that show slightly different values.

⁽¹⁶⁾Based on 1% sulfur dioxide = 1184 gr/100 SCF @ 14.696 psia and 59°F (101.315 kPa and 15°C).

⁽¹⁷⁾Sulfur dioxide has physiological effects on humans. These effects vary from person to person. FOR ADDITIONAL INFORMATION, CONSULT WITH THE EMPLOYER AND RESEARCH THE MATERIAL SAFETY DATA SHEETS (MSDS).

⁽¹⁸⁾TLV is a trademarked term of American Conference of Governmental Industrial Hygienists (ACGIH). Refer to *Threshold Limit Values and Biological Indices* and companion documents available from ACGIH, 1330

Kemper Meadow Drive, Cincinnati, Ohio 45240.

⁽¹⁹⁾IDLH means an atmospheric concentration of any toxic, corrosive, or asphyxiant substance that poses an immediate threat to life or would cause irreversible or delayed adverse health effects or would interfere with an individual's ability to escape from a dangerous atmosphere (refer to 29 Code of Federal Regulations Part 1910.120). NIOSH considers 100 ppm or more to be the IDLH concentration for sulfur dioxide (refer to *NIOSH Pocket Guide to Chemical Hazards*).

⁽²⁰⁾Available from Superintendent of Documents, U. S. Government Printing Office, Washington, D. C. 20402.

Table B-2—Summary of Occupational Exposure Values for Sulfur Dioxide

OSHA PELs ⁽²¹⁾				ACGIH TLVs ⁽²²⁾				NIOSH RELs ⁽²³⁾			
TWA		STEL		TWA		STEL		TWA		STEL	
ppm	mg/m ³	ppm	ppm	ppm	mg/m ³	ppm	mg/m ³	ppm	mg/m ³	ppm	mg/m ³
5	14	N/A	N/A	2	5	5	13	2	5	5	13

PELs Permissible Exposure Limits.

TLVs Threshold Limit Values.

RELs Recommended Exposure Limits.

TWA Eight-hour Time Weighted Average (refer to specific reference document for different methods of weighting used).

STEL Short Term Exposure Limit averaged over a period of 15 minutes.

N/A Not Applicable.

⁽²¹⁾Refer to 29 Code of Federal Regulations Part 1910.1000, Subpart Z, Table Z-1.

⁽²²⁾Refer to *Threshold Limit Values and Biological Exposure Indices, 1993-94* (check latest edition).

⁽²³⁾Refer to *NIOSH 77-158: Criteria for a Recommended Standard for Occupational Exposure to Sulfur Dioxide*.

APPENDIX C—A SCREENING APPROACH TO DISPERSION OF HYDROGEN SULFIDE

Note: The exposure radii shown in Figures C-1 through C-4 represent estimates developed by API's Air Modeling Task Force (AQ7) using simple screening models and modeling techniques. These models should be reasonably accurate for low velocity releases of neutrally-buoyant mixtures of hydrogen sulfide and carrier gas. Figures C-1 through C-4 are useful as a conservative screening tool for high velocity releases and for light hydrogen sulfide carrier gas mixtures. Figures C-1 through C-4 are not recommended for low velocity releases of heavier-than-air hydrogen sulfide/carrier gas mixtures or of potential aerosol-generating mixtures, since these illustrations sometimes will underpredict exposure radii for these mixtures. Site specific conditions should be assessed to determine the need for additional, more rigorous modeling techniques. Users should evaluate their operations and select proper modeling applications for their specific emergency planning purposes.

C.1 Introduction

The material presented in Appendix C is generic in nature and is intended for emergency response planning purposes to arrive at conservative hydrogen sulfide dispersion estimates. Figures C-1 through C-4 present the screening-level, model-predicted radius of exposure (ROE) for atmospheric concentrations of hydrogen sulfide at 10, 30, 100, 300, and 500 ppm for both continuous and puff (instantaneous) releases of pure hydrogen sulfide. The ROE represents the distance from the emission source to the concentration of interest measured along the plume's centerline at ground level. Equations were developed for predicting the ROE as a function of the quantity/rate of hydrogen sulfide released for each of the hydrogen sulfide concentrations modeled and the type of release (continuous and puff). The equations and corresponding coefficients are presented in Par. C.8 and Table C-1. Meteorological conditions typical of worst-case daytime and nighttime conditions were modeled.

Various regulations dealing with hydrogen sulfide operations prescribe a method(s) or technique(s) for ROE predictions. Such methods must be taken into account because specific compliance actions may require use of a method(s) specified by the regulation, unless use of other methods are allowed.

C.2 Methodology

The ROEs shown in Figures C-1, C-2, C-3, and C-4 were predicted using standard EPA-approved modeling procedures based on Gaussian dispersion theory. The ROEs shown in Figures C-1 and C-2 were predicted by modeling a continuous, steady-state point source release of 100 percent hydrogen sulfide. The ROEs shown in Figures C-3 and C-4 were predicted by modeling an instantaneous hydrogen sulfide release. Both hydrogen sulfide release types were modeled as releases of a neutrally-buoyant material under steady-state meteorological conditions. An effective plume height (release height plus plume rise) of 10 feet was used in all the modeling work. It was assumed that the predicted ROEs do not vary significantly with effective plume height in the range of 0-50 feet.

Table C-1—Linear Regression Coefficients for Mathematical Predictions of ROE as a Function of Downwind Hydrogen Sulfide Concentration and Release Quantity/Rate

Time*	Type of Release	Concentration, ppm	Coefficients	
			A	B
Day	Continuous	10	0.61	0.84
Day	Continuous	30	0.62	0.59
Day	Continuous	100	0.58	0.45
Day	Continuous	300	0.64	-0.08
Day	Continuous	500	0.64	-0.23
Night	Continuous	10	0.68	1.22
Night	Continuous	30	0.67	1.02
Night	Continuous	100	0.66	0.69
Night	Continuous	300	0.65	0.46
Night	Continuous	500	0.64	0.32
Day	Puff	10	0.39	2.23
Day	Puff	30	0.39	2.10
Day	Puff	100	0.39	1.91
Day	Puff	300	0.39	1.70
Day	Puff	500	0.40	1.61
Night	Puff	10	0.39	2.77
Night	Puff	30	0.39	2.60
Night	Puff	100	0.40	2.40
Night	Puff	300	0.40	2.20
Night	Puff	500	0.41	2.09

*Day Meteorological Conditions: Stability Class PG D (Neutral)—5 mph Wind Speed.

*Night Meteorological Conditions: Stability Class PG F (Stable)—2.2 mph Wind Speed.

For the purposes of dispersion modeling, the amount of turbulence in the ambient air is categorized into defined increments or stability classes. The most widely used categories are the Pasquill-Gifford (PG) Stability Classes A, B, C, D, E, and F (Pasquill, F., *Atmospheric Diffusion*, Second Edition, John Wiley & Sons, New York, New York, 1974). PG Stability Class A denotes the most unstable (most turbulent) air conditions and PG Stability Class F denotes the most stable (least turbulent) air conditions. PG Stability Class D denotes neutral atmospheric conditions where the ambient temperature gradient is essentially the same as the adiabatic lapse rate. Under neutral conditions, rising or sinking air parcels cool or heat at the same rate as the ambient air, resulting in no enhancement or suppression of vertical air motion.

Standard Pasquill-Gifford (PG) dispersion coefficients for flat, open grassland were used in the continuous hydrogen sulfide release model. The Slade (refer to *NTIS-TID 24190: Slade, D. H., Meteorology and Atomic Energy*, 1968) dispersion coefficients for flat, open grassland were used in the puff (instantaneous) release model. When modeling instantaneous hydrogen sulfide releases it was assumed that the downwind (x) and the crosswind (y) dispersion coefficients




Figure C-1—Radius of Hydrogen Sulfide Exposure
 Continuous Daytime Hydrogen Sulfide Releases [PG D (Neutral)—5 MPH Wind Speed]




Figure C-2—Radius of Hydrogen Sulfide Exposure
 Continuous Nighttime Hydrogen Sulfide Releases [PG F (Stable)—2.2 MPH Wind Speed]




Figure C-3—Radius of Hydrogen Sulfide Exposure
 Instantaneous Daytime Hydrogen Sulfide Releases [Slade A (Slightly Unstable)—5 MPH Wind Speed]




Figure C-4—Radius of Hydrogen Sulfide Exposure
 Instantaneous Nighttime Hydrogen Sulfide Releases [Slade B (Neutral)—2.2 MPH Wind Speed]

were equivalent. This assumption results in conservative (worst case) estimates of the ROEs. The following meteorological conditions were assumed to be representative of worst case daytime and nighttime conditions. For continuous daytime releases a neutral Stability Class (PG D) and 5 miles per hour wind speed were chosen. For continuous nighttime releases, a stable Stability Class (PG F) and a 2.2 miles per hour wind speed were chosen. For instantaneous (puff) daytime releases, a slightly unstable Stability Class (Slade A) and a 5 miles per hour wind speed were chosen. For instantaneous nighttime releases, a neutral-to-stable Stability Class (Slade B) and a 2.2 miles per hour wind speed were chosen.

The ROEs for continuous hydrogen sulfide releases at 30, 100, 300, and 500 ppm are valid for averaging times of 10 minutes to 1 hour. The ROEs shown for 10 ppm (continuous hydrogen sulfide release) are based on an 8-hour average concentration, since 10 ppm represents the 8-hour time weighted average (TWA) for hydrogen sulfide. To obtain the 8-hour/10 ppm average concentration a factor of 0.7 was used to convert the 1-hour concentrations (refer to EPA-450/4-88-009: *A Workbook of Screening Techniques for Assessing Impacts of Toxic Air Pollutants*). The ROEs for the puff (instantaneous) hydrogen sulfide releases at 30, 100, 300, and 500 ppm are valid for averaging times of 1 to 10 minutes. EPA's 0.7 conversion factor was used to obtain the 10 minute/10 ppm time averaged concentrations from instantaneous peak concentrations predicted by the model. For continuous releases, the EPA considers 10-minute and 1-hour averaging times to be equivalent. The modeling reported herein assumed that an instantaneous release would be of a very short duration (10 to 15 minutes maximum).

Brief descriptions of the models used to predict the ROEs for both continuous and puff (instantaneous) hydrogen sulfide releases are presented in Par. C.13.

C.3 Results

ROEs for atmospheric plume-centerline, ground-level concentrations of hydrogen sulfide resulting from instantaneous and continuous hydrogen sulfide releases were predicted and are presented in Figures C-1 through C-4. Figures C-1 and C-2 present the predicted ROEs for continuous hydrogen sulfide releases during worst case daytime and nighttime meteorological conditions, respectively. Figures C-3 and C-4 present the predicted ROEs for instantaneous hydrogen sulfide releases during worst case daytime and nighttime meteorological conditions, respectively. The ROEs for concentrations of 10, 30, 100, 300 and 500 ppm were modeled for both release types. The 10 ppm concentration ROEs represent an 8-hour averaging time for the continuous hydrogen sulfide release and a 10-minute averaging time for the instantaneous release. The 30, 100, 300, and 500 ppm concentration ROEs represent a 10-minute averaging time for the continuous hydrogen sulfide release and a 1-minute averaging

time for the instantaneous release. A hydrogen sulfide release rate range of 10 to 10,000 lb/hr (111.8 to 111,765 SCFH) was modeled for the continuous type release. For the puff (instantaneous) type hydrogen sulfide release, a release quantity range of 0.1 to 1000 lbs (1.1 to 11,177 SCF) was modeled. If the hydrogen sulfide release is based on pounds, standard cubic feet (SCF) can be obtained by multiplying pounds by a factor of 11.2.

Note: The ROEs presented in Figures C-1 through C-4 are plotted against the amount of hydrogen sulfide released. For the release of a multi-component gas stream, the actual amount of hydrogen sulfide released should be used to determine the ROE.

Equation coefficients based on linear regression for predicting the ROE as a function of the release type (continuous/puff) and quantity/rate of hydrogen sulfide released for both daytime and nighttime meteorological conditions are presented in Table C-1. The equation is given in Par. C.8. The coefficients are applicable only over the ranges presented in Figures C-1 through C-4, and extrapolation could result in overly conservative estimates of the ROEs. Any release lasting significantly longer than 15 minutes should be interpreted as a continuous release. The modeling work presented in Appendix C assumes steady-state meteorological conditions. ROEs predicted for a long averaging time (8-hour) and long downwind distances are conservative because it is unlikely that the same meteorological conditions will persist during that time period.

C.4 Additional Considerations

The modeling work presented in Appendix C assumes a neutrally-buoyant, gaseous hydrogen sulfide release in flat, rural terrain under steady-state meteorological conditions. Also, the ROEs shown in Figures C-1 through C-4 are for a generic class of hydrogen sulfide releases covering a wide range of site and release conditions. Actual ROEs will be dependent on the specifics of the type of release, release conditions, and release site. For instance, the ROEs for a release in a more urban setting where structures, buildings, etc. are present will be reduced significantly due to structure-induced turbulence. Some other conditions that could significantly affect the actual ROE include: a liquid/aerosol release, dense cloud behavior, a buoyant cloud (plume liftoff), a jet release, time-dependent release (well blowout, pipeline ruptures, etc.), and complex terrain. If any of these phenomena are present, then more rigorous modeling may be necessary.

The ROE curves of Figures C-1 through C-4 should not be used when the mixture of hydrogen sulfide and carrier gas being dispersed is significantly heavier than air and the mixture is released at a low velocity. If the hydrogen sulfide/carrier gas mixture specific gravity exceeds approximately 1.2, Figures C-1 through C-4 may not give conservative ROEs for all release rates and meteorological conditions. Hydrogen sulfide, as encountered in the petroleum industry, is usually

a minor constituent of a carrier gas, such as natural gas or carbon dioxide. Carbon dioxide has a specific gravity of 1.52. Dispersion predictions for hydrogen sulfide/carbon dioxide mixtures, using a dense gas model sometimes underpredict hydrogen sulfide ROEs for low velocity gas releases. Low velocity gas releases would include those with initial velocities less than 200 feet/second and releases greater than 200 feet/second involve impact of the gas jet from the leak with a nearby surface, thereby breaking the jet's momentum. Likewise, Figures C-1 through C-4 should not be used with any hydrogen sulfide/carrier gas release that potentially could form an aerosol.

Figures C-1 through C-4 can also substantially overpredict ROEs. In the case of hydrogen sulfide/carrier gas mixtures significantly lighter than air (i.e., specific gravity less than 0.8) released at low velocity, use of these illustrations may overpredict ROEs by a factor of 2 to 3. Use of these illustrations can result in overestimation of ROEs for high velocity hydrogen sulfide/carrier gas releases (i.e., gas release velocities greater than 200 feet/second) regardless of the orientation of the release. However, this overprediction is particularly significant in the case of vertical, high-velocity releases. In such situations, the overprediction can be two orders of magnitude. The user should consult more rigorous atmospheric dispersion models.

When calculating the ROE for dilute concentrations of hazardous gases, a significant overestimation can result. For example, it would not be practical to expect higher downwind atmospheric concentrations than are present in the released gas stream. The user should consult more rigorous atmospheric dispersion models.

In summary, the composition of the hydrogen sulfide/carrier gas and the velocity and orientation of the release are critical variables, dramatically affecting predicted hydrogen sulfide ROEs. Also, other variables, such as released gas temperature and flashing or aerosol formation involving liquid containing dissolved hydrogen sulfide, can have significant impacts on ROE predictions. Accurate atmospheric dispersion techniques are, of necessity, complex. Under some circumstances, such as those mentioned above, more rigorous modeling may be required.

References and models are available to address special release scenarios. A partial list of models that may be used in such cases is shown in Pars. C.5 and C.6. API does not endorse any one particular model. Further guidance on appropriate model selection and application can be obtained from the model developers as well as other individuals experienced in this field. A specific reference to address well blowout and pipeline ruptures is "*Release and Dispersion of Gas from Pipe Line Ruptures*," Wilson, D. J., Department of Mechanical Engineering, University of Alberta, Edmonton, Canada.

In the event that hydrogen sulfide release quantities calculated by the user are below the ranges shown in Figures C-1

through C-4, extensions of the ROE curves are allowed to a minimum ROE of 50 feet. In some cases, ROEs of less than 50 feet may be inferred from extrapolation of the curves. Figures C-1 through C-4 were developed using an assumed release height plus plume rise of 10 feet. Actual release heights of other than 10 feet will result in different ROEs.

C.5 Proprietary Dispersion Models

Note: Users should carefully evaluate applicability of these models to prevailing conditions.

A list of some proprietary models that can be used to address special site-specific scenarios follows:

CHARM—(Radian Corporation): CHARM is a Gaussian puff model for continuous and instantaneous releases of gases or liquids. The model is configured to handle chemicals that are buoyant, neutrally buoyant, and heavier than air. Heavy gas dispersion is estimated using the Eidsvik model. Source components in the model include a modified version of Shell Oil Company's SPILLS Model. (Radian Corp., 850 MOPAC Blvd., Austin, TX 78759.)

FOCUS—(Quest Consultants, Inc.): FOCUS is a modeling package that includes both emission rate models (two-phase discharges, pool evaporation, jet vapor releases, etc.) and dispersion models for both neutrally-buoyant and dense-gas plumes. The models can be run separately or in a linked mode. (Quest Consultants, Inc., 908 26th Avenue, NW, Suite 103, Norman, OK 73069-6216.)

TRACE—(Dupont): TRACE uses a multiple Lagrangian Wall dispersion model to handle both puff and continuous releases. Wind channeling can be incorporated. Liquid evaporation and buoyancy effects are considered also. (E. I. Dupont de Nemours & Company, 5700 Corea Avenue, Westlake Village, CA 91362.)

WHAZAN—(Technica International): WHAZAN is a package of dispersion models for both neutrally-buoyant and dense-gas plumes. Submodels are included to handle two-phase discharges, evaporation, and vapor dispersion as a free jet. The model can be run both individually and in a linked mode. (Technica International Associates, Inc., Box 187, Woodstock, GA 30128-4420.)

C.6 Publicly-available Models

Note: Users should carefully evaluate applicability of these models to prevailing conditions.

A list of some publicly-available models that can be used to address special site-specific scenarios follows:

DEGADIS—(U. S. Coast Guard): DEGADIS, the Dense Gas Dispersion Model, is designed to simulate dispersion of heavier-than-air gas releases. It can handle both evaporative emissions from liquid spills and jet emissions. It is basically steady-state but simulates transient conditions by a series of steady-state calculations. Vapor generation rate, spill area, and meteorological parameters are important inputs to the

model. Information available through National Technical Information Service (NTIS), U. S. Department of Commerce, Springfield, VA 22161.

HEGADAS—(Shell Research B.V.): HEGADAS is a dispersion model for neutrally-buoyant and dense gases. The basic model components are solutions to the advection/diffusion equations and are in the standard form of Gaussian dispersion models. The model can handle a wide variety of source types, including transient horizontal jets. Information available through National Technical Information Service, U. S. Department of Commerce, Springfield, VA 22161.

SLAB—(Lawrence Livermore National Laboratory): SLAB is designed for application to dense gases that are emitted from liquid spills. The model considers the concentration integrated over a cross-section perpendicular to the plume centerline. The downwind variation of the integrated concentration is calculated. The size and emission rate of the liquid spill are required inputs to the model. Information available through Lawrence Livermore National Laboratory, Box 808, Livermore, CA 94550, or contact American Petroleum Institute, Health & Environmental Sciences Department, 1220 L Street, NW, Washington, D.C. 20005.

C.7 Sample Calculations for Figures C-1 through C-4

The following calculations may be used to estimate volume and mass of hydrogen sulfide when total gas volume and its hydrogen sulfide content are known:

Continuous Release.

Assume: Release of 5,000,000 SCFD of natural gas containing 8,000 ppm (by volume) of hydrogen sulfide.

Note: The user must know both the volume (or flow rate) of natural gas and its hydrogen sulfide concentration so that Figures C-1 through C-4 can be effectively used.

To determine standard cubic feet per hour (SCFH) of hydrogen sulfide released, the following calculations should be performed using appropriate values for the conditions being evaluated:

$$\frac{5,000,000 \text{ SCFD} \times 8,000 \text{ ppm H}_2\text{S}}{24,000,000} \\ = 1,667 \text{ SCFH of H}_2\text{S released.}$$

To determine the pounds of hydrogen sulfide released per hour, the following calculations should be performed using appropriate values for the conditions being evaluated:

$$\frac{5,000,000 \text{ SCFD} \times 8,000 \text{ ppm H}_2\text{S}}{267,605,634} \\ = 150 \text{ lb/hr of H}_2\text{S released.}$$

Instantaneous Release.

Assume: Release of 100,000 SCF of natural gas containing 8,000 ppm (by volume) of hydrogen sulfide. Also, assume this example is a daytime release, 5 miles per hour

wind speed (refer to Figure C-3).

To determine the volume (SCF) of hydrogen sulfide released, the following calculations should be performed using appropriate values for the conditions being evaluated:

$$\frac{100,000 \text{ SCF} \times 8,000 \text{ ppm H}_2\text{S}}{1,000,000} \\ = 800 \text{ SCF of H}_2\text{S released}$$

After applying the appropriate calculations and using known factors to arrive at either hydrogen sulfide release rate or quantity of hydrogen sulfide released, refer to the appropriate chart (Figs. C-1 through C-4) or the equation in Par. C.8 (example calculations in Pars. C.9 through C.12) for obtaining radius of exposure (ROE) information.

The following equation can be used to convert percent hydrogen sulfide to parts per million on a volume basis:

$$\text{Percent H}_2\text{S} \times 10,000 = \text{ppm H}_2\text{S}$$

C.8 Radius of Exposure (ROE) Calculation

Using the values of coefficients "A" and "B" in Table C-1, the radius of exposure (ROE) for various hydrogen sulfide release rates (H₂S) can be mathematically predicted using the following equation:

$$\text{ROE} = \text{Antilog} [A \times \log (\text{H}_2\text{S}) + B]$$

For a continuous release, enter the hydrogen sulfide release rate (H₂S) in standard cubic feet per hour (SCFH). For a puff (instantaneous) release, enter the quantity of hydrogen sulfide (H₂S) released in standard cubic feet (SCF).

C.9 Sample Calculation—Continuous Release (Daylight)

Determine the ROE_{100 ppm} for a continuous release of 100 percent hydrogen sulfide gas at a rate of 11,170 SCFH in daylight (PG D stability) conditions and 5 mph wind speed. Using Table C-1, the coefficients applicable to this scenario are: A = 0.58; B = 0.45. Using the equation in Par. C.8:

$$\text{ROE}_{100 \text{ ppm}} = \text{Antilog} [0.58 \times \log (11,170) + 0.45] = 628 \text{ feet.}$$

C.10 Sample Calculation—Continuous Release (Nighttime)

Determine the ROE_{100 ppm} for a continuous release of 100 percent hydrogen sulfide gas at a rate of 11,170 SCFH in nighttime (PG F stability) conditions and 2.2 mph wind speed. Using Table C-1, the coefficients applicable to this scenario are: A = 0.66; B = 0.69. Using the equation in Par. C.8:

$$\text{ROE}_{100 \text{ ppm}} = \text{Antilog} [0.66 \times \log (11,170) + 0.69] \\ = 2,300 \text{ feet}$$

C.11 Sample Calculation— Instantaneous Release (Daylight)

Determine the ROE_{100ppm} for an instantaneous release of 100 percent hydrogen sulfide gas of 1,117 SCF in daylight (Slade A stability) conditions and 5 mph wind speed. Using Table C-1, the coefficients applicable to this scenario are: $A = 0.39$; $B = 1.91$. Using the equation in Par. C.8:

$$ROE_{100ppm} = \text{Antilog} [0.39 \times \log (1,117) + 1.91] = 1,255 \text{ feet.}$$

C.12 Sample Calculation— Instantaneous Release (Nighttime)

Determine the ROE_{100ppm} for an instantaneous release of 100 percent hydrogen sulfide gas of 1,117 SCF in nighttime (Slade B stability) conditions and 2.2 mph wind speed. From Table C-1, the coefficients applicable to this scenario are: $A = 0.40$; $B = 2.40$. Using the equation in Par. C.8:

$$ROE_{100ppm} = \text{Antilog} [0.40 \times \log (1,117) + 2.40] = 4,161 \text{ feet.}$$

C.13 Descriptions of Gaussian and Puff Dispersion Models

C.13.1 INTRODUCTION

The emergency response Gaussian and Puff screening models are designed to predict the downwind dispersion (plume-centerline, ground-level concentration and maximum ground-level plume width as a function of downwind distance) of a neutrally-buoyant, steady-state point source gaseous release under steady-state meteorological conditions. Classical EPA-approved Gaussian dispersion theory is applied in the models. The programs are in BASIC and are designed for use on personal computers. The models are described below. The program listings and runs should use the IDLH, ERPG-2, and TLV and STEL levels as the concentrations of interest because they usually are the concentration values of concern. Both models can be run for other concentrations by substituting the values of interest in place of the

values for IDLH, ERPG-2, and TLV and STEL in the computer programs. Copies of the example program listings and computer runs are available on request from American Petroleum Institute, Exploration & Production Department, 700 North Pearl Street, Suite 1840, Dallas, Texas 75201-2845.

C.13.2 Gaussian Model

This model calculates the plume-centerline, ground-level concentration, and maximum ground-level plume width for a single, steady-state, continuous-point release at user-specified, steady-state meteorological conditions and downwind distances. The model uses standard Gaussian dispersion modeling with Pasquill-Gifford dispersion coefficients. The user inputs the release rate, effective release height (release height plus plume rise), nominal wind speed, incremental downwind distance for which calculations are to be made, type of material released, and the stability class. A total of eight compounds are currently accepted by this model. Additional compounds can be entered by replacing compounds presently in the model. The model uses a default D Stability Class; but, can be run with any of the standard six Pasquill-Gifford Stability Classes (A, B, C, D, E, or F—with A being the most unstable and F being the most stable).

C.13.3 Puff Model

This model calculates the plume-centerline, ground-level concentration, and maximum ground-level plume width for a single, instantaneous-point release at user-specified, steady-state meteorological conditions and downwind distances. The model uses standard Gaussian dispersion theory for an instantaneous (puff) release with Slade dispersion coefficients. User inputs to the model are the same as those used in the Gaussian model except that the total amount of material released is entered rather than the rate of release. Three values are accepted for the Stability Class (A, B, or C—with A being unstable, B being neutral, and C being stable).

APPENDIX D—DEFINITION OF A SOUR ENVIRONMENT (REPRINTED FROM NACE STANDARD MR0175-94: STANDARD MATERIAL REQUIREMENTS SULFIDE STRESS CRACKING RESISTANT METALLIC MATERIALS FOR OILFIELD EQUIPMENT⁽²⁴⁾)

D.1 Sour Environments

D.1.1 Sour Environments are defined as fluids containing water as a liquid and hydrogen sulfide exceeding the limits defined in Pars. D.1.1.1 and D.1.1.2; these environments may cause sulfide stress cracking (SSC) of susceptible materials.

CAUTION: It should be noted that highly susceptible materials may fail in less severe environments. The SSC phenomenon is affected by complex interactions of parameters including:

- a. chemical composition, strength, heat treatment, and microstructure of the material;
- b. hydrogen ion concentration (pH) of the environment;
- c. hydrogen sulfide concentration and total pressure;
- d. total tensile stress (applied plus residual);
- e. temperature; and
- f. time.

The user shall determine whether the environmental conditions fall within the scope of this standard. (*Editorial Comment:* The critical hydrogen sulfide levels in D.1.1.1 and D.1.1.2 and Figures D-1 and D-2 were developed from data derived from low alloy steel.)

D.1.1.1 Sour Gas

Materials shall be selected to be resistant to SSC or the environment should be controlled if the gas being handled is at a total pressure of 0.4 MPa (65 psia) or greater and if the partial pressure of hydrogen sulfide in the gas is greater than 0.0003 MPa (0.05 psia). Systems operating below 0.4 MPa (65 psia) total pressure or below 0.0003 MPa (0.05 psia) hydrogen sulfide partial pressure are outside the scope of this standard. Partial pressure is determined by multiplying the mole fraction ($\text{mol } \% \div 100$) of hydrogen sulfide in the gas by the total system pressure. Figure D-1 provides a convenient method for determining whether the partial pressure of

hydrogen sulfide in a sour environment exceeds 0.0003 MPa (0.05 psia). A few examples are provided:

- a. partial pressure of hydrogen sulfide in a system containing 0.01 mol % hydrogen sulfide (100 ppm or 6.7 grains per 100 standard cubic feet [SCF]) at a total pressure of 7 MPa (1,000 psia) exceeds 0.0003 MPa (0.05 psia) (Point A on Figure D-1).
- b. partial pressure of hydrogen sulfide in a system containing 0.005 mol % hydrogen sulfide (50 ppm or 3.3 grains per 100 SCF) at a total pressure of 1.4 MPa (200 psia) does not exceed 0.0003 MPa (0.05 psia) (Point B on Figure D-1).

D.1.1.2 Sour Oil and Multiphases

Sour crude oil systems that have operated satisfactorily using standard equipment are outside the scope of this standard when the fluids being handled are either crude oil, or two- or three-phase crude, water, and gas when:

- a. the maximum gas:oil ratio is 5000 SCF:bb1 (barrel of oil);
- b. the gas phase contains a maximum of 15% hydrogen sulfide;
- c. the partial pressure of hydrogen sulfide in the gas phases is a maximum of 0.07 MPa (10 psia);
- d. the surface operating pressure is a maximum of 1.8 MPa (265 psia) (see Figure D-2); and
- e. when pressure exceeds 1.8 MPa (265 psia), refer back to D.1.1.1.

The satisfactory service of the standard equipment in these low-pressure systems is believed to be a result of the inhibitive effect of the oil and the low stresses encountered under the low-pressure conditions.

⁽²⁴⁾©Copyright 1994, by NACE International, P.O. Box 218340, Houston, Texas 77218-8340. All rights reserved by NACE; reprinted by permission. NACE Standard MR0175 is revised annually. Users are cautioned to obtain the latest edition; information in an outdated version of the standard may not be accurate.





Figure D1*—Sour Gas Systems (Refer to Par. D.1.1.1)



Metric Conversion Factor: 1 MPa = 145.089 psia

Figure D2*—Sour Multiphase Systems (Refer to Par. D.1.1.2)

*© Copyright 1994 by NACE International. All rights reserved by NACE; reprinted by permission. NACE Standard MR0175 is revised annually. Users are cautioned to obtain the latest edition; information in an outdated version of the standard may not be accurate.



Effective January 1, 2007.

API Members receive a 30% discount where applicable.

The member discount does not apply to purchases made for the purpose of resale or for incorporation into commercial products, training courses, workshops, or other commercial enterprises.

2007 Publications Order Form

Available through IHS:

Phone Orders: 1-800-854-7179 (Toll-free in the U.S. and Canada)
303-397-7956 (Local and International)

Fax Orders: 303-397-2740

Online Orders: global.ihs.com

Date: _____

API Member (Check if Yes)

Invoice To Check here if same as "Ship To")

Ship To (UPS will not deliver to a P.O. Box)

Name: _____

Name: _____

Title: _____

Title: _____

Company: _____

Company: _____

Department: _____

Department: _____

Address: _____

Address: _____

City: _____ State/Province: _____

City: _____ State/Province: _____

Zip/Postal Code: _____ Country: _____

Zip/Postal Code: _____ Country: _____

Telephone: _____

Telephone: _____

Fax: _____

Fax: _____

E-Mail: _____

E-Mail: _____

Quantity	Product Number	Title	SO★	Unit Price	Total

Payment Enclosed P.O. No. (Enclose Copy) _____

Charge My IHS Account No. _____

VISA MasterCard American Express Diners Club Discover

Credit Card No.: _____

Print Name (As It Appears on Card): _____

Expiration Date: _____

Signature: _____

Subtotal
Applicable Sales Tax (see below)
Rush Shipping Fee (see below)
Shipping and Handling (see below)
Total (in U.S. Dollars)

★ To be placed on Standing Order for future editions of this publication, place a check mark in the SO column and sign here:

Pricing and availability subject to change without notice.

Mail Orders - Payment by check or money order in U.S. dollars is required except for established accounts. State and local taxes, \$10 processing fee, and 5% shipping must be added. Send mail orders to: **API Publications, IHS, 15 Inverness Way East, c/o Retail Sales, Englewood, CO 80112-5776, USA.**

Purchase Orders - Purchase orders are accepted from established accounts. Invoice will include actual freight cost, a \$10 processing fee, plus state and local taxes.

Telephone Orders - If ordering by telephone, a \$10 processing fee and actual freight costs will be added to the order.

Sales Tax - All U.S. purchases must include applicable state and local sales tax. Customers claiming tax-exempt status must provide IHS with a copy of their exemption certificate.

Shipping (U.S. Orders) - Orders shipped within the U.S. are sent via traceable means. Most orders are shipped the same day. Subscription updates are sent by First-Class Mail. Other options, including next-day service, air service, and fax transmission are available at additional cost. Call 1-800-854-7179 for more information.

Shipping (International Orders) - Standard international shipping is by air express courier service. Subscription updates are sent by World Mail. Normal delivery is 3-4 days from shipping date.

Rush Shipping Fee - Next Day Delivery orders charge is \$20 in addition to the carrier charges. Next Day Delivery orders must be placed by 2:00 p.m. MST to ensure overnight delivery.

Returns - All returns must be pre-approved by calling the IHS Customer Service Department at 1-800-624-3974 for information and assistance. There may be a 15% restocking fee. Special order items, electronic documents, and age-dated materials are non-returnable.



2007 Publications Order Form

Effective January 1, 2007.

API Members receive a 30% discount where applicable.

The member discount does not apply to purchases made for the purpose of resale or for incorporation into commercial products, training courses, workshops, or other commercial enterprises.

Available through IHS:

Phone Orders: 1-800-854-7179 (Toll-free in the U.S. and Canada)
303-397-7956 (Local and International)

Fax Orders: 303-397-2740

Online Orders: www.global.ihs.com

★ To be placed on Standing Order for future editions of this publication, place a check mark in the SO column and sign where indicated on the other side of this form. Pricing and availability subject to change without notice.

Quantity	Product Number	Title	SO★	Unit Price	Total
Subtotal (Transfer to other side of Order Form)					

ADDITIONAL COPIES AVAILABLE FROM
PUBLICATIONS AND DISTRIBUTION
(202) 682-8375

American Petroleum Institute
1220 L Street, Northwest
Washington, D.C. 20005



Order No. 811-55002