# **Specification for Fire Test for Check** Valves

API SPECIFICATION 6FD FIRST EDITION, FEBRUARY 1995

**REAFFIRMED, OCTOBER 2013** 



Licensee=University of Alberta/5966844001, User=sharabiani, shahramfs Not for Resale, 04/27/2014 20:38:59 MDT

# **Specification for Fire Test for Check** Valves

**Upstream Segment** 

API SPECIFICATION 6FD FIRST EDITION, FEBRUARY 1995

**REAFFIRMED, OCTOBER 2013** 



#### SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication date as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Authoring Department [telephone (214) 953-1101]. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API *standard*. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the director of the Exploration and Production Department, American Petroleum Institute, 700 North Pearl, Suite 1840, Dallas, Texas 75201. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

#### Copyright © 1994 American Petroleum Institute

## CONTENTS

		Page
1	SCOPE	1
2	DESCRIPTION OF FIRE TEST	1
3	TEST PROCEDURE	1
4	PERFORMANCE REQUIREMENTS	6
	<ul> <li>4.1 Through Leakage—During Burn Period (High Test Pressure)</li> <li>4.2 External Leakage—During Burn and Cool-Down Period</li> </ul>	6
	(High Test Pressure, Valve in Closed Position)	6
	4.3 Through Leakage—After Cooldown (Low Test Pressure)	6
	4.4 External Leakage—After Cooldown (Low Test Pressure)	6
	4.6 External Leakage—Open Position (High Test Pressure)	6
	4.7 Tests Required	6
5	CERTIFICATION	7
6	SAFETY CONSIDERATIONS	7
7	EQUIPMENT MARKING	7
AP	PENDIX A—CONVERSIONS OF ENGLISH UNITS TO SI METRIC UNITS	9
Fig	ures	
	1-Location of Thermocouples and Calorimeters	
	Smaller Flanged Check Valves	1
	2—Location of Thermocouples and Calorimeters—	~
	Larger Flanged Check Valves	2
•	Smaller Wafer Type Check Valves	2
4	4—I ocation of Thermocounles and Calorimeters—	2
	Larger Wafer Type Check Valves	3
	5—Calorimeter Cube Design	4
(	6-Schematic of Suggested Systems for Fire Test for Check Valves	5
Tab	bles	
	1—Test Pressure During Fire Test	4
	2-Qualification of Other Size Valves	7
1	3-Qualification of Other Pressure Rating Valves	8

#### FOREWORD

This Specification is under the jurisdiction of the API Committee on Standardization of Valves and Wellhead Equipment. This edition of Spec 6FD is the first edition and was approved by letter ballot in September 1994.

Other standards under the jurisdiction of this committee include:

API

Spec OA Specification for wenneau and Christinas free Equipment	Spec 6A	Specification f	or Wellhead a	nd Christmas	Tree Equipmen
-----------------------------------------------------------------	---------	-----------------	---------------	--------------	---------------

Spec 6D Specification for Pipeline Valves (Gate, Plug, Ball, and Check Valves).

Spec 6FB Specification for Fire Test for End Connections

Spec 6FC Specification for Fire Test for Valves with Automatic Backseats.

- Bul 6AF Bulletin on Capabilities of API Flanges Under Combinations of Load.
- Bul 6AF1 Bulletin on Temperature Derating of API Flanges Under Combination of Loading.
  - Bul 6F1 Performance of API and ANSI End Connections in a Fire Test According to API Spec 6FA.
  - Bul 6F2 Fire Resistance Improvements for API Flanges.

This specification shall become effective on the date printed on the cover but may be used voluntarily from the date of distribution.

#### IMPORTANT INFORMATION CONCERNING USE OF ASBESTOS OR ALTERNATIVE MATERIALS

Asbestos is specified or referenced for certain components of the equipment described in some API standards. It has been of great usefulness in minimizing fire hazards associated with petroleum processing. It has also been a universal sealing material, compatible with most petroleum fluid services.

Certain serious adverse health effects are associated with asbestos, among them the serious and often fatal diseases of lung cancer, asbestosis, and mesothelioma (a cancer of the chest and abdominal linings). The degree of exposure to asbestos varies with the product and the work practices involved.

Consult the most recent edition of the U.S. Department of Labor, Occupational Safety and Health Administration (OSHA) Health Standard for Asbestos, 29 Code of Federal Regulations Section 1910:1001; the U.S. Environmental Protection Agency's National Emission Standard for Hazardous Air Pollutants concerning Asbestos, 40, Code of Federal Regulations Section 61.140 through 61.156; and the U.S. Environmental Protection Agency (EPA) labeling requirements and phased banning of asbestos products, published at 54 Federal Register 29460-29513 (July 12, 1989) 40CFR763.160-179.

There are currently in use and under development a number of substitute materials to replace asbestos in certain applications. Manufacturers and users are encouraged to develop and use effective substitute materials which can meet the specifications for, and operating requirements of, the equipment to which they would apply.

Safety and health information with respect to particular products or materials can be obtained from the employer, the manufacturer or supplier of that product or material, or the material safety data sheet.

### Specification for Fire Test for Check Valves

#### 1 Scope

It is the purpose of this document to establish the requirements for testing and evaluating the pressure containing performance of API Spec 6A and 6D check valves when exposed to fire. The performance requirements of this document are intended to establish standard limits of acceptability regardless of size or pressure rating.

This document establishes acceptable levels of leakage through the test valve and also external leakage after exposure to a fire for a 30-minute time period.

The burn period has been established on the basis that it represents the maximum time required to extinguish most fires. Fires of greater duration are considered to be of a major magnitude with consequences greater than those anticipated in this test.

#### 2 Description of Fire Test

**2.1** The valve shall be tested in its normal operating position, with water as the test medium, and pressurized from the normally downstream end.

**2.2** The valve will be enveloped in flame having a temperature of 1400-1800°F (761 to 980°C) average of two thermocouples located as shown in Figure 1 through 4. The test setup shall include  $1^{1}/2^{11}$  (38 mm) cube calorimeter blocks made of carbon steel with a thermocouple located in the cen-

ter of each block (Refer to Figure 5 for calorimeter block configuration). For API Spec 6A valves size  $7^{1/16}$ " and smaller and API Spec 6D valves size 6" and smaller, two blocks shall be located as shown in Figures 1 or 3. For larger size valves, three blocks shall be used, as shown in Figures 2 or 4. Piping upstream of the test valve larger than one inch (25 mm) nominal pipe size or one-half of valve nominal size (whichever is smaller) must be enveloped in flame for a distance of at least six inches (152 mm).

**2.3** The burn period shall be 30 minutes from ignition.

**2.4** The end connection piping-to-valve joint leakage (flanged, threaded, or welded) is not considered a part of this test and is not included in the allowable external leakage in Paragraphs 4.2, 4.4, and 4.6. For the test, it may be necessary to modify this joint to eliminate leakage.

#### 3 Test Procedure (Refer to Figure 6)

**3.1** Open valves (Items 15, 21, 22, 23, 24, and 25). Close valves (Items 16 and 17). Open valves (Items 5 and 6) to flood the system and purge the air.

**3.2** Close fill valve (Item 5) and valves (Items 15, 22, 23, 24, and 25). Open the downstream shutoff valve (Item 16) The piping system upstream of the test valve shall be



Figure 1—Location of Thermocouples and Calorimeters—Smaller Flanged Check Valves

API SPECIFICATION 6FD



Figure 2—Location of Thermocouples and Calorimeters—Larger Flanged Check Valves



Figure 3—Location of Thermocouples and Calorimeters—Smaller Wafer Type Check Valves

#### API SPEC\*6FD 95 🖿 0732290 0538645 14T 🖬

SPECIFICATION FOR FIRE TEST FOR CHECK VALVES



Figure 4—Location of Thermocouples and Calorimeters—Larger Wafer Type Check Valves

pletely water filled and the system downstream shall be drained.

**3.3** Pressurize the system to the appropriate high test pressure from Table 1. Maintain this pressure during the burn and cool-down period. Momentary pressure losses are permissible, provided their cumulative recovery time is less than two minutes. Record the reading on the calibrated sight gauge (Item 4). Empty the graduated downstream container (Item 19).

**3.4** Open fuel supply, establish a fire and monitor the flame temperature. The average of two thermocouples (Item 14) must reach  $1400^{\circ}$ F (761°C) within two minutes. Maintain the average temperature between  $1400^{-1}800^{\circ}$ F (761-980°C), with no reading less than  $1300^{\circ}$ F (704°C) for the remainder of the burn period.

**3.5** The average temperature of the calorimeters (Item 13) shall reach  $1200^{\circ}F(650^{\circ}C)$  within 15 minutes of fire ignition. For the remainder of the burn period the calorimeters shall maintain a minimum average temperature of  $1200^{\circ}F(650^{\circ}C)$  with no reading less than  $1050^{\circ}F(565^{\circ}C)$ .

Note: Impingement of water or steam from external leakage onto flame thermocouples or calorimeters can result in a substantial drop in the indicated temperature of the affected sensor(s), even if no actual drop in flame temperature has occurred. Such drops in indicated temperature(s) shall be noted in the test report. The test may continue with no downward adjustment of the burner controls and provided that at least one flame thermocouple and one calorimeter are functioning.

**3.6** Record instrument readings (Items 7, 13, and 14) at least every 30 seconds during the test period.

**3.7** At the end of the burn period (30 minutes from ignition), shutoff the fuel supply.

**3.8** Immediately determine and record the amount of water collected in the calibrated container (Item 19) to establish the total through valve seat leakage. Continue collecting water in the calibrated container for use in establishing the external leakage rate.

**3.9** Cool the valve (or allow to cool) to  $212^{\circ}$ F (100°C) or less. Cooling may, at the manufacturer's option, be natural or forced. Record the readings on the sight gauge (Item 4) and the calibrated container (Item 19).

4

**API SPECIFICATION 6FD** 

	Valve Rating			High Test Pressure			Low Test Pressure		
	Class	(PN*)		psi	(bar)	(MPa)	psi	(bar)	(MPa)
Spec 6D	150	(20)	_	210	(14,5)	(1,5)	29	(2,0)	(0,2)
Valves	300	(50)		540	(37,2)	(3,7)	50	(3,4)	(0,34)
	400	(64)	_	720	(49,6)	(5,0)	70	(4,8)	(0,48)
	600	(110)	_	1080	(74,5)	(7,5)	105	(7,2)	(0,72)
	900	(150)		1620	(111,7)	(11,2)	_		
	1500	(260)		2700	(186,2)	(18,6)	_	_	_
	2500	(420)		4500	(310,3)	(31,0)	—		—
	psi	(bar)	(MPa)	psi	(bar)	(MPa)			
Spec 6A	2000	(138)	(13,8)	1500	(103,4)	(10,3)	_	_	_
Valves	3000	(207)	(20,7)	2250	(155,1)	(15,5)		_	
2	5000	(345)	(34,5)	3750	(258,6)	(25,9)		_	_
	10000	(690)	(69,0)	7500	(517,1)	(51,7)		_	
	15000	(1034)	(103,5)	11250	(775,7)	(77,6)	_	_	_
E)	20000	(1379)	(138,0)	15000	(1034,2)	(103,5)		<u> </u>	_

#### Table 1—Test Pressure During Fire Test

Note: Tolerance on all test pressures is  $\pm 10\%$ .

\*"PN" is the pressure class designation utilized in ISO (International Standards Organization) documents.





#### API SPEC\*6FD 95 🖿 0732290 0538647 T12 🔳



11. Test valve mounted in its normal operating position.

Figure 6—Schematic of Suggested Systems for Fire Test for Check Valves

**3.10** This step is required only for API Spec 6D valves with ratings of class 600 and lower. Decrease the test pressure to the low test pressure value shown in Table 1. Measure and record the through valve and external leakages over a 5-minute period.

**3.11** Decrease the test pressure to 1% or less of the valve's rated room temperature pressure.

**3.12** While maintaining the test pressure of Step 3.11, vent air or steam at vent valves (Items 15 and 23).

**3.13** Close the downstream shutoff valve (Item 16).

**3.14** Open valves (Items 22, 24, and 25) to water fill and purge air from the downstream piping, then close the vent valve (Item 24).

**3.15** Close the shutoff valve (Item 21), to isolate the pressure source from the upstream end of the test valve (Item 11).

**3.16** Open the upstream vent valve (Item 23). Verify that the test valve has unseated, by observation of steady flow through the vent valve, then close the vent valve.

**3.17** Increase the pressure at the source (Item 1) to the high test pressure shown in Table 1. Verify pressurization of the entire test valve body by briefly opening the body cavity vent valve (Item 15), and observing flow.

**3.18** Measure and record the external leakage over a 5-minute period while at the high test pressure.

**3.19** Test Adjustments. The test system, excluding the test valve, may be adjusted during the test period to keep the test within the limits specified herein.

#### 4 Performance Requirements

#### 4.1 THROUGH LEAKAGE—DURING BURN PERIOD (HIGH TEST PRESSURE)

The maximum through seat leakage shall not be greater than the value shown below (Ref. 3.8):

Burn Period	30 minutes
Rate	400 ml/in/min*
	(15.7 ml/mm/min)

#### 4.2 EXTERNAL LEAKAGE-DURING BURN AND COOL-DOWN PERIOD (HIGH TEST PRESSURE, VALVE IN CLOSED POSITION)

The maximum external leakage shall not be greater than the value shown below (Ref. 3.9):

Test Duration	30 Minutes plus time
	to cool-down to
	212°F (100°C)
Rate	100 ml/in/min*
	(3.9  m/mm/min)

#### 4.3 THROUGH LEAKAGE—AFTER COOL-DOWN (LOW TEST PRESSURE)

The maximum through seat leakage shall not be greater than the value shown below (Ref. 3.10):

Test Duration	5 Minutes
Rate	40 ml/in/min*
	(1.6 ml/mm/min)

#### 4.4 EXTERNAL LEAKAGE—AFTER COOL-DOWN (LOW TEST PRESSURE)

The maximum external leakage shall not be greater than the value shown below (Ref. 3.10):

Test Duration	5 Minutes
Rate	20 ml/in/min*
	(0.8 ml/mm/min)

\*Note: Leakage rates are milliliters per inch of nominal valve size per minute (milliliters per millimeter of nominal valve size per minute), average over the duration of the particular test period.

#### 4.5 OPERATION OF VALVE AFTER FIRE TEST

The valve shall be capable of being unseated from the closed position one time (Ref. 3.16).

#### 4.6 EXTERNAL LEAKAGE—OPEN POSITION (HIGH TEST PRESSURE)

With the test valve unseated, measure and record the external leakage, per Paragraph 3.18. The leakage shall not be greater than 200 ml/in/min (8 ml/mm/min).

#### 4.7 TESTS REQUIRED

In lieu of testing each size and pressure rating of a given valve design, other valves of the same basic design as the test valve and same nonmetallic materials with respect to the seat to closure member seal, seat to body seal, and body joint and seal, may be qualified, subject to the following limitations:

**4.7.1** One test valve may be used to qualify valves larger than the test valve, not exceeding twice the size of the test valve (Ref. Table 2). A NPS 16 valve will qualify all larger sizes.

**4.7.2** One test valve may be used to qualify valves with higher pressure ratings, but no greater than twice the pressure rating of the test valve (Ref. Table 3).

**4.7.3** The nominal size of the test valve is determined by the size of the end connections.

**4.7.4** Valves shall not be protected with insulation material of any form during testing, except where such protection is part of the design of the component.

#### 5 Certification

Records of the test upon which certifications are based shall be available for purchaser's review on request.

#### 6 Safety Considerations

Because of the possible design of the test valve and the nature of the test program, the potential may exist for a haz-

۰,

ardous rupture of the pressure boundary components. Protection for test personnel shall be provided.

#### 7 Equipment Marking

In addition to the marking requirements, specified in API Spec 6A or 6D, valves which have been qualified by this specification shall be permanently marked:

6FD

Size of Test Val	ve	Other Valve Sizes Qualifie	ed.
NPS	DN*	NPS	DN*
2" API 6D, 1 <sup>13</sup> /16, 2 <sup>1</sup> /16 API 6A	50	2, 2 <sup>1</sup> /2, 3, 4 API 6D, 1 <sup>13</sup> /16, 2 <sup>1</sup> /16, 2 <sup>9</sup> /16, 3 <sup>1</sup> /8, 4 <sup>1</sup> /16 API 6A	50, 65 80, 100
2 <sup>9</sup> /16 API 6A, 2 <sup>1</sup> /2 API 6D	65	2 <sup>9</sup> /16, 3 <sup>1</sup> /8, 4 <sup>1</sup> /16, 5 <sup>1</sup> /8 API 6A, 2 <sup>1</sup> /2, 3, 4 API 6D	65, 80 100, 125
3 API 6D, 3 <sup>1</sup> /8 API 6A	80	3, 4, 6 API 6D, 3 <sup>1</sup> /8, 4 <sup>1</sup> /16, 5 <sup>1</sup> /8, 7 <sup>1</sup> /16 API 6A	80, 100 125, 150
4 API 6D, 4 <sup>1/</sup> 16 API 6A	100	4, 6, 8 API 6D, 4 <sup>1</sup> /16, 5 <sup>1</sup> /8, 7 <sup>1</sup> /16 API 6A	100, 125, 150, 200
5 <sup>1</sup> /8 API 6A	125	5 <sup>1</sup> /8, 7 <sup>1</sup> /16, 9 API 6A, 6, 8, 10 API 6D	125, 150, 200, 250
6 API 6D, 7 <sup>1</sup> /16 API 6A	150	6, 8, 10, 12 API 6D, 7 <sup>1</sup> /16, 9, 11 API 6A	150, 200 250, 300
8 API 6D	200	8, 10, 12, 14, 16 API 6D, 9, 11 API 6A	200, 250, 300, 350, 400
9 API 6A	N/A	9, 11, API 6A, 8 through 16 API 6D	250 through 400
10 API 6D	250	10 through 20 API 6D, 11 API 6A	250 through 500
11 API 6A	N/A	11 API 6A, 10 through 24 API 6D	300 through 500
12 API 6D	300	12 through 24 API 6D	300 through 600
14 API 6D	350	14 through 28 API 6D	350 through 700
16 API 6D	400	16 and larger API 6D	400 and larger

Table 2—Qualification of Other Size Valves (Ref. 4.7.1)

\*"DN" is the size designation utilized in ISO (International Standards Organization) documents.

**API SPECIFICATION 6FD** 

Rati	ng of Test Valve		C			
Class	PN*	Bar	Class or psi	PN*	MPa	Bar
150 API 6D	20	N/A	150, 300 API 6D	20, 50	N/A	N/A
300 API 6D	50	N/A	300, 400, 600 API 6D	50, 64, 110	N/A	N/A
400 API 6D	64	N/A	400, 600 API 6D	64, 110	N/A	N/A
600 API 6D	110	N/A	600, 900 API 6D, 2000, 3000 API 6A	110, 150 N/A	N/A 13.8, 20.7	N/A 138, 207
900 API 6D	150	N/A	900, 1500 API 6D, 3000 API 6A	150, 260 N/A	N/A 10.7	N/A 207
1500 API 6D	260	N/A	1500, 2500 API 6D, 5000 API 6A	260, 420 N/A	N/A 34.5	N/A 345
2500 API 6D	420	N/A	2500 API 6D, 10000 API 6A	420 N/A	N/A 69.0	N/A 690
psi	MPa	Bar	psi or Class	PN*	MPa	Bar
2000 API 6A	13.8	138	2000, 3000 API 6A, 900, 1500 API 6D	N/A 150, 260	13.8, 20.7 N/A	138, 207 N/A
3000 API 6A	20.7	207	3000, 5000 API 6A, 1500, 2500 API 6D	N/A 260, 420	20.7, 34.5 N/A	207, 345 N/A
5000 API 6A	34.5	345	5000, 10000 API 6A, 2500 API 6D	N/A 420	34.5, 69.0 N/A	345, 690 N/A
10000 API 6A	69.0	690	10000, 15000, 20000 API 6A	N/A	69.0, 103.5 138.0	690, 1 034, 1 379
15000 API 6A	103.5	1 034	15000, 20000 API 6A	N/A	103.5, 138.0	1 034, 1 379
20000 API 6A	138.0	1 379	20000 API 6A	N/A	138.0	1 379

#### Table 3—Qualification of Other Pressure Rating Valves (Ref. 4.7.2)

\*"PN" is the pressure class designation utilized in ISO (International Standards Organization) documents.

8

#### APPENDIX A—CONVERSIONS OF ENGLISH UNITS TO SI METRIC UNITS

Conversions of English units to International System (SI) metric units are provided throughout the text of this specification in parentheses, e.g., 6 in. (152,4 mm). Note that the comma is used as a decimal marker for metric data. SI equivalents have also been included in all tables. English units are in all cases preferential and shall be the standard in this specification. The factors used for conversion of English units to SI units are listed below:

Table A-1—SI Units
--------------------

Quanity	U.S. Customary	SI Unit
Length	1 inch (in.)	25,4 millimetres (mm) exactly
Pressure	l pound per square inch (psi)	0,06894757 Bar 0,006894757 MPa
Temperature	The following formula was used to convert degrees Fahrenheit (°F) to degrees Celsius (°C): °C = $5/9$ (°F -32)	

In addition to the above conversions, the designations PN for nominal pressure and DN for nominal size are sometimes used. For the purpose of this specification, the PN designations relate to pressure classes, and the DN designations relate to NPS, or nominal pipe sizes, as follows:

Class $150 = PN 20$	Class $300 = PN 50$
Class 400 = PN 64	Class 600 = PN 110
Class 900 = PN 150	Class 1500 = PN 260
Class 2500 = PN 420	
NPS $2 = DN 50$	NPS $2^{1}/_{2} = DN 65$
NPS 3 - DN 80	NPS 4 = DN 100
M = D M = 0	MIST = DIVIOU

For NPS 4 and greater listed sizes, multiply the NPS by 25 to obtain the DN, except that there is no equivalent DN for NPS 36.



# 2008 **Publications Order Form**

#### Effective January 1, 2008.

API Members receive a 30% discount where applicable.

The member discount does not apply to purchases made for the purpose of resale or for incorporation into commercial products, training courses, workshops, or other commercial enterprises.

#### Available through IHS:

Phone Orders:	1-800-854-7179 303-397-7956	(Toll-free in the U.S. and Canada) (Local and International)
Fax Orders: Online Orders:	303-397-2740 global.ihs.com	

#### **API Member** (Check if Yes) Date: Ship To (UPS will not deliver to a P.O. Box) **Invoice To** ( Check here if same as "Ship To") Name: Name: Title: Title: Company: Company: Department: Department: Address: Address: State/Province: City: Zip/Postal Code: Country: Telephone: Fax:

City:	State/Province:
Zip/Postal Code:	Country:
Telephone:	
Fax:	
Email:	

Quantity	Title			so★	Unit Price	Total
Payment Enclosed P.O. No. (Enclose Copy)		Subtotal				
Charge My IHS Account No.		Applicable Sales Tax (see below)				
VISAMasterCardDiners ClubDiscover		American Express	Rush	Rush Shipping Fee (see below)		
			Shipping and Handling (see below)			
Credit Card No.:						
Print Name (As It Appears on Card):		★ To be placed on Standing Order for future editions of this publication, place a check mark in the SO column and sign here:				
Expiration Date:						
Signature:		Pricing and availability subject to change without notice.				

Mail Orders - Payment by check or money order in U.S. dollars is required except for established accounts. State and local taxes, \$10 processing fee, and 5% shipping must be added. Send mail orders to: API Publications, IHS, 15 Inverness Way East, c/o Retail Sales, Englewood, CO 80112-5776, USA.

Purchase Orders - Purchase orders are accepted from established accounts. Invoice will include actual freight cost, a \$10 processing fee, plus state and local taxes.

Telephone Orders - If ordering by telephone, a \$10 processing fee and actual freight costs will be added to the order.

Sales Tax - All U.S. purchases must include applicable state and local sales tax. Customers claiming tax-exempt status must provide IHS with a copy of their exemption certificate. Shipping (U.S. Orders) - Orders shipped within the U.S. are sent via traceable means. Most orders are shipped the same day. Subscription updates are sent by First-Class Mail. Other options, including next-day service, air service, and fax transmission are available at additional cost. Call 1-800-854-7179 for more information.

Shipping (International Orders) - Standard international shipping is by air express courier service. Subscription updates are sent by World Mail. Normal delivery is 3-4 days from shipping date.

Rush Shipping Fee - Next Day Delivery orders charge is \$20 in addition to the carrier charges. Next Day Delivery orders must be placed by 2:00 p.m. MST to ensure overnight delivery. Returns - All returns must be pre-approved by calling the IHS Customer Service Department at 1-800-624-3974 for information and assistance. There may be a 15% restocking fee. Special order items, electronic documents, and age-dated materials are non-returnable.

Email:

# THERE THIS CAME FROM.

API provides additional resources and programs to the oil and natural gas industry which are based on API Standards. For more information, contact:

# API MONOGRAM<sup>®</sup> LICENSING PROGRAM

 Phone:
 202-962-4791

 Fax:
 202-682-8070

 Email:
 certification@api.org

# API QUALITY REGISTRAR (APIQR®)

> ISO 9001 Registration
> ISO/TS 29001 Registration
> ISO 14001 Registration
> API Spec Q1<sup>®</sup> Registration
Phone: 202-962-4791
Fax: 202-682-8070
Email: certification@api.org

# API PERFORATOR DESIGN REGISTRATION PROGRAM

 Phone:
 202-682-8490

 Fax:
 202-682-8070

 Email:
 perfdesign@api.org

## API TRAINING PROVIDER CERTIFICATION PROGRAM (API TPCP™)

Phone: 202-682-8490 Fax: 202-682-8070 Email: tpcp@api.org

# API INDIVIDUAL CERTIFICATION PROGRAMS (ICP®)

 Phone:
 202-682-8064

 Fax:
 202-682-8348

 Email:
 icp@api.org

# API ENGINE OIL LICENSING AND CERTIFICATION SYSTEM (EOLCS)

 Phone:
 202-682-8516

 Fax:
 202-962-4739

 Email:
 eolcs@api.org

# API PETROTEAM (TRAINING, EDUCATION AND MEETINGS)

 Phone:
 202-682-8195

 Fax:
 202-682-8222

 Email:
 petroteam@api.org

# API UNIVERSITY<sup>TM</sup>

 Phone:
 202-682-8195

 Fax:
 202-682-8222

 Email:
 training@api.org

Check out the API Publications, Programs, and Services Catalog online at www.api.org.



Copyright 2008 - API, all rights reserved. API, API monogram, APIQR, API Spec Q1, API TPCP, ICP, API University and the API logo are either trademarks or registered trademarks of API in the United States and/or other countries.



1220 L Street, NW Washington, DC 20005-4070 USA

202.682.8000

Additional copies are available through IHS Phone Orders: 1-800-854-7179 (Toll-free in the U.S. and Canada) 303-397-7956 (Local and International) Fax Orders: 303-397-2740 Online Orders: global.ihs.com

Licensee=University of Alberta/5966844001, User=sharabiani, shahram/s Not for Resale, 04/27/2014 20:38:59 MDT Information about API Publications, Programs and Services is available on the web at www.api.org