

Date of Issue: May 2017

Affected Publication: API 510, *Pressure Vessel Inspection Code: In-service Inspection, Rating, Repair, and Alteration*, Tenth Edition, May 2014

Addendum 1

Page 26, Section 5.5.6.1, shall read:

Inspection for CUI shall be considered for externally insulated vessels and those that are in intermittent service or operate at temperatures between:

- a) 10 °F (–12 °C) and 350 °F (177 °C) for carbon and low alloy steels,
- b) 140 °F (60 °C) and 350 °F (177 °C) for austenitic stainless steels,
- c) 280 °F (138 °C) and 350 °F (177 °C) for duplex stainless steels.

Page 60, Section 9.3.5, the section header shall read:

9.3.5 Inspection Intervals

Page 62, Section 9.3.6c, shall read:

Air receivers (other than portable equipment) shall be inspected at least every five years unless inspected by RBI.