ASME A112.18.3-2002 (Revision of ASME A112.18.3M-1996)

PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS

AN AMERICAN NATIONAL STANDARD







Α Ν Μ R Ν 0 Ν S Т Ν R Α Ε С Α Ν Α Т L Α L Α D Α D

PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS



Date of Issuance: May 23, 2003

This Standard will be revised when the Society approves the issuance of a new edition. There will be no addenda issued to this edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Interpretations are published on the ASME Web site under the Committee Pages at http://www.asme.org/codes/ as they are issued.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

The American Society of Mechanical Engineers Three Park Avenue, New York, NY 10016-5990

Copyright © 2003 by THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS All rights reserved Printed in U.S.A.



In memory of, and dedicated to the life of, our dear friend, colleague, and long-standing industry leader, Thomas P. Konen. His contributions to the plumbing industry at large and to this committee will never be forgotten.



INTENTIONALLY LEFT BLANK



Copyrighted material licensed to Stanford University by Thomson Scientific (www.techstreet.com), downloaded on Oct-05-2010 by Stanford University User. No further reproduction or distribution is permitted. Uncontrolled w

CONTENTS

| A112 | 2 Dedication | iii |
|--------|--|---------|
| Fore | eword | vi |
| Corr | nmittee Roster | vii |
| Corr | respondence With the A112 Committee | ix |
| 1 | Purpose | 1 |
| 2 | Scope | 1 |
| 3 | Reference Standards | 1 |
| 4 | Definitions | 1 |
| 5 | Application of Backflow Prevention Devices | 2 |
| 6 | General Requirements for Backflow Prevention Devices | 3 |
| 7 | Evaluation of Backflow Prevention Devices | 3 |
| 8 | Fixture Fittings With Internal Devices Complying With Paras. 6 and 7 | 3 |
| 9 | Fixture Fittings With Internal Devices Not Complying With Para. 7 | 4 |
| 10 | Test Methods and Performance Criteria | 5 |
| 11 | Functional Test of Backflow Prevention Devices | 5 |
| 12 | Functional Test of Backflow Prevention Systems | 6 |
| 13 | Independence of Devices | 7 |
| 14 | Leakage of Protection Systems With Atmospheric Vents | 8 |
| 15 | Durability Tests | 8 |
| 16 | Verification of the Critical Level [Hose Connected Movable Outlet Faucets With Atmospheric Vents, Paras. 8.1.1(b), (c), and (d)] | 10 |
| Figu | res | |
| 1 | Test Protocol for Devices | 4 |
| 2 | Test Protocol for Fittings Without Approved Components | 6 |
| 3 4 | Functional Performance for Check valves | 7 |
| 5 | Functional Performance of Backflow Prevention Systems With Regard to Back | , |
| | Pressure Backflow | 8 |
| 6 | Functional Performance of Backflow Prevention Systems With Regard to Back | 0 |
| 7 | Schematic Drawing of Test Facility | 9 10 |
| 8 | Verification of the Critical Level (Hose Conected Outlet Faucets With Atmospheric Vents) | 11 |
| Table | es | |
| 1 | Acceptance Sampling Plan — Devices | 3 |
| 2 | Acceptance Sampling Plan — Fittings | 5 |
| 3 | Formulation for ASME A112.18.3 Water | 9 |
| Non | mandatory Appendix | |
| А | Rationale for Sampling Scheme and Statistical Procedures | 13 |



v

\$

FOREWORD

In November 1987, Panel 18 of the ASME Committee A112, Plumbing Materials and Equipment, initiated work to develop requirements for the protection against back pressure backflow and back siphonage in an emerging class of fittings, wherein the spout and side spray were combined for efficient use and operation. The increased concern for the protection of drinking water encouraged the Committee to look beyond traditional protection methods and develop a performance standard which excludes the contamination of potable water but gives needed freedom to manufacturers to produce fittings of complex design and construction as demanded by today's worldwide markets.

While the probability of occurrence associated with the contamination of potable water through backflow at various plumbing fixture fittings is minimal, there remains a need for a protection system. This Standard establishes performance requirements with specific criteria for acceptance, to ensure a high degree of reliability for the safety system throughout the useful life of the fitting.

Extensive testing and engineering reviews of current practice demonstrated that backflow protection is mainly a function of the check valve or check valve assembly and that reliance on vacuum breakers is dependent on the adequacy of the air vent. In achieving this, para. 6.3 of this Standard requires durability testing of multiple specimens and internationally recognized statistical methods for evaluating the results.

This Standard provides for the evaluation and approval of devices which may be combined to form a safety system being integrated into different products without further durability tests. In addition, this Standard provides for the evaluation of production fittings complete with an integrated protection system, which however does not examine the performance of the device individually. It is designed to confirm the overall reliability of the integrated safety system.

This Standard is written to give freedom to the manufacturer in design and technology to produce products with devices and system reliability consistent with good engineering practices for the protection of public health.

Suggestions for improvement of this Standard will be welcomed. They should be sent to The American Society of Mechanical Engineers; Attn: Secretary, A112 Standards Committee; Three Park Avenue; New York, NY 10016.

This Standard was approved as an American National Standard on September 6, 2002.





ASME A112 COMMITTEE Standardization of Plumbing Materials and Equipment

(The following is the roster of the Committee at the time of approval of this Standard.)

OFFICERS

P. J. Higgins, Chair S. A. Remedios, Vice Chair C. J. Gomez, Secretary

COMMITTEE PERSONNEL

R. H. Ackroyd, Consultant J. C. Aiello, Jacuzzi Whirlpool Bath J. A. Ballanco, JB Engineering & Code Consulting J. Bouwer, Sanitary for All Ltd. S. L. Cavanaugh, United Associated A. Cohen, Arthur Cohen & Associates P. V. DeMarco, American Standard, Inc. N. Covino, Alternate, American Standard, Inc. G. S. Duren, Code Compliance, Inc. R. Emmerson, Chicago Faucet Co. F. C. Evans, Alternate, Chicago Faucet Co. L. S. Galowin, National Institute of Standards and Technology C. J. Gomez, The American Society of Mechanical Engineers R. I. Greenwald, Sunroc Corp. J. P. Gronewold, NSF International P. J. Higgins, P. J. Higgins & Associates, Inc. E. Ho, CSA International D. E. Holloway, SGS U.S. Testing Co. M. Klimboff, Consultant M. T. Kobel. IAPMO N. M. Kummerlen, Moen, Inc. L. A. Mercer, Alternate, Moen, Inc. J. W. Lauer, Sloan Valve Co. R. M. Martin, California Energy Commission P. Meikle, Underwriters Laboratories, Inc. L. M. Kriegbaum, Alternate, Underwriters Laboratories, Inc. S. Rawalpindiwala, Kohler Co. J. A. Sargent, Alternate, Kohler Co. S. A. Remedios, Delta Faucet Co. G. L. Simmons, Charlotte Pipe and Foundry L. M. Simnick, BOCA International W. M. Smith, Jay R. Smith Manufacturing Co. D. W. Viola, Plumbing Manufacturers Institute R. E. White, Consultant W. C. Whitehead, Plumbing and Drainage Institute A112 PROJECT TEAM 18.3 - BACKFLOW DEVICES

R. H. Ackroyd, Project Team Leader, Rand Engineering

J. A. Ballanco, JB Engineering & Consulting

S. L. Cavanaugh, United Association

N. Covino, American Standard, Inc.

R. Emmerson, Chicago Faucets Co.



F. C. Evans, Zin-Plas Corp.

K. Fromme, Bradley Cor.

C. R. Graham, Martech Enterprises

P. J. Higgins, PJ Higgins & Associates, Inc.

E. Ho, CSA International

M. Joedicke, Friedrich Grohe AG

M. Klimboff, Consultant

M. T. Kobel, IAPMO

T. P. Konen, Stevens Institute

N. M. Kummerlen, Moen, Inc.

F. L. Luedke, Neoperl Inc.

R. B. Martin, W/C Tech Corp.

P. Meikle, Underwriters Laboratories, Inc.

L. A. Mercer, Moen, Inc.

- S. Rawalpindiwala, Kohler Co.
- S. A. Remedios, Delta Faucet Co.

J. A. Sargent, Kohler Co.

D. W. Viola, Plumbing Manufacturers Institute





CORRESPONDENCE WITH THE A112 COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions, and attending Committee meetings. Correspondence should be addressed to:

Secretary, A112 Standards Committee The American Society of Mechanical Engineers Three Park Avenue New York, NY 10016-5990

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the edition, the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation. When appropriate, proposals should be submitted using the A112 Project Initiation Request Form.

Interpretations. Upon request, the A112 Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the A112 Standards Committee.

The request for interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his/her request in the following format:

| a applicable edition of the Standard for which the interpretation |
|---|
| e applicable edition of the Standard for which the interpretation |
| g requested. |
| the question as a request for an interpretation of a specific ement suitable for general understanding and use, not as a reques approval of a proprietary design or situation. The inquirer may clude any plans or drawings that are necessary to explain the on; however, they should not contain proprietary names or infor |
| |

Requests that are not in this format will be rewritten in this format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Attending Committee Meetings. The A112 Standards Committee schedules meetings as needed, which are open to the public. Persons wishing to attend any meeting should contact the Secretary of the A112 Standards Committee. The A112 home page contains information on future meeting dates and locations.



Copyrighted material licensed to Stanford University by Thomson Scientific (www.techstreet.com), downloaded on Oct-05-2010 by Stanford University User. No further reproduction or distribution is permitted. Uncontrolled w

INTENTIONALLY LEFT BLANK

Copyright \bigcirc 2003 by the American Society of Mechanical Engineers. No reproduction may be made of this material without written consent of ASME.

x



Copyrighted material licensed to Stanford University by Thomson Scientific (www.techstreet.com), downloaded on Oct-05-2010 by Stanford University User. No further reproduction or distribution is permitted. Uncontrolled w

Copyrighted material licensed to Stanford University by Thomson Scientific (www.techstreet.com), downloaded on Oct-05-2010 by Stanford University User. No further reproduction or distribution is permitted. Uncontrolled w

PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS

1 PURPOSE

The purpose of this Standard is to establish performance requirements and statistically valid evaluation methods including durability tests for the manufacture of safe, efficient, and reliable backflow protection devices and systems for plumbing fixture fittings.

Alternative designs or configurations which comply with the intent of this Standard shall be permitted.

2 SCOPE

This Standard addresses functional performance and requires physical characteristics of devices and systems which provide backflow protection consistent with the level of risk associated with the plumbing fixture fitting application. The Standard establishes specific performance criteria and provides the test methods to prove compliance. It is applicable to all plumbing fixture fittings with outlets not protected by an air gap.

3 REFERENCE STANDARDS

The following documents form a part of this Standard to the extent specified herein. The latest issue shall apply.

ASTM D 1193, Specification for Reagent Water

- Publisher: The American Society for Testing and Materials (ASTM), 100 Barr Harbor Drive, West Conshohocken, PA 19428
- ASME A112.1.2, Air Gaps in Plumbing Systems

ASME A112.18.1, Plumbing Fixture Fittings

- ASME PTC 19.2, Supplement on Instruments and Apparatus, Part 2 Pressure Measurement
- Publisher: The American Society of Mechanical Engineers (ASME International), Three Park Avenue, New York, NY 10016-5990
- ANSI/ASSE 1001, Pipe Applied Atmospheric Type Vacuum Breakers
- ANSI/ASSE 1011, Performance Requirements for Hose Connection Vacuum Breakers
- ANSI/ASSE 1014, Performance Requirements for Hand-Held Showers
- ANSI/ASSE 1025, Performance Requirements for Diverters for Plumbing Faucets With Hose Spray, Anti-Siphon Type, Residential Applications
- ANSI/ASSE 1052, Hose Connection Backflow Preventors

- ASSE 1012, Performance Requirements for Backflow Preventers With Intermediate Atmospheric Vent
- ASSE 1013, Performance Requirements for Reduced Pressure Principle Backflow Preventers
- ASSE 1019, Vacuum Breaker Wall Hydrants, Frost Resistant Automatic Draining Type
- ASSE 1035, Performance Requirements for Laboratory Faucet Vacuum Breakers
- ASSE 1056, Performance Requirements for Back Siphonage Backflow Vacuum Breakers
- Publisher: The American Society of Sanitary Engineering, 2890 Clemens Road, Suite 100, West Lake, OH 44145
- AWWA C511, Reduce Pressure Principle Backflow Preventor Assembly
- AWWA 10079, Standard Methods for the Examination of Water and Wastewater
- Publisher: The American Water Water Works Association (AWWA), 6666 West Quincy Ave., Denver, CO 80235

CSA B 64, Backflow Preventers and Vacuum Breakers CSA B 125, Plumbing Fittings

Publisher: CSA International, 178 Rexdale Blvd., Toronto, Ontario, Canada M9W1R3

4 DEFINITIONS

Nomenclature and definitions applicable to faucets, fixture fittings, and backflow requirements shall be as follows:

acceptance sampling plan: the correlation of sample size and allowed failure rate.

air gap: the unobstructed vertical distance through the free atmosphere between the lowest opening from any pipe or faucet and the flood-level rim of a receptor. See ASME A112.1.2.

approved: accepted by the authority having jurisdiction *backflow:* the reversal of flow direction from that normally intended. Back siphonage is one type of backflow. Back pressure backflow is another type.

backflow prevention system: any mechanical system, consisting of two or more devices, designed to automatically prevent an unintentional reversal of flow in a potable water distribution system. A backflow prevention system prevents back siphonage and back pressure backflow.



back pressure: a pressure higher at the outlet of a fitting than that at the inlet or a point upstream.

back siphonage: the flowing back of water from a plumbing fixture, vessel, or other source into the fitting as the result of a vacuum at the inlet of the fitting.

bidet: a fixture and/or wall mounted fitting with transfer valves for vertical spray and rim flushing; a deck mounted fitting with hose connected outlets.

certified: indicates that testing has been conducted by an approved independent testing agency in accordance with the applicable standard and found to be in full compliance with the standard.

commercial fitting: a hose and spray assembly for food service, dispensers, and similar nonresidential applications other than those where an air gap is maintained by design, such as spring-action goosenecks.

critical level: level at which polluted water, entering through an outlet of the supply fitting, will flow back to the supply lines by gravity and/or any negative pressure in the supply line when the water control valve is fully open.

cross connection: an actual or potential connection or arrangement between two or more separate piping systems, one of which contains potable water and one of the others a source of questionable or unknown quality. The direction of flow will depend upon the pressure differential between the two systems.

deck mounted and combination fitting: residential deck mounted fitting for tubs. It often includes a hand-held or personal shower.

device: one of the constituent parts of a backflow prevention system which by itself provides a form of backflow protection.

fill valve: a water supply valve (also known as a ballcock), opened or closed by means of a float or similar device, used to supply water to a tank.

fitting with side sprays: a kitchen deck mounted fitting with integral diverter and hose connected side spray. The primary outlet is protected with an air gap.

fitting wih pull-out spout: a deck mounted fixture fitting with a primary removable spout that is connected to the body of the faucet through a flexible hose. Applications are residential kitchens, low sinks, and lavatories.

hand held shower: a product consisting of a hose and discharge piece, such as a shower head or spray; it is used in conjunction with bath and shower fittings or dedicated wall outlets.

hose bibb: a fitting terminating with a hose thread.

inspection: the process of measuring, examining, testing, gauging, or otherwise comparing the unit with the applicable requirements.

laboratory fitting: a fitting terminating with a serrated hose tip.

potable water: water which is suitable for drinking and free from impurities present in amounts which are sufficient to cause disease or harmful physiological effects.

random sample: a sample taken in a manner which gives every item in the lot, or every portion of the lot for bulk materials, an equal probability of being selected as part of the sample.

sample: the number of specimens selected from a production lot as representative of that lot.

sampling scheme, multiple: a sampling method in which, after each sample is inspected, the decision is made to accept a lot, to reject it, or to take another sample, the test result of which shall be added to that of the previous one.

shampoo fitting: a hose and spray assembly for attachment to a wall outlet or lavatory fitting.

specimen: an individual component which combined with others makes up a required sample.

upper confidence limit: the maximum probable percentage of individual safety devices subject to backflow in the field under those conditions defined in the life test.

vacuum breaker: a device or means to prevent back siphonage by allowing air to enter a fitting.

vent to air: a backflow prevention device which opens a fitting or part of a fitting to the atmosphere.

5 APPLICATION OF BACKFLOW PREVENTION DEVICES

5.1 Minimum Level of Protection

Fixture fittings which are not protected against backflow by an air gap in accordance with ASME A112.1.2 under all conditions of usage shall incorporate backflow protection by means described in paras. 6 through 16 or use a system or device in compliance with the following standards: ANSI/ASSE 1001, ANSI/ASSE 1011, ASSE 1012, ASSE 1013, ANSI/ASSE 1014, ASSE 1019, ASSE 1035, ASSE 1052, ASSE 1056, AWWA C511, CSA B64, or CSA B125 dependent on their application and code instalation requirements with no further testing to this Standard.

5.2 Application

(*a*) Backflow prevention devices or systems not covered by the standards listed in para. 5.1 shall comply with paras. 6 and 7.

(*b*) Fittings with internal backflow prevention devices or systems complying with paras. 6 and 7 shall be tested to para. 8.

(c) Fittings with internal backflow prevention devices or systems not complying with paras. 6 and 7 shall comply with para. 9.



| Cumulative Sample Size (Specimens) | Failures Allowed |
|---------------------------------------|------------------|
| 7 | 0 |
| 10 | 1 |
| 13 | 2 |
| 17 | 3 |

Table 1 Acceptance Sampling Plan — Devices

6 GENERAL REQUIREMENTS FOR BACKFLOW PREVENTION DEVICES

6.1 Functional

Backflow prevention devices shall be designed to prevent pollution and contamination of the potable water system.

6.2 Materials

Materials in contact with potable water shall comply with the requirements of ASME A112.18.1M.

6.3 Environment

6.3.1 Working Pressure. Backflow prevention devices shall be designed to function at water working pressures up to 125 psig (861 kPa gage).

6.3.2 Working Temperature. Backflow prevention devices shall be designed to function at water supply temperatures ranging from 40°F to 160°F (4.4°C to 71°C).

6.4 Reliability

Backflow prevention devices shall be resistant to mechanical wear, deposition of minerals, aging, and corrosion of the materials as determined by the test procedure of para. 7. The manufacturer shall establish the reliability of the individual backflow prevention device, and it shall be confirmed by durability tests in accordance with para. 7.

7 EVALUATION OF BACKFLOW PREVENTION DEVICES

7.1 Sample Size

The minimum initial sample size per set shall be seven specimens. The incremental increases and cumulative sample sizes shall be as shown in Table 1.

7.2 Test Methodology

7.2.1 Facilities. The backflow prevention devices shall be tested individually in fittings or test fixtures representing the dimensions and tolerances specified by the device manufacturer.

7.2.2 Protocol. The functional performance of the device shall be determined before and after the durability test sequence. The functional performance of a device

shall be determined in accordance with para. 11. The durability test sequence for a device shall be conducted in accordance with para. 15. The process for evaluation of backflow prevention devices is illustrated in Fig. 1.

Two sample sets, each consisting of a minimum of seven specimens, shall be evaluated for durability by tests defined in para. 15. At the start of the evaluation, both sets samples shall be tested for functional performance (para. 11). Thereafter, one sample set shall be tested for mechanical wear and mineral deposition (para. 15.2), and the second sample set shall be tested for aging and corrosion (para. 15.1). When retested, there shall be a maximum of three incremental increases.

7.3 Conformance

Any physical damage to internal devices known to preclude functional performance shall be cause for rejection. The allowable failures shall not exceed the values shown in Table 1.

8 FIXTURE FITTINGS WITH INTERNAL DEVICES COMPLYING WITH PARAS. 6 AND 7

The purpose of this paragraph is to define the requirements and test procedures for the evaluation of finished products incorporating certified backflow protection devices which have been demonstrated to be in compliance with paras. 6 and 7 of this Standard.

8.1 Health and Safety

8.1.1 There shall be at least two backflow prevention devices, in series proven by tests as in compliance with para. 7 of this Standard. They shall operate independently as integral parts of the fixture fitting. At least one device shall be a check valve, called the primary check in this Standard.

Among the protection devices are

- (a) check valves
- (b) vents to air
- (c) vacuum breakers
- (d) automatic diverters

8.1.2 Contaminants shall not enter the potable water system through backflow nor shall contaminants be allowed to enter the fitting beyond the first barrier when the backflow preventer is operating properly. The test shall be in accordance with para. 12.

8.1.3 The manufacturer shall specify the type and location of the backflow protection system in the product literature or in the installation instructions.

8.2 Performance Tests

8.2.1 Selection of Test Specimens. To comply with this Standard, two specimens will be selected at random from a lot of five production fittings. Before mounting the fixture fittings in the test rig, correct installation of



PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS



Fig. 1 Test Protocol for Devices

the protecting devices shall be verified as conforming to the manufacturer's drawings and specifications.

8.2.2 Conformance. The sample shall pass the following tests:

- (*a*) back pressure, see para. 12.1;
- (b) back siphonage, see para. 12.2;
- (c) independence of devices, see para. 13; and

(*d*) leakage of protection systems with atmospheric vents, see para. 14.

9 FIXTURE FITTINGS WITH INTERNAL DEVICES NOT COMPLYING WITH PARA. 7

The purpose of this paragraph is to define the requirements and test procedures for the evaluation of finished products incorporating backflow protection devices that have not been demonstrated to be in compliance with para. 7 of this Standard.

This method does not examine the performance of the devices individually and therefore gives no detailed insight into their reliability. It is designed to confirm the overall minimum reliability of the integrated safety system as equal to or greater than 0.80.

9.1 Requirements

Backflow protection systems shall be designed to prevent contamination of the potable water system and shall comply with the requirements of the following paragraphs:

- (a) 6.2 Materials
- (b) 6.3 Environment
- (c) 6.4 Reliability
- (d) 8.1 Health and Safety

9.2 Sample Size

The manufacturer shall submit a minimum of 17 specimens for each of the two sample sets, plus two for the general inspection, for a total of 36 fittings. A multiple sampling scheme, as shown in Table 2, shall be used.



Copyrighted material licensed to Stanford University by Thomson Scientific (www.techstreet.com), downloaded on Oct-05-2010 by Stanford University User. No further reproduction or distribution is permitted. Uncontrolled w

| Cumulative Sample Size (Specimens) | Failures Allowed |
|---------------------------------------|------------------|
| 17 | 0 |
| 26 | 1 |
| 35 | 2 |
| 43 | 3 |

 Table 2
 Acceptance Sampling Plan — Fittings

9.3 Test Methodology

The following tests shall be completed in the order listed in Fig. 2. Conformance to the referenced paragraphs of this Standard shall be required.

9.3.1 General. Two specimens (Sample Set C), selected at random from those submitted, shall be inspected for:

(a) independence of devices, see para. 13;

(b) leakage of protection systems with atmospheric vents, see para. 14.

9.3.2 Conformance

(*a*) *Sample Set A*. The sample shall pass the following tests:

(1) back pressure, see para. 12.1;

(2) back siphonage, see para. 12.2;

(3) aging and corrosion, see para. 15.1;

(4) back pressure, see para. 12.1;

(5) back siphonage, see para. 12.2; and

(6) leakage of protection systems with atmospheric vents, see para. 14.

(*b*) *Sample Set B.* The sample shall pass the following tests:

(1) back pressure, see para. 12.1;

(2) back siphonage, see para. 12.2;

(3) mechanical wear and mineral deposition, see para. 15.2;

(4) back pressure, see para. 12.1;

(5) back siphonage, see para. 12.2; and

(6) leakage of protection systems with atmospheric vents, see para. 14.

9.3.3 Instrumentation. Pressure and vacuum measurements shall be in accordance with ASME PTC 19.2.

10 TEST METHODS AND PERFORMANCE CRITERIA

With new products, failure of the function test (as described in para. 11 or 12) shall require discontinuation of further evaluation. Failure of the function test after the durability tests does not automatically mean the rejection of the device or the system. The testing of an additional sample shall not be conducted unless done in accordance with the multiple sampling scheme given in Table 2.

11 FUNCTIONAL TEST OF BACKFLOW PREVENTION DEVICES

When the backflow prevention devices are check valves, testing shall be conducted in accordance with para. 11.1. When the backflow prevention devices are vacuum breakers or automatic diverters and vents, testing shall be conducted in accordance with para. 11.2. Install the devices in their normal position in a test rig in accordance with the manufacturer's instructions. Where the device is intended to be installed in a housing or test fixture supplied by the manufacturer, the dimensional requirements, including tolerances, shall be accounted for in the installation.

11.1 Check Valves (New and After Durability Tests)

Check valves shall be watertight over the range of back pressures from 0.5 in. to 80 in. H_2O (0.12 kPa gage to 19.9 kPa gage) and at vacuums from 0 in. Hg to 25 in. Hg (0 kPa gage to 84 kPa gage).

Connect the inlet of the devices to a water supply capable of delivering water through each device at a flow of 1.0 gpm to 2.0 gpm (0.063 L/s to 0.126 L/s), to a vacuum system capable of maintaining a vacuum from 0 in. Hg to 25 in. Hg (0 kPa gage to 84 kPa gage) and to atmosphere. Flush the devices to purge air from the system. For basic test setup, see Fig. 3.

Connect a 0.25 in. (6.35 mm) minimum nominal inside diameter transparent sight tube in a leakproof manner to the devices or test rig outlet such that the tube is vertical upward. Apply 0.5 in. H₂O (0.12 kPa gage) back pressure and observe for leaks during a 5 min interval. Increase the back pressure up to 80 in. H₂O (19.9 kPa gage) and inspect for leakage during a 5 min interval. Reduce the back pressure to 1 in. H₂O (0.25 kPa gage) by opening the drain valve. Apply a vacuum of 5 in. Hg (17 kPa gage), increase up to 25 in. Hg (84 kPa gage), and inspect for leakage by observing the water in the sight glass.

Subject the check valve to five vacuum surges of 0 in. Hg to 25 in. Hg (0 kPa gage to 84 kPa gage) by quickly opening and closing Valves 2 and 3 sequentially.

There shall be no leakage.

11.2 Vacuum Breakers, Automatic Diverters, and Vents

The vacuum at which the vacuum breaker, the vent to air, or the automatic diverter opens to the atmosphere shall be defined by the manufacturer and tested.

Connect the inlet of each specimen to a vacuum capable of maintaining 25 in. Hg (84 kPa gage) at the inlet after the device opens. Gradually apply a vacuum until the vacuum breaker, diverter, or vent opens. Record the opening vacuum. See Fig. 4 for basic test setup. Increase the vacuum measured at the fitting to 25 in. Hg (84 kPa gage). Record the indicated air flow rate and the pressure drop. The functional performance rating shall be: the

5



PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS



Fig. 2 Test Protocol for Fittings Without Approved Components

maximum opening pressure, the minimum flow rate at 25 in. Hg (84 kPa gage), and the corresponding pressure drop (vacuum gauge reading).

An increase in pressure drop or reduction in air flow rate larger than 20% after completion of the durability tests shall be cause for rejection.

12 FUNCTIONAL TEST OF BACKFLOW PREVENTION SYSTEMS

12.1 Back Pressure

Mount the fixture fitting as received from the manufacturer in its normal position in accordance with the installation instructions. Connect the inlet pipes collectively to a water supply capable of delivering water through each device at a flow of 1.0 gpm to 2.0 gpm (0.063 L/s to 0.126 L/s) to a vacuum system capable of maintaining a vacuum from 0 in. Hg to 25 in. Hg (0 kPa gage to 84 kPa gage). See Fig. 5.

Connect a $\frac{1}{2}$ in. minimum inside diameter transparent sight glass in a leakproof manner to the hose connected outlet. Open Valve 1 with Valve 2 and Valve 3 closed and flush the fitting to purge air from it. Close Valve 1. Adjust the water level in the sight glass to be $\frac{1}{2}$ in. (13 mm) above the highest level of the fitting. Open Valve 2. Observe the level of water in the sight glass for a 5 min period as an indication of leakage. Raise and hold the hose outlet for 5 min at its maximum vertical extension. Inspect for leakage.

There shall be no leakage.

Copyrighted material licensed to Stanford University by Thomson Scientific (www.techstreet.com), downloaded on Oct-05-2010 by Stanford University User. No further reproduction or distribution is permitted. Uncontrolled w

6



PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS



Fig. 3 Functional Performance for Check Valves

12.2 Back Siphonage

Mount the fitting according to Fig. 6.

Adjust the fitting to deliver water at full flow with the valve or valves positioned to deliver an equal mix from each side. The entire fitting shall be free of water.

Submerge the lower end of the sight glass in a receptor providing a minimum 0.25 in. (6.35 mm) annular clearance which shall contain colored water. Position the receptor such that the surface of the water is level with the deck.

Open Valve 3. Apply and maintain a vacuum of 5 in. Hg (17 kPa gage). Observe and note any rise in the water level in the sight glass above the water level in the receptor during a 5 min interval. Increase and maintain the vacuum to a maximum of 25 in. Hg (84 kPa gage). Observe and note any rise in the water level in the sight glass above the water level in the reservoir during a 5 min interval.

Subject the fitting to five vacuum surges of from 0 in. Hg to 25 in. Hg (0 kPa gage to 84 kPa gage) by quickly opening and closing Valves 2 and 3 sequentially. Observe and note any rise in the water level in the sight glass



Vacuum source

Fig. 4 Functional Performance for Vacuum Breakers, Diverters, and Vents to Air

above the water level in the receptor during a 5 min interval.

When conducted in conjunction with the durability tests of para. 15, any rise of colored water into the sight glass above the water level in the reservoir before the durability tests, for fixture fittings with backflow protection in accordance with para. 8.1.1(a), shall constitute failure of these tests.

When conducted in conjunction with the durability tests of para. 15, any rise of colored water in the sight glass above the water level in the reservoir after the durability tests, for fixture fittings with backflow protection in accordance with para. 8.1.1(a), shall constitute failure of these tests.

After the durability tests, for fixture fittings with backflow protection in accordance with para. 8.1.1(b), (c), or (d), a water rise of colored water in the sight glass above the water level in the reservoir within 0.5 in. (12.7 mm) of the verified critical level (specified by the manufacturer and confirmed in para. 16) shall constitute failure of these tests.

13 INDEPENDENCE OF DEVICES

Evaluate the independence of all backflow protecting devices in a fitting by comparison of the product description received from the manufacturer with the actual product. An independent device shall share no common parts with another device except for body housing. The failure of one device in any mode shall not affect the operation of another device.

PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS



Fig. 5 Functional Performance of Backflow Prevention Systems With Regard to Back Pressure Backflow

14 LEAKAGE OF PROTECTION SYSTEMS WITH ATMOSPHERIC VENTS

The fitting shall be operated by opening and closing its valves 50 times. There shall be no visible external leakage under operating conditions of the fixture fitting at 160°F (71.1°C) and 125 psig (861 kPa gage).

15 DURABILITY TESTS

15.1 Aging and Corrosion

The tests shall be performed on one sample set of devices or systems after their functional performance has been verified as described in paras. 11, 12, 13, and 14, whichever is applicable.

Resistance to corrosion of metals and the aging of plastics and elastomers shall be tested in an endurance immersion test using Type 3 water as defined by ASTM D 1193.

The complete fitting or test body shall be preheated to 140°F (60°C) and filled with 140°F (60°C) water, purged of air and completely immersed in a constant temperature bath or oven set, and maintained at a temperature of $160^{\circ}F \pm 5^{\circ}F$ (71.1°C $\pm 2.8^{\circ}C$) for 800 hr in its normal field installation position.

15.2 Mechanical Wear and Mineral Deposits

The devices or systems shall be set up in an operating fitting with the shut-off valve open or in a test fixture and connected to the water supply system. The supply valve of the test rig shall be opened and closed 200,000 times or 60,000 times if the device or fitting is solely to be used for secondary outlets. If the fixture fitting is a single lever mixer, it shall be set in the average mixed water supply position. Each cycle shall be as follows:

| Opening time | $0.4 \pm 0.1 \text{ sec}$ |
|--------------------------------|---------------------------|
| Idle period in open position | $4.0 \pm 0.5 \text{sec}$ |
| Closing time | $0.4 \pm 0.1 \sec$ |
| Idle period in closed position | $1.3 \pm 0.1 \sec$ |

The test shall be interrupted for a period of 1 hr after every 1,000 opening and closing cycles. After completing 25%, 50%, and 75% of the opening and closing cycles, there shall be a 48 hr idle period. There shall be a 192 hr idle period at the conclusion of the test.

Copyright \bigcirc 2003 by the American Society of Mechanical Engineers. No reproduction may be made of this material without written consent of ASME.

8





Fig. 6 Functional Performance of Backflow Prevention Systems With Regard to Back Siphonage (Hose Connected Movable Outlet Faucets)

During these periods the supply valve of the test rig or the fitting shall be closed.

Where a vacuum breaker or atmospheric vent is under test, the ambient air temperature to it shall be between 110° F and 115° F (43.3°C and 46.1°C).

Temperature changes encountered in everyday practice shall be simulated by periodically cycling the water supply from hot to cold as described below. Where complete fittings are used, their water supply inlets shall be interconnected, so that hot or cold water flows into the fitting through both inlets.

Further conditions:

| Hot water temperature | $140^{\circ}F \pm 5^{\circ}F (60^{\circ}C \pm 3^{\circ}C)$ |
|------------------------------|--|
| Cold water temperature | $65^{\circ}F \pm 10^{\circ}F (18.5^{\circ}C \pm 5.5^{\circ}C)$ |
| Period of hot water flow | $5 \min \pm 20 \sec$ |
| Period of cold water flow | 15 min ± 20 sec |
| Flow pressure | 50 psig ± 5 psig |
| | (345 kPa gage ± 34 kPa gage) |
| Water hardness | 200 ppm to 270 ppm $CaCO_3$ |
| Saturation index (Langelier) | 0.2 to 0.3 |
| | |

 Table 3
 Formulation for ASME A112.18.3 Water

| | | DI W | ater |
|--------------------------------|------------------|----------|--------|
| Chemical | Molecular Weight | g/50 gal | mg/L |
| $MgSO_4 \cdot 7H_2O$ | 246.5 | 28.62 | 151.21 |
| $MgCl_2 \cdot 6H_2O$ | 203.8 | 5.19 | 27.42 |
| $Ca(NO_3)_2 \cdot 4H_2O$ | 244.7 | 0.14 | 0.074 |
| $CaCl_2 \cdot 6H_2O$ | 219.1 | 36.89 | 194.9 |
| $Ca(OH)_2$ | 74.1 | 12.25 | 64.72 |
| K ₂ SO ₄ | 174.3 | 1.16 | 6.13 |
| Na HCO ₃ | 84.0 | 3.12 | 16.48 |
| | | | |

GENERAL NOTES:

(a) Total Hardness = 250 mg/L as CaCO₃.

(b) Dissolve $Ca(OH)_2$ separately in 20 gal of DI water by bubbling CO_2 ; if necessary add tiny amounts of 0.1N HCl. Combine this with 30 gal of DI water containing the remaining chemicals.

- (c) All the chemicals are available from laboratory supply houses (e.g., Fischer Scientific).
- (d) Source: Stevens Institute of Technology, May 28, 1998.

The saturation index shall be determined based on values of the parameters measured at the discharge of the water from the devices on test. The pk¹ value shall

be based on calcite. The procedure shall be in accordance with Section 2330 of AWWA 10079. The index shall be determined at least once during each 10,000 cycles throughout the test.

The formulation of the test water is given in Table 3. A schematic drawing of the facility is given in Fig. 7.



¹ AWWA 10079, The Standard Methods for the Examination of Water and Wastewater, provides the method for determing the Calcium Carbonate Saturation Index. K is the solubility product constant for CaCO₃ at water temperature. The p designates –log10. Calcite is one of several forms of CaCO₃ that form in aqueous systems. A table in AWWA 10079 gives values for pK. Note that an upper case K is used in denoting pK.

PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS



Fig. 7 Schematic Drawing of Test Facility

15.3 Inspection and Evaluation

At the conclusion of the durability tests, the device or the system shall be tested for functional performance in accordance with para. 11, 12, or 14, whichever is applicable, and against the criteria in para. 7.3.

16 VERIFICATION OF CRITICAL LEVEL [HOSE CONNECTED MOVABLE OUTLET FAUCETS WITH ATMOSPHERIC VENTS, PARAS. 8.1.1(B), (C), AND (D)]

The laboratory shall confirm the critical level.

Mount the fixture fitting in a test facility as shown in Fig. 8. Remove all check valves or block them full open. Open the fitting control valve, and place the moveable outlet in its pullout position. Connect a transparent flexible hose [1] and reservoir [2] to the fitting outlet in a leakproof manner. Adjust the fitting to deliver water at full flow with the valve or valves postioned to deliver an equal mix from each side. Flow water through the fitting until it is completely full of water and purged of any air. Fill the reservoir with water such that level [A] is below the manufacturer's specified critical level. Disconnect the inlets from the supplies and allow water

10



PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS



Fig. 8 Verification of the Critical Level (Hose Connected Outlet Faucets With Atmospheric Vents)

to drain from the inlets. Place a glass container [3] under the inlet pipes of the fitting.

The determination of critical level requires that the vent to atmosphere must be open, and it shall be manually opened if required.

Slowly elevate the reservoir upwards. While monitoring the fitting inlet pipes, continue raising the reservoir until the water begins to flow from the fitting inlets. Maintain this level [B] of the reservoir until the flow ceases. The horizontal plane located at the water surface in the reservoir [2], when the flow from the fitting ceases, is the actual critical level of the fitting.

The distance [C] from the mounting deck of the fitting to the actual critical level shall be a minimum of 1 in.

NOTE: The pullout spout (wand) may be removed from the fitting outlet flexible hose, and the transparent flexible hose connected to the end of the outlet flexible hose.



INTENTIONALLY LEFT BLANK

Copyright \bigcirc 2003 by the American Society of Mechanical Engineers. No reproduction may be made of this material without written consent of ASME.

12



Copyrighted material licensed to Stanford University by Thomson Scientific (www.techstreet.com), downloaded on Oct-05-2010 by Stanford University User. No further reproduction or distribution is permitted. Uncontrolled w

NONMANDATORY APPENDIX A RATIONALE FOR SAMPLING SCHEME AND STATISTICAL PROCEDURES

The provisions of ASME A112.18.3-2002 have been written to provide safety systems with a minimum reliability of 80% throughout the useful life of plumbing fixture fittings. This reliability exceeds the performance of traditional plumbing fixture fittings incorporating diverters as protection systems, which have been proven adequate through many years of service (see Reference [1]).

The actual probability of backflow occurring in a faucet equipped with a safety system is calculated from the natural probability multiplied by the upper confidence limits of the individual devices featured in the safety system:

$$P = NR \ C = NR \ (P_{u1} \ P_{u2} \ P_{u3} \ \dots)$$

where

- *C* = upper confidence limit, i.e., maximum possible percentage of safety assemblies subject to backflow in the field under those conditions defined in the life test
- NR = natural reliability, i.e., probability of backflow occurring without the use of safety systems
- P = probability of backflow occurring
- $P_{u1}, P_{u2}... =$ upper confidence limit, i.e., maximum possible percentage of individual safety devices subject to backflow in the field under those conditions defined in the life test

A discussion of the natural reliability may be found in Reference [2].

Safety devices are

- (a) check valves
- (b) vacuum breakers
- (c) vents to air
- (d) automatic diverters

The fitting under examination must in all cases be protected by an assembly comprising at least two safety devices, of which the first barrier must be a check valve to safeguard against back pressure and back siphonage backflow.

The reliability of the safety system is defined as:

$$R_d = 1 - P = 1 - (P_{u1} P_{u2} \dots)$$

where

 R_d = reliability of the safety system based on the upper confidence limits of P_{u1} , P_{u2} ...

The upper confidence limits are based on measured failure rates for devices subjected to the durability tests defined in ASME A112.18.3-2002.

The upper confidence limits, for a P_a of 97.5% unilateral, being usual for technical products of the type under examination, are given in Table A1 for selected sample sizes and failure rates.

If, for example, 2 out of n = 10 specimens (= 20%) fail to meet the requirements in the life test, the upper confidence limit for all of these products in the field is 55.6%. This means the maximum probable failure rate may account for 55.6%.

For devices of the type under examination, it is proposed not to permit an upper confidence limit, i.e., the maximum probable failure rate in the field, in excess of 56%.

It shall also be mathematically possible to add the results of several tests performed to the same specification on differing numbers of specimens. This technique is referred to as a multiple sampling scheme and is widely recognized in quality control work.

Therefore, adding a second test result from 5 test specimens with 1 failure to the above described result produces an upper confidence limit for the final test result of <48.1% and means, with respect to the above assumed limit of 56%, that the product tested in this way has passed the test. It is proposed that the tested device, or the entire product in the case of integrated solutions, be certified.

The described method of computing the reliability of safety systems is mathematically exact, noninterpretable, extremely simple for test engineers and manufacturers to use, and extremely flexible in application. The latter two criteria are of particular significance to pragmatic approval testing.

The failure rate confidence limit, Table A1, is computed from the binomial distribution according to Clopper-Pearson (see Reference [3]) for the upper limit as

$$P_{u'} = \frac{(i+1) \ F_p(f1:f2)}{(n-i) + (i+1) \ F_p(f1:f2)}$$

Copyright © 2003 by the American Society of Mechanical Engineers. No reproduction may be made of this material without written consent of ASME.

14

where

- $F_v = F$ -distribution threshold value, calculated with the degrees of freedom f1 and f2(see Table A2)
- i = number of failed parts after test
- n = sample batch size

The F-distribution is a test distribution used in mathematical statistics and is applied in test evaluations of the type in hand. The nomograph, Fig. A1, provides a graphical solution.

SAMPLE CALCULATION

Determine the upper confidence limit for a device that has been evaluated in accordance with paras. 6 and 7 of ASME A112.18.3-2002. The sample size n was 13 and the number of failures i = 2.

$$P_{u'} = \frac{(i+1) F_p}{(n-i) + (i+1) F_p}$$

 F_n is determined from Table A2 using the values for *f*1 and *f*2 calculated from:

$$f1 = 2 (i + 1)$$

$$f2 = 2 (n - i)$$

$$f1 = 2 (2 + 1) = 6$$

$$f2 = 2 (13 - 2) = 22$$

 F_v (read from Table A2) = 3.05

$$P_{u}' = \frac{(i+1) F_{p}}{(n-i) + (i+1) F_{p}}$$

ALTERNATIVE SOLUTION USING CLOPPER-**PEARSON NOMOGRAPH (REFERENCE [4])**

Determine the failure rate: (i/n)100 = (2/13)100 =15.4%. Enter the graph at 15.4% on the abscissa (*x* axis). Follow a vertical path and intersect with sample size line (13). Follow a horizontal line to the ordinate (y axis), and read the upper confidence limit as 45%.

NOTES APPLICABLE TO SPECIFIC PARAGRAPHS OF ASME A112.18.3-2002

(a) Paragraph 7.3

(1) Upper Confidence Limit. The upper confidence limit of the individual backflow prevention device subject to backflow in the field shall not exceed 45% with a 97.5 confidence level, and shall be confirmed using the multiple sampling scheme described in para. 7.2 and the durability tests which are defined in para. 15.

(2) Table 1. Table 1 is based on the binomial distribution of the lower and upper confidence limits, i.e., the confidence interval versus failure rates, established with a 97.5% confidence level.

(b) Paragraph 8

(1) Reliability Evaluation. Conformance to the requirements of ASME A112.18.3-2002 shall be based on reliability data and the corresponding laboratory confirmed quality level of the individual devices.

(c) Paragraph 9

= 0.45 or 45%

Table A1 Failure Rate Upper Confidence Limits, %, With a Confidence Level of 97.5%

| Number of Failures for | | | | | | | | | | | | | | |
|---------------------------|-----|-----|-----|-----|-----|----|--------|-----------|----|----|----|----|----|----|
| Given | | | | | | | Sample | e Size, n | | | | | | |
| Sample Size, | | | | | | | | | | | | | | |
| i | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 17 | 26 | 35 | 43 |
| 0 | 46 | 40 | 36 | 33 | 30 | 28 | 26 | 24 | 23 | 21 | 19 | 13 | 9 | 8 |
| 1 | 64 | 57 | 52 | 48 | 44 | 41 | 38 | 35 | 33 | 31 | 28 | 19 | 14 | 12 |
| 2 | 77 | 71 | 65 | 60 | 55 | 51 | 45 | 45 | 42 | 40 | 36 | 25 | 19 | 15 |
| 3 | 88 | 81 | 75 | 70 | 65 | 60 | 57 | 53 | 50 | 48 | 43 | 30 | 23 | 19 |
| 4 | 95 | 90 | 84 | 78 | 73 | 69 | 65 | 61 | 58 | 55 | 49 | 34 | 26 | 22 |
| 5 | 99 | 96 | 91 | 86 | 81 | 76 | 72 | 68 | 64 | 61 | 55 | 39 | 30 | 25 |
| 6 | 100 | 99 | 96 | 92 | 87 | 83 | 78 | 74 | 71 | 67 | 61 | 43 | 33 | 27 |
| 7 | | 100 | 99 | 97 | 93 | 89 | 84 | 80 | 77 | 73 | 67 | 47 | 36 | 30 |
| 8 | | | 100 | 99 | 97 | 94 | 90 | 86 | 82 | 78 | 72 | 51 | 40 | 33 |
| 9 | | | | 100 | 99 | 97 | 94 | 90 | 87 | 83 | 77 | 55 | 43 | 36 |
| 10 | | | | | 100 | 99 | 97 | 94 | 91 | 88 | 81 | 59 | 46 | 38 |

ASME A112.18.3-2002

(2 + 1) (3.05)

(13-2) + (2+1) (3.05)

| eshold Values for $P = 0.975$ | |
|-------------------------------|-----------|
| ith Upper Thr | al) |
| ld Values, Wi | (Unilater |
| tion Thresho | |
| 2 F-Distribut | |
| ible A: | |

| f2 = | | | | | | | | f | 1 = 2 (i + | 1) | | | | | | | |
|---------|------|------|------|------|------|------|------|------|------------|------|------|------|------|------|------|------|------|
| 2 (n-i) | 1 | 2 | ю | 4 | 5 | 9 | 7 | 8 | 6 | 10 | 12 | 14 | 16 | 18 | 20 | 22 | 24 |
| 1 | 648 | 800 | 864 | 900 | 922 | 937 | 948 | 957 | 963 | 969 | 977 | 983 | 987 | 066 | 993 | 995 | 266 |
| 2 | 38.5 | 39.0 | 39.2 | 39.2 | 39.3 | 39.3 | 39.4 | 39.4 | 39.4 | 39.4 | 39.4 | 39.4 | 39.4 | 39.4 | 39.4 | 39.5 | 39.5 |
| m | 17.4 | 16.0 | 15.4 | 15.1 | 14.9 | 14.7 | 14.6 | 14.5 | 14.5 | 14.4 | 14.3 | 14.3 | 14.2 | 14.2 | 14.2 | 14.2 | 14.1 |
| 4 | 12.2 | 10.6 | 9.98 | 9.61 | 9.36 | 9.20 | 9.07 | 8.98 | 8.91 | 8.85 | 8.75 | 8.68 | 8.63 | 8.59 | 8.56 | 8.53 | 8.51 |
| ъ | 10.0 | 8.43 | 7.76 | 7.39 | 7.15 | 6.98 | 6.85 | 6.76 | 6.68 | 6.62 | 6.53 | 6.46 | 6.40 | 6.36 | 6.33 | 6.30 | 6.28 |
| 9 | 8.81 | 7.26 | 6.60 | 6.23 | 5.99 | 5.82 | 5.70 | 5.60 | 5.52 | 5.46 | 5.37 | 5.30 | 5.24 | 5.20 | 5.17 | 5.14 | 5.12 |
| 7 | 8.07 | 6.54 | 5.89 | 5.52 | 5.29 | 5.12 | 5.00 | 4.90 | 4.82 | 4.76 | 4.67 | 4.60 | 4.54 | 4.50 | 4.47 | 47.4 | 4.42 |
| 8 | 7.57 | 6.06 | 5.42 | 5.05 | 4.82 | 4.65 | 4.53 | 4.43 | 4.36 | 4.30 | 4.20 | 4.13 | 4.08 | 4.03 | 4.00 | 3.97 | 3.95 |
| 6 | 7.21 | 5.72 | 5.08 | 4.72 | 4.48 | 4.32 | 4.20 | 4.10 | 4.03 | 3.96 | 3.87 | 3.80 | 3.74 | 3.70 | 3.67 | 3.64 | 3.61 |
| 10 | 6.94 | 5.46 | 4.83 | 4.47 | 4.24 | 4.07 | 3.95 | 3.86 | 3.78 | 3.72 | 3.62 | 3.55 | 3.50 | 3.45 | 3.42 | 3.39 | 3.37 |
| 12 | 6.55 | 5.10 | 4.47 | 4.12 | 3.89 | 3.73 | 3.61 | 3.51 | 3.44 | 3.37 | 3.28 | 3.21 | 3.15 | 3.11 | 3.07 | 3.04 | 3.02 |
| 14 | 6.30 | 4.86 | 4.24 | 3.89 | 3.66 | 3.50 | 3.38 | 3.29 | 3.21 | 3.15 | 3.05 | 2.98 | 2.92 | 2.88 | 2.84 | 2.81 | 2.79 |
| 16 | 6.12 | 4.69 | 4.08 | 3.73 | 3.50 | 3.34 | 3.22 | 3.13 | 3.05 | 2.99 | 2.89 | 2.82 | 2.76 | 2.72 | 2.68 | 2.65 | 2.63 |
| 18 | 5.98 | 4.56 | 3.95 | 3.61 | 3.38 | 3.22 | 3.10 | 3.01 | 2.93 | 2.87 | 2.77 | 2.70 | 2.64 | 2.60 | 2.56 | 2.53 | 2.50 |
| 20 | 5.87 | 4.46 | 3.86 | 3.52 | 3.29 | 3.13 | 3.01 | 2.91 | 2.84 | 2.77 | 2.68 | 2.60 | 2.55 | 2.50 | 2.46 | 2.43 | 2.41 |
| 22 | 5.79 | 4.38 | 3.78 | 3.44 | 3.22 | 3.06 | 2.93 | 2.84 | 2.76 | 2.70 | 2.60 | 2.53 | 2.47 | 2.43 | 2.39 | 2.36 | 2.33 |
| 24 | 5.72 | 4.32 | 3.72 | 3.38 | 3.16 | 3.00 | 2.87 | 2.78 | 2.70 | 2.64 | 2.54 | 2.47 | 2.41 | 2.37 | 2.33 | 2.30 | 2.27 |
| 26 | 5.66 | 4.27 | 3.67 | 3.33 | 3.11 | 2.95 | 2.82 | 2.73 | 2.65 | 2.59 | 2.49 | 2.42 | 2.36 | 2.31 | 2.28 | 2.24 | 2.22 |
| 28 | 5.61 | 4.22 | 3.63 | 3.29 | 3.06 | 2.90 | 2.78 | 2.69 | 2.61 | 2.55 | 2.45 | 2.37 | 2.32 | 2.27 | 2.23 | 2.20 | 2.17 |
| 30 | 5.57 | 4.18 | 3.59 | 3.25 | 3.03 | 2.87 | 2.75 | 2.65 | 2.58 | 2.51 | 2.41 | 2.34 | 2.28 | 2.23 | 2.20 | 2.16 | 2.14 |
| 32 | 5.53 | 4.15 | 3.56 | 3.22 | 3.00 | 2.84 | 2.72 | 2.62 | 2.54 | 2.48 | 2.38 | 2.31 | 2.25 | 2.20 | 2.16 | 2.13 | 2.10 |
| 34 | 5.50 | 4.12 | 3.53 | 3.19 | 2.97 | 2.81 | 2.69 | 2.59 | 2.52 | 2.45 | 2.35 | 2.28 | 2.22 | 2.17 | 2.14 | 2.10 | 2.08 |
| 36 | 5.47 | 4.09 | 3.51 | 3.17 | 2.94 | 2.78 | 2.66 | 2.57 | 2.49 | 2.43 | 2.33 | 2.25 | 2.20 | 2.15 | 2.11 | 2.08 | 2.05 |
| 38 | 5.45 | 4.07 | 3.48 | 3.15 | 2.92 | 2.76 | 2.64 | 2.55 | 2.47 | 2.41 | 2.31 | 2.23 | 2.17 | 2.13 | 2.09 | 2.06 | 2.03 |
| 40 | 5.42 | 4.05 | 3.46 | 3.13 | 2.90 | 2.74 | 2.62 | 2.53 | 2.45 | 2.39 | 2.29 | 2.21 | 2.15 | 2.11 | 2.07 | 2.04 | 2.01 |
| 42 | 5.40 | 4.03 | 3.45 | 3.11 | 2.89 | 2.73 | 2.61 | 2.51 | 2.44 | 2.37 | 2.27 | 2.20 | 2.14 | 2.09 | 2.05 | 2.02 | 1.99 |
| 44 | 5.39 | 4.02 | 3.43 | 3.09 | 2.87 | 2.71 | 2.59 | 2.50 | 2.42 | 2.36 | 2.26 | 2.18 | 2.12 | 2.07 | 2.03 | 2.00 | 1.97 |
| 46 | 5.37 | 4.00 | 3.42 | 3.08 | 2.86 | 2.70 | 2.58 | 2.48 | 2.41 | 2.34 | 2.24 | 2.17 | 2.11 | 2.06 | 2.02 | 1.99 | 1.96 |
| 48 | 5.35 | 3.99 | 3.40 | 3.07 | 2.84 | 2.69 | 2.57 | 2.47 | 2.39 | 2.33 | 2.23 | 2.15 | 2.09 | 2.05 | 2.01 | 1.97 | 1.94 |
| 50 | 5.34 | 3.98 | 3.39 | 3.05 | 2.83 | 2.67 | 2.55 | 2.46 | 2.38 | 2.32 | 2.22 | 2.14 | 2.08 | 2.03 | 1.99 | 1.96 | 1.93 |
| 52 | 5.33 | 3.96 | 3.38 | 3.04 | 2.82 | 2.66 | 2.54 | 2.45 | 2.37 | 2.31 | 2.21 | 2.13 | 2.07 | 2.02 | 1.98 | 1.95 | 1.92 |
| 54 | 5.32 | 3.95 | 3.37 | 3.03 | 2.81 | 2.65 | 2.53 | 2.44 | 2.36 | 2.30 | 2.20 | 2.12 | 2.06 | 2.01 | 1.97 | 1.94 | 1.91 |
| 56 | 5.31 | 3.94 | 3.36 | 3.02 | 2.80 | 2.64 | 2.52 | 2.43 | 2.35 | 2.29 | 2.19 | 2.11 | 2.05 | 2.00 | 1.96 | 1.93 | 1.90 |
| 58 | 5.30 | 3.93 | 3.35 | 3.02 | 2.79 | 2.64 | 2.52 | 2.42 | 2.34 | 2.28 | 2.18 | 2.10 | 2.04 | 1.99 | 1.95 | 1.92 | 1.89 |
| 60 | 5.29 | 3.93 | 3.34 | 3.01 | 2.79 | 2.63 | 2.51 | 2.41 | 2.33 | 2.27 | 2.17 | 2.09 | 2.03 | 1.99 | 1.94 | 1.91 | 1.88 |
| 62 | 5.28 | 3.92 | 3.34 | 3.00 | 2.78 | 2.62 | 2.50 | 2.40 | 2.33 | 2.26 | 2.16 | 2.09 | 2.03 | 1.98 | 1.94 | 1.90 | 1.87 |
| 64 | 5.27 | 3.91 | 3.33 | 2.99 | 2.77 | 2.61 | 2.49 | 2.40 | 2.32 | 2.26 | 2.16 | 2.08 | 2.02 | 1.97 | 1.93 | 1.90 | 1.87 |
| 66 | 5.26 | 3.90 | 3.32 | 2.99 | 2.77 | 2.61 | 2.49 | 2.39 | 2.31 | 2.25 | 2.15 | 2.07 | 2.01 | 1.96 | 1.92 | 1.89 | 1.86 |
| 68 | 5.25 | 3.90 | 3.32 | 2.98 | 2.76 | 2.60 | 2.48 | 2.39 | 2.31 | 2.24 | 2.14 | 2.07 | 2.01 | 1.96 | 1.92 | 1.88 | 1.85 |
| 70 | 5.25 | 3.89 | 3.31 | 2.98 | 2.75 | 2.60 | 2.47 | 2.38 | 2.30 | 2.24 | 2.14 | 2.06 | 2.00 | 1.95 | 1.91 | 1.88 | 1.85 |

15

\$





(1) Minimum Reliability of the Backflow Prevention System. The backflow prevention system shall have a minimum reliability of 0.80. The minimum reliability shall be the resultant of the quality level of the individual devices and determined by the following equation:

$$R_d = 1 - (P_{u1} \ P_{u2} \ \dots \ P_{un})$$

where

 P_{un} = upper confidence limit, i.e., maximum possible percentage of the individual safety devices subject to backflow in the field under those conditions defined in the life test

 R_d = reliability of the backflow prevention system

(2) *Reliability*. The backflow prevention system shall have a minimum reliability of 0.80. This shall be determined by the following equation:

$$R_d = 1 - P_{un}$$

where

- P_{un} = upper confidence limit, i.e., maximum possible percentage of the individual safety devices subject to backflow in the field under those conditions defined in the life test
- R_d = reliability of the backflow prevention system

REFERENCES

[1] Lipowski, K., H. D. Eichholz, and T. P. Konen. "Backflow Protection at Plumbing Fixture Fittings With Hose Connected Outlets." *Plumbing Engineer* (November/December 1988)

[2] Lipowski, K. and G. Schieweck. "Backflow Protection and Associated Risk for Sanitary Fittings With Hose Connected Outlets." *Technical Proceedings*. American Society of Plumbing Engineers. CIB/W62 International Symposium (Washington, DC: 1992), 43–58

[3] Gibra, I. N. *Probability and Statistical Inference for Scientists and Engineers*. Englewood Cliffs: Prentice-Hall (1973)

[4] Clopper, C. J., and E. S. Pearson. "The Use of Confidence or Fiducial Limits Illustrated in the Case of the Binomial." *Biometrika* 26 (1934), 404



ASME STANDARDS RELATED TO PLUMBING

| Air Gaps in Plumbing Systems. | A112.1.2-1991(R1998) |
|---|--|
| Air Gap Fittings for Use with Plumbing Fixtures, Appliances, and | |
| Appurtenances | A112.1.3-2000 |
| Performance Standard and Installation Procedures for Stainless Steel | |
| Drainage Systems for Sanitary, Storm, and Chemical Applications, | |
| Above and Below Ground | A112.3.1-1993 |
| Macerating Toilet Systems and Related Components | A112.3.4-2000 |
| Water Heater Relief Valve Drain Tubes | A112.4.1-1993(R1998) |
| Plastic Fittings for Connecting Water Closets to the | |
| Sanitary Drainage System | A112.4.3-1999 |
| Point of Use and Branch Water Submetering Systems | A112.4.7-2002 |
| Floor-Affixed Supports for Off-the-Floor Plumbing Fixtures for | |
| Public Use | A112.6.1M-1997 |
| Framing-Affixed Supports for Off-the-Floor Water Closets With | |
| Concealed Tanks | A112.6.2-2000 |
| Floor and Trench Drains | A112.6.3-2001 |
| Enameled and Epoxy Coated Cast Iron and PVC Plastic Sanitary | |
| Floor Sinks | A112.6.7-2001 |
| Backwater Valves | . A112.14.1-1975(R1998) |
| Grease Interceptors | A112.14.3-2000 |
| Grease Removal Devices | A112.4.4-2001 |
| Plumbing Fixture Fittings | A112.18.1-2000 |
| Plumbing Fixture Waste Fittings | A112.18.2-2002 |
| Performance Requirements for Backflow Protection Devices | |
| and Systems in Plumbing Fixture Fittings | A112.18.3-2002 |
| Flexible Water Connectors | A112.18.6-1999 |
| Deck-Mounted Bath/Shower Transfer Valves With Integral | |
| | A112.18.7-1999 |
| Enameled Cast Iron Plumbing Fixtures | 4112.19.1M-1994(R1999) |
| Vitreous China Plumping Fixtures | AII2.19.2W-1998 |
| Stainless Steel Plumbing Fixtures (Designed for Residential Use) | ATTZ.19.3-2000 |
| Trim for Weter Closet Pourle, Tenke, and Urinele | 4112.19.4W-1994(R1999) |
| Hudroulia Parformance Poquiromanta for Water Classic and Urinals | A112 10 6 1005 |
| Which and Bathtub Appliances | A112 10 7M 1005 |
| Suction Eittings for Liss in Swimming Pools, Wading Pools, Space | ATT2.19.7WI-1995 |
| Hot Tube, and Whirlood Bathtub Appliances | A112 10 8M 1087/B1006) |
| Non-Vitreous Ceramic Plumbing Eixtures | A112.19.000-1907(11990) A112.19.900-1907(11990) |
| Dual Flush Devices for Water Closets | Δ112 19 10-1997 |
| Wall Mounted and Pedestal Mounted Adjustable and Pivoting | A112.13.10-1334 |
| Lavatory and Sink Carrier Systems | A112 19 12-2000 |
| Electrohydraulic Water Closets | Δ112 19 13-2001 |
| Six-Liter Water Closets Equipped With a Dual Flushing Device | Δ112 19 1/-2001 |
| Bathtub/Whirlpool Bathtubs With Pressure Sealed Doors | Δ112 19 15-2001 |
| Manufactured Safety Vacuum Release Systems (SVRS) for Residential and | |
| Commercial Swimming Pool Spa Hot Tub and Wading | |
| Pool Suction Systems | A112 19 17-2002 |
| Floor Drains | A112.21.1M-1991(R1998) |
| Roof Drains. | A112.21.2M-1983 |
| Hydrants for Utility and Maintenance Use | A112.21.3M-1985(R1995) |
| Cleanouts | A112.36.2M-1991(R1998) |

The ASME Publications Catalog shows a complete list of all the Standards published by the Society. For a complimentary catalog, or the latest information about our publications, call 1-800-THE-ASME (1-800-843-2763).

ASME Services

ASME is committed to developing and delivering technical information. At ASME's Information Central, we make every effort to answer your questions and expedite your orders. Our representatives are ready to assist you in the following areas:

- ASME Press Codes & Standards Credit Card Orders IMechE Publications Meetings & Conferences Member Dues Status
- Member Services & Benefits Other ASME Programs Payment Inquiries Professional Development Short Courses Publications

Public Information Self-Study Courses Shipping Information Subscriptions/Journals/Magazines Symposia Volumes Technical Papers

How can you reach us? It's easier than ever!

There are four options for making inquiries* or placing orders. Simply mail, phone, fax, or E-mail us and an Information Central representative will handle your request.

| Mail | Call Toll Free | Fax-24 hours | E-Mail-24 hours |
|------------------------|---------------------------|--------------|-----------------|
| ASME | US & Canada: 800-THE-ASME | 973-882-1717 | Infocentral |
| 22 Law Drive, Box 2900 | (800-843-2763) | 973-882-5155 | @asme.org |
| Fairfield, New Jersey | Mexico: 95-800-THE-ASME | | |
| 07007-2900 | (95-800-843-2763) | | |
| | Universal: 973-882-1167 | | |

* Information Central staff are not permitted to answer inquiries about the technical content of this code or standard. Information as to whether or not technical inquiries are issued to this code or standard is shown on the copyright page. All technical inquiries must be submitted in writing to the staff secretary. Additional procedures for inquiries may be listed within.







