

**ASME B73.1-2001**  
[Revision of ASME B73.1M-1991(R1999)]

# **SPECIFICATION FOR HORIZONTAL END SUCTION CENTRIFUGAL PUMPS FOR CHEMICAL PROCESS**

**AN AMERICAN NATIONAL STANDARD**



**The American Society of  
Mechanical Engineers**





The American Society of  
Mechanical Engineers

A N A M E R I C A N N A T I O N A L S T A N D A R D

# **SPECIFICATION FOR HORIZONTAL END SUCTION CENTRIFUGAL PUMPS FOR CHEMICAL PROCESS**

**ASME B73.1-2001**

**[Revision of ASME B73.1M-1991(R1999)]**

Date of Issuance: February 25, 2002

The next edition of this Standard is scheduled for publication in 2006. There will be no addenda or written interpretations of the requirements of this Standard issued to this edition.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,  
in an electronic retrieval system or otherwise,  
without the prior written permission of the publisher.

The American Society of Mechanical Engineers  
Three Park Avenue, New York, NY 10016-5990

Copyright © 2002 by  
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS  
All Rights Reserved  
Printed in U.S.A.

## FOREWORD

In 1955, the Standards Committee on Centrifugal Pumps for Chemical Industry Use, B73, undertook the development of centrifugal pump standards to meet the needs of the chemical industry. Although the Standards Committee had not completed its assignment, the work of one of its task forces resulted in the development of a de facto standard which was published by the Manufacturing Chemists Association in 1962 as an American Voluntary Standard. More than a dozen manufacturers of chemical process pumps have been marketing pumps conforming with the AVS since that time.

In 1965 the Hydraulic Institute published a tentative standard similar in content to the AVS, but updated certain portions. Although the Hydraulic Institute Tentative Standard reflected more nearly the current practice of manufacturers and users, it was believed necessary to publish a new document which would supersede both the original AVS and the tentative standard, and which could incorporate the technical content of both documents, in addition to dimensional criteria and features generally accepted by manufacturers and users. The January 1968 revision of the AVS was therefore approved as an American National Standard under the existing standards method and published as ANSI B123.1-1971.

ANSI B73.1 superseded ANSI B123.1-1971 and was first published in 1974. The 1974 edition brought to 15 the number of pump sizes covered by the standard. Since then, the committee has continued to be active and has added five more sizes for a total of 20, and made a number of revisions in the text of the standard.

Shortly thereafter, the American National Standards Committee B73 undertook to revise the standard, and as a result, new information on baseplate rigidity, bearing frame adapter, and bearing housing drain was introduced. The 1984 edition included, for the first time, information that covered documentation of pump and driver outline drawing of the centrifugal pump, data sheet, mechanical seal drawing, stuffing box piping plans, and cooling/heating piping plans.

The 1991 revision included larger and self-venting tapered seal chambers, as well as conventional stuffing boxes, revised baseplate dimensions, with a new identification numbering system, and a ductile material requirement for the bearing frame adapter if it clamps the rear cover plate to the casing.

With the expanding utilization of the ASME B73.1 pumps in the chemical process industry and its growing acceptance in the hydrocarbons processing industry, the B73 committee has continued to improve the B73.1 standard. This revision of the Standard incorporates 7 new sizes of pumps, bringing the total number to 27. Many of the new additions were at the request of the user population. Although inclusion of "ISO" standard size pumps was entertained, the proposed additions of the "ISO" sizes were rejected by the committee. It was thought that the addition of the "ISO" sizes made the standard overly complex and weakened its mechanical fortitude. The material of construction section of the standard was expanded to include readily available corrosion resistant alloys. Recent publications by the Hydraulic Institute in areas such as baseplate tolerance, acceptable nozzle loads, preferred operating region and NPSH margin have been incorporated into this revision. The former Appendix covering documentation has been established as an integral portion of the Standard. This is in part in response to the needs of the user community for compliance to U.S. Government regulations covering chemical process equipment and pumps specifically OSHA

Process Safety Management, 29 CFR 1910.119. In total, these revisions to the standard are intended to better serve process industries and expand the use of ASME B73 pumps world wide.

Suggestions for improvement in this Standard will be welcome and should be sent to the American Society of Mechanical Engineers, Attn: Secretary B73 Committee, Three Park Ave., New York, NY 10016-5990.

This revision was approved as an American National Standard on September 7, 2001.

## **ASME STANDARDS COMMITTEE B73**

### **Chemical Standard Pumps**

(The following is the roster of the Committee at the time of approval of this Standard.)

#### **OFFICERS**

**R. J. Hart**, *Chair*  
**G. W. Sabol**, *Vice Chair*  
**C. J. Gomez**, *Secretary*

#### **COMMITTEE PERSONNEL**

**B. M. Burkelman**, Ingersoll-Dresser Pumps  
**F. W. Buse**, *Alternate*, Ingersoll-Dresser Pumps  
**G. C. Clasby**, Flowserve Corp., Pump Division  
**J. F. Dolniak**, Eli Lilly & Co.  
**R. W. Estep**, Union Carbide Corp.  
**C. J. Gomez**, The American Society of Mechanical Engineers  
**R. J. Hart**, E.I. DuPont de Nemours & Co.  
**M. T. Henessey**, Flowserve Corp.  
**W. G. Klingberg**, Sterling Fluid Systems  
**E. W. Allis**, *Alternate*, Sterling Fluid Systems  
**T. Matthews**, Dow Chemical Co.  
**R. A. Lewis**, *Alternate*, Dow Chemical Co.  
**R. H. Monroe, Jr.**, Solutia Inc.  
**J. C. Osborne**, AR Wilfley & Sons Inc.  
**J. D. Quill**, ITT Industries — Goulds  
**A. E. Stavale**, *Alternate*, ITT Industries — Goulds  
**J. L. Ryan**, Met-Pro Corp., Dean Pump Division  
**G. W. Sabol**, Union Carbide Corp.  
**M. D. Smith**, Syndyne Corp.  
**D. M. Threlkel**, NEMA

# CONTENTS

Foreword .....	iii
Committee Roster .....	v
<b>1 Scope .....</b>	<b>1</b>
<b>2 Alternative Design .....</b>	<b>1</b>
<b>3 Nomenclature and Definitions .....</b>	<b>1</b>
3.1 Source .....	1
<b>4 Design and Construction Features .....</b>	<b>1</b>
4.1 Pressure and Temperature Limits .....	1
4.2 Flanges .....	1
4.3 Casing .....	1
4.4 Impeller .....	5
4.5 Shaft .....	5
4.6 Shaft Sealing .....	5
4.7 Bearings .....	13
4.8 Materials of Construction .....	13
4.9 Corrosion Allowance .....	13
4.10 Direction of Rotation .....	13
4.11 Dimensions .....	14
4.12 Miscellaneous Design Features .....	14
<b>5 General Information .....</b>	<b>14</b>
5.1 Application .....	14
5.2 Test .....	16
5.3 Nameplates .....	16
<b>6 References .....</b>	<b>17</b>
<b>7 Documentation .....</b>	<b>18</b>
7.1 General .....	18
7.2 Requirements .....	18
7.3 Information .....	18
7.4 Specially Requested Documentation .....	21
<b>Figures</b>	
1 Shaft Sleeve Runout .....	5
2 Mechanical Seal Piping Plans .....	6
3 Cooling and Heating Piping Plans .....	9
4 Typical Seal Arrangements .....	10
5 Cylindrical Seal Chamber .....	11

6	Self-Venting Tapered Seal Chamber .....	11
7	Stuffing Box .....	12
8	Seal Chamber Face Runout .....	12
9	Seal Chamber Register Concentricity .....	12
10	Sample Outline Drawing .....	19

#### **Tables**

1	Pump Dimensions .....	2
2	Baseplate Dimensions .....	4
3	Approximate Performance of Standard Pumps (50 Hz) .....	15
4	Approximate Performance of Standard Pumps (60 Hz) .....	16
5	Minimum Continuous Flow .....	17
6	B73 Standardized Electronic Data Exchange File Specification .....	22

#### **Nonmandatory Appendix**

A	ASME Centrifugal Pump Data Sheet .....	31
---	--	----





# SPECIFICATION FOR HORIZONTAL END SUCTION CENTRIFUGAL PUMPS FOR CHEMICAL PROCESS

## 1 SCOPE

This Standard covers centrifugal pumps of horizontal, end suction single stage, centerline discharge design. This Standard includes dimensional interchangeability requirements and certain design features to facilitate installation and maintenance. It is the intent of this Standard that pumps of the same standard dimension designation from all sources of supply shall be interchangeable with respect to mounting dimensions, size and location of suction and discharge nozzles, input shafts, baseplates, and foundation bolt holes (see Tables 1 and 2).

## 2 ALTERNATIVE DESIGN

Alternate designs will be considered, provided they meet the intent of this Standard and cover construction and performance which are equivalent to and otherwise in accordance with these specifications. All deviations from these specifications shall be described in detail.

## 3 NOMENCLATURE AND DEFINITIONS

### 3.1 Source

All nomenclature and definitions of pump components shall be in accordance with HI 1.1–1.2.

## 4 DESIGN AND CONSTRUCTION FEATURES

### 4.1 Pressure and Temperature Limits

**4.1.1 Pressure Limits.** Pressure limitations shall be stated by the pump manufacturer.

**4.1.1.1** The design pressure of the casing, including stuffing box or seal chamber and gland, shall be at least as great as the pressure-temperature rating of ASME B16.5 or ASME B16.42 Class 150 flanges for the material used.

**4.1.1.2** The design pressure of jackets shall be at least 100 psig (690 kPa gage) at 340°F (170°C). Heating jackets may be required for jacket temperatures

to 500°F (260°C) with a reduction in pressure corresponding to the reduction in yield strength of the jacket material.

**4.1.1.3** Casing, stuffing box, cover or seal chamber, and jackets shall be designed to withstand a hydrostatic test at 1.5 times the maximum design pressure for the particular component and material of construction used (see para. 5.2.1).

**4.1.2 Temperature Limits.** Temperature limitations shall be stated by the pump manufacturer. Pumps should be available for temperatures up to 500°F (260°C). Jacketing and other modifications may be required to meet the operating temperature.

### 4.2 Flanges

Suction and discharge nozzles shall be flanged. Flanges shall conform to ASME B16.5 or ASME B16.42 Class 150 standards except that marking requirements are not applicable and the maximum acceptable tolerance on parallelism of the back of the flange shall be 3 deg and bolt holes may be tapped where noted in Table 1. Through bolt holes are preferred. When tapped holes are supplied, they shall be noted on the outline drawing. As an option, Class 300 flanges in accordance with ASME B16.5 or ASME B16.42 may be offered subject to the manufacturer's casing pressure-temperature limitations. All pumps regardless of flange rating shall conform to the X and Y dimensions shown in Table 1.

### 4.3 Casing

**4.3.1 Drain Connection Boss(es).** Pump casing shall have boss(es) to provide for drain connection(s) in the lowest part of the casing. Boss size shall accommodate 1/2 in. NPT min. Boss(es) shall be drilled and tapped when specified by customer.

**4.3.2 Auxiliary Connection Boss(es).** The suction and discharge nozzles shall have boss(es) for gage connections. Boss size shall accommodate 1/4 in. NPT min., 1/2 in. NPT preferred. Boss(es) shall be drilled and tapped when specified by customer.




TABLE 1 PUMP DIMENSIONS

Dimension Designation	Size; Suction × Discharge × Nominal Impeller Diameter	$CP$	$D$	$2E_1$	$2E_2$	$F$
AA	1.5×1×6 (40×25×150)	17.5 (445)	5.25 (133)	6 (152)	0	7.25 (184)
AB	3×1.5×6 (80×40×150)	17.5 (445)	5.25 (133)	6 (152)	0	7.25 (184)
AC [Note (2)]	3×2×6 (80×50×150)	17.5 (445)	5.25 (133)	6 (152)	0	7.25 (184)
AA [Note (2)]	1.5×1×8 (40×25×200)	17.5 (445)	5.25 (133)	6 (152)	0	7.25 (184)
AB [Note (2)]	3×1.5×8 (80×40×200)	17.5 (445)	5.25 (133)	6 (152)	0	7.25 (184)
A10	3×2×6 (80×50×150)	23.5 (597)	8.25 (210)	9.75 (248)	7.25 (184)	12.5 (318)
A50	3×1.5×8 (80×40×200)	23.5 (597)	8.25 (210)	9.75 (248)	7.25 (184)	12.5 (318)
A60	3×2×8 (80×50×200)	23.5 (597)	8.25 (210)	9.75 (248)	7.25 (184)	12.5 (318)
A70	4×3×8 (100×80×200)	23.5 (597)	8.25 (210)	9.75 (248)	7.25 (184)	12.5 (318)
A05 [Note (2)]	2×1×10 (50×25×250)	23.5 (597)	8.25 (210)	9.75 (248)	7.25 (184)	12.5 (318)
A50	3×1.5×10 (80×40×250)	23.5 (597)	8.25 (210)	9.75 (248)	7.25 (184)	12.5 (318)
A60	3×2×10 (80×50×250)	23.5 (597)	8.25 (210)	9.75 (248)	7.25 (184)	12.5 (318)
A70	4×3×10 (100×80×250)	23.5 (597)	8.25 (210)	9.75 (248)	7.25 (184)	12.5 (318)
A40	4×3×10 (100×80×250)	23.5 (597)	10 (254)	9.75 (248)	7.25 (184)	12.5 (318)
A80 [Note (3)]	6×4×10 (150×100×250)	23.5 (597)	10 (254)	9.75 (248)	7.25 (184)	12.5 (318)
A20 [Note (2)]	3×1.5×13 (80×40×330)	23.5 (597)	10 (254)	9.75 (248)	7.25 (184)	12.5 (318)
A30	3×2×13 (80×50×330)	23.5 (597)	10 (254)	9.75 (248)	7.25 (184)	12.5 (318)
A40	4×3×13 (100×80×330)	23.5 (597)	10 (254)	9.75 (248)	7.25 (184)	12.5 (318)
A80 [Note (3)]	6×4×13 (150×100×330)	23.5 (597)	10 (254)	9.75 (248)	7.25 (184)	12.5 (318)
A90 [Note (3)]	8×6×13 (200×150×330)	33.875 (860)	14.5 (368)	16 (406)	9 (229)	18.75 (476)
A100 [Note (3)]	10×8×13 (250×200×330)	33.875 (860)	14.5 (368)	16 (406)	9 (229)	18.75 (476)
A105 [Note (3)]	6×4×15 (150×100×380)	33.875 (860)	14.5 (368)	16 (406)	9 (229)	18.75 (476)
A110 [Note (3)]	8×6×15 (200×150×380)	33.875 (860)	14.5 (368)	16 (406)	9 (229)	18.75 (476)
A120 [Note (3)]	10×8×15 (250×200×380)	33.875 (860)	14.5 (368)	16 (406)	9 (229)	18.75 (476)
A105 [Note (3)]	6×4×17 (150×100×430)	33.875 (860)	14.5 (368)	16 (406)	9 (229)	18.75 (476)
A110 [Note (3)]	8×6×17 (200×150×430)	33.875 (860)	14.5 (368)	16 (406)	9 (229)	18.75 (476)
A120 [Note (3)]	10×8×17 (250×200×430)	33.875 (860)	14.5 (368)	16 (406)	9 (229)	18.75 (476)

(continued)

**TABLE 1 PUMP DIMENSIONS (CONT'D)**

Dimension Designation	H	O	U [Note (1)]		V Min.	X	Y
			Diameter	Keyway			
AA	0.625 (16)	11.75 (298)	0.875 (22.23)	0.188×0.094 (4.76×2.38)	2 (51)	6.5 (165)	4 (102)
AB	0.625 (16)	11.75 (298)	0.875 (22.23)	0.188×0.094 (4.76×2.38)	2 (51)	6.5 (165)	4 (102)
AC [Note (2)]	0.625 (16)	11.75 (298)	0.875 (22.23)	0.188×0.094 (4.76×2.38)	2 (51)	6.5 (165)	4 (102)
AA [Note (2)]	0.625 (16)	11.75 (298)	0.875 (22.23)	0.188×0.094 (4.76×2.38)	2 (51)	6.5 (165)	4 (102)
AB [Note (2)]	0.625 (16)	11.75 (298)	0.875 (22.23)	0.188×0.094 (4.76×2.38)	2 (51)	6.5 (165)	4 (102)
A10	0.625 (16)	16.5 (420)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	8.25 (210)	4 (102)
A50	0.625 (16)	16.75 (425)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	8.5 (216)	4 (102)
A60	0.625 (16)	17.75 (450)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	9.5 (242)	4 (102)
A70	0.625 (16)	19.25 (490)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	11 (280)	4 (102)
A05 [Note (2)]	0.625 (16)	16.75 (425)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	8.5 (216)	4 (102)
A50	0.625 (16)	16.75 (425)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	8.5 (216)	4 (102)
A60	0.625 (16)	17.75 (450)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	9.5 (242)	4 (102)
A70	0.625 (16)	19.25 (490)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	11 (280)	4 (102)
A40	0.625 (16)	22.5 (572)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	12.5 (318)	4 (102)
A80 [Note (3)]	0.625 (16)	23.5 (597)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	13.5 (343)	4 (102)
A20 [Note (2)]	0.625 (16)	20.5 (520)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	10.5 (266)	4 (102)
A30	0.625 (16)	21.5 (546)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	11.5 (292)	4 (102)
A40	0.625 (16)	22.5 (572)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	12.5 (318)	4 (102)
A80 [Note (3)]	0.625 (16)	23.5 (597)	1.125 (28.58)	0.25×0.125 (6.35×3.18)	2.625 (67)	13.5 (343)	4 (102)
A90 [Note (3)]	0.875 (22)	30.5 (775)	2.375 (60.33)	0.625×0.313 (15.88×7.94)	4 (102)	16 (406)	6 (152)
A100 [Note (3)]	0.875 (22)	32.5 (826)	2.375 (60.33)	0.625×0.313 (15.88×7.94)	4 (102)	18 (457)	6 (152)
A105 [Note (3)]	0.875 (22)	30.5 (775)	2.375 (60.33)	0.625×0.313 (15.88×7.94)	4 (102)	16 (406)	6 (152)
A110 [Note (3)]	0.875 (22)	32.5 (826)	2.375 (60.33)	0.625×0.313 (15.88×7.94)	4 (102)	18 (457)	6 (152)
A120 [Note (3)]	0.875 (22)	33.5 (851)	2.375 (60.33)	0.625×0.313 (15.88×7.94)	4 (102)	19 (483)	6 (152)
A105 [Note (3)]	0.875 (22)	30.5 (775)	2.375 (60.33)	0.625×0.313 (15.88×7.94)	4 (102)	16 (406)	6 (152)
A110 [Note (3)]	0.875 (22)	32.5 (826)	2.375 (60.33)	0.625×0.313 (15.88×7.94)	4 (102)	18 (457)	6 (152)
A120 [Note (3)]	0.875 (22)	33.5 (851)	2.375 (60.33)	0.625×0.313 (15.88×7.94)	4 (102)	19 (483)	6 (152)

**GENERAL NOTES:**

(a) Dimensions in parentheses are approximate equivalents in millimeters.

(b) All other dimensions are in inches.

**NOTES:**

(1) "U" Diameter may be 1.625 in. (41.28 mm) in A05 through A80 sizes to accommodate high torque values.

(2) Discharge flange may have tapped bolt holes.

(3) Suction flange may have tapped bolt holes.

**4.3.3 Support.** The casing shall be supported by feet beneath the casing or a suitable support between the casing and baseplate.

**4.3.4 Disassembly.** The design shall permit back removal of the rotating element from the casing without disturbing the suction and discharge connections or the driver. Tapped holes for jackscrews, or equivalent means, shall be provided to facilitate disassembly of the casing and stuffing box cover or seal chamber and to avoid the necessity of drive wedges or prying implements.

**4.3.5 Jackets**


**4.3.5.1** Jackets for heating or cooling the casing, stuffing box, or seal chamber are optional. Connection

shall be  $\frac{3}{8}$  in. NPT min., with  $\frac{1}{2}$  in. NPT preferred. When a jacket is to be used for heating by steam, the inlet connection shall be located at the top quadrant of the casing, stuffing box, or seal chamber; and the drain connection shall be located at the bottom portion of the casing, stuffing box, or seal chamber to prevent the formation of water pockets. Jackets for water cooling shall have a drain for freeze protection.

**4.3.5.2** There are several available methods of cooling or heating specific areas of most ASME pumps. The following are examples of acceptable methods and should be available as optional features.

(a) Stuffing Box Jacket

(b) Seal Chamber Jacket



## TABLE 2 BASEPLATE DIMENSIONS

Max. NEMA Frame	Baseplate No.	A Min.	HA Max. [Note (2)]	HB	HT Min.	HD Max. [Note (4)]										
						D = 5.25 (133)	D = 8.25 (210)	D = 10 (254)	D = 14.5 (1368)							
139	184T	12 (305)	15 (381)	39 (991)	3.5 (89)	9 (229)	...	...	...	4.5 (114)	36.5 (927)	3.75 (95)	0.75 (19)	4.5 (114)	1.25 (32)	
		15 (381)	18 (457)	48 (1219)	3.5 (89)	10.5 (267)	...	...	...	6 (152)	45.5 (1156)	4.13 (105)	0.75 (19)	4.5 (114)	1.25 (32)	
		18 (457)	21 (533)	53 (1346)	3.5 (89)	12.88 (327)	...	...	...	7.5 (191)	50.5 (1283)	4.75 (121)	0.75 (19)	4.5 (114)	1.25 (32)	
245	184T	12 (305)	15 (381)	45 (1143)	3.5 (89)	...	12 (305)	13.75 (349)	...	4.5 (114)	42.5 (1080)	3.75 (95)	0.75 (19)	4.5 (114)	1.25 (32)	
		15 (381)	18 (457)	52 (1321)	3.5 (89)	...	12.38 (314)	14.13 (359)	...	6 (152)	49.5 (1257)	4.13 (105)	0.75 (19)	4.5 (114)	1.25 (32)	
		18 (457)	21 (533)	58 (1473)	3.5 (89)	...	13 (330)	14.75 (375)	...	7.5 (191)	55.5 (1410)	4.75 (121)	1 (25)	4.5 (114)	1.25 (32)	
264	3365T	18 (457)	21 (533)	64 (1626)	3.5 (89)	...	13.88 (353)	14.75 (375)	...	7.5 (191)	61.5 (1562)	4.75 (121)	1 (25)	4.5 (114)	1.25 (32)	
		22 (559)	26 (660)	68 (1727)	3.5 (89)	...	14.88 (378)	14.88 (378)	...	9.5 (241)	65.5 (1664)	4.75 (121)	1 (25)	4.5 (114)	1.25 (32)	
		280	22 (559)	26 (660)	80 (2032)	3.5 (89)	...	15.88 (403)	15.88 (403)	...	9.5 (241)	77.5 (1969)	4.75 (121)	1 (25)	4.5 (114)	1.25 (32)
368	286T	22 (559)	26 (660)	68 (1727)	5 (1271)	...	...	...	19.25 (489)	9.5 (241)	65.5 (1664)	4.75 (121)	1 (25)	6.5 (165)	1.25 (32)	
		380	22 (559)	26 (660)	80 (2032)	5 (127)	...	...	...	19.25 (489)	9.5 (241)	77.5 (1969)	4.75 (121)	1 (25)	6.5 (165)	1.25 (32)
		398	22 (559)	26 (660)	98 (2489)	5 (127)	...	...	...	19.25 (489)	9.5 (241)	95.5 (2426)	4.75 (121)	1 (25)	6.5 (165)	1.25 (32)

GENERAL NOTES:  
(a) Dimensions in parentheses are approximate equivalents in millimeters.  
(b) All other dimensions are in inches.

NOTES:

- (1) Motor should not extend beyond end of baseplate.
- (2) Contact manufacturer for additional space required for free standing baseplates.
- (3) Baseplate number denotes pump frame 1, 2, or 3 and baseplate *HB* in inches.
- (4) Includes 0.13 in. (3 mm) shimming allowance where motor height controls.

- (c) Pump Casing Jacket
- (d) Bolt on External Heating and Cooling Jacket
- (e) Bearing Housing Cooling

**4.3.6 Gasket(s).** The casing-to-cover gasket shall be confined on the atmospheric side to prevent blowout.

## 4.4 Impeller

**4.4.1 Types.** Impellers of open, semi-open, and closed designs are optional.

**4.4.2 Adjustment.** Means for external adjustment (without disassembly of the pump except for the coupling guard) of the impeller axial clearance shall be provided if adjustment is required by the design.

**4.4.3 Balance.** Impellers shall meet ISO 1940 Grade 6.3 after final machining.

**4.4.4 Attachment.** The impeller may be keyed or threaded to the shaft with rotation to tighten. Shaft threads and keyways shall be protected so they will not be wetted by the pumped liquid.

## 4.5 Shaft

**4.5.1 Diameter.** The seal mounting surface includes the shaft or shaft sleeve outside diameter within the stuffing box or seal chamber and enough length beyond to accommodate outside seals. The diameter of the seal mounting surface shall be sized in increments of  $\frac{1}{8}$  in. (3.2 mm). To provide for the use of mechanical seals, the tolerance on that diameter shall not exceed nominal to minus 0.002 in. (0.05 mm).

**4.5.2 Finish.** Surface finish of the shaft or sleeve through the stuffing box or seal chamber and at rubbing contact bearing housing seals shall not exceed an arithmetic roughness average of 32  $\mu$ in. (0.8  $\mu$ m) unless otherwise required for the mechanical seal.

**4.5.3 Runout.** Shaft runout shall be limited as follows:

- (a) shaft rotated on centers: 0.001 in. (0.025 mm) full indicator movement (FIM) reading at any point;
- (b) outside diameter of shaft or removable sleeve when installed in pump: 0.002 in. (0.05 mm) FIM at the gland end of stuffing box or seal chamber (see Fig. 1).

**4.5.4 Deflection.** Dynamic shaft deflection at the impeller centerline shall not exceed 0.005 in. (0.13 mm) anywhere within the design region as specified




FIG. 1 SHAFT SLEEVE RUNOUT

in para. 5.1.6. Hydraulic loads and shaft deflection shall be calculated in accordance with HI 1.3.

**4.5.5 Running Clearances.** Running clearance must be sufficient to prevent internal rubbing contact within the design region (para. 5.1.6) and is subjected to the maximum allowable flange loads as specified in para. 5.1.2.

**4.5.6 Critical Speed.** The first lateral critical speed of the rotating assembly shall be at least 120% of the maximum operating speed. A “dry critical speed” calculation (see HI 9.6.4) is adequate to verify compliance. HI 9.6.4 shall be used to calculate static deflections used for the critical speed calculation.


**4.5.7 Fillets and Radii.** All shaft shoulder fillets and radii shall be made as large as practical and finished to reduce additional stress risers.

## 4.6 Shaft Sealing


**4.6.1 Design.** Two basic types of sealing covers shall be offered, one called a seal chamber and a second called a stuffing box. The seal chamber is designed to accommodate mechanical seals only and can be of several designs for various types of seals. The design includes a separate gland plate where required. The stuffing box is designed for packing, but may be able to accommodate mechanical seals as an alternative. Figures 2 and 3 show some piping systems that can be used with the various seals shown in Fig. 4. A separate universal cover adapter to accommodate either a seal chamber or stuffing box is optional.

**4.6.2 Seal Chamber.** The seal chamber can be a cylindrical or a tapered design. The tapered bore seal chamber shall have a minimum of a 4 deg taper open toward the pump impeller.




SEAL FLUSH PIPING  
RECIRCULATION OF PUMP FLUID**Plan No. 7301**


Internal recirculation  
from pump case to seal.

**Plan No. 7302**


Dead-ended seal chamber with no  
circulation of flush fluid.

**Plan No. 7311**


Recirculation from pump case through  
orifice to seal.

**Plan No. 7312**

Recirculation from pump case through  
strainer and orifice  
to seal.

**Plan No. 7313**


Recirculation from seal chamber  
through orifice and back to  
pump suction.

**Plan No. 7314**


Recirculation from seal chamber through a  
flow control orifice to the seal and simultaneously  
from the seal chamber through a control orifice  
(if required) to pump suction. Plan 14 is a  
combination of Plan 11 and Plan 13.

**Plan No. 7321**


Recirculation from  
pump case through  
orifice and cooler to seal.

**Plan No. 7322**


Recirculation from pump case through  
strainer, orifice and cooler to seal.

**Plan No. 7323**


Recirculation from seal with pumping  
ring through cooler and back to seal.

**Plan No. 7331**

Recirculation from pump case  
through cyclone separator  
delivering clean fluid to  
seal and fluid with solids  
back to pump suction.

**Plan No. 7332**

Injection to seal from external  
source of clean cool/fluid.  
[Note (1)]

**Plan No. 7341**

Recirculation from pump case through  
cyclone separator delivering clean fluid  
through cooler to seal and fluid with  
solids back to pump suction.

- (FI) Flow indicator
- (FS) Flow Switch
- (LS) Level Switch
- (PI) pressure gage with block valve
- (PS) pressure switch, including block valve, only when specified.
- (TI) dial thermometer, only when specified


## LEGEND

- back pressure regulator
- block valve
- check valve
- flow regulating valve
- cyclone separator


- filter
- heat exchanger
- orifice (removable orifice or an integral pressure breakdown arrangement)
- trap
- Y-type strainer

**FIG. 2 MECHANICAL SEAL PIPING PLANS**


**BUFFER FLUID AND QUENCH PIPING**




**Plan No. 7351**  
Dead-ended blanket




**Plan No. 7352**  
External fluid reservoir for tandem seals.  
thermosyphon or forced circulation,  
as required. [Note (1)]




**Plan No. 7353A**  
Pressurized external barrier fluid  
reservoir supplying clean fluid to  
the seal chamber. Circulation is by  
an internal pumping ring. Reservoir  
pressure is greater than the process  
pressure being sealed.




**Plan No. 7353B**  
External piping provides fluid for the  
outer seal of a pressurized dual seal  
arrangement. Prepressurized bladder  
accumulator provides pressure to the  
circulation system. Flow is maintained  
by an internal pumping ring. Heat is  
removed from the circulation system  
by an air-cooled or water-cooled heat  
exchanger.




**Plan No. 7353C**  
External piping provides fluid for the  
outer seal of a pressurized dual seal  
arrangement. Reference line from the  
seal chamber to a piston accumulator  
provides pressure to the circulation  
system. Flow is maintained by an  
internal pumping ring. Heat is removed  
from the circulation system by an air-  
cooled or water-cooled heat exchanger.



**Plan No. 7354**  
Circulation of clean buffer  
fluid from an external  
source. [Note (1)]




**Plan No. 7361**  
Tapped connections for user's use.  
Note (1) shall apply when user is to  
supply fluid (steam, gas, water, other)  
to auxiliary sealing device.



**Plan No. 7362**  
External fluid quench  
(steam, gas, water, other)  
[Note (1)]

**FIG. 2 MECHANICAL SEAL PIPING PLANS (CONT'D)**

**MATERIALS OF CONSTRUCTION**


- Code A (a) Tubing: carbon steel,  $\frac{3}{8}$  in. O.D. x 0.035 in. wall ASTM A 519;  
(b) Tube Fittings: carbon steel, bite type.
- Code B (a) Tubing: 316 stainless steel,  $\frac{3}{8}$  in O.D. x 0.035 in. wall, ASTM A 269;  
(b) tube Fittings: 316 stainless steel, bite type.
- Code C (a) Pipe: carbon steel,  $\frac{3}{8}$  in. nominal Schedule 40, ASTM A 106;  
(b) Pipe Fittings: carbon steel, 150 deg ASTM A 105.
- Code D (a) Pipe: 316 stainless steel,  $\frac{3}{8}$  in. nominal Schedule 40, ASTM A 312;  
(b) Pipe Fittings: 316 stainless steel, 150 deg ASTM A 182.
- Code E (a) Tubing: armored TFE resin with suitable alloy fittings, design pressure of 350 psi (2413 kPa) at 500 °F (260 °C).
- Code F (a) Other (specify).

**GENERAL NOTE:** These plans represent commonly used systems. Other variations are available and should be specified in detail.

**NOTE:**


- (1) User shall specify fluid characteristics when supplemental seal fluid is provided. manufacturer shall specify the required flow rate and pressure where these are factors.

**FIG. 2 MECHANICAL SEAL PIPING PLANS (CONT'D)**




GENERAL NOTE: Flow indications are optional, furnished only when specified.

**FIG. 3 COOLING AND HEATING PIPING PLANS**




## Single Mechanical Seal – S

Unbalanced (as is sketches) or balanced with or without circulation or injection to the sealed faces. With or without throat bushing. See Note (1).




## Multiple Mechanical Seal – D

Either or both may be unbalanced or balanced. See Note (1).



## Quench Arrangement –G

For soft packing, single and double mechanical seal.




## GENERAL NOTES:

- (a) Liquid quench – in at bottom, out at top
- (b) Steam or gas quench – in at top, out at bottom

## NOTE:

- (1) Add “C” to “S” or “D” for cartridge arrangement.

**FIG. 4 TYPICAL SEAL ARRANGEMENTS**



Lead chamfer for o-ring and  
other sealing devices

Dimension Designation	Radial Clearance x Min.
AA – AB	$x = \frac{3}{4}$ in. (19.05 mm)
A05 – A80	$x = \frac{7}{8}$ in. (22.22 mm)
A90 – A120	$x = 1.0$ in. (25.40 mm)

**FIG. 5 CYLINDRICAL SEAL CHAMBER**


The seal chamber shall be designed to incorporate the details quantified in Figs. 5 and 6.

The secondary seal contact surface(s) shall not exceed a roughness of 63  $\mu$ in. (1.6  $\mu$ m). Seal chamber bore corners and entry holes, such as those used for flushing or venting, shall be suitably chamfered or rounded to prevent damage to secondary seals at assembly.

The seal chamber shall include means of eliminating trapped air or gas. Vent connections, when required for this purpose, shall be located at the highest practical point; drains, when provided, shall be located at the lowest practical point. The location of piping connections to the seal chamber for other functions is optional.

Cartridge seals may center on the shaft and not pilot on the seal chamber.

Pumps equipped with seal chambers experience increased process fluid velocity in the seal chamber and



Lead chamfer for o-ring and  
other sealing devices

Dimension Designation	Radial Clearance x Min.
AA – AB	$x = \frac{3}{4}$ in. (19.05 mm)
A05 – A80	$x = \frac{7}{8}$ in. (22.22 mm)
A90 – A120	$x = 1.0$ in. (25.40 mm)

**FIG. 6 SELF-VENTING TAPERED SEAL CHAMBER**


mechanical seal gland area. Any particles in the process fluid, including fluids described as clear that have incidental particles, can collect in this area and cause erosion. Contact the pump manufacturer for solutions that extend the life of the seal chamber and mechanical seal gland.

The size of all piping connections to the seal and seal gland shall be  $\frac{1}{4}$  in. NPT min. with  $\frac{1}{2}$  in. NPT preferred.

**4.6.3 Seal Chamber Runout.** Mechanical seal performance is highly dependent on the runout conditions that exist at the mechanical seal chamber. Pump shall be designed for compliance with the runout limits shown below. On smaller sizes, the actual measurement of these runout values may not be possible or practical on an assembled pump. Types of runout having significant effect on seal performance include:

(a) *Seal Chamber Face Runout.* This is a measure of the squareness of the seal chamber face with respect





**Dimension  
Designation**

AA – AB  
A05 – A80  
A90 – A120

**Radial Clearance  
x Min.**

$x = \frac{5}{16}$  in. (7.94 mm)  
 $x = \frac{3}{8}$  in. (9.52 mm)  
 $x = \frac{7}{16}$  in. (11.11 mm)


**FIG. 7 STUFFING BOX**

to the pump shaft. It is measured by mounting a dial indicator on the pump shaft and measuring FIM at the face of the seal chamber. The maximum allowable runout is 0.003 in. (0.08 mm) FIM (see Fig. 8).


(b) *Seal Chamber Register Runout.* Provisions shall be made for centering the gland with either an inside or outside diameter register. This register shall be concentric with the shaft or sleeve within 0.005 in. (0.13 mm) FIM (see Fig. 9).

**4.6.4 Stuffing Box.** The stuffing box packing bore surface shall not exceed a roughness of 63  $\mu$ in. (1.6  $\mu$ m). One lantern ring connection shall be provided. A second connection and the location of piping connections to the stuffing box and gland are optional. The size shall be  $\frac{1}{4}$  in. NPT min., with  $\frac{1}{2}$  in. NPT preferred. Registers shall maintain the stuffing box bore concentric with the axis of the pump shaft within 0.005 in. (0.13 mm) FIM and the stuffing box face perpendicular to

**SPECIFICATION FOR HORIZONTAL END SUCTION  
CENTRIFUGAL PUMPS FOR CHEMICAL PROCESS**



**FIG. 8 SEAL CHAMBER FACE RUNOUT**



**FIG. 9 SEAL CHAMBER REGISTER  
CONCENTRICITY**

the axis of the assembled pump shaft within 0.003 in. (0.08 mm) FIM. Figure 7 shows the recommended stuffing box dimensions.

The box also shall be suitable for proper installation and operation of mechanical seals, including means of eliminating trapped air or gas at the highest practical point.

**4.6.5 Space Requirements**

**4.6.5.1** Space in the various seal chamber designs shall provide for one or more of the following configurations of cartridge or noncartridge seals:

- (a) single inside mechanical seal, balanced or unbalanced, with or without a throat bushing, and with or without a throttle bushing
- (b) double seal, balanced or unbalanced inboard and outboard
- (c) outside mechanical seal, balanced or unbalanced, with or without a throat bushing
- (d) tandem seals, either balanced or unbalanced
- (e) gas seals

**4.6.5.2** Space in the stuffing box and exterior clearance area shall provide for:

(a) five rings of packing plus a lantern ring and repacking space

(b) throat bushing, a lantern ring, and three rings of packing

#### 4.6.6 Gland

**4.6.6.1 Bolting.** Pumps shall be designed for four gland bolts, but glands shall be:

(a) two-bolt or four-bolt for packing

(b) four-bolt for mechanical seals

Minimum bolt sizes are as follows:

Pump Length, <i>CP</i>	Gland Bolt Size
17½ in. (445 mm)	¾ in
23½ in. (597 mm)	¾ in
33¾ in. (860 mm)	1½ in

**4.6.6.2 Gasket.** The gland-to-seal chamber gasket or *O*-ring used for mechanical seals shall be confined on the atmospheric side to prevent blowout. It is acceptable for cartridge seals to pilot off of the shaft and not require a register fit to the seal chamber.

**4.6.6.3 Materials of Construction.** The mechanical seal gland shall be 316 SS minimum. Reference ASTM A 276 for glands made from wrought bar and ASTM A 744 (CF8M) for glands made from castings. Other materials shall be the purchaser's option.

#### 4.7 Bearings

**4.7.1 Design.** Two antifriction bearing assemblies shall be provided, one assembly free to float within the frame to carry radial loading only, and the other assembly arranged to carry both radial loading and axial thrust.

**4.7.2 Life.** Bearings shall be selected in accordance with ABMA 9, ABMA 11, and ISO 281. The minimum  $L'_{10h}$  bearing life shall be 17,500 hr in the design region as defined in para. 5.1.6 and for all standard and optional arrangements of bearings, lubrication, shafts, covers, sealing, and impellers.

**4.7.3 End Play.** End play of the shaft from the thrust bearing and its assembly due to internal bearing clearances and tolerances shall be a minimum to maximize seal and bearing life.

**4.7.4 Sealing.** Bearing housing shall be constructed to protect the bearings from water, dust, and other contaminants. The design shall allow for the use of lip seals, labyrinths or magnetic oil seals, as appropriate, for bearing housing end seals.

**4.7.5 Lubrication.** Oil lubrication is standard. Bearing housings for oil bath lubrication shall be provided with a level indicator which is capable of optionally being installed on either or both sides of the bearing housing. A constant level oil feed regulator shall be available, and when provided, be set initially by the manufacturer for the proper level during operation. The proper oil level shall be indicated on the outside of the bearing housing. Other methods of lubrication may be specified, such as oil mist, greased-for-life, or re-greaseable lubrication and, when provided, the necessary additional taps shall be provided.

**4.7.6 Drain.** Bearing housing shall be provided with tapped and plugged drain hole at its lowest point. When replacement grease is specified, a means for grease relief shall be provided.

#### 4.8 Materials of Construction

The identifying material of a pump shall be that of which the major pumpage-wetted parts are constructed. Pump should be available with the following material of construction:

Material	Material Specification
Cast ductile iron	ASTM A 395 (for pressure containing parts) ASTM A 395 or A 536 for non-pressure containing parts
Cast carbon steel	ASTM A 216 - Grade WCB
Cast high alloy steel (similar to 316 stainless steel)	ASTM A 744 - Grade CF8M
Cast Alloy 20	ASTM A 744 - Grade CN7M
Other	Optional

No repair by plugging, peening, or impregnation is allowed on any pressure containing, wetted metal parts.

#### 4.9 Corrosion Allowance

The casing, cover, and gland shall have a corrosion allowance of at least 0.12 in. (3.2 mm).

#### 4.10 Direction of Rotation

Direction of rotation shall be clockwise when viewed from the coupling end. An arrow showing the direction of rotation shall be provided, either cast on the casing

or stamped on a plate of durable construction affixed to the pump in a prominent location.

#### 4.11 Dimensions

Pump dimensions shall conform to Table 1. Baseplate dimensions shall conform to Table 2.

#### 4.12 Miscellaneous Design Features

**4.12.1 Safety Guards.** As a minimum a coupling guard in accordance with ASME B15.1 shall be furnished on all units that include a pump and driver mounted on a common baseplate. An auxiliary device to control spray from stuffing box/seal chamber leakage shall be provided when specified. Local regulations may require additional guards.

**4.12.2 Threads.** All threaded parts, such as bolts, nuts, and plugs, shall conform to ANSI standards.

**4.12.3 Lifting Rings.** A lifting ring or other equivalent device shall be provided to facilitate handling the frame and associated assembly if its mass exceeds 60 lb (27 kg). The frame assembly lifting ring must not be used to lift the entire pump or assembly.

Eyebolts on motors are not suitable for lifting the entire pump and motor assembly. The pump manufacturer's manual shall provide lifting instructions.

**4.12.4 Tapped Openings.** All tapped openings, including those in the mechanical seal gland which may be exposed to the pumped fluid under pressure, shall be plugged with threaded metal plugs. Plugs normally in contact with the pumped fluid shall be of the same material as the casing, except that carbon steel plugs may be used in ductile iron pumps. Threaded plugs shall not be used in the heating or cooling jackets, including glands with heating or cooling passages; instead, snap-in plugs or waterproof tape shall be used to relieve possible pressure accumulation until piping is installed.

All tapped openings in the mechanical seal gland shall be identified to designate their purpose. This designation should be cast or stamped immediately adjacent to the opening. The markings shall be in accordance with para. 7.3.1. When a steam quench is specified, the inlet connection shall be located at the top quadrant of the mechanical seal gland, and the drain connection shall be located at the bottom position of the mechanical seal gland to prevent the formation of water pockets.

**4.12.5 Identification.** The manufacturer's part identification number and material designation shall be cast or clearly die stamped or engraved on the casing, cover, and impeller.

**4.12.6 Adapter.** The bearing frame adapter shall be designed to resist a torque at least as high as the ultimate torque strength of the pump shaft at the coupling end.

The frame adapter or adapter ring, when it clamps the rear cover plate to the pump casing, shall be made of a material which is classified as ductile throughout the full range of operating temperatures, such as cast ductile iron or cast carbon steel.

**4.12.7 Baseplates.** Baseplates shall be designed according to HI 1.3, para. 1.3.4. Baseplates which are to be freestanding (foot or spring supported rather than held by anchor bolts and grouted) shall be so structurally rigid as to limit the movement of the driver shaft relative to the pump shaft to 0.002 in. (0.05 mm) parallel offset when the driver torque of nameplate horsepower is applied.

### 5 GENERAL INFORMATION

#### 5.1 Application

**5.1.1 Terminology.** Terminology shall be in accordance with HI 1.1–1.2.

**5.1.2 Flange Loading.** Allowable flange loading imposed by the piping shall be in accordance with HI 9.6.2.

**5.1.3 Sound.** The maximum sound pressure level produced by the pump and driver shall comply with the limit specified by the customer. Test, if specified, shall be conducted in accordance with the standards of HI 9.1/9.5, para. 9.4. Driver noise data must be determined separately.

**5.1.4 Vibration.** The vibration level measured on the pump bearing housing at the manufacturer's test facility at rated condition point (speed  $\pm 5\%$ , flow  $\pm 5\%$ ) shall not exceed twice the limits shown in Fig. 9.6.4.4 of HI 9.6.4.

**5.1.5 Hydraulic Coverage.** Tables 3 and 4 show the approximate hydraulic coverage for 50 and 60 Hz.

**5.1.6 Operating Region.** Pumps shall be designed to operate continuously between 110% of best efficiency flow and the minimum flows shown on Table 5, unless

**TABLE 3 APPROXIMATE PERFORMANCE OF STANDARD PUMPS (50 Hz)**

Dimension Designation	Size; Suction × Discharge × Nominal Impeller Diameter	1450 rpm				2000 rpm			
		Capacity		Total Head		Capacity		Total Head	
		gpm	m <sup>3</sup> /h	ft	m	gpm	m <sup>3</sup> /h	ft	m
AA	1.5×1×6	31	7.0	22	6.7	62	14.2	86	26.5
AB	3×1.5×6	62	14.2	22	6.7	125	28.3	86	26.5
AC	3×2×6	104	23.7	22	6.7	217	47.3	86	26.5
A10	3×2×6	104	23.7	22	6.7	208	47.2	86	26.5
AA	1.5×1×8	42	9.4	44	13.3	83	18.9	174	52.9
AB	3×1.5×8	83	18.9	44	13.3	167	37.8	174	52.9
A50	3×1.5×8	83	18.9	44	13.3	167	37.8	174	52.9
A60	3×2×8	125	28.3	44	13.3	250	56.7	174	52.9
A70	4×3×8	208	47.2	44	13.3	417	94.6	174	52.9
A05	2×1×10	42	9.4	61	18.6	83	18.9	243	74.1
A50	3×1.5×10	83	18.9	61	18.6	167	37.8	243	74.1
A60	3×2×10	125	28.3	61	18.6	250	56.7	243	74.1
A70	4×3×10	250	56.7	61	18.6	500	113.4	243	74.1
A40	4×3×10	417	94.6	61	18.6	542	123	243	74.1
A80	6×4×10	830	188.6	61	18.6	1077	244.8	243	74.1
A20 [Note (1)]	3×1.5×13	166	37.7	104	31.7	331	73.2	412	123.6
A30 [Note (1)]	3×2×13	250	56.7	104	31.7	456	103.6	378	115.2
A40 [Note (1)]	4×3×13	500	113.6	104	31.7	704	160	275	83.3
A80	6×4×13	911	207	104	31.7	...	...	...	...
A90	8×6×13	1666	378.2	94	28.7	...	...	...	...
A100	10×8×13	2917	662.2	94	28.7	...	...	...	...
A105	6×4×15	1250	284.2	139	42.4	...	...	...	...
A110	8×6×15	1666	348.2	137	42.4	...	...	...	...
A120	10×8×15	2917	662.2	137	42.4	...	...	...	...
A105	6×4×17	1500	340.8	174	52.8	...	...	...	...
A110	8×6×17	2500	568.3	174	52.8	...	...	...	...
A120	10×8×17	3333	757.5	156	47.9	...	...	...	...

GENERAL NOTE: This Standard does not cover exact hydraulic performance of pumps. Information on approximate head and capacity at the best efficiency point for standard pumps is for general information only. Consult manufacturers regarding hydraulic performance data for specific applications.

NOTE:

(1) Maximum impeller diameter may be limited due to limitations of pump's rotor assembly.

specifically noted otherwise by the manufacturer, and meet the requirements of para. 4.5.4 (shaft deflection), para. 4.7.2 (bearing life) and para. 5.1.4 (vibration) when pumping water at ambient conditions.

**CAUTION:** The values in Table 5 do not consider minimum thermal flow for a specific installation; therefore, the practical minimum operating flow may be higher than shown. Pumpage is heated as it goes through a pump and the minimum thermal flow is that where the temperature rises enough through the pump that recirculation of some of the flow reduces the available net positive suction head below that required by the pump, resulting in cavitation or vaporization of the pumped liquid. Refer to HI 1.3, for detailed application information.

**5.1.7 NPSH Margin.** An operating NPSH margin is necessary to ensure satisfactory operation. A minimum margin of 3 ft (0.9 m) or a margin ratio of 1.2 (whichever yields a higher NPSH requirement) should be made available. This margin should be increased if variables exist that will increase the NPSH-Required of the pump. Refer to HI 9.6.1 for additional application information.

**5.1.8 Performance Curves.** Published performance curves in written or electronic format shall be based on tests conducted in accordance with HI 1.6, so the performance shall meet acceptance level "A".

**TABLE 4 APPROXIMATE PERFORMANCE STANDARD PUMPS (60 Hz)**

Dimension Designation	Size; Suction × Discharge × Nominal Impeller Diameter	1750 rpm				3500 rpm			
		Capacity		Total Head		Capacity		Total Head	
		gpm	m <sup>3</sup> /h	ft	m	gpm	m <sup>3</sup> /h	ft	m
AA	1.5×1×6	37	8.4	32	9.8	75	17	125	38.1
AB	3×1.5×6	75	17	32	9.8	150	34	125	38.1
AC	3×2×6	125	28.4	32	9.8	250	56.7	125	38.1
A10	3×2×6	125	28.4	32	9.8	250	56.7	125	38.1
AA	1.5×1×8	50	11.3	63	19.2	100	22.7	250	76.2
AB	3×1.5×8	100	22.7	63	19.2	200	45.4	250	76.2
A50	3×1.5×8	100	22.7	63	19.2	200	45.4	250	76.2
A60	3×2×8	150	34	63	19.2	300	68.1	250	76.2
A70	4×3×8	250	56.7	63	19.2	500	113.5	250	76.2
A05	2×1×10	50	11.3	88	26.8	100	22.7	350	106.7
A50	3×1.5×10	100	22.7	88	26.8	200	45.4	350	106.7
A60	3×2×10	150	34	88	26.8	300	68.1	350	106.7
A70	4×3×10	300	68.1	88	26.8	600	136.2	350	106.7
A40 [Note (1)]	4×3×10	500	113.6	88	26.8	650	147.7	350	106.7
A80 [Note (1)]	6×4×10	1000	227	88	26.8	1300	295	350	106.7
A20 [Note (1)]	3×1.5×13	200	45.4	150	45.7	400	90.9	600	182.6
A30 [Note (1)]	3×2×13	300	68.1	150	45.7	500	114	550	167.6
A40 [Note (1)]	4×3×13	600	136.4	150	45.7	850	193.2	400	121.9
A80	6×4×13	1100	250	150	45.7	...	...	...	...
A90	8×6×13	2000	454	135	41	...	...	...	...
A100	10×8×13	3500	796	135	41	...	...	...	...
A105	6×4×15	1500	341	200	61	...	...	...	...
A110	8×6×15	2000	455	200	61	...	...	...	...
A120	10×8×15	3500	796	200	61	...	...	...	...
A105	6×4×17	1800	409	250	76	...	...	...	...
A110	8×6×17	3000	682	250	76	...	...	...	...
A120	10×8×17	4000	909	225	69	...	...	...	...

GENERAL NOTE: This Standard does not cover exact hydraulic performance of pumps. Information on approximate head and capacity at the best efficiency point for standard pumps is for general information only. Consult manufacturers regarding hydraulic performance data for specific applications.

NOTE:

(1) Liquid end may be modified for this condition or maximum impeller diameter may be limited due to limitations of rotor system.

## 5.2 Test

**5.2.1 Hydrostatic.** After machining, casings, covers, and jackets shall be hydrostatically tested for 10 min min. with water at 1.5 times the maximum design pressure corresponding to 100°F (38°C) for the material of construction used. No leakage through the part shall be permitted.

**5.2.2 Performance.** When performance tests are required, they shall be conducted in accordance with HI 1.6, level “A”. A complete written record of the

relevant test information including performance curves, the date of the tests, and the signature of the person(s) responsible for conducting the tests shall be delivered as part of the pump documentation.

**5.2.3 Mechanical.** When mechanical tests are required, they shall be conducted in accordance with HI 1.6, para. 1.6.7.

## 5.3 Nameplates

Nameplate(s) shall be of 24 U.S. Std. Gage (minimum) AISI 300 series stainless steel and shall be

**TABLE 5 MINIMUM CONTINUOUS FLOW**

Dimension Designation	Size; Suction × Discharge × Nominal Impeller Diameter	Minimum Continuous Flow, % <i>BEP</i> [Note (1)]	
		3500/2900 rpm 60/50 Hz	1750/1450 rpm 60/50 Hz
AA	1.5×1×6	15	10
AB	3×1.5×6	15	10
AC	3×2×6	20	10
AA	1.5×1×8	20	10
AB	3×1.5×8	20	10
A10	3×2×6	20	10
A50	3×1.5×8	20	10
A60	3×2×8	20	10
A70	4×3×8	20	10
A05	2×1×10	25	10
A50	3×1.5×10	25	10
A60	3×2×10	30	15
A70	4×3×10	30	15
A40	4×3×10	30	15
A80	6×4×10	40	20
A20	3×1.5×13	30	15
A30	3×2×13	40	15
A40	4×3×13	40	40
A80	6×4×13	...	40
A90	8×6×13	...	40
A100	10×8×13	...	40
A105	6×4×15	...	50
A110	8×6×15	...	50
A120	10×8×15	...	50
A105	6×4×17	...	50
A110	8×6×17	...	50
A120	10×8×17	...	50

GENERAL NOTE: See para. 5.1.6 for caution using values in this table.

NOTE:

- (1) Limits refer to actual hydraulic performance, not the approximate values in Tables 3 and 4.  
Consult Manufacturers regarding hydraulic performance data for specific applications.

securely attached to the pump. It shall include pump model, standard dimension designation, serial number, size, impeller diameter (maximum and installed), material of construction, and maximum design pressure for 100°F (38°C).

## 6 REFERENCES

The following documents form a part of this Standard to the extent specified herein. The latest edition shall apply.

ABMA 9, Load Ratings and Fatigue Life for Ball Bearings<sup>1</sup>  
ABMA 11, Load Ratings and Fatigue Life for Roller Bearings<sup>1</sup>

Publisher: American Bearing Manufacturers Association  
(ABMA), 2025 M Street, Washington, DC 20036

ASME B15.1, Safety Standard for Mechanical Power  
Transmission Apparatus

ASME B16.5, Pipe Flanges and Flanged Fittings

<sup>1</sup> May also be obtained from American National Standards Institute  
(ANSI), 11 West 42nd Street, New York, NY 10036.



ASME B16.42, Ductile Iron Pipe Flanges and Flanged Fittings: Class 150 and 300

Publisher: The American Society of Mechanical Engineers (ASME), Three Park Avenue, New York, NY 10016

ASTM A 105/A 105M, Standard Specification for Carbon Steel Forgings for Piping Applications<sup>1</sup>

ASTM A 106, Standard Specification for Seamless Carbon Steel Pipe for High-Temperature Service<sup>1</sup>

ASTM A 216/A 216M, Standard Specification for Steel Castings, Carbon, Suitable for Fusion Welding, for High Temperature Service<sup>1</sup>

ASTM A 269, Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service<sup>1</sup>

ASTM A 276, Standard Specification for Stainless Steel Bars and Shapes<sup>1</sup>

ASTM A 312/A 312M, Standard Specification for Seamless and Welded Austenitic Stainless Steel Pipes<sup>1</sup>

ASTM A 395, Standard Specification for Ferritic Ductile Iron Pressure-Retaining Castings for Use at Elevated Temperatures<sup>1</sup>

ASTM A 519, Standard Specification for Seamless Carbon and Alloy Steel Mechanical Tubing<sup>1</sup>

ASTM A 536, Standard Specification for Ductile Iron Castings<sup>1</sup>

ASTM A 744/A 744M, Standard Specification for Castings, Iron-Chromium-Nickel, Corrosion Resistant, for Severe Service<sup>1</sup>

Publisher: American Society for Testing and Material (ASTM), 100 Barr Harbor Drive, West Conshohocken, PA 19428

HI 1.1–1.2, Centrifugal Pumps — Nomenclature and Definitions<sup>1</sup>

HI 1.3, Centrifugal Pumps — Design and Applications<sup>1</sup>

HI 1.6, Centrifugal Pump Tests<sup>1</sup>

HI 9.1–9.5, Pumps — General Guidelines<sup>1</sup>

HI 9.6.1, Centrifugal and Vertical Pumps — NPSH Margin<sup>1</sup>

HI 9.6.4, Centrifugal and Vertical Pumps — Vibration Measurement and Allowable Values<sup>1</sup>

HI 9.6.2, Centrifugal & Vertical Pumps — Allowable Nozzle Loads<sup>1</sup>

Publisher: Hydraulic Institute (HI), 9 Sylvan Way, Parsippany, NJ 07054-3802

ISO 281, Rolling Bearings — Dynamics Load Ratings and Rating Life

ISO 1940, Balance Quality Requirements of Rigid Rotors

Publisher: International Organization for Standardization (ISO), 1 rue de Varembe, Case Postale 56, CH-1211 Genève 20, Switzerland/Suisse

## 7 DOCUMENTATION

### 7.1 General

The documentation specified covers the minimum required to provide clear communication between the pump user and pump manufacturer and to facilitate the safe design, installation, and operation of the pump. Additional data, as required for specific purposes, shall be available, if requested. It is the intent that information be furnished in a similar form from all sources to improve clarity and foster efficient utilization of the documentation.

### 7.2 Requirements

The following documents shall be supplied for each. There can be a difference between proposal and purchase documents:

- (a) Pump and driver outline drawing.
- (b) Centrifugal pump data sheet.
- (c) Mechanical seal drawing (if applicable).
- (d) Mechanical seal piping drawing (if applicable).
- (e) Vendor's cooling/heating piping drawing (if applicable).
- (f) Performance curve with rated point.
- (g) Cross-section drawing with parts list.
- (h) Instruction manual.
- (i) Coupling data.
- (j) If specified, certificate of compliance of ASME B73.1 with purchaser's specification.

### 7.3 Information

A description of each document is as follows.

#### 7.3.1 Pump and Driver Outline Drawing

(a) The pump and driver outline drawing may contain all information shown on and may be arranged as the sample outline drawing included herein and identified as Fig. 10.

(b) Tapped openings, when supplied, shall be identified with the following markings:

<sup>1</sup> May also be obtained from American National Standards Institute (ANSI), 11 West 42nd Street, New York, NY 10036.

Pump Size \_\_\_\_\_ Model \_\_\_\_\_ Brg. Frame \_\_\_\_\_

**Flange Holes**

**Suction** Thru ☐ Thru ☐ Tapped ☐ Tapped ☐

**Discharge** Thru ☐ Thru ☐ Tapped ☐ Tapped ☐

☐ Class 150 flanges

☐ Class 300 flanges

☐ Flat face flanges

☐ Raised face flanges

**Type of Baseplate**

☐ Steel ☐ With driprim

☐ Cast Iron ☐ With driprim

☐ Adjustable foot supports

☐ Grouted

**Lubrication of Bearings**

☐ Oil

Type of oil lubricator \_\_\_\_\_

☐ Pure mist

☐ Oil mist

☐ Grease

☐ Grease - lubed for life

**Shaft Type**

☐ Plain

☐ Sleeved

☐ Jacketed

☐ Traced

**Motor Specifications**

Mfr. \_\_\_\_\_

☐ Single ☐ Dual

☐ Cartridge ☐ Pressurized

hp \_\_\_\_\_ s.f. \_\_\_\_\_

rpm \_\_\_\_\_

Enclosure \_\_\_\_\_

Voltage \_\_\_\_\_

Hertz \_\_\_\_\_

Phase \_\_\_\_\_

For piping B/M, see drawing

No. \_\_\_\_\_

**Coupling Specifications**

Pump \_\_\_\_\_

Mfr. \_\_\_\_\_

Type \_\_\_\_\_

Size \_\_\_\_\_

Baseplate (incl. Cplg. & Guard) \_\_\_\_\_

Bore \_\_\_\_\_

Driver \_\_\_\_\_

No. rings \_\_\_\_\_

Size \_\_\_\_\_

**Mechanical Seal Specifications**

Mfr. \_\_\_\_\_

☐ Single ☐ Dual

☐ Cartridge ☐ Pressurized

☐ Bellows

Model \_\_\_\_\_

Code \_\_\_\_\_

Dwg. No. \_\_\_\_\_

For piping B/M, see drawing

No. \_\_\_\_\_

**Motor** ☐ Motor ☐ Furnished by ☐ Others ☐ Pump mfg. ☐ Pump mfg.

**Coupling** ☐ Coupling ☐ Furnished by ☐ Others ☐ Pump mfg. ☐ Pump mfg.

**Coupling Guard** ☐ Coupling Guard ☐ Furnished by ☐ Others ☐ Pump mfg. ☐ Pump mfg.

**Usage Nomenclature**

A = piped by manufacturer

B = piped by user

C = plugged by manufacturer

D = Open (warning-remove shipping plug)

E = other

**Customer / user**

Location \_\_\_\_\_

Customer P.O. no. \_\_\_\_\_ Ser. no. \_\_\_\_\_

Item no. \_\_\_\_\_ Equip. no. \_\_\_\_\_

Factory order no. \_\_\_\_\_ Date \_\_\_\_\_

Certified by \_\_\_\_\_ Date \_\_\_\_\_

Rev. \_\_\_\_\_

Drawing is not to scale.

All dimensions are in inches.

Weights are approximate.

Dwg. No. \_\_\_\_\_

FIG. 10 SAMPLE OUTLINE DRAWING

Marking	Purpose
I	Casing Drain
II	Discharge Gage or Flush Connection
III	Suction Gage or Flush Connection
X	Oil Drain
XI	Bearing Frame Cooling
F	Mechanical Seal Flush or Lantern Ring
FI	Flush Inlet
FO	Flush Outlet
BI	Barrier/Buffer Fluid Inlet
BO	Barrier/Buffer Fluid Outlet
V	Vent
D	Drain
Q	Quench
C/HI	Cooling/Heating Inlet
C/HO	Cooling/Heating Outlet
CSD	Containment Seal Drain
CSV	Containment Seal Vent
GBI	Gas Barrier/Buffer Inlet
GBO	Gas Barrier/Buffer Outlet

### 7.3.2 Centrifugal Pump Data

(a) *Data Sheet.* Form A1 or A2 in Nonmandatory Appendix A should be used as the centrifugal pump data sheet.

(b) *Electronic Data.* The B73 Standardized Electronic Data Exchange File Specification may be used for the electronic transfer of centrifugal pump data (see Table 6).

(c) The data sheet and/or electronic file should be used for inquiry, proposal, and as-built.

### 7.3.3 Mechanical Seal Drawing

(a) A mechanical seal drawing shall be included if the pump is fitted with a mechanical shaft seal.

(b) The drawing shall show the general arrangement of the mechanical seal, identifying all parts with name, part number and material of construction.

(c) If a throat bushing is to be installed in the seal cavity, it is to be clearly indicated and identified on the seal drawing.

(d) Drawings for non-cartridge seals shall include dimensions complete with the seal setting dimension referenced to the seal chamber face.

(e) The drawings shall have a title block including the information on the title block of the pump data sheet, Form A1 or A2, and have a blank space for the user's identification stamp 1½ in. × 3 in. (38 mm × 76 mm) min.

### 7.3.4 Mechanical Seal Piping Drawing

(a) A mechanical seal piping drawing or schematic shall be included if the pump is fitted with a mechanical seal piping system supplied by the pump manufacturer.

(b) The mechanical seal piping drawing or schematic may contain all information and uniform nomenclature shown in and may be arranged as the sample drawing included herein and identified as Fig. 2.

### 7.3.5 Manufacturer's Cooling/Heating Piping Drawing

(a) A cooling/heating piping drawing shall be included if the pump is fitted with a heating/cooling piping system supplied by the pump manufacturer.

(b) The cooling/heating piping drawing may contain all information and uniform nomenclature shown in and may be arranged as the sample drawings included herein and identified as Fig. 3.

### 7.3.6 Published or Proposal Performance Curve

(a) The performance curve shall be the composite (family) type curve for full impeller diameter range, plotting head against capacity and including efficiency, minimum flow, NPSH, power consumption and speed. Power consumption shall be provided at all flows including shutoff. The design impeller diameter shall be stated with the rated point identified for proposal and as built curves.

(b) If the pumped fluid viscosity or specific gravity affects the pump performance, it shall be so noted on the proposal performance curve.

**7.3.7 Cross Section Drawing.** The cross section drawing shall show all assembled parts of the pump. It shall be complete with a parts list referenced to the drawing and shall include material descriptions.

### 7.3.8 Instruction Manual

(a) The instruction manual should include information on the correct installation, preparation for start-up, starting up, operation, trouble checklist, maintenance information, and special tools required for the pump model furnished.

(b) Any limitation or warning on the installation, operation, etc., of the unit should be clearly defined.

(c) The instruction manual shall be in booklet form.

(d) The use of a single manual to describe many similar model of pumps should be minimized to reduce user confusion on the exact model furnished.

(e) Recommended tolerance for coupling alignment shall be supplied to the user.

(f) Instruction manual for the pump driver, mechanical seal, coupling, etc., shall be furnished by the pump vendor if included as part of their supply.

**7.3.9 Certificate of Compliance** A certificate of compliance shall be included if specified. This certificate of compliance shall include the necessary evidence and assurance that the pump supplied is being supplied according to the requirements of this Standard and meets additional requirements identified in the purchaser's specification and purchase order. It shall be the purchaser's responsibility to select the manufacturer that is capable and qualified to supply the specified pumping equipment and that maintains the proper credentials for supplying the certificate of compliance.

## **7.4 Specially Requested Documentation**

Documentation in addition to that listed above is sometimes required by some users. This additional documentation shall be made available to those users upon specific request.

### **7.4.1 Master Document List**

(a) This is a composite list of all documents submitted by the manufacturer, including title of document and drawing or other identification numbers, including revision dates.

(b) This list shall be submitted along with the first document in order for the user to be aware of the documents which will follow.

(c) Revisions to this document list shall be made as required.

**7.4.2 External Forces and Moments on Nozzles.** The allowable external forces and moments on pump suction and discharge nozzles shall be in accordance with para. 5.1.2.

### **7.4.3 Parts List**

(a) A list of all pump parts with pump identification number(s) shall be supplied by the manufacturer.

(b) A list of recommended spare parts shall be supplied by the manufacturer and shall be subdivided into two categories:

(1) for start-up

(2) for 1 year's operation

(c) The pump manufacturer should also furnish a spare parts list for equipment supplied with the pump, but not of their manufacture, as recommended by the manufacturer of that particular equipment. This would include, as applicable, mechanical seal, coupling, driver, gear boxes, etc.

(d) These lists shall be presented to the user before the equipment is shipped, in order to permit obtaining the necessary parts prior to equipment start-up.

**7.4.4 Special Operating or Design Data.** Special operating and design data required by the user shall be supplied. This may include the following:

(a) Minimum mechanical seal flush flow.

(b) Stuffing box pressure.

(c) Maximum allowable casing pressure and temperature.

(d) Maximum allowable jacket pressure and temperature.

**7.4.5 Special Testing, Painting, and Preparation.** Any special testing, painting and preparation furnished shall be specified on the centrifugal pump data sheet or purchase order.

**TABLE 6 B73 STANDARDIZED ELECTRONIC DATA EXCHANGE FILE SPECIFICATION**

No.	Name	Field	Type	Length	Contents/Unit
<b>Pump Data</b>					
<b>Headings</b>					
A001	Job Number	JOB_NO	C	10	
A002	Item Number	JOB_NO	C	25	
A003	Requisition Number	REQ_N	C	25	
A004	Specification Number	SPEC_N	C	25	
A005	Purchase Order Number	PO_NO	C	25	
A006	Purchase Order Date	DATE	D	8	YYYYMMDD
A007	Inquiry Number	INQ_NO	C	25	
A008	Inquiry By	INQ_BY	C	15	
A011	For	FOR	C	59	
A013	Unit	UNIT	C	20	
A014	Site	SITE	C	59	
A015	Number Required	NO_REQD	I	5	
A016	Service	SERVICE	C	30	
A017	Pump Size	PUMP_SIZE	C	30	
A018	Pump Type	PUMP_TYPE	C	20	
A020	Manufacturer	MFGR	C	25	
A021	Model	MODEL	C	20	
A022	Serial Number	SERIAL	C	20	
<b>General</b>					
A023	Operation	OPERATE	C	1	A:parallel; B:series;C: both, series and parallel; Z: other
A027	Number Motor Driven	NO_PMPS_M	I	5	
A028	Number Turbine Driven	NO_PMPS_T	I	5	
A029	With	PUMP_WITH	C	20	
A031	Pump Item Number Turbine Drive	ITEM_NO_T	C	24	
A032	Gear Item Number	G_ITEM_NO	C	24	
A033	Motor Item Number	M_ITEM_NO	C	24	
A034	Turbine Item Number	T_ITEM_NO	C	24	
A035	Gear Provided By	G_BY	C	20	
A036	Motor Provided By	M_BY	C	20	
A037	Turbine Provided By	T_BY	C	20	
A038	Gear Mounted By	G_MTD_BY	C	20	
A039	Motor Mounted By	M_MTD_BY	C	20	
A040	Turbine Mounted By	T_MTD_BY	C	20	
<b>Operating Conditions</b>					
A044	Normal Capacity	NORM_CAP	N	13	m <sup>3</sup> /h
A045	Rated Capacity	RATED_CAP	N	13	m <sup>3</sup> /h
A047	Suction Pressure Maximum	SUCT_PRESM	N	13	kPa
A048	Suction Pressure Rated	SUCT_PRES	N	13	kPa
A049	Discharge Pressure	DISCH_PRES	N	13	kPa
A050	Differential Pressure	DIFF_PRESS	N	13	kPa
A051	Differential Head	HEAD	N	13	m
A052	NPSH Available	NPSHA	N	13	m
A053	Hydraulic Power	HYD_POWER	N	13	kW
A056	Service	OPER_SERV	C	1	A:continuous; B:Intermittent; Z:other
A057	Starts Per Day	STRTS_PER	I	5	

(continued)

**TABLE 6 B73 STANDARDIZED ELECTRONIC DATA EXCHANGE FILE SPECIFICATION (CONT'D)**

No.	Name	Field	Type	Length	Contents/Unit
<b>Site and Utility Data</b>					
A059	Indoor	INDOOR	C	1	1:yes (true); 0:no (false)
A060	Outdoor	OUTDOOR	C	1	1:yes (true); 0:no (false)
A067	Electric Area Classification CL	ELECT_CL	C	6	
A068	Electric Area Classification GR	ELECT_GR	C	6	
A069	Electric Area Classification DIV	ELECT_DIV	C	1	
A072	Altitude	ELEV	N	13	m
A074	Ambient Temperature: Min.	SITE_TM_MIN	N	13	°C
A075	Ambient Temperature: Max.	SITE_TM_MX	N	13	°C
A103	Cooling Water Temperature Inlet	C_WTR_TMIN	N	13	°C
A104	Cooling Water Maximum Return	C_WTR_TMOU	N	13	°C
A108	Cooling Water Maximum Delta P	C_WTR_PRDI	N	13	kPa
<b>Liquid</b>					
A113	Name of Liquid	LIQ_NAME	C	40	
A114	Pumping Temperature Normal	TEMP_NORM	N	13	°C
A115	Pumping Temperature Maximum	TEMP_MAX	N	13	°C
A116	Pumping Temperature Minimum	TEMP_MIN	N	13	°C
A117	Specific Gravity at Normal Temperature	SG_NORM	C	13	
A118	Specific Gravity at Maximum Temperature	SG_MAX	C	13	
A119	Specific Gravity at Minimum Temperature	SG_MIN	C	13	
A126	Corrosive/Erosive Agent	CORROSIVE	C	15	
A129	Hazardous (Toxic)	TOXIC	C	1	1:yes (true); 0:no (false)
A130	Flammable	FLAMMABLE	C	1	1:yes (true); 0:no (false)
A131	Other Liquid Hazard	OTHER_HZRD	C	1	1:yes (true); 0:no (false)
<b>Performance</b>					
A132	Rated Pump Speed	PMP_RPM	N	13	rpm
A133	Proposal Curve Number	PROP_CRV_N	C	15	
A134	Impeller Diameter Rated	IMP_DIA_RA	N	13	mm
A135	Impeller Diameter Maximum	IMP_DI_MAX	N	13	mm
A137	Rated Power	BHP	N	13	kW
A138	Efficiency	EFF	N	13	% (0 to 100)
A139	Minimum Flow: Thermal	MN_FL_THER	N	13	m <sup>3</sup> /h
A140	Minimum Flow Stable	MN_FL_STAB	N	13	m <sup>3</sup> /h
A141	Maximum Head Rated Impeller	MAX_HEAD	N	13	m
A144	Allowable Operating Region (minimum)	ALWB_OPER1	N	13	m <sup>3</sup> /hr
A145	Allowable Operating Region (maximum)	ALBWB_OPER2	N	13	
A146	Maximum Power Rated Impeller	MAX_PWR	N	13	KW
A148	Suction Specific Speed	SP_SPEED	N	13	Metric units (see para. 1.4.42)
A149	Maximum Sound Pressure Level Required	DBA	N	13	DBA
A151	Performance Remark	PERF_REMK	C	140	

(continued)

**TABLE 6 B73 STANDARDIZED ELECTRONIC DATA EXCHANGE FILE SPECIFICATION (CONT'D)**

No.	Name	Field	Type	Length	Contents/Unit
<b>Construction</b>					
A152	Pump Classification ID	PUMP_CLASS	C	3	OVERHUNG TYPE: OH1:foot mounted/horizontal/ flexibly coupled OH2:center line mounted/horizontal/ flexibly coupled OH3:in-line bearing frame/vertical/ flexibly coupled OH4: in-line/vertical/rigidly coupled
A156	Suction Size	SUCT_SIZE	C	10	The decimal numeric value is followed by "mm" or "in.". Example: 1.5 in. or 38 mm
A157	Suction Rating	SUCT_RATE	C	10	
A158	Suction Facing	SUCT_FACE	C	1	A:flat face; B:rated flange; C:ring type joint; D:threaded
A160	Discharge Size	DISCH_SIZE	C	10	The decimal numeric value is followed by "mm" or "in.". Example: 1.5 or 38 mm
A161	Discharge Rating	DISCH_RATE	C	10	
A162	Discharge Facing	DISCH_FACE	C	1	A:flat face; B:rated flange; C:ring type joint; D:threaded
A173	Drain Size	DRN_SIZE	C	10	The decimal numeric value is followed by "mm" or "in.". Example: 1.5 in. or 38 mm
A197	Maximum Allowable Working Pressure	MAWP	N	13	kPa
A198	Reference temperature for MAWP	T_MAWP	N	13	°C
A199	Casing Hydrotest Pressure	CASE_HYD	N	13	kPa
A200	Rotation	ROTATION	C	1	A:CW; B:CCW per Hydraulic Institute; Z:other
A209	Coupling Make	CPLG_MFG	C	15	
A210	Coupling Model	CPLG_MODEL	C	10	
A214	Coupling Spacer Length	CPLG_SPCR	N	13	mm
A221	Non Grout Construction	NON_GROUT	C	1	1:yes (true); 0:no (false)
A224	Coupling remark	CPLG_REMK	C	140	
<b>Materials</b>					
A225	Table H1 material class	MATL_CLASS	C	5	
A227	Barrel/Case Material	MATL_CASE	C	20	
A228	Impeller Material	MATL_IMP	C	20	
A231	Shaft Material	MATL_SHAFT	C	20	
A232	Sleeve Material	MATL_SLEEV	C	20	
A237	Baseplate Material	MATL_BASEPL	C	20	
<b>Bearings and Lubrication</b>					
A239	Radial Bearing Type	RAD_BRG_TY	C	10	
A240	Radial Bearing Number	RAD_BRG/NU	C	10	
A241	Thrust Bearing Type	THR_BRG_TY	C	10	
A242	Thrust Bearing Number	THR_BRG_NO	C	10	
A246	Constant Lever Offer	CONST_LVL	C	1	1:yes (true); 0:no (false)
A250	Oil Viscosity ISO Grade	ISO_VIS	C	15	
A253	Lubrication Remark	LUBE_RMK	C	140	

(continued)

**TABLE 6 B73 STANDARDIZED ELECTRONIC DATA EXCHANGE FILE SPECIFICATION (CONT'D)**

No.	Name	Field	Type	Length	Contents/Unit
<b>Mechanical Seal or Packing</b>					
A265	Seal Manufacturer	SEAL_MFR	C	15	
A268	Manufacturer Code	SEAL_MFR_C	C	15	
A272	Circulating Device	CIRC_DEV	C	1	1:yes(true); 0:no(false)
A273	Sleeve Material	SLEEVE_MAT	C	10	
A274	Gland Material	GLAND_MATL	C	10	1:yes(true); 0:no(false)
A277	Flush Gland Taps	F_GLAND_TA	C	1	1:yes(true); 0:no(false)
A278	Drain Gland Taps	D_GLAND_TA	C	1	1:yes(true); 0:no(false)
A282	Quench Gland Taps	Q_GLAND_TA	C	1	1:yes(true); 0:no(false)
A290	Flush Minimum Temperature	FLUSH_T_MI	N	13	°C
A291	Flush Maximum Temperature	FLUSH_T_MA	N	13	°C
A292	Specific Gravity	FLUSH_SG	C	13	
A294	Flush fluid Name	FLUSH_FLUI	C	20	
A295	Flush Specific Heat	FLUSH_SP_H	N	13	KJ/Kg°C
A296	Flush vapor pressure	FLUSH_VP	N	13	kPa abs
A297	Flush vapor pressure temperature	FLUSH_VP_T	N	13	°C
A300	Flush Other	FLUSH_OTHE	C	15	
A301	Flush Maximum Flowrate	FLUSH_MAX	N	13	m³/h
A302	Flush Minimum Flowrate	FLUSH_MIN	N	13	m³/h
A303	Flush Maximum Pressure	FLUSH_P_MX	N	13	kPa
A304	Flush Minimum Pressure	FLUSH_P_MIN	N	13	kPa
A305	Flush Maximum Temperature	FLSH_T_MX	N	13	°C
A306	Flush Minimum Temperature	FLUSH_T_MIN	N	13	°C
A307	Barrier Minimum Temperature	BARR_TM_MN	N	13	°C
A308	Barrier Maximum Temperature	BARR_TM_MX	N	13	°C
A309	Barrier SG	BARR_SG	C	13	
A311	Barrier Liquid Name	BARR_FLUID	C	20	
A312	Barrier Vapor Pressure	BARR_VP_TM	N	13	kPa abs
A313	Barrier Vapor Pressure Temperature	BARR_VP_TM	B	13	°C
A319	Barrier Maximum Pressure	BARR_PR_MX	N	13	kPa
A320	Barrier Minimum Pressure	BARR_PR_MN	N	13	kPa
A321	Barrier Temperature Maximum	BARR_T_MAX	N	13	°C
A322	Barrier Temperature Minimum	BARR_T_MIN	N	13	°C
A326	Seal Piping Construction	SEAL_PIPE	C	1	A:tubing; B:piping; C:other; Z:other
A327	Piping Material	PIPE_MAT	C	1	A:carbon steel; B:stainless steel; C:other; Z:other
A328	Other Material Description	O_MTL_DESC	C	20	
A330	Aux Piping Plan Construction	AUX_PLAN_T	C	1	A:tubing; B:pipe; Z:other;
A331	Aux Piping Plan Material	AUX_PLAN_M	C	1	A:carbon steel; B:stainless steel; C:other; Z:other
A332	Other Aux Material Description	O_AUX_M_D	C	20	
A337	Seal Flow Indicator	SEAL_FL	C	1	1:yes (true); 0:no(false)
A342	Seal Level Switch Type	SEAL_LS_TY	C	15	
A343	Sea Level Gauge	SEAL_LG	C	1	1:yes (true); 0:no(false)
A346	Mechanical Seal Remarks	SEAL_RMK	C	140	
<b>Cooling Water Piping</b>					
A356	Cooling Water Sight Flow Indicator	SIGHT_FLOW	C	1	1:yes (true); 0:no (false)
A357	Cooling Water Manifold Outlet Valve	MANIFOLD_V	C	1	1:yes(true); 0:no(false)

(continued)



**TABLE 6 B73 STANDARDIZED ELECTRONIC DATA EXCHANGE FILE SPECIFICATION (CONT'D)**

No.	Name	Field	Type	Length	Contents/Unit
A358	Cooling Water Piping Material	CW_PIP_MAT	C	1	A:galvanized pipe; B:copper tube; C:stainless tubing; Z:other
A367	Total Cooling Water Flow	TOTAL_FLOW	N	13	m <sup>3</sup> /h
A369	Cooling Water Remark	CW_RMK	C	140	
<b>Instrumentation</b>					
A381	Temperature Gauges	TEMP_GAGES	C	1	1:yes (true); 0:no (false)
A388	Instrument Remark	INST_RMK	C	140	
<b>Motor Drive</b>					
A395	Motor Power	MTR_POWER	N	13	kW
A396	Motor Speed	MTR_SPEED	C	13	RPM
A423	Motor Remark	MTR_RMK	C	140	
<b>Surface Preparation and Painting</b>					
A474	Manufacturer Preparation Standard	PREP_MFR_S	C	1	1:yes (true); 0:no (false)
A475	Prep other	PREP_OTHER	C	20	
A486	Shipment Type	SHP_DEST	C	1	A:domestic; B:export; Z:other
A487	Export Boxing Required	SHP_EXP_BO	C	1	1:yes (true); 0:no (false)
<b>QA Inspection and Test</b>					
A525	Shop Inspection	SHOP_INSP	C	1	1:yes (true); 0:no (false)
A527	Hydrostatic Test	HYD	C	1	1:yes (true); 0:no (false)
A528	Performance Test	PERF	C	1	A:non witnessed; B:witnessed; C:observed; D:none; Z:other
A529	NPSH Test	NPSH	C	1	A:non witnessed; B:witnessed; C:observed; D:none; Z:other
A532	Dismantle After Test	DISM	C	1	A:non witnessed; B:witnessed; C:observed; D:none; Z:other
A538	Other Test Description 1	DESC_OTH_1	C	20	
A539	Other Test 1	TEST_OTH_1	C	1	A:nonwitnessed; B:witnessed; C:observed; D:none; Z:other
A546	Material Certificate for Casing	MAT_CER_CA	C	1	1:yes (true); 0:no (false)
A547	Material Certificate for Impeller	MAT_CER_IM	C	1	1:yes (true); 0:no (false)
A548	Material Certificate for Shaft	MAT_CER_SH	C	1	1:yes (true); 0:no (false)
A549	Material Certificate for Other	MAT_CER_OT	C	20	
A550	Casting Repair Procedure Approval	CAS_REP_PR	C	1	1:yes(true); 0:no(false)
<b>General Remarks</b>					
A573	General Remark 1	GEN_RMK1	C	254	
A574	General Remark 2	GEN_RMK2	C	254	
A575	General Remark 3	GEN_RMK3	C	254	
A576	General Remark 4	GEN_RMK4	C	254	
A577	General Remark 5	GEN_RMK5	C	254	
A578	General Remark 6	GEN_RMK6	C	254	
<b>Additional Data</b>					
<b>Construction</b>					
8009	Coupling Guard Non-Spark	CP_G_N_SP	C	1	1:yes (true); 0:no (false)

(continued)

**TABLE 6 B73 STANDARDIZED ELECTRONIC DATA EXCHANGE FILE SPECIFICATION (CONT'D)**

No.	Name	Field	Type	Length	Contents/Unit
<b>Liquid</b>					
B026	Solid Dia	SOLID_DIA	N	13	
<b>Materials</b>					
B032	Guard Material	MTR_MATL	C	20	
<b>PIP Data</b>					
P001	Maximum Capacity	MAX_CAP	N	13	
P002	Minimum Capacity	MAX_CAP	N	13	m <sup>3</sup> /h
P003	Suction Pressure Minimum	SUCTPR_MIN	N	13	kPa
P004	Operating Time at Rated Capacity	OPT_RATED	N	5	hr/yr
P005	Operating Time at Maximum Capacity	OPT_MAX	N	5	hr/yr
P006	Operating Time at Normal Capacity	OPT_NORM	N	5	hr/yr
P007	Operating Time at Minimum Capacity	OPT_MIN	N	5	hr/yr
P008	NPSH Available at Rated Capacity	RATED_NPSH	N	13	m
P009	NPSH Available at Maximum Rated Capacity	MAX_NPSH	N	13	m
P010	NPSH Available at Normal Capacity	NORM_NPSH	N	13	m
P011	NPSH Available at Minimum Capacity	MIN_NPSH	N	13	m
P012	System Design	SYS_DESIGN	C	1	A:stand alone; B:parallel; C:series
P013	System Control Method	SYS_CONTRL	C	1	A:speed; B:flow; D:temperature; E:pressure; F:pi
P014	Pumping Temperature Rated	TEMP_RATED	N	13	°C
P015	Specific Gravity at Rated Temperature	SG_RATED	N	13	
P016	Vapor Pressure at Rated Temperature	VP_RATED	N	13	kPa abs
P017	Vapor Pressure at Maximum Temperature	VP_MAX	N	13	kPa abs
P018	Vapor Pressure at Normal Temperature	VP_NORM	N	13	kPa abs
P019	Vapor Pressure at Minimum Temperature	VP_MIN	N	13	kPa abs
P020	Viscosity at Rated Temperature	VISC_RATED	N	13	cP
P021	Viscosity at Maximum Temperature	VISC_MAX	N	13	cP
P022	Viscosity at Normal Temperature	VISC_NORM	N	13	cP
P023	Viscosity at Minimum Temperature	VISC_MIN	N	13	kJ/kg°C
P024	Specific Heat at Rated Temperature	SPHT_RATED	N	13	kJ/kg°C
P025	Specific Heat at Maximum Temperature	SPHT_MAX	N	13	kJ/kg°C
P026	Specific Heat at Normal Temperature	SPHT_NORM	N	13	kJ/kg°C
P027	Specific Heat at Minimum Temperature	SPHT_MIN	N	13	kJ/kg°C

(continued)

**TABLE 6 B73 STANDARDIZED ELECTRONIC DATA EXCHANGE FILE SPECIFICATION (CONT'D)**

No.	Name	Field	Type	Length	Contents/Unit
P028	Initial Boiling Point Temperature	BP_TEMP	N	13	°C
P029	Initial Boiling Point Pressure	BP_PRESS	N	13	kPa abs
P030	NPSH Required at Rated Capacity	NPSHR_RATE	N	13	m
P031	NPSH Required at Maximum Capacity	NPSHR_MAX	N	13	m
P032	NPSH Required at Normal Capacity	NPSHR_NORM	N	13	m
P033	NPSH Required at Minimum Capacity	NPSHR_MIN	N	13	m
P034	Total Differential Head at Rated Impeller	RATED_HEAD	N	13	m
P035	Best Efficiency Point for Rated impeller	BEP	N	13	m <sup>3</sup> /h
P036	Non Hazardous Electrical Classification	ELEC_HAZRD	C	1	1:yes(true); 0:no(false)
P037	Impeller Type	IMPLR_TYPE	C	1	A:closed; B:semi-opened; C:opened; D:other
P038	Other Impeller Type	OTHER_IMP	C	15	
P039	Bearing Manufacturer	BRG_MANUF	C	20	
P040	Bearing isolators	BRG_ISOL	C	25	
P041	Shaft Stiffness Ratio (L3/D4)	SS_RATIO	N	13	1/mm
P042	Lubrication	LUBE_TYPE	C	1	A:food; B:grease; C:purge mist; E:sheilded; B:seal
P043	Housing Vent Required	HSG_VENT	C	1	1:yes (true) 0:no (false)
P044	Magnetic Drain Plug In Housing Required	MAG_PLUG	C	1	1:yes (true); 0:no (false)
P045	Oil Cooler Required	OIL_COOLER	C	1	1:yes (true) 0:no (false)
P046	Seal Spray Guard Required	SPRAY_GRD	C	1	1:yes (true) 0:no (false)
P047	Drain Required	DRAIN	C	1	1:yes (true) 0:no (false)
P048	Drain Connection Type	DRAIN_CONN	C	1	A:threaded; B:welded and flanged; Z:other
P049	Cover Material	MATL_COVER	C	25	
P050	Casing Gasket Material	ML_CSG_GKT	C	25	
P051	Impeller Gasket Material	ML_IMP_GKT	C	25	
P052	Casing Fastener Material	ML_CSG_FST	C	25	
P053	Gland Fastener Material	ML_GLD_FST	C	25	
P054	Bearing Housing Material	ML_BRG_HSG	C	25	
P055	Bearing Housing Adapter Material	ML_BRG_HA	C	25	
P056	Bearing Housing End Seals	ML_BRG_ESL	C	25	
P057	Driver Selected For Maximum Specific Gravity	DR_MAX_SG	N	13	
P058	Driver Selected fo Maximum Viscosity	DR_MAX_VSC	N	13	cP
P059	Coupling Type	CPLING_TYPE	C	20	
P060	Coupling Size	CPLING_SIZE	C	20	
P061	Coupling Guard Manufacturer's Standard	CG_MFG_STD	C	1	1:yes(true) 0:no(false)
P062	Coupling Guard Baseplate Mounted	CG_BP_MNT	C	1	1:yes(true) 0:no(false)
P063	Baseplate Type	BP_TYPE	C	1	A:grouted; B:freestanding; Z:other
P064	Centerline of Pump to Stilt Bottom	CTR_P_TO_S	N	13	mm
P065	Vertical Pump Case Support Bracket	VPC_SUP_BR	C	1	1:yes (true); 0:no (false)
P066	Baseplate Design	BP_DESIGN	C	1	A:PIP standard RESP002; B: manufacturer's standard; Z:other

(continued)

**TABLE 6 B73 STANDARDIZED ELECTRONIC DATA EXCHANGE FILE SPECIFICATION (CONT'D)**

No.	Name	Field	Type	Length	Contents/Unit
P067	Baseplate Remarks	BP_REMARKS	C	50	
P068	Baseplate Paint	BP_PAINT	C	1	A:Manufacturer's standard; B:Other
P069	Other Baseplate Paint	BP_OTH_PNT	C	20	
P070	Number of Months of Storage	MTH_STRO	N	3	Month
P071	Days Notification Required Final Shop Inspection	DAYS_FI	N	3	Day
P072	Hydrostatic Certificate Required	HYDRO_CRT	C	1	1:yes (true) 0:no (false)
P073	Performance Certificate Required	PERF_CRT	C	1	1:yes (true) 0:no (false)
P074	NPSHR Certificate Required	NPSH_CRT	C	1	1:yes (true) 0:no (false)
P075	Vibration Test	VIBRATION	C	1	A:non-witnessed; B:witnessed; C:none; Z:other
P076	Vibration Certificate Required	VIBE_CRT	C	1	1:yes (true) 0:no (false)
P077	Other Test Certificate Required	TST_OT_CRT	C	1	1:yes (true) 0:no (false)
P078	Material Certificate for Cover	MAT_CER_CV	C	1	1:yes (true) 0:no (false)
P079	Inspection for Connection Welds	CONN_INSP	C	1	A:manufacturer's standard; B:visual inspection; C:none; Z:other
P080	Inspections for Castings	CAST_INSP	C	1	A:manufacturer's standard; B:visual inspection; C:none Z:other
P081	Other Inspection Required for Castings	OTH_CINSP	C	25	
P082	For Vendor Data Requirements Refer to:	VNDR_DATA	C	15	
P083	Manufacturer Documentation Remarks	MD_REMARKS	C	00	
P084	Mechanical Seal Supplied By	MS_SUPP_BY	C	1	A:pump manufacturer; B:purchaser; Z:other
P085	Mechanical Seal Mounted By	MS_MNT_BY	C	1	A:pump manufacturer; B:purchaser; Z:other
P086	Seal Classification Code	MS_CODE	C	5	
P087	Seal Model	SEAL_MODEL	C	25	
P088	Cartridge or Component Seal Type	MS_TYPE_CC	C	1	A:cartridge; B:component; Z:other
P089	Seal Design Type	SEAL_DSGN	C	1	A:single; B:dual; C:dry gas; D:liquid dual; Z:other
P090	Seal Pressurized or Unpressurized Type	SEAL_PRTYP	C	1	A:pressurized; B:unpressurized
P091	Seal Chamber	SEALI_CHAM	C	1	A:taper bore; B:cylindrical bore; Z:other
P092	Seal Chamber Size	SEAL_CHSIZ	C	1	A:oversized; B:standard; Z:other
P093	Throat Bushing Required	THRO_B	C	1	1yes (true) 0:no (false)
P094	Throat Bushing Material	THRO_B_MAT	C	20	
P095	Other Taps Required	OT_TAP	C	1	1yes (true) 0:no (false)
P096	Other Taps Required Description	OSC_OT_TAP	C	20	
P097	Throttle Bushing Required	THRT_B	C	1	1yes (true) 0:no (false)
P098	Throttle Bushing Material	THRT_B_MAT	C	20	
P099	Primary Flush Plan Number	PR_PI_PL	C	1	A:none; B:ASME Plan 7301; C:ASME Plan 7302; D:ASME Plan 7311
P100	Primary Flush Piping/ Tubing Size	PR_FL_SIZE	N	5	mm
P101	Primary Flush Piping Assembly	PR_FL_ASM	C	1	A:threded; B:unions; C:flanged; D:tube type fittings; E:s
P102	Barrier Flush Plan	BR_PI_PL	C	1	A:none; B:ASME Plan 7351; C:ASME Plan 7352; D:ASME Plan 7353
P103	Barrier Fluid Specific heat	BR_FL_SH	N	13	kJ/kg°C
P104	MAWP of Secondary Seal System	BR_MAWP	N	13	kPa

(continued)

**TABLE 6 B73 STANDARDIZED ELECTRONIC DATA EXCHANGE FILE SPECIFICATION (CONT'D)**


No.	Name	Field	Type	Length	Contents/Unit
P105	Barrier Flush Piping/Tubing Size	BR_FL_SIZE	N	13	mm
P106	Barrier Flush Piping Assembly	BR_FL_ASM	C	1	A:threaded; B:unions; C:flanged; D:tube fittings; E:socket welded
P107	Primary Seal Flow Gauge Required	SEAL_PFG	C	1	1:yes (true) 0:no (false)
P108	Primary Seal Flow Switch Required	SEAL_PFS	C	1	1:yes (true) 0:no (false)
P109	Primary Seal Temperature Switch Required	SEAL_PTS	C	1	1:yes (true) 0:no (false)
P110	Primary Seal Pressure Gauge Required	SEAL_PPG	C	1	1:yes (true) 0:no (false)
P111	Primary Seal Pressure Switch Required	SEAL_PPS	C	1	1:yes (true) 0:no (false)
P112	Secondary Seal Flow Switch Required	SEAL_PSS	C	1	1:yes (true) 0:no (false)
P113	Secondary Seal Pressure Gauge	SEAL_SPG	C	1	1:yes (true) 0:no (false)

GENERAL NOTE: This table is composed of the applicable fields from Appendix Q, ANSI/API 610, Centrifugal Pumps for Petroleum, Heavy-Duty Chemical and Gas Industry Services, with the addition of data fields from the Process Industry Practices (PIP) specification that completely define necessary data for the electronic exchange of ASME B73 pump data. See Appendix Q, API 610 for complete information on the neutral data exchange file format.


## **NONMANDATORY APPENDIX A ASME CENTRIFUGAL PUMP DATA SHEET**

This data sheet was provided by the Process Industry Practices Initiative (PIP). Copies of the data sheet may be obtained from PIP through their website at <http://www.pip.org>.


		<b>FORM A1 ASME CENTRIFUGAL PUMP</b> Data Sheet (US Customary Units)				<b>RESP73</b> PAGE 1 of 3 November 2000																																														
Job Number _____		Item Number _____		Purchase Order Number _____		Date _____																																														
Req./Spec. Number _____		/ _____		Inquiry Number _____		By _____																																														
Note: <input type="radio"/> Indicates Information Completed by Purchaser <input type="checkbox"/> by Manufacturer <input checked="" type="checkbox"/> by Purchaser or Manufacturer																																																				
<input type="radio"/> For _____		<input type="radio"/> Unit _____																																																		
<input type="radio"/> Site _____		<input type="radio"/> Service _____																																																		
<input type="radio"/> No. Req. _____		<input checked="" type="checkbox"/> Pump Size _____		<input checked="" type="checkbox"/> Type _____																																																
<input checked="" type="checkbox"/> Manufacturer _____		<input checked="" type="checkbox"/> Model _____		<input type="checkbox"/> Serial Number _____																																																
<b>GENERAL</b>																																																				
<input type="radio"/> Number Motor Driven _____		<input type="radio"/> Number Turbine Driven _____		<input type="radio"/> Gearbox Item Number _____																																																
<input type="radio"/> Motor Item Number _____		<input type="radio"/> Turbine Item Number _____		<input type="radio"/> Gearbox Provided By _____																																																
<input type="radio"/> Motor Provided By _____		<input type="radio"/> Turbine Provided By _____		<input type="radio"/> Gearbox Mounted By _____																																																
<input type="radio"/> Motor Mounted By _____		<input type="radio"/> Turbine Mounted By _____																																																		
<b>OPERATING CONDITIONS</b>				<b>PERFORMANCE</b>																																																
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Rated</th> <th>Max.</th> <th>Normal</th> <th>Min.</th> </tr> </thead> <tbody> <tr> <td>Capacity (gpm)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Suction Pressure (psig)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Discharge Pressure (psig)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Differential Pressure (psi)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Differential Head (ft.)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Hydraulic Power (hp)</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					Rated	Max.	Normal	Min.	Capacity (gpm)					Suction Pressure (psig)					Discharge Pressure (psig)					Differential Pressure (psi)					Differential Head (ft.)					Hydraulic Power (hp)					<input type="checkbox"/> Performance Curve No. _____ <input checked="" type="checkbox"/> Speed (rpm) _____													
	Rated	Max.	Normal	Min.																																																
Capacity (gpm)																																																				
Suction Pressure (psig)																																																				
Discharge Pressure (psig)																																																				
Differential Pressure (psi)																																																				
Differential Head (ft.)																																																				
Hydraulic Power (hp)																																																				
<b>At Designated Capacity</b> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Rated</th> <th>Max.</th> <th>Normal</th> <th>Min.</th> </tr> </thead> <tbody> <tr> <td>Operating Time (hr./yr.)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>NPSH Availabl (ft.)</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					Rated	Max.	Normal	Min.	Operating Time (hr./yr.)					NPSH Availabl (ft.)					<b>Measured at Capacity</b> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Rated</th> <th>Max.</th> <th>Normal</th> <th>Min.</th> </tr> </thead> <tbody> <tr> <td><input type="checkbox"/> NPSH Req'd (ft.)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> Total Differential Head @ Rated Impeller _____ (ft.)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> Max. Differential Head @ Rated Impeller _____ (ft.)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> Minimum Continuous Flow</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Thermal (gpm) _____ Stable (gpm) _____</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					Rated	Max.	Normal	Min.	<input type="checkbox"/> NPSH Req'd (ft.)					<input type="checkbox"/> Total Differential Head @ Rated Impeller _____ (ft.)					<input type="checkbox"/> Max. Differential Head @ Rated Impeller _____ (ft.)					<input type="checkbox"/> Minimum Continuous Flow					Thermal (gpm) _____ Stable (gpm) _____				
	Rated	Max.	Normal	Min.																																																
Operating Time (hr./yr.)																																																				
NPSH Availabl (ft.)																																																				
	Rated	Max.	Normal	Min.																																																
<input type="checkbox"/> NPSH Req'd (ft.)																																																				
<input type="checkbox"/> Total Differential Head @ Rated Impeller _____ (ft.)																																																				
<input type="checkbox"/> Max. Differential Head @ Rated Impeller _____ (ft.)																																																				
<input type="checkbox"/> Minimum Continuous Flow																																																				
Thermal (gpm) _____ Stable (gpm) _____																																																				
<b>System Design</b> <input type="radio"/> Stand Alone Operation <input type="radio"/> Parallel Operation <input type="radio"/> Series Operation with Item Number _____				<input type="checkbox"/> Allowable Operating Region _____ To _____ (gpm) <input type="checkbox"/> Best Efficiency Point for Rated Impeller _____ (gpm) <input type="checkbox"/> Suction Specific Speed _____ <input type="checkbox"/> Impeller Diameter Rated _____ Max. _____ Min. _____ (In.) <input type="checkbox"/> Pump Rated Power _____ (bhp) <input type="checkbox"/> Efficiency _____ (%) <input type="checkbox"/> Maximum Power @ Rated Impeller _____ (bhp)																																																
<b>Service</b> <input type="radio"/> Continuous <input type="radio"/> Intermittent (Starts/Day) _____				Rotation (Viewed from Coupling End) <input type="checkbox"/> CW <input type="checkbox"/> CCW																																																
<b>System Control Method</b> <input type="radio"/> Speed <input type="radio"/> Flow <input type="radio"/> Level <input type="radio"/> Temperature <input type="radio"/> Pressure <input type="radio"/> Pipe Friction Resistance Only				<b>Case Pressure Rating</b> <input type="checkbox"/> Max. Allowable Working Pressure _____ (psig) @ _____ (°F) <input type="checkbox"/> Hydrostatic Test Pressure _____ (psig)																																																
<b>PUMPED FLUID</b>				<b>SITE CONDITIONS</b>																																																
Pumped Fluid _____				Location <input type="radio"/> Indoor <input type="radio"/> Outdoor Altitude _____ (ft.) Range of Ambient Temperatures Min./Max. _____ / _____ (°F) Electrical Classification CL. _____ Gr. _____ Div. _____ <input type="radio"/> Non Hazardous																																																
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Rated</th> <th>Max.</th> <th>Normal</th> <th>Min.</th> </tr> </thead> <tbody> <tr> <td>Pumping Temperature (°F)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><b>At Designated Temperature</b></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Specific Gravity</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vapor Pressure (psia)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Viscosity (cp)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Specific Heat (BTU/Lb. °F)</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					Rated	Max.	Normal	Min.	Pumping Temperature (°F)					<b>At Designated Temperature</b>					Specific Gravity					Vapor Pressure (psia)					Viscosity (cp)					Specific Heat (BTU/Lb. °F)					<b>GENERAL REMARKS</b>													
	Rated	Max.	Normal	Min.																																																
Pumping Temperature (°F)																																																				
<b>At Designated Temperature</b>																																																				
Specific Gravity																																																				
Vapor Pressure (psia)																																																				
Viscosity (cp)																																																				
Specific Heat (BTU/Lb. °F)																																																				
Initial Boiling Point _____ (°F) @ _____ (psia)																																																				
<b>Liquid</b> <input type="radio"/> Hazardous <input type="radio"/> Flammable <input type="radio"/> Other _____																																																				
Corrosion/Erosion Caused By _____																																																				
% Solid _____ Max. Particle Size _____ (in.)																																																				
4																																																				
3																																																				
2																																																				
1																																																				
0																																																				
REV	DATE	REASON FOR REVISION				BY	CHECK APPROVED																																													


		<b>FORM A1 ASME CENTRIFUGAL PUMP</b> Data Sheet (US Customary Units)		<b>RESP73</b> PAGE 2 of 3 November 2000	
Job Number _____		Item Number _____		Purchase Order Number _____	
Req./Spec. Number _____		Inquiry Number _____		Date _____	
By _____					
<b>MECHANICAL DATA</b>		<b>COUPLING BETWEEN PUMP AND DRIVER</b>			
<b>Impeller Type</b>		Manufacturer _____			
<input type="checkbox"/> Closed <input type="checkbox"/> Open		Type _____			
<input type="checkbox"/> Semi-open <input type="checkbox"/> Other _____		Size _____			
<b>Casing Mounting</b>		Model _____			
<input type="checkbox"/> Foot <input type="checkbox"/> Centerline		Spacer Length (In.) _____			
<input type="checkbox"/> Vertical Inline <input type="checkbox"/> Close-coupled		<b>Coupling Guard Type</b>			
<b>Bearings</b>		<input type="checkbox"/> Manufacturer's Standard			
<input type="checkbox"/> Bearings Manufacturer _____		<input type="checkbox"/> Baseplate Mounted			
<input type="checkbox"/> Radial Bearing Type _____ No. _____		<input type="checkbox"/> Non-Spark Coupling Guard Required			
<input type="checkbox"/> Thrust Bearing Type _____ No. _____		Remarks _____			
<input type="checkbox"/> Bearing Isolators _____					
<input type="checkbox"/> Shaft Stiffness Ratio ( $L^3/D^4$ ) _____					
<b>Lubrication</b>		<b>BASEPLATE</b>			
<input type="radio"/> Flood <input type="radio"/> Pure Mist <input type="radio"/> Shielded (Grease)		Remarks <input type="radio"/> Grounded <input type="radio"/> Free Standing			
<input type="radio"/> Grease <input type="radio"/> Purge Mist <input type="radio"/> Sealed (Grease)		<input type="checkbox"/> Centerline of Pump to Stilt Bottom _____ (In.)			
<input type="radio"/> Constant Level Oiler Required		<input type="radio"/> Vertical Pump Case Support Bracket			
<input type="checkbox"/> Housing Vent Required		<b>Design</b> <input type="radio"/> PIP Standard RESP002 (Data Sheet Attached)			
<input type="checkbox"/> Magnetic Drain Plug in Housing Required		<input type="radio"/> Manufacturer's Standard			
<input type="checkbox"/> Oil Cooler Required		Remarks _____			
<input type="radio"/> Seal Spray Guard Required					
<input type="checkbox"/> Oil Viscosity ISO Grade _____		<b>PAINT AND SHIPMENT PREPARATION</b>			
<input type="checkbox"/> Other _____					
<b>Nozzle Connections</b> <input type="checkbox"/> Size <input type="checkbox"/> Rating <input type="checkbox"/> Facing		<b>Pump</b>		<b>Baseplate</b>	
Suction _____		<input type="radio"/> Manufacturer's Standard		<input type="radio"/> Manufacturer's Standard	
Discharge _____		<input type="radio"/> Other _____		<input type="radio"/> Other _____	
Aux. Case Connection <input type="radio"/> Drain Required		<b>Shipment</b>			
<input type="checkbox"/> Size _____ (In.)		<input type="radio"/> Domestic <input type="radio"/> Export <input type="radio"/> Export Boxing Required			
<input type="radio"/> Threaded <input type="radio"/> Welded and Flanged		<input type="radio"/> Number of Months of Storage _____			
<b>MATERIALS</b>		<b>Total Weight</b> _____ (Lbs.)			
<b>Material Class Code</b> _____		<b>INSPECTION AND TESTING</b>			
Casing _____		<input type="radio"/> Final Inspection Required <input type="radio"/> Days Notification Required _____			
Impeller _____		<b>Test</b> <b>Non-Witnessed</b> <b>Witnessed</b> <b>Certificate</b>			
Cover _____		Hydrostatic <input type="radio"/> <input type="radio"/> <input type="radio"/> <input type="radio"/>			
Shaft _____		Performance <input type="radio"/> <input type="radio"/> <input type="radio"/> <input type="radio"/>			
Shaft Sleeve _____		NPSHR <input type="radio"/> <input type="radio"/> <input type="radio"/> <input type="radio"/>			
Baseplate _____		Vibration <input type="radio"/> <input type="radio"/> <input type="radio"/> <input type="radio"/>			
Casing Gasket _____		Other <input type="radio"/> <input type="radio"/> <input type="radio"/> <input type="radio"/>			
Impeller Gasket _____		<input type="radio"/> Dismantle and Inspect After Test			
Casing Fasteners _____		<input type="radio"/> Casting Repair Procedure Approval Required			
Bearing Housing _____		<b>Material Certification Required</b>			
Bearing Housing Adapter _____		<input type="radio"/> Casing <input type="radio"/> Cover <input type="radio"/> Impeller <input type="radio"/> Shaft			
Bearing Housing End Seals _____		<input type="radio"/> Other _____			
Coupling Guard _____		<b>Inspection Required for Connection Welds</b>			
Mechanical Seal Gland _____		<input type="radio"/> Manufacturer's Standard <input type="radio"/> Visual Inspection			
Mechanical Seal Gland Fasteners _____		<b>Inspection Required for Castings</b>			
		<input type="radio"/> Manufacturer's Standard <input type="radio"/> Visual Inspection			
		<input type="radio"/> Other _____			
<b>DRIVER</b>		<b>MANUFACTURER DOCUMENTATION REQUIREMENTS</b>			
Horsepower Rating _____ (hp) Speed _____ (rpm)		<input type="radio"/> For Vendor Data Requirements Refer to: _____			
Drive HP Selected or Max. S.G. _____ & Max. Visc. _____ (cp)		Remarks _____			
Remarks _____					



		<b>FORM A1 ASME CENTRIFUGAL PUMP</b> Data Sheet (US Customary Units)		<b>RESP73</b> PAGE 3 of 3 November 2000																															
Job Number _____		Item Number _____		Purchase Order Number _____																															
Req./Spec. Number _____		Inquiry Number _____		Date _____																															
<b>MECHANICAL SEAL</b>		<b>BARRIER/BUFFER FLUSH SYSTEM</b>																																	
<b>Supplied By</b> <input type="radio"/> Pump Manufacturer <input type="radio"/> Purchaser <b>Mounted By</b> <input type="radio"/> Pump Manufacturer <input type="radio"/> Purchaser Seal Classification Code _____ <input checked="" type="checkbox"/> Manufacturer _____ <input checked="" type="checkbox"/> Model _____ <input checked="" type="checkbox"/> Manufacturer Code _____ <b>Seal Type</b> <input type="radio"/> Cartridge <input type="radio"/> Component <b>Seal Design</b> <input type="radio"/> Single <input type="radio"/> Dual <input type="radio"/> Dry Gas <input type="radio"/> Pressurized <input type="radio"/> Unpressurized <b>Seal Chamber</b> <input type="radio"/> Taper Bore <input type="radio"/> Cylindrical Bore <b>Seal Chamber Size</b> <input type="radio"/> Oversized <input type="radio"/> Standard <input checked="" type="checkbox"/> Pumping Ring Required <input checked="" type="checkbox"/> Throat Bushing Required <input checked="" type="checkbox"/> Materials _____ Remarks _____		Barrier Flush Plan _____ <input type="radio"/> Barrier Flush Liquid _____ <input type="radio"/> Temperature Min./Max. _____ / _____ (°F) <input type="radio"/> Specific Gravity _____ <input type="radio"/> Specific Heat _____ (BTU/Lb. °F) <input type="radio"/> Vapor Pressure _____ (psia) @ _____ (°F) <input checked="" type="checkbox"/> Pressure Required Min./Max. _____ / _____ (psig) <input type="checkbox"/> MAWP of Secondary Seal System _____ (psig) <input type="radio"/> Temperature Required Min./Max. _____ / _____ (°F) <b>Secondary Seal Flush Piping</b> <input type="radio"/> Tubing <input type="radio"/> Pipe <b>Material</b> <input type="radio"/> 316SS <input type="radio"/> Carbon Steel <input type="radio"/> Other _____ <input type="radio"/> Piping/Tubing Size _____ (In.) <b>Piping Assembly</b> <input type="radio"/> Threaded <input type="radio"/> Unions <input type="radio"/> Flanged <input type="radio"/> Tube Type Fittings <input type="radio"/> Socket Welded Remarks _____																																	
<b>SEAL GLAND</b>		<b>SEAL SYSTEM INSTRUMENTATION</b>																																	
<b>Taps Required</b> <input type="radio"/> Quench <input type="radio"/> Flush <input type="radio"/> Drain <input type="radio"/> Other _____ <input checked="" type="checkbox"/> Throttle Bushing <input checked="" type="checkbox"/> Materials _____ <b>SEAL FLUSHING</b> Primary Flush Plan No. _____ <input type="radio"/> External Flush Liquid _____ <input type="radio"/> Supply Temperature Min./Max. _____ / _____ (°F) <input type="radio"/> Specific Gravity _____ <input type="radio"/> Specific Heat _____ (BTU/Lb. °F) <input type="radio"/> Vapor Pressure _____ (psia) @ _____ (°F) <input type="checkbox"/> Flow Rate Required Min./Max. _____ / _____ (gpm) <input type="checkbox"/> Pressure Required Min./Max. _____ / _____ (psig) <input type="checkbox"/> Temperature Required Min./Max. _____ / _____ (°F) <b>Primary Seal Flush Piping</b> <input type="radio"/> Tubing <input type="radio"/> Pipe <input type="radio"/> Other _____ <b>Material</b> <input type="radio"/> 316SS <input type="radio"/> Carbon Steel <input type="radio"/> Other _____ <input type="radio"/> Piping/Tubing Size _____ (In.) <b>Piping Assembly</b> <input type="radio"/> Threaded <input type="radio"/> Unions <input type="radio"/> Flanged <input type="radio"/> Tube Type Fittings <input type="radio"/> Socket Welded Remarks _____		<table border="1"> <thead> <tr> <th></th> <th>Gauges</th> <th>Switches</th> </tr> </thead> <tbody> <tr> <td><b>Primary Seals</b></td> <td></td> <td></td> </tr> <tr> <td>Flow</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Temperature</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Pressure</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td><b>Secondary Seals</b></td> <td></td> <td></td> </tr> <tr> <td>Flow</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Pressure</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Level</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Remarks</td> <td colspan="2"></td> </tr> </tbody> </table>					Gauges	Switches	<b>Primary Seals</b>			Flow	<input type="radio"/>	<input type="radio"/>	Temperature	<input type="radio"/>	<input type="radio"/>	Pressure	<input type="radio"/>	<input type="radio"/>	<b>Secondary Seals</b>			Flow	<input type="radio"/>	<input type="radio"/>	Pressure	<input type="radio"/>	<input type="radio"/>	Level	<input type="radio"/>	<input type="radio"/>	Remarks		
	Gauges	Switches																																	
<b>Primary Seals</b>																																			
Flow	<input type="radio"/>	<input type="radio"/>																																	
Temperature	<input type="radio"/>	<input type="radio"/>																																	
Pressure	<input type="radio"/>	<input type="radio"/>																																	
<b>Secondary Seals</b>																																			
Flow	<input type="radio"/>	<input type="radio"/>																																	
Pressure	<input type="radio"/>	<input type="radio"/>																																	
Level	<input type="radio"/>	<input type="radio"/>																																	
Remarks																																			
		<b>COOLING OR HEATING PIPING PLANS</b>																																	
		<input type="radio"/> Piping Plan No. _____ <input type="radio"/> Name of Fluid _____ <input type="radio"/> Inlet Temperature _____ (°F) <input type="radio"/> Outlet Temperature _____ (°F) <input type="checkbox"/> Rated Flow _____ (gpm) <input type="checkbox"/> Supply Pressure _____ (psig) <input type="checkbox"/> Max. Allowable ΔP _____ (psi) <input type="radio"/> Galvanized Pipe <input type="radio"/> SS Tubing <input type="radio"/> Sight Flow Indicator <input type="radio"/> Outlet Shut-Off Valve Remarks _____																																	

		<b>FORM A2 ASME CENTRIFUGAL PUMP</b> Data Sheet (SI Units)				<b>RESP73</b> PAGE 1 of 3 November 2000																																														
Job Number _____		Item Number _____		Purchase Order Number _____		Date _____																																														
Req./Spec. Number _____		/ _____		Inquiry Number _____		By _____																																														
Note: <input type="radio"/> Indicates Information Completed by Purchaser <input type="checkbox"/> by Manufacturer <input checked="" type="checkbox"/> by Purchaser or Manufacturer																																																				
<input type="radio"/> For _____		<input type="radio"/> Unit _____																																																		
<input type="radio"/> Site _____		<input type="radio"/> Service _____																																																		
<input type="radio"/> No. Req. _____		<input checked="" type="checkbox"/> Pump Size _____		<input checked="" type="checkbox"/> Type _____																																																
<input checked="" type="checkbox"/> Manufacturer _____		<input checked="" type="checkbox"/> Model _____		<input checked="" type="checkbox"/> Serial Number _____																																																
<b>GENERAL</b>																																																				
<input type="radio"/> Number Motor Driven _____		<input type="radio"/> Number Turbine Driven _____		<input type="radio"/> Gearbox Item Number _____																																																
<input type="radio"/> Motor Item Number _____		<input type="radio"/> Turbine Item Number _____		<input type="radio"/> Gearbox Provided By _____																																																
<input type="radio"/> Motor Provided By _____		<input type="radio"/> Turbine Provided By _____		<input type="radio"/> Gearbox Mounted By _____																																																
<input type="radio"/> Motor Mounted By _____		<input type="radio"/> Turbine Mounted By _____																																																		
<b>OPERATING CONDITIONS</b>				<b>PERFORMANCE</b>																																																
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Rated</th> <th>Max.</th> <th>Normal</th> <th>Min.</th> </tr> </thead> <tbody> <tr> <td>Capacity (m<sup>3</sup>/h)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Suction Pressure (kPa)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Discharge Pressure (kPa)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Differential Pressure (kPa)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Differential Head (m)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Hydraulic Power (kW)</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					Rated	Max.	Normal	Min.	Capacity (m <sup>3</sup> /h)					Suction Pressure (kPa)					Discharge Pressure (kPa)					Differential Pressure (kPa)					Differential Head (m)					Hydraulic Power (kW)					<input type="checkbox"/> Performance Curve No. _____ <input checked="" type="checkbox"/> Speed (rpm) _____													
	Rated	Max.	Normal	Min.																																																
Capacity (m <sup>3</sup> /h)																																																				
Suction Pressure (kPa)																																																				
Discharge Pressure (kPa)																																																				
Differential Pressure (kPa)																																																				
Differential Head (m)																																																				
Hydraulic Power (kW)																																																				
<b>At Designated Capacity</b> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Rated</th> <th>Max.</th> <th>Normal</th> <th>Min.</th> </tr> </thead> <tbody> <tr> <td>Operating Time (hr./yr.)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>NPSH Availabl (m)</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					Rated	Max.	Normal	Min.	Operating Time (hr./yr.)					NPSH Availabl (m)					<b>Measured at Capacity</b> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Rated</th> <th>Max.</th> <th>Normal</th> <th>Min.</th> </tr> </thead> <tbody> <tr> <td><input type="checkbox"/> NPSH Req'd (m)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> Total Differential Head @ Rated Impeller _____ (m)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> Max. Differential Head @ Rated Impeller _____ (m)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> Minimum Continuous Flow</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Thermal (m<sup>3</sup>/h) _____ Stable (m<sup>3</sup>/h) _____</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					Rated	Max.	Normal	Min.	<input type="checkbox"/> NPSH Req'd (m)					<input type="checkbox"/> Total Differential Head @ Rated Impeller _____ (m)					<input type="checkbox"/> Max. Differential Head @ Rated Impeller _____ (m)					<input type="checkbox"/> Minimum Continuous Flow					Thermal (m <sup>3</sup> /h) _____ Stable (m <sup>3</sup> /h) _____				
	Rated	Max.	Normal	Min.																																																
Operating Time (hr./yr.)																																																				
NPSH Availabl (m)																																																				
	Rated	Max.	Normal	Min.																																																
<input type="checkbox"/> NPSH Req'd (m)																																																				
<input type="checkbox"/> Total Differential Head @ Rated Impeller _____ (m)																																																				
<input type="checkbox"/> Max. Differential Head @ Rated Impeller _____ (m)																																																				
<input type="checkbox"/> Minimum Continuous Flow																																																				
Thermal (m <sup>3</sup> /h) _____ Stable (m <sup>3</sup> /h) _____																																																				
<b>System Design</b> <input type="radio"/> Stand Alone Operation <input type="radio"/> Parallel Operation <input type="radio"/> Series Operation with Item Number _____				<input type="checkbox"/> Allowable Operating Region _____ To _____ (m <sup>3</sup> /h) <input type="checkbox"/> Best Efficiency Point for Rated Impeller _____ (m <sup>3</sup> /h) <input type="checkbox"/> Suction Specific Speed _____ <input type="checkbox"/> Impeller Diameter Rated _____ Max. _____ Min. _____ (mm) <input type="checkbox"/> Pump Rated Power _____ (bhp) <input type="checkbox"/> Efficiency _____ (%) <input type="checkbox"/> Maximum Power @ Rated Impeller _____ (kW)																																																
<b>Service</b> <input type="radio"/> Continuous <input type="radio"/> Intermittent (Starts/Day) _____				Rotation (Viewed from Coupling End) <input type="checkbox"/> CW <input type="checkbox"/> CCW																																																
<b>System Control Method</b> <input type="radio"/> Speed <input type="radio"/> Flow <input type="radio"/> Level <input type="radio"/> Temperature <input type="radio"/> Pressure <input type="radio"/> Pipe Friction Resistance Only				<b>Case Pressure Rating</b> <input type="checkbox"/> Max. Allowable Working Pressure _____ (kPa) @ _____ (°C) <input type="checkbox"/> Hydrostatic Test Pressure _____ (kPa)																																																
<b>PUMPED FLUID</b>				<b>SITE CONDITIONS</b>																																																
Pumped Fluid _____				Location <input type="radio"/> Indoor <input type="radio"/> Outdoor Altitude _____ (m) Range of Ambient Temperatures Min./Max. _____ / _____ (°C) Electrical Classification CL. _____ Gr. _____ Div. _____ <input type="radio"/> Non Hazardous																																																
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Rated</th> <th>Max.</th> <th>Normal</th> <th>Min.</th> </tr> </thead> <tbody> <tr> <td>Pumping Temperature (°C)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><b>At Designated Temperature</b></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Specific Gravity</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vapor Pressure (kPa abs)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Viscosity (cp)</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Specific Heat (kJ/kg °C)</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					Rated	Max.	Normal	Min.	Pumping Temperature (°C)					<b>At Designated Temperature</b>					Specific Gravity					Vapor Pressure (kPa abs)					Viscosity (cp)					Specific Heat (kJ/kg °C)					<b>GENERAL REMARKS</b>													
	Rated	Max.	Normal	Min.																																																
Pumping Temperature (°C)																																																				
<b>At Designated Temperature</b>																																																				
Specific Gravity																																																				
Vapor Pressure (kPa abs)																																																				
Viscosity (cp)																																																				
Specific Heat (kJ/kg °C)																																																				
Initial Boiling Point _____ (°C) @ _____ (kPa abs)																																																				
<b>Liquid</b> <input type="radio"/> Hazardous <input type="radio"/> Flammable <input type="radio"/> Other _____																																																				
Corrosion/Erosion Caused By _____																																																				
% Solid _____ Max. Particle Size _____ (mm)																																																				
4																																																				
3																																																				
2																																																				
1																																																				
0																																																				
REV	DATE	REASON FOR REVISION				BY	CHECK APPROVED																																													

		<b>FORM A2 ASME CENTRIFUGAL PUMP</b> Data Sheet (SI Units)		<b>RESP73</b> PAGE 2 of 3 November 2000																									
Job Number _____		Item Number _____		Purchase Order Number _____																									
Req./Spec. Number _____ / _____		Inquiry Number _____		Date _____																									
By _____																													
<b>MECHANICAL DATA</b>		<b>COUPLING BETWEEN PUMP AND DRIVER</b>																											
<b>Impeller Type</b> <input type="checkbox"/> Closed <input type="checkbox"/> Open <input type="checkbox"/> Semi-open <input type="checkbox"/> Other _____		Manufacturer _____ Type _____ Size _____ Model _____ Spacer Length (mm) _____																											
<b>Casing Mounting</b> <input type="checkbox"/> Foot <input type="checkbox"/> Centerline <input type="checkbox"/> Vertical Inline <input type="checkbox"/> Close-coupled		<b>Coupling Guard Type</b> <input type="checkbox"/> Manufacturer's Standard <input type="checkbox"/> Baseplate Mounted <input type="checkbox"/> Non-Spark Coupling Guard Required																											
<b>Bearings</b> <input type="checkbox"/> Bearings Manufacturer _____ <input type="checkbox"/> Radial Bearing Type _____ No. _____ <input type="checkbox"/> Thrust Bearing Type _____ No. _____ <input type="checkbox"/> Bearing Isolators _____ <input type="checkbox"/> Shaft Stiffness Ratio ( $L^3/D^4$ ) _____		Remarks _____ _____ _____																											
<b>Lubrication</b> <input type="radio"/> Flood <input type="radio"/> Pure Mist <input type="radio"/> Shielded (Grease) <input type="radio"/> Grease <input type="radio"/> Purge Mist <input type="radio"/> Sealed (Grease) <input type="radio"/> Constant Level Oiler Required <input type="checkbox"/> Housing Vent Required <input type="radio"/> Magnetic Drain Plug in Housing Required <input type="checkbox"/> Oil Cooler Required <input type="radio"/> Seal Spray Guard Required <input type="checkbox"/> Oil Viscosity ISO Grade _____ <input type="checkbox"/> Other _____		<b>BASEPLATE</b> <b>Remarks</b> <input type="radio"/> Grounded <input type="radio"/> Free Standing <input type="checkbox"/> Centerline of Pump to Stilt Bottom _____ (mm) <input type="radio"/> Vertical Pump Case Support Bracket <b>Design</b> <input type="radio"/> PIP Standard RESP002 (Data Sheet Attached) <input type="radio"/> Manufacturer's Standard Remarks _____																											
<b>Nozzle Connections</b> <input type="checkbox"/> Size <input type="checkbox"/> Rating <input type="checkbox"/> Facing Suction _____ Discharge _____ Aux. Case Connection <input type="radio"/> Drain Required <input type="checkbox"/> Size _____ (mm) <input type="radio"/> Threaded <input type="radio"/> Welded and Flanged		<b>PAINT AND SHIPMENT PREPARATION</b> <b>Pump</b> <input type="radio"/> Manufacturer's Standard <input type="radio"/> Manufacturer's Standard <input type="radio"/> Other _____ <input type="radio"/> Other _____ <b>Shipment</b> <input type="radio"/> Domestic <input type="radio"/> Export <input type="radio"/> Export Boxing Required Number of Months of Storage _____ <b>Total Weight</b> _____ (kg)																											
<b>MATERIALS</b> <b>Material Class Code</b> _____ Casing _____ Impeller _____ Cover _____ Shaft _____ Shaft Sleeve _____ Baseplate _____ Casing Gasket _____ Impeller Gasket _____ Casing Fasteners _____ Bearing Housing _____ Bearing Housing Adapter _____ Bearing Housing End Seals _____ Coupling Guard _____ Mechanical Seal Gland _____ Mechanical Seal Gland Fasteners _____		<b>INSPECTION AND TESTING</b> <input type="radio"/> Final Inspection Required <input type="radio"/> Days Notification Required _____ <table border="1"> <thead> <tr> <th>Test</th> <th>Non-Witnessed</th> <th>Witnessed</th> <th>Certificate</th> </tr> </thead> <tbody> <tr> <td>Hydrostatic</td> <td><input type="radio"/></td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Performance</td> <td><input type="radio"/></td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>NPSHR</td> <td><input type="radio"/></td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Vibration</td> <td><input type="radio"/></td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Other</td> <td><input type="radio"/></td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> </tbody> </table> <input type="radio"/> Dismantle and Inspect After Test <input type="radio"/> Casting Repair Procedure Approval Required <b>Material Certification Required</b> <input type="radio"/> Casing <input type="radio"/> Cover <input type="radio"/> Impeller <input type="radio"/> Shaft <input type="radio"/> Other _____ <b>Inspection Required for Connection Welds</b> <input type="radio"/> Manufacturer's Standard <input type="radio"/> Visual Inspection <b>Inspection Required for Castings</b> <input type="radio"/> Manufacturer's Standard <input type="radio"/> Visual Inspection <input type="radio"/> Other _____				Test	Non-Witnessed	Witnessed	Certificate	Hydrostatic	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Performance	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	NPSHR	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Vibration	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Other	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Test	Non-Witnessed	Witnessed	Certificate																										
Hydrostatic	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>																										
Performance	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>																										
NPSHR	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>																										
Vibration	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>																										
Other	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>																										
<b>DRIVER</b> Horsepower Rating _____ (kW) Speed _____ (rpm) Drive HP Selected or Max. S.G. _____ & Max. Visc. _____ (cp) Remarks _____ _____ _____ _____		<b>MANUFACTURER DOCUMENTATION REQUIREMENTS</b> <input type="radio"/> For Vendor Data Requirements Refer to: _____ Remarks _____ _____ _____ _____																											

		<b>FORM A2 ASME CENTRIFUGAL PUMP</b> Data Sheet (SI Units)		<b>RESP73</b> PAGE 3 of 3 November 2000																												
Job Number _____		Item Number _____		Purchase Order Number _____																												
Req./Spec. Number _____		Inquiry Number _____		Date _____																												
By _____																																
<input type="checkbox"/> <b>MECHANICAL SEAL</b>		<input type="checkbox"/> <b>BARRIER/BUFFER FLUSH SYSTEM</b>																														
<b>Supplied By</b> <input type="radio"/> Pump Manufacturer <input type="radio"/> Purchaser <b>Mounted By</b> <input type="radio"/> Pump Manufacturer <input type="radio"/> Purchaser Seal Classification Code _____ <input type="checkbox"/> Manufacturer _____ <input type="checkbox"/> Model _____ <input type="checkbox"/> Manufacturer Code _____ <b>Seal Type</b> <input type="radio"/> Cartridge <input type="radio"/> Component <b>Seal Design</b> <input type="radio"/> Single <input type="radio"/> Dual <input type="radio"/> Dry Gas <input type="radio"/> Pressurized <input type="radio"/> Unpressurized <b>Seal Chamber</b> <input type="radio"/> Taper Bore <input type="radio"/> Cylindrical Bore <b>Seal Chamber Size</b> <input type="radio"/> Oversized <input type="radio"/> Standard <input type="checkbox"/> Sleeve Material _____ <input type="checkbox"/> Pumping Ring Required _____ <input type="checkbox"/> Throat Bushing Required <input type="checkbox"/> Materials _____ Remarks _____		Barrier Flush Plan _____ <input type="radio"/> Barrier Flush Liquid _____ <input type="radio"/> Temperature Min./Max. _____ / _____ (°C) <input type="radio"/> Specific Gravity _____ <input type="radio"/> Specific Heat _____ (kJ/kg °C) <input type="radio"/> Vapor Pressure _____ (kPa abs) @ _____ (°C) <input type="checkbox"/> Pressure Required Min./Max. _____ / _____ (kPa) <input type="checkbox"/> MAWP of Secondary Seal System _____ (kPa) <input type="radio"/> Temperature Required Min./Max. _____ / _____ (°C) <b>Secondary Seal Flush Piping</b> <input type="radio"/> Tubing <input type="radio"/> Pipe <b>Material</b> <input type="radio"/> 316SS <input type="radio"/> Carbon Steel <input type="radio"/> Other _____ <input type="radio"/> Piping/Tubing Size _____ (mm) <b>Piping Assembly</b> <input type="radio"/> Threaded <input type="radio"/> Unions <input type="radio"/> Flanged <input type="radio"/> Tube Type Fittings <input type="radio"/> Socket Welded Remarks _____																														
<input type="checkbox"/> <b>SEAL GLAND</b>		<input type="checkbox"/> <b>SEAL SYSTEM INSTRUMENTATION</b>																														
<b>Taps Required</b> <input type="radio"/> Quench <input type="radio"/> Flush <input type="radio"/> Drain <input type="radio"/> Other _____ <input type="checkbox"/> Throttle Bushing <input type="checkbox"/> Materials _____ <input type="checkbox"/> <b>SEAL FLUSHING</b> Primary Flush Plan No. _____ <input type="radio"/> External Flush Liquid _____ <input type="radio"/> Supply Temperature Min./Max. _____ / _____ (°C) <input type="radio"/> Specific Gravity _____ <input type="radio"/> Specific Heat _____ (kJ/kg °C) <input type="radio"/> Vapor Pressure _____ (kPa abs) @ _____ (°C) <input type="checkbox"/> Flow Rate Required Min./Max. _____ / _____ (m³/h) <input type="checkbox"/> Pressure Required Min./Max. _____ / _____ (kPa) <input type="checkbox"/> Temperature Required Min./Max. _____ / _____ (°C) <b>Primary Seal Flush Piping</b> <input type="radio"/> Tubing <input type="radio"/> Pipe <input type="radio"/> Other _____ <b>Material</b> <input type="radio"/> 316SS <input type="radio"/> Carbon Steel <input type="radio"/> Other _____ <input type="radio"/> Piping/Tubing Size _____ (mm) <b>Piping Assembly</b> <input type="radio"/> Threaded <input type="radio"/> Unions <input type="radio"/> Flanged <input type="radio"/> Tube Type Fittings <input type="radio"/> Socket Welded Remarks _____		<table border="0"> <tr> <td><b>Primary Seals</b></td> <td>Gauges</td> <td>Switches</td> </tr> <tr> <td>Flow</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Temperature</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Pressure</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td><b>Secondary Seals</b></td> <td></td> <td></td> </tr> <tr> <td>Flow</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Pressure</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td>Level</td> <td><input type="radio"/></td> <td><input type="radio"/></td> </tr> <tr> <td colspan="3">Remarks _____</td> </tr> </table>				<b>Primary Seals</b>	Gauges	Switches	Flow	<input type="radio"/>	<input type="radio"/>	Temperature	<input type="radio"/>	<input type="radio"/>	Pressure	<input type="radio"/>	<input type="radio"/>	<b>Secondary Seals</b>			Flow	<input type="radio"/>	<input type="radio"/>	Pressure	<input type="radio"/>	<input type="radio"/>	Level	<input type="radio"/>	<input type="radio"/>	Remarks _____		
<b>Primary Seals</b>	Gauges	Switches																														
Flow	<input type="radio"/>	<input type="radio"/>																														
Temperature	<input type="radio"/>	<input type="radio"/>																														
Pressure	<input type="radio"/>	<input type="radio"/>																														
<b>Secondary Seals</b>																																
Flow	<input type="radio"/>	<input type="radio"/>																														
Pressure	<input type="radio"/>	<input type="radio"/>																														
Level	<input type="radio"/>	<input type="radio"/>																														
Remarks _____																																
		<input type="checkbox"/> <b>COOLING OR HEATING PIPING PLANS</b>																														
		<input type="radio"/> Piping Plan No. _____ <input type="radio"/> Name of Fluid _____ <input type="radio"/> Inlet Temperature _____ (°C) <input type="radio"/> Outlet Temperature _____ (°C) <input type="checkbox"/> Rated Flow _____ (m³/h) <input type="checkbox"/> Supply Pressure _____ (kPa) <input type="checkbox"/> Max. Allowable ΔP _____ (kPa) <input type="radio"/> Galvanized Pipe <input type="radio"/> SS Tubing <input type="radio"/> Sight Flow Indicator <input type="radio"/> Outlet Shut-Off Valve Remarks _____																														

## ASME Services

ASME is committed to developing and delivering technical information. At ASME's Information Central, we make every effort to answer your questions and expedite your orders. Our representatives are ready to assist you in the following areas:

ASME Press  
*Codes & Standards*  
Credit Card Orders  
IMEchE Publications  
Meetings & Conferences  
Member Dues Status

Member Services & Benefits  
Other ASME Programs  
Payment Inquiries  
Professional Development  
Short Courses  
Publications

Public Information  
Self-Study Courses  
Shipping Information  
Subscriptions/Journals/Magazines  
Symposia Volumes  
Technical Papers

### How can you reach us? It's easier than ever!

There are four options for making inquiries\* or placing orders. Simply mail, phone, fax, or E-mail us and an Information Central representative will handle your request.

*Mail*  
**ASME**  
22 Law Drive, Box 2900  
Fairfield, New Jersey  
07007-2900

*Call Toll Free*  
**US & Canada:** 800-THE-ASME  
(800-843-2763)  
**Mexico:** 95-800-THE-ASME  
(95-800-843-2763)  
**Universal:** 973-882-1167

*Fax-24 hours*  
973-882-1717  
973-882-5155

*E-Mail-24 hours*  
Infocentral @asme.org

\* Information Central staff are not permitted to answer inquiries about the technical content of this code or standard. Information as to whether or not technical inquiries are issued to this code or standard is shown on the copyright page. All technical inquiries must be submitted in writing to the staff secretary. Additional procedures for inquiries may be listed within.



ISBN 0-7918-2713-5



9 780791 827130



J01901