

ASME B73.2-2016
[Revision of ASME B73.2-2003 (R2008)]

Specification for Vertical In-Line Centrifugal Pumps for Chemical Process

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME B73.2-2016

[Revision of ASME B73.2-2003 (R2008)]

Specification for Vertical In-Line Centrifugal Pumps for Chemical Process

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: April 14, 2017

This Standard will be revised when the Society approves the issuance of a new edition. There will be no written interpretations of the requirements of this Standard issued to this edition.

Periodically certain actions of the ASME B73 Committee may be published as Cases. Cases are published on the ASME Web site under the B73 Committee Page at go.asme.org/B73committee as they are issued.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The B73 Committee Page can be found at go.asme.org/B73committee. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting “Errata” in the “Publication Information” section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2017 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	v
Committee Roster	vii
Correspondence With the B73 Committee	viii
1 Scope	1
2 References	1
3 Alternative Design	3
4 Nomenclature and Definitions	4
4.1 Definition of Terms	4
4.2 Additional Definitions	4
5 Design and Construction Features	4
5.1 Pressure and Temperature Limits	4
5.2 Flanges	4
5.3 Casing	4
5.4 Impeller	5
5.5 Shaft	5
5.6 Shaft Sealing	6
5.7 Driver and Coupling Design	9
5.8 Materials of Construction	14
5.9 Corrosion Allowance	14
5.10 Direction of Rotation	14
5.11 Dimensions	14
5.12 Miscellaneous Design Features	14
6 General Information	17
6.1 Application	17
6.2 Tests and Inspections	20
6.3 Nameplates	21
7 Documentation	21
7.1 General	21
7.2 Requirements	21
7.3 Document Description	21
7.4 Specially Requested Documentation	23
Figures	
1 Shaft Sleeve Runout	6
2 Cylindrical Seal Chamber	7
3 Tapered Seal Chamber	8
4 Face Runout	9
5 Register Concentricity	9
6 Packing Box	11
7 Sample Outline Drawing	22
Tables	
1 Pump Dimensions	2
2 Universal Cover Dimensions	10

3	Nominal Shaft Extension and Mounting Dimensions for Vertical Solid Shaft P-Base In-Line Pump Motors	12
4	Motor Horsepower Selection	13
5	Pump Material Classification Code	15
6	Material of Construction	16
7	Minimum Requirement for Auxiliary Piping Materials	17
8	Approximate Performance of Standard Pumps (60 Hz)	18
9	Approximate Performance of Standard Pumps (50 Hz)	19
10	Minimum Continuous Flow	20
 Mandatory Appendices		
I	ASME Centrifugal Pump Data Sheet	25
II	Mechanical Seal and Packing Configuration Codes	34
 Nonmandatory Appendix		
A	Electronic Data Exchange	36

FOREWORD

The vertical in-line style of centrifugal pump was introduced for chemical process use. These pumps have certain advantages that have led to growing acceptance of this configuration for chemical process applications. In January 1969, in response to this interest, the Manufacturing Chemists Association (MCA) requested that the American National Standards Institute (ANSI) develop a standard. In 1971, the scope of B73 was expanded to include vertical in-line pumps, using the MCA draft of February 1971 as a basis.

American National Standard B73.2 was developed and was approved by the B73 Standards Committee; final approval by ANSI was granted on April 21, 1975.

Shortly thereafter, the American National Standards Committee B73 revised the Standard, introducing new information on critical speed, bearing housing design, vibration, bearing frame adapter, and bearings. The 1984 edition included, for the first time, an appendix that covered documentation of pump and driver outline drawing, a vertical in-line pump data sheet, mechanical seal drawing, stuffing box piping plans, and cooling/heating piping plans.

That edition was approved by letter ballot of the B73 Main Committee on April 25, 1983. Following acceptance by the Sponsor, the revision was referred to ANSI for designation as an American National Standard. Designation was granted on March 23, 1984.

In 1986, the Committee began discussing revisions that resulted in changes to the section on jackets. Additionally, the information on the stuffing box and seal chamber was expanded. Modifications were also made to the appendix drawings and plans.

These revisions were approved by the B73 Committee. Following B73 approval, the proposal was submitted to ANSI for recognition as an American National Standard. Approval was granted on January 22, 1991.

With the expanding utilization of ASME B73 pumps in the chemical process industry and their growing acceptance in the hydrocarbons processing industry, the B73 Committee has continued to improve the B73.2 Standard. The 2003 revision of the Standard incorporated the addition of the technical documentation of the pump as a mandatory portion of the Standard, which previously appeared as a nonmandatory appendix. The incorporation was partly in response to the needs of the user community for compliance to U.S. government regulations covering chemical process equipment and pumps, specifically OSHA Process Safety Management, 29 CFR 1910.119. Recent publications by the Hydraulic Institute (HI) in areas such as preferred operating region and NPSH margin were incorporated into this revision. Additionally, the materials of construction section was expanded to include readily available corrosion-resistant alloy. In total, these revisions to the Standard were intended to better serve process industries and expand the use of ASME B73 pumps worldwide.

The 2016 edition of the Standard includes a number of revisions. Reference is made to the current API practices for mechanical seal configurations and cooling and heating plans. A mechanical seal configuration code that is aligned with the API sealing standard and a material classification code have been added to B73.2. A universal cover has been offered as an option to the Standard as an alternate sealing cover. Requirements for the bearing frame have been revised to ensure more robust pumps. Nomenclature for the pump sizes has been added to align with the more commonly used sizes identified in B73.1. Approximate hydraulic performance for the B73.2 pumps has been established. The default performance test acceptance grade has been revised to reflect the new HI/ISO performance test standard. More detail was added to the required drawings, curve, and documentation that should be included with the pump. A new data sheet common to the B73.1 and B73.2 Standards has been developed and added. This Standard endorses the Electronic Data Exchange standard, which was developed by the Hydraulic Institute and Fiatech AEX project. These revisions have been made to further improve the reliability of the B73.2 pumps. These changes also better align with the HI and API pump standards.

Suggestions for improvement to this Standard are welcome and should be sent to the Secretary, B73 Main Committee, The American Society of Mechanical Engineers, Two Park Avenue, New York, NY 10016-5990.

This revision was approved as an American National Standard on November 16, 2016.

ASME B73 COMMITTEE

Chemical Standard Pumps

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

K. R. Burkhardt, *Chair*

R. W. Estep, *Vice Chair*

A. R. Amaral, *Secretary*

STANDARDS COMMITTEE PERSONNEL

A. R. Amaral, The American Society of Mechanical Engineers

K. R. Burkhardt, Dupont

D. Clark, HMD Sealless Pumps, Ltd.

G. C. Clasby, Flowserve Corp.

M. Coussens, Peerless Pump Co.

R. W. Estep, The Dow Chemical Co.

J. A. Wilson, *Alternate*, The Dow Chemical Co.

J. Hubbard, ITT Goulds Pumps

M. B. Huebner, Flowserve Corp.

I. S. James, Amec Foster Wheeler

B. S. Myers, Bayer Crop Science

G. W. Sabol, Flint Hills Resources

C. K. van der Sluijs, Flowserve Corp.

E. Eylat, *Alternate*, Flowserve Corp.

A. E. Stavale, ITT Goulds Pumps

E. J. Kupf, *Alternate*, ITT Goulds Pumps

D. W. Wood, Chemours

CORRESPONDENCE WITH THE B73 COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by proposing revisions or a case, and attending Committee meetings. Correspondence should be addressed to:

Secretary, B73 Standards Committee
The American Society of Mechanical Engineers
Two Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued to provide alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Standard and the paragraph, figure, or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

Attending Committee Meetings. The B73 Standards Committee regularly holds meetings and/or telephone conferences that are open to the public. Persons wishing to attend any meeting and/or telephone conference should contact the Secretary of the B73 Standards Committee. Future Committee meeting dates and locations can be found on the Committee Page at go.asme.org/B73committee.

SPECIFICATION FOR VERTICAL IN-LINE CENTRIFUGAL PUMPS FOR CHEMICAL PROCESS


1 SCOPE

This Standard is a design and specification standard that covers metallic centrifugal pumps of vertical shaft single-stage design with suction and discharge nozzles in-line. This Standard includes dimensional interchangeability requirements and certain design features to facilitate installation and maintenance and enhance reliability and safety of B73.2 pumps. It is the intent of this Standard that pumps of the same standard dimension designation from all sources of supply shall be interchangeable with respect to mounting dimensions, size, and location of suction and discharge nozzles (see Table 1). Maintenance and operation requirements are not included in this Standard.

2 REFERENCES

The following documents form a part of this Standard to the extent specified herein. The latest edition shall apply:

- ANSI B11.19, Performance Requirements for Safeguarding
Publisher: Association for Manufacturing Technology (AMT), 7901 Westpark Drive, McLean, VA 22102-4206 (www.amtonline.org)
- ANSI/ABMA 9, Load Ratings and Fatigue Life for Ball Bearings
ANSI/ABMA 11, Load Ratings and Fatigue Life for Roller Bearings
Publisher: American Bearing Manufacturers Association (ABMA), 2025 M Street, NW, Suite 800, Washington, DC 20036 (www.americanbearings.org)
- ANSI/HI 1.1-1.2, Rotodynamic Centrifugal Pumps for Nomenclature and Definitions
ANSI/HI 1.3, Rotodynamic Centrifugal Pumps for Design and Application
ANSI/HI 1.4, Rotodynamic Centrifugal Pumps for Manuals Describing Installation, Operation and Maintenance
ANSI/HI 9.1-9.5, Pumps — General Guidelines for Types, Applications, Definitions, Sound Measurements, and Documentation
ANSI/HI 9.6.1, Rotodynamic Pumps Guideline for NPSH Margin
ANSI/HI 9.6.2, Rotodynamic Pumps for Assessment of Applied Nozzle Loads
- ANSI/HI 9.6.4, Rotodynamic Pumps for Vibration Measurements and Allowable Values
ANSI/HI 14.6, Rotodynamic Pumps for Hydraulic Performance Acceptance Tests
Publisher: Hydraulic Institute (HI), 6 Campus Drive, Parsippany, NJ 07054-4406 (www.pumps.org)
- ANSI/NEMA MG 1, Motors and Generators
Publisher: National Electrical Manufacturers Association (NEMA), 1300 North 17th Street, Suite 900, Arlington, VA 22209 (www.nema.org)
- API 610, Centrifugal Pumps for Petroleum, Petrochemical and Natural Gas Industries
API 682, Pumps-Shaft Sealing Systems for Centrifugal and Rotary Pumps
Publisher: American Petroleum Institute (API), 1220 L Street, NW, Washington, DC 20005 (www.api.org)
- ASME B16.5, Pipe Flanges and Flanged Fittings
ASME B16.11, Forged Fittings, Socket-Welding and Threaded
ASME B16.42, Ductile Iron Pipe Flanges and Flanged Fittings, Classes 150 and 300
Publisher: The American Society of Mechanical Engineers (ASME), Two Park Avenue, New York, NY 10016-5990 (www.asme.org)
- ASTM A48/A48M, Standard Specification for Gray Iron Castings
ASTM A105/A105M, Standard Specification for Carbon Steel Forgings for Piping Applications
ASTM A106/A106M, Standard Specification for Seamless Carbon Steel Pipe for High-Temperature Service
ASTM A108, Standard Specification for Steel Bar, Carbon and Alloy, Cold-Finished
ASTM A182/A182M, Standard Specification for Forged or Rolled Alloy and Stainless Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High-Temperature Service
ASTM A193/A193M, Standard Specification for Alloy-Steel and Stainless Steel Bolting for High-Temperature or High Pressure Service and Other Special Purpose Applications

Table 1 Pump Dimensions

Dimension Designation [Note (2)]		Size; Suction × Discharge × Nominal Impeller Diameter		<i>SD</i>		<i>T</i> , Max.	
in.	(mm)	in.	(mm)	in. (+0.10, −0.08)	[mm (+2.5, −2.0)]	in.	(mm)
2015/15	(50-40-380)	2 × 1.5 × 6	(50 × 40 × 150)	14.96	(380)	6.89	(175)
2015/17	(50-40-430)	2 × 1.5 × 8	(50 × 40 × 200)	16.93	(430)	6.89	(175)
2015/19	(50-40-480)	2 × 1.5 × 10	(50 × 40 × 250)	18.9	(480)	6.89	(175)
3015/15	(80-40-380)	3 × 1.5 × 6	(80 × 40 × 150)	14.96	(380)	7.87	(200)
3015/19	(80-40-480)	3 × 1.5 × 8	(80 × 40 × 200)	18.9	(480)	7.87	(200)
3015/19	(80-40-480)	3 × 1.5 × 10	(80 × 40 × 250)	18.9	(480)	7.87	(200)
3015/24	(80-40-610)	3 × 1.5 × 13	(80 × 40 × 330)	24.02	(610)	7.87	(200)
3020/17	(80-50-430)	3 × 2 × 6	(80 × 50 × 150)	16.93	(430)	7.87	(200)
3020/17	(80-50-430)	3 × 2 × 7	(80 × 50 × 180)	16.93	(430)	7.87	(200)
3020/20	(80-50-510)	3 × 2 × 10	(80 × 50 × 250)	20.08	(510)	7.87	(200)
3020/24	(80-50-610)	3 × 2 × 13	(80 × 50 × 330)	24.02	(610)	7.87	(200)
4030/22	(100-80-560)	4 × 3 × 8	(100 × 80 × 200)	22.05	(560)	8.86	(225)
4030/25	(100-80-635)	4 × 3 × 10	(100 × 80 × 250)	25	(635)	8.86	(225)
4030/28	(100-80-710)	4 × 3 × 13	(100 × 80 × 330)	27.95	(710)	8.86	(225)
6040/24	(150-100-610)	6 × 4 × 9	(150 × 100 × 225)	24.02	(610)	9.84	(250)
6040/28	(150-100-710)	6 × 4 × 10	(150 × 100 × 250)	27.95	(710)	9.84	(250)
6040/30	(150-100-760)	6 × 4 × 13	(150 × 100 × 330)	29.92	(760)	9.84	(250)

NOTES:

(1) Optional separate pedestal.

(2) Pump designation defines design, flange sizes, and *SD* dimension (e.g., VC, VB 2015/15).

- ASTM A194/A194M, Standard Specification for Carbon Steel, Alloy Steel, and Stainless Steel Nuts for Bolts for High Pressure or High Temperature Service, or Both
- ASTM A216/A216M, Standard Specification for Steel Castings, Carbon, Suitable for Fusion Welding, for High Temperature Service
- ASTM A269, Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service
- ASTM A276, Standard Specification for Stainless Steel Bars and Shapes
- ASTM A312/A312M, Standard Specification for Seamless, Welded, and Heavily Cold Worked Austenitic Stainless Steel Pipes
- ASTM A395/A395M, Standard Specification for Ferritic Ductile Iron Pressure-Retaining Castings for Use at Elevated Temperatures
- ASTM A434/A434M, Standard Specification for Steel Bars, Alloy, Hot-Wrought or Cold-Finished, Quenched and Tempered
- ASTM A479/A479M, Standard Specification for Stainless Steel Bars and Shapes for Use in Boilers and Other Pressure Vessels
- ASTM A494/A494M, Standard Specification for Castings, Nickel and Nickel Alloy
- ASTM A519, Standard Specification for Seamless Carbon and Alloy Steel Mechanical Tubing
- ASTM A536, Standard Specification for Ductile Iron Castings
- ASTM A743/A743M, Standard Specification for Castings, Iron-Chromium, Iron-Chromium-Nickel, Corrosion Resistant, for General Application
- ASTM A744/A744M, Standard Specification for Castings, Iron-Chromium-Nickel, Corrosion Resistant, for Severe Service
- ASTM A890/A890M, Standard Specification for Castings, Iron-Chromium-Nickel-Molybdenum Corrosion-Resistant, Duplex (Austenitic/Ferritic) for General Application
- ASTM A995/A995M, Standard Specification for Castings, Austenitic-Ferritic (Duplex) Stainless Steel, for Pressure-Containing Parts
- ASTM B160, Standard Specification for Nickel Rod and Bar
- ASTM B164, Standard Specification for Nickel-Copper Alloy Rod, Bar and Wire
- ASTM B335, Standard Specification for Nickel-Molybdenum Alloy Rod
- ASTM B348, Standard Specification for Titanium and Titanium Alloy Bars and Billets
- ASTM B367, Standard Specification for Titanium and Titanium Alloy Castings
- ASTM B473, Standard Specification for UNS N08020, UNS N08024, and UNS N08026 Nickel Alloy Bar and Wire
- ASTM B574, Standard Specification for Low-Carbon Nickel-Chromium-Molybdenum, Low-Carbon Nickel-Molybdenum-Chromium, Low-Carbon Nickel-Molybdenum-Chromium-Tantalum, Low-Carbon Nickel-Chromium-Molybdenum-Copper, and Low-Carbon Nickel-Chromium-Molybdenum-Tungsten Alloy Rod
- ASTM B575, Standard Specification for Low-Carbon Nickel-Chromium-Molybdenum, Low-Carbon Nickel-Chromium-Molybdenum-Copper, Low-Carbon Nickel-Chromium-Molybdenum-Tantalum, Low-Carbon Nickel-Chromium-Molybdenum-Tungsten, and Low-Carbon Nickel-Molybdenum-Chromium Alloy Plate, Sheet, and Strip
- Publisher: American Society for Testing and Materials (ASTM International), 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959 (www.astm.org)
- AWS B1.11, Guide for the Visual Examination of Welds
- Publisher: American Welding Society (AWS), 8669 NW 36 Street, No. 130, Miami, FL 33166 (www.aws.org)
- ISO 281, Rolling bearings — Dynamic load ratings and rating life
- ISO 1940-1, Mechanical vibration — Balance quality requirements for rotors in a constant (rigid) state — Part 1: Specification and verification of balance tolerances
- ISO 13709, Centrifugal pumps for petroleum, petrochemical and natural gas industries
- ISO 21049, Pumps — Shaft sealing systems for centrifugal and rotary pumps
- Publisher: International Organization for Standardization (ISO), Central Secretariat, Chemin de Blandonnet 8, Case Postale 401, 1214 Vernier, Geneva, Switzerland (www.iso.org)
- MSS SP-55, Quality Standard for Steel Castings for Valves, Flanges, Fittings, and Other Piping Components — Visual Method for Evaluation of Surface Irregularities
- Publisher: Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS), 127 Park Street, NE, Vienna, VA 22180 (www.msshq.org)

3 ALTERNATIVE DESIGN

Alternate designs will be considered, provided they meet the intent of this Standard and cover construction characteristics that are equivalent to and otherwise in accordance with these specifications. All deviations from these specifications shall be described in detail.

4 NOMENCLATURE AND DEFINITIONS

4.1 Definition of Terms

The nomenclature and definitions of pump components shall be in accordance with ANSI/HI 1.1-1.2 except as noted below.

4.2 Additional Definitions

auxiliary piping: includes all piping connected to the pump, seal chamber, packing box, or seal piping plan excluding the main piping connected at the pump suction and discharge flanges. Auxiliary piping includes piping, tubing, and all attached components such as valves, instrumentation, coolers, and seal reservoirs.

in-line pump: an overhung impeller-type pump whose driver is supported exclusively by the pump, and whose suction and discharge connections have a common centerline that is perpendicular to, and intersects, the shaft axis.

non-pressure-containing nonwetted parts: pump parts that do not contain or retain pressure and are not wetted by the pumped fluid.

non-pressure-containing wetted parts: pump parts that do not contain or retain pressure, but are wetted by the pumped fluid (e.g., wear ring).

pressure-containing wetted parts: pump parts that contain pressure and are wetted by the pumped fluid (e.g., casing and sealing cover).

pressure-retaining nonwetted parts: pump parts that retain pressure but are not wetted by the pumped fluid (e.g., adapter and fasteners).

sealing cover: refers to seal chamber, universal cover, or packing box.

supplier: manufacturer or manufacturer's representative that supplies the equipment.

5 DESIGN AND CONSTRUCTION FEATURES

5.1 Pressure and Temperature Limits

5.1.1 Pressure Limits. Pressure limitations shall be stated by the pump manufacturer. See para. 5.8.3 for auxiliary piping.

5.1.1.1 The design pressure of the casing, including seal chamber or stuffing box and gland, shall be at least as great as the pressure-temperature rating of ASME B16.5 Class 150 flanges or ASME B16.42 Class 150 flanges for the material used.

5.1.1.2 The design pressure of jackets shall be at least 100 psig (689 kPa) gage at 340°F (171°C). Heating jackets may be required for jacket temperatures to 500°F (260°C) with a reduction in pressure corresponding to the reduction in yield strength of the jacket material.

5.1.1.3 Casing, sealing cover, gland, and jackets shall be designed to withstand a hydrostatic test at 1.5 times the maximum design pressure for the particular component and material of construction used (see para. 6.2.1.1).

5.1.2 Temperature Limits. Temperature limitations shall be stated by the pump manufacturer. Pumps should be available for temperatures up to 500°F (260°C). Jacketing and other modifications may be required to meet the operating temperature. See para. 5.8.3 for auxiliary piping.

5.2 Flanges

5.2.1 General. Suction and discharge nozzles shall be flanged. Flange drilling, facing, and minimum thickness shall conform to ASME B16.5 Class 150 or ASME B16.42 Class 150 standards except that marking requirements are not applicable and the maximum acceptable tolerance on parallelism of the back of the flange shall be 3 deg. Flanges shall be flat-faced at the full raised-face thickness (minimum) called for in the ASME standards for the material of construction. Raised-face flanges may be offered as an option. Bolt holes shall straddle the horizontal and vertical centerline. Bolt holes may be tapped when adequate space for nuts is not available behind flanges as noted in Table 1. Through bolt holes are preferred. When tapped holes are supplied, they shall be noted on the outline drawing.

5.2.2 Class 300 Option. As an option, Class 300 flanges in accordance with ASME B16.5 or ASME B16.42 may be offered with pressure ratings subject to the manufacturer's casing pressure-temperature limitations. Class 300 flanges shall be flat-faced at full raised-face thickness (minimum), or raised-face flanges may be offered as an option.

5.2.3 All pumps regardless of flange rating shall conform to the *SD* dimensions shown in Table 1.

5.2.4 Heavy Hex Nuts. Where heavy hex nuts cannot be used, the location shall be noted on the outline drawing.

NOTE: ASME B16.5 and ASME B16.42 indicate the use of heavy hex nuts for certain flange connections. On many B73 pumps, heavy hex nuts cannot be used due to available space. Standard hex nuts are often substituted. The use of standard hex nuts may not allow the achievement of full bolt stress, which may impact proper gasket compression. With most gasket materials, this does not reduce the gasket's ability to properly seal. However, this is a consideration for metallic and semi-metallic (i.e., spiral wound) gaskets where significant preload may be required to achieve sufficient tightness.

5.3 Casing

5.3.1 Drain Connection Boss(es). Pump casing shall have boss(es) to provide for drain connection(s) in the lowest part of the casing. Boss size shall accommodate

$\frac{1}{2}$ in. NPT minimum. Boss(es) shall be drilled and tapped when specified by the purchaser.

5.3.2 Auxiliary Connection Boss(es). The suction and discharge nozzles shall have boss(es) for gage connections. Boss size shall accommodate $\frac{1}{4}$ in. NPT minimum, $\frac{1}{2}$ in. NPT preferred. Bosses shall be drilled and tapped when specified by the purchaser.

5.3.3 Support. The casing shall be designed to be supported by the suction and discharge flanges alone when mounted with the shaft in the vertical position; however, all casings shall be designed to accommodate an optional auxiliary support.

5.3.4 Disassembly. The design shall permit removal of the back pull-out assembly from the casing without disturbing the suction and discharge connections. Tapped holes for jackscrews, slots for wedges, or equivalent means, shall be provided to facilitate removal of the back pull-out assembly. Jackscrews shall not cause damage to parts that will interfere with reassembly and sealing when the parts are reused.

5.3.5 Heating or Cooling

5.3.5.1 There are several methods of cooling or heating areas of most ASME B73.2 pumps. The sealing cover, pump casing, and bearing housing are areas of the pump that may have design features available for heating or cooling.

5.3.5.2 Jackets for heating or cooling the casing and/or sealing cover are optional. Connections shall be $\frac{3}{8}$ in. NPT minimum, with $\frac{1}{2}$ in. NPT preferred. When a jacket is to be used for heating by steam, the inlet connection shall be located at the top of the jacket, and the drain connection shall be located at the bottom of the jacket to prevent the formation of water pockets. Jackets for liquid cooling shall have the outlet at the top to prevent the formation of vapor pockets and a drain at the bottom for freeze protection.

5.3.6 Gasket. The casing-to-cover gasket(s) shall be confined on the atmospheric side to prevent blowout. Design shall consider thermal cycling that may occur as a condition of service. Gaskets shall be selected so the required seating stress is compatible with the available bolt load (strength and area). The gasket material shall be suitable for the service conditions and flange facing/finish.

5.3.7 Bolting. The pressure-containing fasteners shall be designed to account for maximum allowable working pressure (MAWP) and be capable of maintaining a seal on the gasket during operation. The fasteners shall have a sufficient bolt area to ensure that the resulting tensile stresses during design loading do not exceed the allowable bolt stresses given in ASME Section II, Part D (Table 3). When there are sufficient strength differences between the material of the

tapped hole and the fastener, the design shall consider possible shearing of the threads of the tapped connection.

5.4 Impeller

5.4.1 Types. Impellers may be of the open, semi-open, or closed design.

5.4.2 Adjustment. If axial adjustment is required by the design, the pump shall be provided with a means for external adjustment of the impeller clearance without disassembly of the pump except for the coupling guard.

5.4.3 Balance. Impellers shall meet ISO 1940-1 Grade 6.3 after final machining.

5.4.4 Attachment. The impeller may be keyed or threaded to the shaft with pump rotation to tighten. Shaft threads and keyways shall be protected so they will not be wetted by the pumped fluid.

5.5 Shaft

5.5.1 Diameter. The seal mounting surface includes the shaft or shaft sleeve outside diameter within the seal chamber or packing box and enough length beyond to accommodate outside seals. The diameter of the seal mounting surface shall be sized in increments of 0.125 in. (3.18 mm). To provide for the use of mechanical seals, the tolerance on that diameter shall not exceed nominal to minus 0.002 in. (0.05 mm).

5.5.2 Finish. Surface finish of the shaft or sleeve through the sealing cover and at bearing housing seals shall not exceed a roughness of 32 μ in. (0.8 μ m) AA, unless otherwise required.


5.5.3 Runout. Shaft runout shall be limited as follows:

- (a) shaft rotated on centers: 0.001 in. (0.025 mm) full indicator movement (FIM) reading at any point; and
- (b) outside diameter of shaft or removable sleeve when installed in pump: 0.002 in. (0.05 mm) FIM at the gland end of sealing cover (see Fig. 1).

5.5.4 Deflection. Dynamic shaft deflection at the impeller centerline shall not exceed 0.005 in. (0.13 mm) anywhere within the allowable operating region as specified in para. 6.1.6. Hydraulic loads and shaft deflection shall be calculated in accordance with ANSI/HI 1.3.

5.5.5 Running Clearances. Clearances must be sufficient to prevent internal rubbing when the pump is subjected to the maximum allowable flange loads (para. 6.1.2) while running within the allowable operating region (para. 6.1.6).

5.5.6 Critical Speed. The first lateral critical speed of the rotating assembly shall be at least 120% of the maximum operating speed. A "dry critical speed" calculation is adequate to verify compliance. ANSI/HI 9.6.4

Fig. 1 Shaft Sleeve Runout

shall be used to calculate static deflections used for the critical speed calculation.

5.5.7 Fillets and Radii. All shaft shoulder fillets and radii shall be made as large as practical and finished to minimize stress risers.

5.6 Shaft Sealing

5.6.1 Design. The following are the three basic types of sealing covers:

- (a) seal chamber
- (b) universal cover
- (c) packing box

The seal chamber and packing box are standard arrangements. The universal cover should be available as an option.

The seal chamber is designed to accommodate mechanical seals only and can be of several designs for various types of seals. The design includes a separate gland plate where required. The universal cover is designed to provide a standard dimensional platform for installation of cartridge-mounted mechanical seals. The packing box is designed for packing, but may be able to accommodate some sizes and types of mechanical seals without the advantages of the seal chamber or universal cover.

Details and tutorials on piping plans for mechanical seals can be found in API 682 (ISO 21049). Piping plan designations found in API 682 (i.e., Plan 11, Plan 53A, etc.) will be applied to ASME B73 pump applications. Details and designations on piping plans involving pump heating or cooling (i.e., bearing bracket cooling, heating and cooling jackets, etc.) can be found in API 610 (ISO 13709). The piping plan references from API 682

and API 610 shall only apply to the schematic and general description of the piping plan and not the specific design of components and hardware that may be contained in these Standards.

5.6.2 Seal Chamber. The seal chamber can be a cylindrical or a tapered design. The tapered bore seal chamber shall have a minimum of 4-deg taper open toward the pump impeller and shall include features that prevent the accumulation of solid particles in the chamber, unless otherwise specified. The seal chamber shall be designed to incorporate the details quantified in Figs. 2 and 3.

The secondary seal contact surface(s) shall not exceed a roughness of 63 $\mu\text{in.}$ (1.60 μm) AA. Seal chamber bore corners and entry holes, such as those used for flushing or venting, shall be suitably chamfered or rounded to prevent damage to secondary seals at assembly.

The seal chamber shall include means of eliminating trapped air or gas. Vent connections, when required for this purpose, shall be located at the highest practical point; drains, when provided, shall be located at the lowest practical point. The location of piping connections to the seal chamber for other functions is optional. A primary flush plan is not recommended for single mechanical seals with tapered bore seal chambers and may impede their operation.

The size of all piping connections to the seal chamber shall be $\frac{1}{4}$ in. NPT minimum, with $\frac{1}{2}$ in. NPT preferred.

5.6.2.1 Seal Chamber Runout. Mechanical seal performance is highly dependent on the runout conditions that exist at the mechanical seal chamber. Pumps shall be designed for compliance with the runout limits shown below. On smaller pump sizes, the actual measurement of these runout values may not be possible or practical on an assembled pump. Types of runout having significant effect on seal performance include the following:


(a) *Seal Chamber Face Runout.* This is a measure of the perpendicularity of the seal chamber face with respect to the pump shaft. It is measured by mounting a dial indicator on the pump shaft and measuring FIM at the face of the seal chamber. The maximum allowable runout is 0.003 in. (0.08 mm) FIM (see Fig. 4).

(b) *Seal Chamber Register Runout.* Provisions shall be made for centering the gland with either an inside or outside diameter register. This register shall be concentric with the shaft or sleeve within 0.005 in. (0.13 mm) FIM (see Fig. 5).

5.6.3 Universal Cover. The universal cover shall be as indicated in Table 2. The runout requirements from para. 5.6.2.1 apply for face and register fits.

NOTE: The seal operating cavity is the responsibility of the mechanical seal supplier and should be incorporated into the seal gland.


Fig. 2 Cylindrical Seal Chamber



Shaft or Sleeve Diameter
Up to 1.5 in. (38 mm)
More than 1.5 in. (38 mm)



Radial Clearance X Min.
X = 0.750 in. (19 mm)
X = 0.875 in. (22.2 mm)

Fig. 3 Tapered Seal Chamber



Shaft or Sleeve Diameter
Up to 1.5 in. (38 mm)
More than 1.5 in. (38 mm)

Radial Clearance X Min.
X = 0.750 in. (19 mm)
X = 0.875 in. (22.2 mm)

Fig. 4 Face Runout**Fig. 5 Register Concentricity**

5.6.4 Packing Box. The packing box packing bore surface shall not exceed a roughness of $63 \mu\text{in.}$ ($1.60 \mu\text{m}$) AA. One flush connection shall be provided as a minimum. Additional connections to the packing box are optional. The size shall be $\frac{1}{4}$ in. NPT minimum, with $\frac{1}{2}$ in. NPT preferred. Registers shall maintain the packing box bore concentric with the axis of the pump shaft within 0.005 in. (0.13 mm) FIM. The packing box face shall be perpendicular to the axis of the assembled pump shaft within 0.003 in. (0.08 mm) FIM. Figure 6 shows the recommended packing box dimensions. The packing box also shall be suitable for proper installation and operation of some sizes and types of mechanical seals, including means of venting trapped air or gas at the highest practical point.

5.6.5 Space Requirements

5.6.5.1 Space in the various seal chamber designs shall provide for the seal configurations identified in Mandatory Appendix II.

5.6.5.2 Space in the packing box and exterior clearance area shall provide for

- (a) five rings of packing plus a lantern ring and repacking space
- (b) throat bushing, a lantern ring, and three rings of packing

5.6.6 Gland

5.6.6.1 Bolting. Pumps shall be designed for four gland bolts, but glands shall be

- (a) two-bolt or four-bolt for packing
- (b) four-bolt for mechanical seals

Minimum gland bolt size shall be $\frac{3}{8}$ in (9.5 mm).


5.6.6.2 Gasket. The gland-to-seal chamber gasket or O-ring used for mechanical seals shall be confined on the atmospheric side to prevent blowout.

5.6.6.3 Cartridge Seal Glands. Cartridge seals shall either center on the shaft or pilot on the seal chamber.

5.6.7 Alternative Seal Specification. As an alternative to the mechanical seal specifications found in this Standard, seals may be provided in accordance with API 682 (ISO 21049) Category 1. The requirement to apply API 682 must be designated on the Pump Data Sheet (Mandatory Appendix I) or on the purchasing specification. Seals provided in accordance with API 682 are only intended for ASME B73 pumps using a cylindrical seal chamber, self-venting tapered seal chamber, or universal cover. The seal chamber design and mechanical seal interface specifications shall be applied from ASME B73.2, not from API 682.

5.7 Driver and Coupling Design


5.7.1 Type VC Vertical Coupled Design. The pump shaft is attached to the motor shaft by a rigid spacer

Table 2 Universal Cover Dimensions

Feature	<i>SD</i> Dimension 14.96/16.93	<i>SD</i> Dimension 18.9 and Above	<i>SD</i> Dimension 18.9 and Above Option
<i>A</i>	3.374 ± .001	4.249 ± .001	4.624 ± .001
<i>B</i>	2.876 ± .001	3.501 ± .001	3.876 ± .001
<i>C</i>	0.19	0.25	0.25
<i>D</i>	1.55	1.75	2.12
<i>E</i>	$\frac{3}{8}$ "-16 UNC	$\frac{5}{8}$ "-11 UNC	$\frac{5}{8}$ "-11 UNC
<i>F</i>	4.25	5.50	5.875

GENERAL NOTE: All dimensions in inches (1 in. = 25.4 mm).

Fig. 6 Packing Box



Shaft or Sleeve Diameter
Up to 1.5 in. (38 mm)
More than 1.5 in. (38 mm)

Radial Clearance X Min.
$X = 0.312 \text{ in. (7.94 mm)}$
$X = 0.375 \text{ in. (9.52 mm)}$

Table 3 Nominal Shaft Extension and Mounting Dimensions for Vertical Solid Shaft P-Base In-Line Pump Motors

NEMA Frames	Shaft Diameter, <i>U</i>	Length of Shaft with <i>U</i> Diameter, <i>V</i>	Shaft Protrusion Below Base, <i>AH</i>	Rabbet Diameter, <i>AK</i>	Bolt Circle, <i>AJ</i>	Base Diameter, <i>BD</i>
143 & 145-LP	1 $\frac{1}{8}$	2 $\frac{3}{4}$	2 $\frac{3}{4}$	8 $\frac{1}{4}$	9 $\frac{1}{8}$	10
182 & 184-LP	1 $\frac{1}{8}$	2 $\frac{3}{4}$	2 $\frac{3}{4}$	8 $\frac{1}{4}$	9 $\frac{1}{8}$	10
213 & 215-LP	1 $\frac{5}{8}$	2 $\frac{3}{4}$	2 $\frac{3}{4}$	8 $\frac{1}{4}$	9 $\frac{1}{8}$	10
254 & 256-LP	1 $\frac{5}{8}$	2 $\frac{3}{4}$	2 $\frac{3}{4}$	8 $\frac{1}{4}$	9 $\frac{1}{8}$	10
284 & 286-LP	2 $\frac{1}{8}$	4	4 $\frac{1}{2}$	13 $\frac{1}{2}$	14 $\frac{3}{4}$	16 $\frac{1}{2}$
324 & 326-LP	2 $\frac{1}{8}$	4	4 $\frac{1}{2}$	13 $\frac{1}{2}$	14 $\frac{3}{4}$	16 $\frac{1}{2}$
364 & 365-LP	2 $\frac{1}{8}$	4	4 $\frac{1}{2}$	13 $\frac{1}{2}$	14 $\frac{3}{4}$	16 $\frac{1}{2}$
404 & 405-LP	2 $\frac{1}{8}$	4	4 $\frac{1}{2}$	13 $\frac{1}{2}$	14 $\frac{3}{4}$	16 $\frac{1}{2}$
444 & 445-LP	2 $\frac{1}{8}$	4	4 $\frac{1}{2}$	13 $\frac{1}{2}$	14 $\frac{3}{4}$	16 $\frac{1}{2}$

GENERAL NOTE: All dimensions in inches (1 in. = 25.4 mm). See ANSI/NEMA MG 1-18.251 for complete dimensions.

coupling, permitting removal of the pump shaft, shaft seal, and impeller without disturbing the motor (see Table 1).

(a) Drive motor for VC pumps shall be NEMA P-base in-line pump motor, available in all standard enclosures. These P-base motors shall have mounting and shaft extension dimensions per ANSI/NEMA MG 1-18.251 (see Table 3).

(b) Tolerance for mounting and shaft dimensions for P-base motors shall also be per ANSI/NEMA MG 1-18.250.

5.7.2 Type VM Vertical Motorshaft Design. For pumps that have the impeller mounted on an extended motor shaft, see Table 1.

(a) Motors for VM pumps shall be NEMA JM or JP solid shaft, designed for vertical operation (JMV, JPV), with mounting and shaft dimensions per ANSI/NEMA MG 1-18.614. Alternative shaft extension dimensions may be offered.

(b) Tolerances for mounting and shaft dimensions for the JMV/JPV motors shall be per ANSI/NEMA MG 1-4.4.4.

5.7.3 Type VB Vertical Bearing Housing Design.

For pumps that have their own bearing housings and bearings designed to handle the pump loads, see Table 1.

(a) Motors for VB pumps shall be NEMA C-face foot or footless motors, available in all standard enclosures.

(b) Shaft and accessories dimensions shall be in accordance with ANSI/NEMA MG 1-11.34.

(c) Tolerance for C-face for mounting foot or footless motors shall be in accordance with ANSI/NEMA MG 1-4.4.4.

(d) The pump shaft is attached to the motor shaft by a flexible spacer coupling, permitting removal of the pump shaft, seal, and impeller without disturbing the motor.

5.7.4 Motor Horsepower Selection. Motors shall be selected having nameplate horsepower ratings at least as high as in Table 4, based on the pump rated bhp in the Table. Where it appears that using this Table leads to unnecessary oversizing of the motor, an alternative size may be offered in addition to the Table selection.

5.7.5 Bearings — VC and VM Pumps

5.7.5.1 Design. The motor bearings shall carry the hydraulic radial load imposed by the pump, and the combined hydraulic thrust load and weight of all rotating parts.

5.7.5.2 Life. After tentative selection of the motor size and motor manufacturer, the pump manufacturer shall be responsible for assuring the motor bearing life, when calculated in accordance with ANSI/ABMA 9, ANSI/ABMA 11, and ISO 281, and will provide for a minimum L_{10h} bearing life of 17,500 hr in the allowable operating region as per para. 6.1.6 and for all allowable standard and optional arrangements of lubrication, shafts, covers, sealing, and impellers. If the calculated bearing life fails to meet this specification, the pump manufacturer shall determine whether to use a different motor whose bearings will meet the specification, or to reduce the loads sufficiently in order to comply.

5.7.5.3 End Play. End play in the shaft from the motor thrust bearing and its assembly due to internal bearing clearances and tolerances shall be a minimum and shall not exceed either the internal pump clearances or pump shaft seal requirements. The maximum allowable shaft end play value shall be provided with the pump documentation.

5.7.6 Bearings — Type VB Pumps

5.7.6.1 Design. Two rolling element bearing assemblies shall be provided: one assembly free to float within the frame to carry radial load only, and the other

Table 4 Motor Horsepower Selection

For Pump Rated bhp up to [Note (1)]	Select Motor With Nameplate, hp Rating		Maximum Allowable Motor Load, hp [Note (2)]	Percent of Margin, Motor hp	For Pump Rated bhp up to [Note (1)]	Select Motor With Nameplate, hp Rating		Maximum Allowable Motor Load, hp [Note (2)]	Percent of Margin, Motor hp
	SF 1.0	SF 1.15				SF 1.0	SF 1.15		
0.70	1	...	1.00	43	21.00	25	...	25.00	19
0.82	...	1	1.15	41	24.40	...	25	28.75	18
1.08	1.5	...	1.50	39	25.50	30	...	30.00	17.5
1.25	...	1.5	1.72	38	29.50	...	30	34.50	17
1.46	2	...	2.00	37	34.50	40	...	40.00	16
1.70	...	2	2.30	35	40.00	...	40	46.00	15
2.25	3	...	3.00	33.5	43.80	50	...	50.00	14
2.62	...	3	3.45	31.5	50.90	...	50	57.50	13
3.85	5	...	5.00	29.5	53.30	60	...	60.00	12.5
4.49	...	5	5.75	28	62.00	...	60	69.00	11.5
5.93	7.5	...	7.50	26.5	67.50	75	...	75.00	11
6.90	...	7.5	8.62	25	78.00	...	75	86.25	10.5
8.10	10	...	10.00	23.5	91.00	100	...	100.00	10
9.36	...	10	11.50	23	104.50	...	100	115.00	10
12.30	15	...	15.00	22	113.50	125	...	125.00	10
14.25	...	15	17.25	21	131.00	...	125	144.00	10
16.60	20	...	20.00	20.5	136.50	150	...	150.00	10
19.20	...	20	23.00	20	156.50	...	150	172.50	10

GENERAL NOTE: 1 hp = 0.746 kW.

NOTES:

(1) bhp at the specified operating condition.

(2) Motor nameplate hp times service factor.

assembly arranged to carry radial loading, axial thrust, and weight of the pump rotor assembly.

5.7.6.2 Life. Bearings shall be selected in accordance with ANSI/ABMA 9, ANSI/ABMA 11, and ISO 281. The minimum L₁₀h bearing life shall be 17,500 hr in the allowable operating region as defined in para. 6.1.6 and for all standard and optional arrangements of bearings, lubrication, shafts, covers, sealing, and impellers.

5.7.6.3 End Play. The maximum end play in the shaft assembly shall not exceed the internal axial clearance for the thrust bearing utilized. Minimum and maximum shaft end play values shall be published in the pump manufacturer's instruction manual.

5.7.7 Lubrication — Type VB Pumps

5.7.7.1 Greased bearing lubrication shall be standard. Greased-for-life or regreaseable lubrication shall be specified on the pump data sheet. When regreaseable lubrication is specified, a means for grease relief shall be provided.

5.7.7.2 Pure oil mist lubrication shall be optional. When pure oil mist lubrication is specified, the location of the inlets, drains, and vents should be mutually agreed between the purchaser and the supplier.

5.7.8 Bearing Frame — Type VB Pumps. Bearing frame shall be constructed to protect the bearings from water, dust, and other contaminants and provide lubrication for the bearings. The standard design is for grease lubrication.

5.7.8.1 Sealing. The standard design is to include lip seals. In addition, optional designs may be offered with the purchaser's approval. In those cases where the bearing frame seal does not allow the bearing frame pressure to equalize with atmospheric pressure during operation, an expansion chamber or breather is necessary.

5.7.8.2 Bearing Frame Drain. As an option, the bearing frame shall be provided with a tapped and plugged drain hole at its lowest point.

5.8 Materials of Construction

5.8.1 General

5.8.1.1 The identifying material of a pump shall be that of which the casing is constructed.

5.8.1.2 The pump material classification code in Table 5 shall be used to specify the pump materials of construction.

5.8.1.3 The pump part materials shall be in accordance with the specific ASTM material specifications in Table 6 for each of the listed material designations.

5.8.1.4 Other materials shall be agreed upon by the purchaser and the supplier.

5.8.1.5 No repair by plugging, peening, or impregnation is allowed on any parts wetted by the pumped fluid.

5.8.2 Gland Material

5.8.2.1 Mechanical seal gland materials shall be in accordance with the ASTM designations in Table 5 with 316 SS as a minimum. If wetted by the pumped fluid and the casing is a higher alloy than 316 SS, the gland shall be constructed of the same material specified for the casing or, with purchaser approval, a material having an equivalent or better corrosion resistance.

5.8.2.2 Gland bolt, stud, and nut materials shall be in accordance with the ASTM designations in Table 5 with 304 SS as a minimum. Grade B7 and Grade 2H carbon steel are not allowed for gland bolt, stud, and nut materials.

5.8.3 Auxiliary Piping

5.8.3.1 Auxiliary piping shall, as a minimum, be available with the materials of construction in accordance with Table 7.

5.8.3.2 Auxiliary piping in contact with the pumped fluid shall have a pressure-temperature rating equal to or greater than the maximum allowable working pressure (MAWP) of the pump. Auxiliary piping that may become exposed to pumped fluid in the event of a seal failure shall meet this requirement.

5.8.3.3 Auxiliary piping and components normally in contact with the pumped fluid shall have a corrosion resistance to the pumped fluid that is equal to or better than that of the casing.

5.9 Corrosion Allowance

The casing, cover, and gland shall have a corrosion allowance of at least 0.12 in. (3.0 mm).

5.10 Direction of Rotation

Direction of rotation shall be clockwise viewed from the motor end of the pump. An arrow showing the

direction of rotation shall be provided, either cast on the casing or stamped on a plate of durable construction affixed to the pump in a prominent location.

5.11 Dimensions

Pump dimensions shall conform to Table 1.

5.12 Miscellaneous Design Features

5.12.1 Safety Guards. Each coupling shall be furnished with a coupling guard. The coupling guard shall prevent personnel from contacting rotating components. An auxiliary guarding device to prevent personnel from contacting rotating components or to control spray from packing box/seal chamber leakage shall be provided when specified. Regional regulations and purchaser requirements may require additional guards. All guards shall meet the performance criteria of ANSI B11.19.

5.12.2 Threads. All threaded parts, such as bolts, nuts, and plugs, shall conform to ASME Standards, unless otherwise specified.

5.12.3 Lifting Rings. A lifting ring or other equivalent device shall be provided to facilitate handling the frame, driver pedestal, or adapter and associated assembly if its mass exceeds 60 lb (27 kg). Eyebolts on motors are not suitable for lifting the entire pump and motor assembly. The pump manufacturer's manual shall provide lifting instructions.

5.12.4 Tapped Openings. All tapped openings, including those in the mechanical seal gland that may be exposed to the pumped fluid under pressure, shall be plugged with threaded metal plugs. Plugs normally in contact with the pumped fluid shall be of the same material as the casing, except that carbon steel plugs may be used in ductile iron pumps. Threaded plugs shall not be used in the heating or cooling jackets, including glands with heating or cooling passages; instead, snap-in plugs or waterproof tape shall be used to relieve possible pressure accumulation until piping is installed.

All tapped openings in the mechanical seal gland shall be identified to designate their purpose. This designation should be cast or stamped immediately adjacent to the opening. The markings shall be in accordance with para. 7.3.1. When a steam quench is specified, the inlet connection shall be located at the highest point on the gland, and the drain connection shall be located at the lowest point on the gland to prevent the formation of water pockets.

5.12.5 Identification. The manufacturer's part identification number and material designation shall be cast, clearly die stamped, or engraved on the casing, cover, and impeller.

5.12.6 Driver Pedestal and Adapter. The driver pedestal on Type VB and Type VC pumps, and adapter on Type VM pumps shall be designed to resist a torque at

Table 5 Pump Material Classification Code

Base Code — Pressure Casing and Impeller							
Part Name	73DI-	73DI/SS-	73SS-	73A20-	73CD4-	73HC276-	73X-
Casing	Ductile iron	Ductile iron	316 SS	Alloy 20	Duplex SS	Alloy C276	As specified
Impeller	Ductile iron	316 SS	316 SS	Alloy 20	Duplex SS	Alloy C276	As specified
Cover	Ductile iron	Ductile iron	316 SS	Alloy 20	Duplex SS	Alloy C276	As specified
Seal gland	316 SS	316 SS	316 SS	Alloy 20	Alloy 20	Alloy C276	As specified
First Suffix — Shaft							
Part Name	A			B		X	
Shaft	Solid shaft			Sleeved shaft		As specified	
Wetted area of shaft with no sleeve	316 SS minimum, same as casing for higher alloy			NA		As specified	
Shaft sleeve	NA			316 SS minimum, same as casing for higher alloy		As specified	
Shaft with sleeve	NA			Carbon steel with 316 SS sleeve or 316 SS with higher alloy sleeve		As specified	
Second Suffix — Fasteners							
Part Name	CS	SS		TCS		X	
Casing fasteners	Carbon steel	304 SS or 316 SS		Carbon steel with PTFE fluoropolymer		As specified	
Gland fasteners	304 SS or 316 SS	304 SS or 316 SS		304 SS or 316 SS		As specified	
Third Suffix — Casing Gasket							
Part Name	AF		T		G		X
Casing gasket	Arimid fiber		Modified PTFE		Flexible graphite		As specified

GENERAL NOTES:

(a) As an example, the pump material classification code 73DI-A-TCS-T indicates the following:

- (1) casing = ductile iron
- (2) impeller = ductile iron
- (3) cover = ductile iron
- (4) seal gland = 316 SS
- (5) shaft = 316 SS solid shaft
- (6) casing fasteners = carbon steel with PTFE coating
- (7) gland fasteners = 304 SS or 316 SS
- (8) casing gasket = modified PTFE

(b) NA = not applicable.

(c) PTFE = polytetrafluoroethylene.

(d) Carbon steel may be offered as an alternative casing material for ductile iron.

Table 6 Material of Construction

Material Designation	ASTM Material Code by Application				
	Casting Wetted by Pumped Fluid	Casting Not Wetted by Pumped Fluid	Bar Stock	Pressure-Retaining Bolts and Studs	Nuts
Standard Available Pump Materials					
Cast iron	...	A48
Ductile iron	A395 Gr 60-40-18	A395 Gr 60-40-18 or A536
Carbon steel	A216 Gr WCB	...	A108 Gr 1144 or A434 Gr 4140	A193 Gr B7	A194 Gr 2H
Carbon steel with PTFE coating	A193 Gr B7 with PTFE coating	A194 Gr 2H with PTFE coating
304 SS	A193 Gr B8	A194 Gr 8
316 SS	A744 Gr CF-8M	A744 Gr CF-8M or A743 Gr CF8M	A276 Type 316 SS	A193 Gr B8M	A194 Gr 8M
Alloy 20 stainless steel	A744 Gr CN-7M	A744 Gr CN-7M	B473 N08020	B473 N08020	B473 N08020
316L SS	A744 Gr CF-3M	A744 Gr CF-3M
Duplex stainless steel	A995 Gr 1B	A743 Gr CF3M	A276 Gr S32205	A276 Gr S32205	A276 Gr S32205
Monel	A494 Gr M-35-1	A890 Gr 1B	B164 N04400
Nickel	A494 Gr CZ-100	A494 Gr CZ-100	B160 N02200
Alloy B2	A494 Gr N-7M	A494 Gr N-7M	B335 N10665
Alloy C4	A494 Gr CW-2M	A494 Gr CW-2M	B575 N06455
Alloy C276	A494 Gr CW-6M A494 Gr CW-2M	A494 Gr CW-6M A494 Gr CW-2M	B574 N10276
Titanium	B367 Gr C-3	B367 Gr C-3	B348 Gr 2

GENERAL NOTES:

(a) For glands and gland fastening, see para. 5.6.6.

(b) PTFE = polytetrafluoroethylene.

Table 7 Minimum Requirement for Auxiliary Piping Materials

Material Designation	ASTM Material Requirements by Type				Pipe Fittings
	Tubing Size range: 3⁄8-in. O.D. to 3⁄4-in. O.D. Minimum wall thickness: 0.035 in.	Tube Fittings		Pipe	ASME B16.11 Class 2000 Minimum
		Compression Type		Schedule 40 Minimum	
Carbon steel	Seamless A519	A108		Seamless A106 Gr B	A105
316 SS	Seamless A269 Gr TP316	Bar Stock	Forgings	Seamless A312 Gr TP316	A182 Gr F316
		A479 Type 316	A182 Gr F316		

least as high as the ultimate torque strength of the pump shaft at the coupling end. When the driver pedestal or adapter is used to clamp the rear cover to the casing, the material properties of the driver pedestal and adapter shall meet the requirement of para. 5.12.7.

5.12.7 Pressure-Retaining Nonwetted Components.

Pressure-retaining nonwetted components shall be made of a material that is classified as ductile throughout the full range of operating temperatures, such as cast ductile iron or cast carbon steel.

5.12.8 Drainage. A threaded drain connection(s) ($\frac{1}{2}$ in. NPT preferred) shall be provided so that liquid will drain from the driver pedestal or adapter, and cover.

6 GENERAL INFORMATION

6.1 Application

6.1.1 Terminology. Terminology shall be in accordance with ANSI/HI 1.1-1.2 and ANSI/HI 14.6, except as net positive suction head required (NPSHR) is clarified in para. 6.1.7.

6.1.2 Nozzle Loading. Allowable nozzle loading imposed by the piping shall be in accordance with ANSI/HI-9.6.2.

6.1.3 Sound. The maximum sound pressure level produced by the pump and driver shall comply with the limit specified by the purchaser. A test, if specified, shall be conducted in accordance with ANSI/HI 9.1-9.5. Driver noise data must be determined separately.

6.1.4 Vibration. The vibration level measured on the pump bearing frame, when specified, at the supplier's test facility at rated condition point (speed $\pm 5\%$, flow $\pm 5\%$) shall not exceed the allowable "factory" pump bearing housing vibration limits shown in ANSI/HI 9.6.4 for types OH3, OH4, and OH5 pumps (B73.2 pumps).

6.1.5 Hydraulic Coverage. Tables 8 and 9 show the approximate hydraulic coverage for 50 Hz and 60 Hz.

6.1.6 Allowable Operating Region. Pumps shall be designed to operate continuously between 120% of the flow at the best efficiency point (BEP) and the minimum flows shown in Table 10, unless specifically noted otherwise by the manufacturer, and meet the requirements of paras. 5.5.4 (shaft deflection), 5.7.5.2 and 5.7.6.2 (bearing life), and 6.1.4 (vibration) when pumping water at ambient conditions.

CAUTION: The values in Table 10 do not consider minimum thermal flow for a specific installation; therefore, the practical minimum operating flow may be higher than shown. Pumped fluid is heated as it goes through a pump, and the minimum thermal flow is where the temperature rises enough through the pump that recirculation of some of the flow reduces the available net positive suction head below that required by the pump, resulting in cavitation or vaporization of the pumped fluid. Refer to ANSI/HI 1.3 for detailed application information.

6.1.7 NPSHR. NPSHR is defined as per ANSI/HI 14.6 except this value is equal to or greater than NPSH3. Under special circumstances, NPSHR may be less than NPSH3, if agreed upon between the supplier and the purchaser.

6.1.8 NPSH Margin. An operating NPSH margin is necessary to ensure satisfactory operation. A minimum margin of 3 ft (0.9 m) or a margin ratio of 1.2 (whichever yields a higher NPSH requirement) should be made available. This margin should be increased if variables exist that will increase the NPSHR of the pump. Refer to ANSI/HI 9.6.1 for additional application information.

6.1.9 Performance Curves. Published performance curves in printed or electronic format shall be based on tests conducted in accordance with ANSI/HI 14.6. Accuracy of the curves shall be that 90% of pumps purchased "untested," when operated between minimum allowable flow and BEP, will perform to the published curve within the following tolerances:

- (a) head $+5\%$, -5%
- (b) efficiency -5%

NOTE: The published performance curves shall be used for preliminary sizing only and are based on water performance with a simple sealing device such as packing or a single mechanical seal.

Table 8 Approximate Performance of Standard Pumps (60 Hz)

Dimension Designation		Size		1,750 rpm				3,500 rpm			
				Capacity		Total Head		Capacity		Total Head	
				gpm	m ³ /h	ft	m	gpm	m ³ /h	ft	m
2015/15	(50-40-380)	2 × 1.5 × 6	(50 × 40 × 150)	54	12	30	9	104	24	121	37
3015/15	(80-40-380)	3 × 1.5 × 6	(80 × 40 × 150)	90	20	31	9	176	40	125	38
3020/17	(80-50-430)	3 × 2 × 6	(80 × 50 × 150)	156	35	32	10	295	67	134	41
2015/17	(50-40-430)	2 × 1.5 × 8	(50 × 40 × 200)	79	18	57	17	151	34	233	71
3020/17	(80-50-430)	3 × 2 × 7	(80 × 50 × 180)	150	34	40	12	294	67	158	48
3015/19	(80-40-480)	3 × 1.5 × 8	(80 × 40 × 200)	115	26	60	18	234	53	242	74
4030/22	(100-80-560)	4 × 3 × 8	(100 × 80 × 200)	270	61	62	19	545	124	252	77
6040/24	(150-100-610)	6 × 4 × 9	(150 × 100 × 200)	515	117	62	19	1,030	234	255	78
2015/19	(50-40-480)	2 × 1.5 × 10	(50 × 40 × 250)	78	18	95	29	147	33	398	121
3015/19	(80-40-480)	3 × 1.5 × 10	(80 × 40 × 200)	144	33	90	27	275	62	380	116
3020/20	(80-50-510)	3 × 2 × 10	(80 × 50 × 250)	206	47	89	27	406	92	364	111
4030/25	(100-80-635)	4 × 3 × 10	(100 × 80 × 250)	345	78	85	26	678	154	344	105
6040/28	(150-100-710)	6 × 4 × 10	(150 × 100 × 250)	1,100	250	92	28	1,820	413	230	70
[Note (1)]											
3015/24	(80-40-610)	3 × 1.5 × 13	(80 × 40 × 330)	225	51	144	44
3020/24	(80-50-610)	3 × 2 × 13	(80 × 50 × 330)	324	73	148	45
4030/28	(100-80-710)	4 × 3 × 13	(100 × 80 × 330)	648	147	163	50	875	202	425	129
[Note (1)]											
6040/30	(150-100-760)	6 × 4 × 13	(150 × 100 × 330)	1,172	266	155	47
[Note (1)]											

GENERAL NOTE: This Standard does not cover exact hydraulic performance of pumps. Information on approximate head and capacity at the best efficiency point for standard pumps is for general information only. Consult manufacturers regarding hydraulic performance data for specific applications.

NOTE:

- (1) Liquid end may be modified for condition, or maximum impeller diameter may be limited due to limitation of the pump's rotor assembly.

Table 9 Approximate Performance of Standard Pumps (50 Hz)

Dimension Designation		Size		1,450 rpm				2,900 rpm			
				Capacity		Total Head		Capacity		Total Head	
				gpm	m ³ /h	ft	m	gpm	m ³ /h	ft	m
in.	(mm)	in.	(mm)								
2015/15	(50-40-380)	2 × 1.5 × 6	(50 × 40 × 150)	46	11	21	6	88	20	80	25
3015/15	(80-40-380)	3 × 1.5 × 6	(80 × 40 × 150)	77	18	21	6	145	33	82	25
3020/17	(80-50-430)	3 × 2 × 6	(80 × 50 × 150)	130	30	22	7	242	55	89	27
2015/17	(50-40-430)	2 × 1.5 × 8	(50 × 40 × 200)	65	15	39	12	126	29	156	48
3020/17	(80-50-430)	3 × 2 × 7	(80 × 50 × 180)	124	28	27	8	243	55	109	33
3015/19	(80-40-480)	3 × 1.5 × 8	(80 × 40 × 200)	99	23	40	12	187	43	164	50
4030/22	(100-80-560)	4 × 3 × 8	(100 × 80 × 200)	224	51	41	12	448	102	167	51
6040/24	(150-100-610)	6 × 4 × 8	(150 × 100 × 200)	420	95	43	13	855	194	180	55
2015/19	(50-40-480)	2 × 1.5 × 10	(50 × 40 × 250)	66	15	64	20	125	29	261	80
3015/19	(80-40-480)	3 × 1.5 × 10	(80 × 40 × 200)	110	25	62	19	242	55	246	75
3020/20	(80-50-510)	3 × 2 × 10	(80 × 50 × 250)	169	38	61	19	334	76	244	74
4030/25	(100-80-635)	4 × 3 × 10	(100 × 80 × 250)	295	67	59	18	555	126	236	72
6040/28	(150-100-710)	6 × 4 × 10	(150 × 100 × 250)	880	200	62	19	1,540	350	157	36
[Note (1)]											
3015/24	(80-40-610)	3 × 1.5 × 13	(80 × 40 × 330)	191	43	97	30
3020/24	(80-50-610)	3 × 2 × 13	(80 × 50 × 330)	268	61	101	31
4030/28	(100-80-710)	4 × 3 × 13	(100 × 80 × 330)	530	120	111	34	858	195	364	111
[Note (1)]											
6040/30	(150-100-760)	6 × 4 × 13	(150 × 100 × 330)	989	225	103	31
[Note (1)]											

GENERAL NOTE: This Standard does not cover exact hydraulic performance of pumps. Information on approximate head and capacity at the best efficiency point for standard pumps is for general information only. Consult manufacturers regarding hydraulic performance data for specific applications.

NOTE:

- (1) Liquid end may be modified for condition, or maximum impeller diameter may be limited due to limitation of the pump's rotor assembly.

Table 10 Minimum Continuous Flow

Dimension Designation		Size		Minimum Continuous Flow, % BEP [Note (1)]	
				3,500 rpm/ 2,900 rpm 60 Hz/50 Hz	1,750 rpm/ 1,450 rpm 60 Hz/50 Hz
in.	(mm)	in.	(mm)		
2015/15	(50-40-380)	2 × 1.5 × 6	(50 × 40 × 150)	15	10
3015/15	(80-40-380)	3 × 1.5 × 6	(80 × 40 × 150)	15	10
3020/17	(80-50-430)	3 × 2 × 6	(80 × 50 × 150)	20	10
3020/17	(80-50-430)	3 × 2 × 7	(80 × 50 × 180)	20	10
2015/17	(50-40-430)	2 × 1.5 × 8	(50 × 40 × 200)	20	10
3015/19	(80-40-480)	3 × 1.5 × 8	(80 × 40 × 200)	20	10
4030/22	(100-80-560)	4 × 3 × 8	(100 × 80 × 200)	20	10
2015/19	(50-40-480)	2 × 1.5 × 10	(50 × 40 × 250)	25	10
3015/19	(80-40-480)	3 × 1.5 × 10	(80 × 40 × 200)	30	15
3020/20	(80-40-510)	3 × 2 × 10	(80 × 50 × 250)	30	15
4030/25	(100-80-635)	4 × 3 × 10	(100 × 80 × 250)	30	15
4030/28	(100-80-710)	4 × 3 × 13	(100 × 80 × 330)	40	40
6040/24	(150-100-610)	6 × 4 × 9	(150 × 100 × 200)	25	25
3015/24	(80-40-610)	3 × 1.5 × 13	(80 × 40 × 200)	30	15
3020/24	(80-50-610)	3 × 2 × 13	(80 × 50 × 330)	40	15
6040/28	(150-100-710)	6 × 4 × 10	(150 × 100 × 250)	40	20
6040/30	(150-100-760)	6 × 4 × 13	(150 × 100 × 330)	...	40

GENERAL NOTE: See para. 6.1.6 for caution using values in this Table.

NOTE:

- (1) Limits refer to actual hydraulic performance, not the approximate values in Tables 8 and 9. Consult manufacturers regarding hydraulic performance data for specific applications.

Other sealing configurations may add to the power requirement. Head and efficiency at flows greater than BEP may have greater variation than the tolerances stated above.

6.2 Tests and Inspections

Unless otherwise agreed upon, the supplier shall give at least five working days of advanced notification of an observed or witnessed test or inspection.

6.2.1 Tests

6.2.1.1 Hydrostatic. After machining, casings, covers, and jackets shall be hydrostatically tested for 10 min minimum with water at 1.5 times the maximum design pressure corresponding to 100°F (38°C) for the material of construction used. No visible leakage through the part shall be permitted. Drilled and tapped connections added post-hydro require a visual inspection only to ensure no voids exist and threads are well formed.

6.2.1.2 Performance

(a) *Procedure.* When performance tests are required, they shall be conducted in accordance with ANSI/HI 14.6.

(b) *Acceptance Criteria.* Performance Acceptance Grade 1B shall be used for all pump input powers. ANSI/HI 14.6 performance acceptance Grade 1B includes power or efficiency as an optional guarantee

requirement. When specified, the acceptance criteria shall include either power or efficiency at the rated condition point.

(c) When specified, the performance test shall include vibration measurements in accordance with para. 6.1.4.

(d) If the tested impeller is required to be trimmed less than 5% of trimmed diameter due to failure to meet acceptance criteria, a retest after trimming is not necessary. Trims of greater than 5% require a retest. If a new impeller is required, a retest is required.

(e) A complete written record of the relevant test information including performance curves, the date of the tests, and the signature of the person(s) responsible for conducting the tests shall be delivered as part of the pump documentation.

6.2.1.3 Additional Data. Additional data, when specified, may be taken during the performance test. These data may include such things as vibration and bearing housing temperature. Unless otherwise specified, the additional data will be taken at the rated duty point. When these data are specified, they shall be conducted in accordance with ANSI/HI 14.6.

6.2.1.4 Leak. When specified by the purchaser, the assembled pump shall be leak tested using a procedure and acceptance criteria as agreed upon. If the assembly is to contain a mechanical seal, consult with

the seal manufacturer for the seal static pressure limits before exposing it to the test pressure.

6.2.1.5 NPSHR. When NPSHR tests are required, they shall be conducted in accordance with ANSI/HI 14.6. Unless otherwise agreed to by the purchaser and supplier, the NPSH test will be a Type II test, which is for determination of NPSH₃ at the rated flow only.

6.2.2 Inspections

6.2.2.1 Final Inspections. A final inspection may be specified by the purchaser. If specified, the purchaser or purchaser's representative will be given access to the completed pump assembly for visual inspection of the assembly prior to shipment.

6.2.2.2 Dismantle and Inspect After Test. If specified, the pump shall be dismantled and inspected after test. Inspection procedure and criteria must be agreed upon by the purchaser and supplier.

6.2.2.3 Inspection of Connection Welds. When a visual inspection of weld connection is specified, it shall be conducted in accordance with AWS B1.11 for evaluation of size of weld, undercut, and splatter. A complete written record of welder, date of welding, method, and filler material must be retained.

6.2.2.4 Inspection of Castings. When inspection of cast parts wetted by the process fluid is specified, a visual inspection shall be conducted in accordance with Manufacturers Standardization Society (MSS) Standard SP-55 for evaluation of cast surfaces. Inspection of the castings by other nondestructive methods such as dye penetrant or x-ray may be agreed upon between manufacturer and purchaser.

6.3 Nameplates

The nameplate(s) is to be of 24 U.S. Standard Gage (minimum) AISI 300 series stainless steel and shall be securely attached to the pump. It shall include pump model, standard dimension designation, serial number, size, impeller diameter (maximum and installed), material of construction, and maximum design pressure for 100°F (38°C).

7 DOCUMENTATION

7.1 General

The documentation specified covers the minimum required to provide clear communication between the pump user and pump manufacturer and to facilitate the safe design, installation, and operation of the pump.

Additional data, as required for specific purposes, shall be available, if requested. It is the intent that information be furnished in a similar form from all sources to improve clarity and foster efficient utilization of the documentation.

7.2 Requirements

The following documents shall be supplied for each pump item furnished. There can be a difference between proposal and purchase documents:

- (a) pump and driver outline drawing
- (b) centrifugal pump data sheet
- (c) mechanical seal drawing (if applicable)
- (d) mechanical seal piping drawing (if applicable)
- (e) cooling/heating piping drawing (if applicable)
- (f) performance curve with rated point
- (g) cross-section drawing with parts list
- (h) manual describing installation, operation, and maintenance
- (i) coupling data (if applicable)
- (j) driver data (if applicable)

7.3 Document Description

7.3.1 Pump and Driver Outline Drawing

(a) The pump and driver outline drawing may contain all information shown on, and may be arranged as, the sample outline drawing included herein and identified as Fig. 7.

(b) Tapped openings, when supplied, shall be identified with the following markings:

Marking	Purpose
I	Casing drain
II	Discharge gage or flush connection
III	Suction gage or flush connection
X	Oil drain
XI	Bearing frame cooling
F	Mechanical seal flush or lantern ring
FI	Flush inlet
FO	Flush outlet
LBI	Liquid barrier/buffer inlet
LBO	Liquid barrier/buffer outlet
V	Vent
D	Drain
Q	Quench
C/HI	Cooling/heating inlet
C/HO	Cooling/heating outlet
CSD	Containment seal drain
CSV	Containment seal vent
GBI	Gas barrier/buffer inlet
GBO	Gas barrier/buffer outlet

7.3.2 Centrifugal Pump Data Sheet

(a) *Data Sheet.* The ASME Centrifugal Pump Data Sheet in Mandatory Appendix I shall be used as the data sheet for all pumps covered by this Standard when the data sheet is initiated by the purchaser. The data sheet, electronic or printed copy, shall be used for inquiry, proposal, and as-built.

(b) *Electronic Data.* See Nonmandatory Appendix A.

7.3.3 Mechanical Seal Drawing

(a) A mechanical seal drawing shall be included if the pump is fitted with a mechanical shaft seal.



(b) The drawing shall show the general arrangement of the mechanical seal, identifying all parts with name, part number, and material of construction.

(c) If a throat bushing is to be installed in the seal cavity, it is to be clearly indicated and identified on the seal drawing.

(d) Drawings for noncartridge seals shall include dimensions complete with the seal setting dimension referred to on the seal chamber face.

(e) The drawings shall have a title block including the information on the title block of the pump data sheet, Form I-1 or Form I-1M, and have a blank space for the user's identification stamp 1½ in. × 3 in. (40 mm × 80 mm) minimum.

7.3.4 Mechanical Seal Piping Drawing

(a) A mechanical seal piping drawing or schematic shall be provided if the pump includes a mechanical seal piping system.

(b) The mechanical seal piping drawing or schematic shall contain information and uniform nomenclature consistent with the references given in para. 5.6.1.

7.3.5 Cooling/Heating Piping Drawing

(a) A cooling/heating piping drawing or schematic shall be provided if the pump includes a heating/cooling piping system.

(b) The cooling/heating piping drawing or schematic shall contain all information and uniform nomenclature consistent with the references given in para. 5.6.1.

7.3.6 Performance Curve

7.3.6.1 Single-Speed Performance. The single-speed performance curve shall be the composite (family) type curve for full impeller diameter range, plotting head against flow and including efficiency, minimum flow, NPSHR, power consumption, and speed. Power consumption shall be provided at all flows including shutoff. Performance curves may be categorized as published, proposal, as-built, and test.

(a) The published, or catalog, performance curve shall be as stated above and is based on water. These performance curves are normally found in the manufacturer's catalogs or electronic media, and do not reflect a pump configured for a specific pumping application.

(b) The proposal performance curve shall be as stated above. The design impeller diameter shall be indicated with the rated duty point identified on the curve. It is not necessary to include the complete composite (family) curves; however, the maximum and minimum impeller diameter head-flow curves must be included. When the pumped fluid viscosity or specific gravity affects the pump performance, the proposal performance curve shall be corrected for these effects. Mechanical seal losses shall be reflected in the proposal performance curve. The proposal performance curves are normally supplied as part of a pump proposal and reflect a pump that has been configured for the specific pumping application.

(c) As-built, or as-configured, performance curves shall be as stated for the proposal performance curves and they must be for the pump configuration actually supplied to the purchaser. As-built, or as-configured, performance curves are provided as part of the pump final documentation package.

7.3.6.2 Variable-Speed Performance. When variable-speed operation is specified, variable-speed performance curves shall be provided. The requirements and categories of variable-speed curves are the same as for single-speed curves (see para. 7.3.6.1), except that the curve will show a composite of curves with a single impeller trim when operated over a range of speeds. The speed for each curve will be clearly indicated.

7.3.6.3 Performance Test Curve. The performance test curve, if specified, shall be at rated speed and as described in para. 6.2.1.2(e) and provided as part of the pump final documentation package.

7.3.7 Cross-Section Drawing. The cross-section drawing shall show all components of the pump. It shall be complete with a parts list referenced to the drawing. Nomenclature and definitions should be in accordance with ANSI/HI 1.1-1.2.

7.3.8 Instruction Manual

(a) The instruction manual should include information on the correct installation, preparation for start-up, starting up, operation, trouble checklist, and maintenance information for the pump model furnished.

(b) Any limitation or warning on the installation, operation, etc., of the unit shall be clearly defined.

(c) The instruction manual shall be in electronic or printed format.

(d) The use of a single manual to describe many similar models of pumps should be minimized to reduce purchaser confusion on the exact model furnished.

(e) If an adjustable alignment feature is provided, the recommended tolerance for coupling alignment shall be supplied to the purchaser.

(f) The instruction manual for the pump driver, mechanical seal, coupling, etc., shall be furnished if included in the scope of supply.

(g) A guideline for developing instruction manuals may be found in ANSI/HI 1.4.

7.3.9 Coupling Data. When flexible couplings are supplied, the coupling data shall include manufacturer, type, model, size, spacer length, materials of construction, and hub-to-shaft attachment method.

7.3.10 Driver. The driver data shall include manufacturer, nameplate, and dimensional data.

7.4 Specially Requested Documentation

Documentation in addition to that listed in para. 7.3 shall be made available when specified.

7.4.1 Master Document List

(a) This is a composite list of all documents submitted by the manufacturer, including title of document and drawing or other identification numbers, including revision dates.

(b) This list shall be submitted along with the first document in order to apprise the purchaser of the documents that will follow.

(c) Revisions to this document list shall be made as required.

7.4.2 External Forces or Moments on Nozzles List.

This list summarizes the allowable external forces and moments on pump suction and discharge nozzles (see para. 6.1.2).

7.4.3 Parts List

(a) A list of all pump parts with pump identification numbers, part numbers, and material descriptions shall be supplied. This list shall be as-built.

(b) A list of recommended spare parts shall be supplied and shall be subdivided into the following two categories:

- (1) for start-up
- (2) for 3-yr operation

(c) The spare parts list for auxiliary equipment shall be supplied with the pump. This would include, as

applicable, mechanical seal, coupling, driver, gear-boxes, etc.

(d) These lists shall be presented to the purchaser before the equipment is shipped, and reflect the as-built equipment.

7.4.4 Special Operating or Design Data. Special operating and design data required by the purchaser shall be supplied. For example, these may include the following:

- (a) minimum mechanical seal flush flow
- (b) seal chamber/packing box pressure
- (c) maximum allowable casing pressure and temperature
- (d) maximum allowable jacket pressure and temperature

7.4.5 Special Testing, Painting, and Preparation.

Any required special testing, painting, or preparation shall be specified on the centrifugal pump data sheet or purchase order.

7.4.6 Statement of Compliance. A statement of compliance shall be included, if specified. This statement shall include assurance that the pump is being supplied according to the requirements of this Standard.

MANDATORY APPENDIX I ASME CENTRIFUGAL PUMP DATA SHEET

See Forms I-1 and I-1M on the following pages.

ASME B73**Form I-1 Centrifugal Pump Data Sheet**

Rev. No.: _____ Rev. Date: _____

Issue Date
APRIL 2012ASME Centrifugal Pumps (U.S. Customary Units)
ASME B73.1, ASME B73.2

Page 1 of 4

Usage key—data provided by:

● Purchaser

■ Supplier

▲ Supplier if not by purchaser

Issued for: ☐ Proposal ☐ Purchase ☐ As built

Facility name / location: _____

Item name: _____ Purchaser / location: _____

Item tag number: _____ Job number: _____

Service: _____ Purchaser order number: _____

Unit: _____ Supplier / location: _____

P&ID number: _____ Supplier order / serial numbers: _____ / _____

● **GENERAL**

No. of pumps req.: _____ Motor item number: _____

▲ Pump size: _____ Motor provided by: _____

▲ Pump model: _____ Motor mounted by: _____

▲ Pump type: _____ Variable-speed operation: ☐ YES ☐ NO● **Operating Conditions**

	Rated	Additional duty points (max., min., or VS)				
Point #:	1	2	3	4	5	
Flow:						(gpm)
Head:						(ft)
NPSHA:						(ft)
Suct. pres.:						(psig)
▲ Speed:						(rpm)

System design:

Suction pressure: min. / max.: _____ / _____ (psig)

Suction temperature: min. / max.: _____ / _____ (°F)

☐ Stand-alone operation☐ Parallel operation with item no.: _____☐ Series operation with item no.: _____

Service:

☐ Continuous ☐ Intermittent: _____ starts/day

System control method:

☐ Speed ☐ Throttle ☐ System Resistance Only● **Pumped Fluid**

Pumped fluid: _____

	RATED	MAX.	NORMAL	MIN.
Pumping temperature:				

*At pumping temperatures designated above

Specific gravity*: _____ (psia)

Vapor pressure*: _____ (cP)

Viscosity*: _____ (Btu/lb °F)

Specific heat*: _____ (Btu/lb °F)

Atm pressure boiling point: _____ (°F) @ _____ (psia)

Liquid: ☐ Hazardous ☐ Flammable pH: _____☐ Other: _____

Corrosion / erosion caused by: _____

% solids: _____ Max. particle size: _____ (in.)

Other: _____

■ **Performance**

Performance curve number: _____ ▲ Speed: _____ (rpm)

Total differential head @ rated impeller: _____ (ft)

Maximum differential head @ rated impeller: _____ (ft)

Point #:

1	2	3	4	5
---	---	---	---	---

 (ft)NPSHR:

--	--	--	--	--

 (ft)

Minimum continuous stable flow: _____ (gpm)

Allowable operating region: _____ to: _____ (gpm)

Best efficiency point for rated impeller: _____ (gpm)

Suction specific speed: _____

Impeller diameter: Rated: _____ Max.: _____ Min.: _____ (in.)

Pump rated power: _____ (bhp) Efficiency: _____ (%)

Maximum power with rated impeller: _____ (bhp)

Case pressure rating:

Maximum allowable working pressure: _____ (psig) @ _____ (°F)

Hydrostatic test pressure: _____ (psig)

● **Site Conditions and Utilities**

Location:

☐ Indoor ☐ Outdoor Altitude: _____ (ft)

Range of ambient temperatures: min. / max.: _____ / _____ (°F)

Electrical area classification: ☐ Nonhazardous

Cl.: _____ Div. or Zone: _____ Gr.: _____ T Code: _____

	Voltage	Phase	Hertz
Electricity			
Drivers			
Heating			

Cooling water: Source: _____

Supply temp.: _____ (°F) Max. return temp.: _____ (°F)

Supply pressure: _____ (psig) Design press.: _____ (psig)

Min. return press.: _____ (psig) Max. allow. D.P.: _____ (psig)

Chloride concentration: _____ (ppm)

● **General Remarks**

Number	Date	Data Revision Description	By	Approved
50				
51				
52				
53				

ASME B73

Form I-1 Centrifugal Pump Data Sheet

Rev. No.: _____ Rev. Date: _____

Issue Date
APRIL 2012ASME Centrifugal Pumps (U.S. Customary Units)
ASME B73.1, ASME B73.2

Page 2 of 4

Usage key—data provided by:		<input checked="" type="radio"/> Purchaser	<input type="radio"/> Supplier	<input type="radio"/> Supplier if not by purchaser
1	Mechanical Data			
2	▲ Impeller Type:			
3	<input type="checkbox"/> Closed <input type="checkbox"/> Open <input type="checkbox"/> Semi-open			
4	▲ Casing Mounting:			
5	<input type="checkbox"/> Foot <input type="checkbox"/> Centerline			
6	<input type="checkbox"/> Vertical in-line			
7	■ Bearings:			
8	▲ Bearing manufacturer: _____			
9	Radial bearing type: _____ No.: _____			
10	Thrust bearing type: _____ No.: _____			
11	▲ Bearing isolators: <input type="checkbox"/> Labyrinth (standard)			
12	<input type="checkbox"/> Magnetic seal			
13	Manufacturer: _____			
14	▲ Lubrication:			
15	<input type="checkbox"/> Flood <input type="checkbox"/> Pure mist <input type="checkbox"/> Shielded (grease)			
16	<input type="checkbox"/> Grease <input type="checkbox"/> Purge mist <input type="checkbox"/> Sealed (grease)			
17	<input type="checkbox"/> Magnetic drain plug in housing required			
18	▲ Oil cooler required			
19	■ Oil viscosity: _____ ISO grade: _____ Other: _____			
20	Nozzle Connections: ▲ Size ▲ Rating ▲ Facing			
21	Suction: _____			
22	Discharge: _____			
23	● Aux. case connection: <input type="checkbox"/> Drain required			
24	▲ Size: _____ (in.)			
25	<input type="checkbox"/> Threaded <input type="checkbox"/> Welded and flanged			
26	▲ Materials			
27	Material class code: _____			
28	Casing: _____			
29	Impeller: _____			
30	Cover: _____			
31	Shaft: _____			
32	Shaft sleeve: _____			
33	Baseplate: _____			
34	Casing gasket: _____			
35	Impeller gasket: _____			
36	Casing fasteners: _____			
37	Gland fasteners: _____			
38	Bearing housing: _____			
39	Bearing housing adapter: _____			
40	Bearing isolators: _____			
41	Coupling guard: _____			
42	Mechanical seal materials — see page 3			
43	▲ Coupling Between Pump and Driver			
44	Specification: _____			
45	Manufacturer: _____			
46	Type: _____			
47	Size: _____			
48	Model: _____			
49	Spacer length: _____ (in.)			
50	Coupling guard type:			
51	<input type="checkbox"/> Pump supplier's standard			
52	<input type="checkbox"/> Baseplate mounted			
53	<input type="checkbox"/> Non-spark coupling guard required			
54	Remarks: _____			
55	_____			
56	_____			
▲ Driver				
Power rating: _____ (hp) Speed: _____ (rpm)				
Drive HP selected for max. S.G.: _____ & max. visc.: _____ (cP)				
Driver specification: _____				
Driver manufacturer: _____				
Driver enclosure: _____ Driver frame: _____				
Remarks: _____				
● Baseplate				
Type: <input type="checkbox"/> Grouted				
<input type="checkbox"/> Pregouted				
<input type="checkbox"/> Ungouted (anchored)				
<input type="checkbox"/> Free standing ▲ Pump CL to foundation _____ (in.)				
<input type="checkbox"/> Vertical in-line pump case support bracket				
Design: <input type="checkbox"/> Purchaser specification _____				
<input type="checkbox"/> Pump supplier's standard				
Remarks: _____				
● Paint, Shipment, and Storage Preparation				
Paint:				
<input type="checkbox"/> Pump supplier's standard				
<input type="checkbox"/> Other: _____				
Shipment:				
<input type="checkbox"/> Domestic <input type="checkbox"/> Export <input type="checkbox"/> Export boxing required				
Storage:				
<input type="checkbox"/> Outside <input type="checkbox"/> Under roof <input type="checkbox"/> Environmentally controlled				
<input type="checkbox"/> Short term <input type="checkbox"/> Long term (>6 months)				
Environment: _____				
<input type="checkbox"/> Supplier's standard preservation specification				
Purchaser storage specification: _____				
■ Unit shipping weight: _____ (lb)				
● Tests and Inspections				
Test: <u>Unwitnessed</u> <u>Witnessed</u> <u>Certificate</u>				
Hydrostatic: <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>				
Leak: <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>				
NPSHR: <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>				
Performance: <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>				
Opt. perf. acceptance criteria: <input type="checkbox"/> Power <input type="checkbox"/> Efficiency <input type="checkbox"/> Neither				
Additional data: <input type="checkbox"/> Vibration <input type="checkbox"/> Bearing temp.				
<input type="checkbox"/> Other perf. data: _____				
<input type="checkbox"/> Final inspection required Days notification required: _____				
<input type="checkbox"/> Dismantle and inspect after test				
<input type="checkbox"/> Casting repair procedure approval required				
Material certification required:				
<input type="checkbox"/> Casing <input type="checkbox"/> Cover <input type="checkbox"/> Impeller <input type="checkbox"/> Shaft				
<input type="checkbox"/> Other: _____				
Inspection required for connection welds:				
<input type="checkbox"/> Manufacturer's standard <input type="checkbox"/> Visual inspection				
Inspection required for castings:				
<input type="checkbox"/> Manufacturer's standard <input type="checkbox"/> Visual inspection				
<input type="checkbox"/> Other: _____				
● Manufacturer Documentation Required				
For supplier data requirements, refer to: _____				
Remarks: _____				

<div style="font-size: 24pt; font-weight: bold; margin: 0;">ASME B73</div>		<div style="font-weight: bold; margin: 0;">Form I-1 Centrifugal Pump Data Sheet</div> <div style="font-size: 10pt; margin: 0;">Rev. No.: _____ Rev. Date: _____</div>		<div style="font-size: 10pt; margin: 0;">Issue Date APRIL 2012</div>	
		<div style="font-size: 10pt; margin: 0;">ASME Centrifugal Pumps (U.S. Customary Units)</div> <div style="font-size: 10pt; margin: 0;">ASME B73.1, ASME B73.2</div>		<div style="font-weight: bold; margin: 0;">Page 3 of 4</div>	
Usage key — data provided by: <input checked="" type="checkbox"/> Purchaser <input type="checkbox"/> Supplier <input type="checkbox"/> Supplier if not purchaser					
1	▲ Shaft Sealing <input type="checkbox"/> Mechanical seal <input type="checkbox"/> Packing Furnished by: <input type="checkbox"/> Supplier <input type="checkbox"/> Purchaser Installed by: <input type="checkbox"/> Supplier <input type="checkbox"/> Purchaser		▲ Flush Plan — Single or Inner Seal Piping plan number(s): _____ External flush fluid: _____ Supply temperature: Min. _____ Max. _____ (°F) Specific gravity: _____ Specific heat: _____ (Btu/lb °F) Vapor pressure: _____ psia @ _____ (°F) Flow rate required: Min. _____ Max. _____ (gpm) Maximum flow rate allowed by process: _____ (gpm) Pressure required: Min. _____ Max. _____ (psig) Maximum pressure allowed by process: _____ (psig) Temperature required: Min. _____ Max. _____ (°F) Inner seal flush plan piping: <input type="checkbox"/> Tube <input type="checkbox"/> Pipe <input type="checkbox"/> Other: _____ Tube/pipe size: _____ Tube/pipe material: <input type="checkbox"/> 316 SS <input type="checkbox"/> Other _____ Tube/pipe specification: _____ Tube/pipe connections: <input type="checkbox"/> Threaded <input type="checkbox"/> Socket weld <input type="checkbox"/> Unions <input type="checkbox"/> Butt weld <input type="checkbox"/> Tube fitting <input type="checkbox"/> Other: _____ Furnished by: <input type="checkbox"/> Supplier <input type="checkbox"/> Purchaser Remarks: _____		
2	▲ Seal Chamber <input type="checkbox"/> Taper bore <input type="checkbox"/> Large cylindrical bore <input type="checkbox"/> Universal cover <input type="checkbox"/> Packing box Throat bushing: <input type="checkbox"/> None <input type="checkbox"/> Fixed bushing <input type="checkbox"/> Floating bushing Throat bushing material: _____ Jacketed seal chamber/packing box: <input type="checkbox"/> Yes <input type="checkbox"/> No For: <input type="checkbox"/> Heating <input type="checkbox"/> Cooling Remarks: _____		▲ Mechanical Seal <input type="checkbox"/> Cartridge <input type="checkbox"/> Component (ref. Mand. App. II) <input type="checkbox"/> Arrangement 1 (single seal) <input type="checkbox"/> Arrangement 2 (dual unpressurized seal) <input type="checkbox"/> Arrangement 3 (dual pressurized seal) Flexible element: <input type="checkbox"/> Rotating <input type="checkbox"/> Stationary B73.1 or B73.2 Mand. App. II configuration code: _____ API 682 Category 1: <input type="checkbox"/> Yes <input type="checkbox"/> No Manufacturer: _____ Model: _____ Manufacturer code: _____ Drawing number: _____ Remarks: _____		
3	▲ Seal Materials — Single or Inner Seal Seal faces: Rotating face: _____ Stationary face: _____ Secondary seals: Rotating face: _____ Stationary face: _____ Sleeve: _____ Springs: _____ Bellows: _____ Metal parts: _____ Remarks: _____		▲ Flush Plan — Outer Seal Piping plan number(s): _____ External flush fluid: _____ Supply temperature: Min. _____ Max. _____ (°F) Specific gravity: _____ Specific heat: _____ (Btu/lb °F) Vapor pressure: _____ psia @ _____ (°F) Flow rate required: Min. _____ Max. _____ (gpm) Maximum flow rate allowed by process: _____ (gpm) Pressure required: Min. _____ Max. _____ (psig) Maximum pressure allowed by process: _____ (psig) Temperature required: Min. _____ Max. _____ (°F) MAWP flush plan: _____ psig @ min. temp. _____ (°F) _____ psig @ max. temp. _____ (°F) Outer seal flush plan piping: <input type="checkbox"/> Tube <input type="checkbox"/> Pipe <input type="checkbox"/> Other: _____ Tube/pipe size: _____ Tube/pipe material: <input type="checkbox"/> 316 SS <input type="checkbox"/> Other _____ Tube/pipe specification: _____ Tube/pipe connections: <input type="checkbox"/> Threaded <input type="checkbox"/> Socket weld <input type="checkbox"/> Unions <input type="checkbox"/> Butt weld <input type="checkbox"/> Tube fitting <input type="checkbox"/> Other: _____ Furnished by: <input type="checkbox"/> Supplier <input type="checkbox"/> Purchaser Remarks: _____		
4	▲ Seal Materials — Outer Seal Seal faces: Rotating face: _____ Stationary face: _____ Secondary seals: Rotating face: _____ Stationary face: _____ Sleeve: _____ Springs: _____ Bellows: _____ Metal parts: _____ Remarks: _____		▲ Quench <input type="checkbox"/> Yes <input type="checkbox"/> No Quench fluid: _____ Flow rate: _____ Remarks: _____		
5	▲ Seal Gland Material: _____ Ports: <input type="checkbox"/> Flush <input type="checkbox"/> Drain <input type="checkbox"/> Vent <input type="checkbox"/> Quench <input type="checkbox"/> Buffer/barrier fluid inlet <input type="checkbox"/> Buffer/barrier fluid outlet Throttle bushing: <input type="checkbox"/> Yes <input type="checkbox"/> No Throttle bushing material: _____ Remarks: _____				

ASME B73

Form I-1M Centrifugal Pump Data Sheet

Rev. No.: _____ Rev. Date: _____

Issue Date
MARCH 2015ASME Centrifugal Pumps (SI Units)
ASME B73.1, ASME B73.2

Page 2 of 4

Usage key—data provided by:

☒ Purchaser☐ Supplier☐ Supplier if not by purchaser

Mechanical Data

▲ Impeller Type:

☐ Closed ☐ Open ☐ Semi-open

▲ Casing Mounting:

☐ Foot ☐ Centerline
☐ Vertical in-line

■ Bearings:

▲ Bearing manufacturer: _____

Radial bearing type: _____ No.: _____

Thrust bearing type: _____ No.: _____

▲ Bearing isolators: ☐ Labyrinth (standard)☐ Magnetic seal

Manufacturer: _____

▲ Lubrication:

☐ Flood ☐ Pure mist ☐ Shielded (grease)☐ Grease ☐ Purge mist ☐ Sealed (grease)☐ Magnetic drain plug in housing required

▲ Oil cooler required

■ Oil viscosity: _____ ISO grade: _____ Other: _____

Nozzle Connections:

▲ Size ▲ Rating ▲ Facing

Suction: _____

Discharge: _____

● Aux. case connection:

☐ Drain required

▲ Size: _____ (mm)

☐ Threaded ☐ Welded and flanged

▲ Materials

Material class code: _____

Casing: _____

Impeller: _____

Cover: _____

Shaft: _____

Shaft sleeve: _____

Baseplate: _____

Casing gasket: _____

Impeller gasket: _____

Casing fasteners: _____

Gland fasteners: _____

Bearing housing: _____

Bearing housing adapter: _____

Bearing isolators: _____

Coupling guard: _____

Mechanical seal materials — see page 3

▲ Coupling Between Pump and Driver

Specification: _____

Manufacturer: _____

Type: _____

Size: _____

Model: _____

Spacer length: _____ (mm)

Coupling guard type:

☐ Pump supplier's standard☐ Baseplate mounted☐ Non-spark coupling guard required

Remarks: _____

▲ Driver

Power rating: _____ (kW) Speed: _____ (rpm)

Drive kW selected for max. S.G.: _____ & max. visc.: _____ (mPa·s)

Driver specification: _____

Driver manufacturer: _____

Driver enclosure: _____ Driver frame: _____

Remarks: _____

● Baseplate

Type: ☐ Grouted☐ Pregouted☐ Ungouted (anchored)☐ Free standing ▲ Pump CL to foundation _____ (mm)☐ Vertical in-line pump case support bracketDesign: ☐ Purchaser specification _____☐ Pump supplier's standard

Remarks: _____

● Paint, Shipment, and Storage Preparation

Paint:

☐ Pump supplier's standard☐ Other: _____

Shipment:

☐ Domestic☐ Export☐ Export boxing required

Storage:

☐ Outside☐ Under roof☐ Environmentally controlled☐ Short term☐ Long term (>6 months)

Environment: _____

☐ Supplier's standard preservation specification

Purchaser storage specification: _____

■ Unit shipping weight:

(kg)

● Tests and Inspections

Test: Unwitnessed Witnessed CertificateHydrostatic: ☐ ☐ ☐Leak: ☐ ☐ ☐NPSHR: ☐ ☐ ☐Performance: ☐ ☐ ☐Opt. perf. acceptance criteria: ☐ Power ☐ Efficiency ☐ NeitherAdditional data: ☐ Vibration ☐ Bearing temp.☐ Other perf. data: _____☐ Final inspection required Days notification required: _____☐ Dismantle and inspect after test☐ Casting repair procedure approval required

Material certification required:

☐ Casing ☐ Cover ☐ Impeller ☐ Shaft☐ Other: _____

Inspection required for connection welds:

☐ Manufacturer's standard☐ Visual inspection

Inspection required for castings:

☐ Manufacturer's standard☐ Visual inspection☐ Other: _____

● Manufacturer Documentation Required

For supplier data requirements, refer to: _____


Remarks: _____

<div style="font-size: 24pt; font-weight: bold; margin: 0;">ASME B73</div>		<div style="font-weight: bold; margin: 0;">Form I-1M Centrifugal Pump Data Sheet</div> <div style="font-size: 10pt; margin: 0;">Rev. No.: _____ Rev. Date: _____</div>		<div style="font-size: 10pt; margin: 0;">Issue Date</div> <div style="font-weight: bold; margin: 0;">MARCH 2015</div>
		<div style="font-weight: bold; margin: 0;">ASME Centrifugal Pumps (SI Units)</div> <div style="font-size: 10pt; margin: 0;">ASME B73.1, ASME B73.2</div>		<div style="font-weight: bold; margin: 0;">Page 3 of 4</div>
Usage key — data provided by: <input checked="" type="checkbox"/> Purchaser <input type="checkbox"/> Supplier <input type="checkbox"/> Supplier if not purchaser				
1	▲ Shaft Sealing <input type="checkbox"/> Mechanical seal <input type="checkbox"/> Packing		▲ Flush Plan — Single or Inner Seal	
2	Furnished by: <input type="checkbox"/> Supplier <input type="checkbox"/> Purchaser		Piping plan number(s): _____	
3	Installed by: <input type="checkbox"/> Supplier <input type="checkbox"/> Purchaser		External flush fluid: _____	
4	▲ Seal Chamber <input type="checkbox"/> Taper bore <input type="checkbox"/> Large cylindrical bore		Supply temperature: Min. _____ Max. _____ (°C)	
5	<input type="checkbox"/> Universal cover <input type="checkbox"/> Packing box		Specific gravity: _____ Specific heat: _____ (kJ/kg °C)	
6	Throat bushing: <input type="checkbox"/> None <input type="checkbox"/> Fixed bushing		Vapor pressure: _____ kPaA @ _____ (°C)	
7	<input type="checkbox"/> Floating bushing		Flow rate required: Min. _____ Max. _____ (m³/h)	
8	Throat bushing material: _____		Maximum flow rate allowed by process: _____ (m³/h)	
9	Jacketed seal chamber/packing box: <input type="checkbox"/> Yes <input type="checkbox"/> No		Pressure required: Min. _____ Max. _____ (kPaG)	
10	For: <input type="checkbox"/> Heating <input type="checkbox"/> Cooling		Maximum pressure allowed by process: _____ (kPaG)	
11	Remarks: _____		Temperature required: Min. _____ Max. _____ (°C)	
12			Inner seal flush plan piping: <input type="checkbox"/> Tube <input type="checkbox"/> Pipe	
13	▲ Mechanical Seal <input type="checkbox"/> Cartridge <input type="checkbox"/> Component		<input type="checkbox"/> Other: _____	
14	(ref. Mand. App. II) <input type="checkbox"/> Arrangement 1 (single seal)		Tube/pipe size: _____	
15	<input type="checkbox"/> Arrangement 2 (dual unpressurized seal)		Tube/pipe material: <input type="checkbox"/> 316 SS <input type="checkbox"/> Other _____	
16	<input type="checkbox"/> Arrangement 3 (dual pressurized seal)		Tube/pipe specification: _____	
17	Flexible element: <input type="checkbox"/> Rotating <input type="checkbox"/> Stationary		Tube/pipe connections: <input type="checkbox"/> Threaded <input type="checkbox"/> Socket weld	
18	B73.1 or B73.2 Mand. App. II configuration code: _____		<input type="checkbox"/> Unions <input type="checkbox"/> Butt weld <input type="checkbox"/> Tube fitting	
19	API 682 Category 1: <input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Other: _____	
20	Manufacturer: _____		Furnished by: <input type="checkbox"/> Supplier <input type="checkbox"/> Purchaser	
21	Model: _____		Remarks: _____	
22	Manufacturer code: _____			
23	Drawing number: _____			
24	Remarks: _____			
25				
26	▲ Seal Materials — Single or Inner Seal		▲ Flush Plan — Outer Seal	
27	Seal faces: Rotating face: _____		Piping plan number(s): _____	
28	Stationary face: _____		External flush fluid: _____	
29	Secondary seals: Rotating face: _____		Supply temperature: Min. _____ Max. _____ (°C)	
30	Stationary face: _____		Specific gravity: _____ Specific heat: _____ (kJ/kg °C)	
31	Sleeve: _____		Vapor pressure: _____ kPaA @ _____ (°C)	
32	Springs: _____ Bellows: _____		Flow rate required: Min. _____ Max. _____ (m³/h)	
33	Metal parts: _____		Maximum flow rate allowed by process: _____ (m³/h)	
34	Remarks: _____		Pressure required: Min. _____ Max. _____ (kPaG)	
35			Maximum pressure allowed by process: _____ (kPaG)	
36	▲ Seal Materials — Outer Seal		Temperature required: Min. _____ Max. _____ (°C)	
37	Seal faces: Rotating face: _____		MAWP flush plan: _____ kPaG @ min. temp. _____ (°C)	
38	Stationary face: _____		_____ kPaG @ max. temp. _____ (°C)	
39	Secondary seals: Rotating face: _____		Outer seal flush plan piping: <input type="checkbox"/> Tube <input type="checkbox"/> Pipe	
40	Stationary face: _____		<input type="checkbox"/> Other: _____	
41	Sleeve: _____		Tube/pipe size: _____	
42	Springs: _____ Bellows: _____		Tube/pipe material: <input type="checkbox"/> 316 SS <input type="checkbox"/> Other _____	
43	Metal parts: _____		Tube/pipe specification: _____	
44	Remarks: _____		Tube/pipe connections: <input type="checkbox"/> Threaded <input type="checkbox"/> Socket weld	
45			<input type="checkbox"/> Unions <input type="checkbox"/> Butt weld <input type="checkbox"/> Tube fitting	
46	▲ Seal Gland Material: _____		<input type="checkbox"/> Other: _____	
47	Ports: <input type="checkbox"/> Flush <input type="checkbox"/> Drain <input type="checkbox"/> Vent <input type="checkbox"/> Quench		Furnished by: <input type="checkbox"/> Supplier <input type="checkbox"/> Purchaser	
48	<input type="checkbox"/> Buffer/barrier fluid inlet <input type="checkbox"/> Buffer/barrier fluid outlet		Remarks: _____	
49	Throttle bushing: <input type="checkbox"/> Yes <input type="checkbox"/> No			
50	Throttle bushing material: _____			
51	Remarks: _____			

MANDATORY APPENDIX II MECHANICAL SEAL AND PACKING CONFIGURATION CODES

See Fig. II-1 on the following page.

Fig. II-1 Mechanical Seal and Packing Configuration Codes



NONMANDATORY APPENDIX A

ELECTRONIC DATA EXCHANGE

The information contained in pump data sheets may be transmitted digitally rather than via a conventional data sheet format. This is suitable when the pump purchaser and supplier have systems that can process digital information rather than paper-based data sheets. Direct electronic transfer can be achieved with a transfer protocol that is adopted by both purchaser and supplier. This transfer protocol must also be commercially neutral if it is to be accepted by all parties. Such a method improves the operating efficiencies of both parties if their internal data systems can import and export via this neutral protocol.

Those interested in adopting electronic data exchange (EDE) are encouraged to reference the EDE technology and implementation standard, HI 50.7, for the digital

transfer of centrifugal pump data. HI 50.7 provides implementation details and examples toward adopting EDE that are suitable for ASME B73 centrifugal pump data. Additional interpretive information is also available at www.pumps.org/ede.

This EDE Standard was developed and supported by the Hydraulic Institute and the Fiatech Automating Equipment Information Exchange (AEX) project. Information on the EDE technology and the AEX XML schemas is available online at www.fiatech.org/projects/idim/aex.htm.

A complete listing of data fields in the ASME B73 data sheet and their corresponding XML structures are found in HI 50.7 or via Fiatech at www.fiatech.org.

ASME Services

ASME is committed to developing and delivering technical information. At ASME's Customer Care, we make every effort to answer your questions and expedite your orders. Our representatives are ready to assist you in the following areas:

ASME Press
Codes & Standards
Credit Card Orders
IMEchE Publications
Meetings & Conferences
Member Dues Status

Member Services & Benefits
Other ASME Programs
Payment Inquiries
Professional Development
Short Courses
Publications

Public Information
Self-Study Courses
Shipping Information
Subscriptions/Journals/Magazines
Symposia Volumes
Technical Papers

How can you reach us? It's easier than ever!

There are four options for making inquiries* or placing orders. Simply mail, phone, fax, or E-mail us and a Customer Care representative will handle your request.

Mail
ASME
150 Clove Road, 6th Floor
Little Falls, New Jersey
07424-2139

Call Toll Free
US & Canada: 800-THE-ASME
(800-843-2763)
Mexico: 95-800-THE-ASME
(95-800-843-2763)

Fax—24 hours
973-882-1717
973-882-5155

E-Mail—24 hours
customer care@asme.org

* Customer Care staff are not permitted to answer inquiries about the technical content of this code or standard. Information as to whether or not technical inquiries are issued to this code or standard is shown on the copyright page. All technical inquiries must be submitted in writing to the staff secretary. Additional procedures for inquiries may be listed within.

ASME B73.2-2016

I S B N 978-0-7918-7134-8

