



Standard Practice for Installation and Use of Reflective Insulation in Building Constructions¹

This standard is issued under the fixed designation C727; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice has been prepared for use by the designer, specifier, and installer of reflective insulation for use in building construction. The scope is limited to recommendations relative to the use and installation of thermal insulation consisting of one or more surfaces, having an emittance of 0.1 or less such as metallic foil or metallic deposits unmounted or mounted on substrates and facing enclosed air spaces. The reflective insulation covered by this practice must meet the requirements of Specification C1224.

1.2 This practice covers the installation process from pre-installation inspection through post-installation procedure. It does not cover the production of the insulation materials.

1.3 This practice is not intended to replace the manufacturer's installation instructions, but shall be used in conjunction with such instructions. This practice is not intended to supersede local, state, or federal codes.

1.4 This practice assumes that the installer possesses a good working knowledge of the applicable codes and regulations, safety practices, tools, equipment, and methods necessary for the installation of thermal insulation materials. It also assumes that the installer understands the fundamentals of construction that affect the installation of insulation.

1.5 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

¹ This practice is under the jurisdiction of ASTM Committee C16 on Thermal Insulation and is the direct responsibility of Subcommittee C16.21 on Reflective Insulation.

Current edition approved May 1, 2012. Published June 2012. Originally approved in 1972. Last previous edition approved 2007 as C727 – 01(2007) ^ε1. DOI: 10.1520/C0727-12.

2. Referenced Documents

2.1 ASTM Standards:²

C168 Terminology Relating to Thermal Insulation

C1224 Specification for Reflective Insulation for Building Applications

E96/E96M Test Methods for Water Vapor Transmission of Materials

2.2 NFPA Standards:

NFPA 31 Standard for the Installation of Oil Burning Equipment³

NFPA 54 National Fuel Gas Code³

NFPA 211 Standard for Chimneys, Fireplaces, and Vents³

2.3 Code of Federal Regulations:

16 CFR 460 Federal Trade Commission Trade Regulation Rule: Labeling and Advertising of Home Insulation⁴

3. Terminology

3.1 *Definitions*—For definitions of terms used in this practice refer to Terminology C168

3.2 Descriptions of Terms Specific to This Standard:

3.2.1 *applicator*—the person or persons who apply thermal insulation materials in buildings whether or not such person or persons have contracted with the owner to perform the work.

3.2.2 *conditioned space*—any space in a building that is served by a heating or cooling system.

3.2.3 *owner*—the person, partnership, corporation, agency, or other entity owning the building to be insulated whether such ownership is by virtue of deed, contract, or any other instrument for acquiring legal title under the laws of the state in which the building is located.

3.2.4 *reflective insulation system*—thermal insulation consisting of one or more low emittance surfaces, bounding one or more enclosed air spaces.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02169-7471, <http://www.nfpa.org>.

⁴ Federal Register, Vol 70, No. 103. Available from Department of Housing and Urban Development, 451 7th St. N.W., Washington, D.C. 20410.

3.2.5 *vapor retarder*—any material (membrane or paint) that has a water vapor permeance (perm) rating of 57 ng/(Pa·s·m²) (1 perm) or less, in accordance with Test Methods E96/E96M, using the desiccant method.

4. Significance and Use

4.1 This practice recognizes that effectiveness, safety, and durability of reflective insulation depends not only on the quality of the insulating materials, but also on proper installation.

4.2 There is potential for reduced thermal effectiveness, fire risks and structural deterioration when the insulation is improperly installed. Specific potential hazards from improper installation include fires caused by (1) heat build-up in recessed lighting fixtures, and (2) deterioration in wood structures and paint failure due to moisture accumulation.

4.3 This practice provides procedures for the installation of reflective insulation in a safe and effective manner. Actual conditions in existing buildings vary greatly and in some cases additional care must be taken to ensure safe and effective installation.

4.4 This practice presents requirements that are general in nature and practical. They are not intended as specific installation instructions. The user shall consult the manufacturer for specific applications/installations.

5. Safety Precautions

5.1 The applicator shall wear proper protective clothing, gloves, and eye protection when installing the insulation.

6. Pre-Installation Inspection and Preparation

6.1 In areas where insulation is to be installed, components of the electrical system shall be in good condition. When the electrical system is found to be faulty, proper inspection and repair shall be accomplished. (See Note 1.)

6.2 Inspect the roof, walls, ceilings, and floors to identify areas where a previous or existing moisture problem has caused paint peeling, warpage, stain, visible fungus growth, rotting, or other structural damage.

6.2.1 Do not install insulation in such areas until the owner has been informed, and these conditions have been corrected and the cause of the condition repaired.

6.3 Prior to installation, provide proper attic ventilation and vapor retarders in accordance with building requirements or codes. Install insulation in such a way as to ensure free movement of air through all vents.

NOTE 1—The CPSC Product Safety Fact Sheet No. 18⁵ has identified the following signs of potential electrical deficiencies: lights dimming, fuses blowing, circuit breakers tripping frequently, electrical sparks and glowing from receptacles, lights flickering, and coverplates on switches and outlets that are warm or hot to the touch.

6.4 In the areas where insulation is to be installed, the applicator shall locate and plan for subsequent blocking around

recessed lighting fixtures, motors, fans, blowers, heaters, flues, chimneys, and other heat-producing electrical or mechanical devices.

6.4.1 Securely fasten blocking, such as wood, metal, or unfaced mineral wool batts, around all heat-producing devices to permanently maintain the clearances specified in 6.4.2, 6.4.3, or the exception in 6.4.4. Install all required blocking at least as high as the height of the finished insulation and in a manner that ensures all devices that require maintenance or servicing remain accessible after the insulation is installed.

6.4.2 Install blocking to provide a minimum three inch (76 mm) clearance around all sides of recessed lighting fixtures, unless such fixtures are approved for installation in direct contact with insulation, including fixture wiring compartments and ballasts and other heat-producing devices not covered with thermal insulation.

6.4.3 The open area above heat producing devices must not be covered, unless they are specifically approved devices for operation when covered with thermal insulation.

6.4.4 Install blocking around gas-fired appliances to provide the minimum clearances specified in NFPA-54. Install blocking around oil-fired appliances to provide the minimum clearances specified in NFPA-31. Install blocking around masonry chimneys or masonry enclosing a flue to provide a minimum 2-in. (50-mm) clearance from the outside face of the masonry. Install blocking around vents, chimney, and vent connectors and chimneys other than masonry chimneys to provide the minimum clearances specified in NFPA-211.

7. Installation Guidelines

7.1 The insulation material shall be handled in accordance with manufacturer's instructions and kept free of extraneous materials. The materials shall be kept dry and shall not be in contact with the ground or other sources of water.

7.2 Installation instructions per the manufacturer and local codes shall be followed to ensure proper installation. The thermal performance of reflective insulation is based on the maintenance of a totally enclosed air space adjacent to the low emittance surface(s).

7.3 The thermal performance of a reflective insulation depends upon adherence to spacing requirements contained within the installation instructions. When instructions for insulating undersize and oversize cavities is not provided the manufacturer shall be consulted.

7.4 Damaged areas will result in loss of performance and shall be repaired with low emittance material(s). Minor damage such as rips, tears, or punctures shall be repaired with low emittance materials while larger damaged areas shall be replaced with new reflective insulation. (See Note 2.)

7.5 The thermal performance of a reflective insulation has the potential to be reduced by a corrosive environment. Reflective insulations shall not be installed in environments that are corrosive to the low emittance surface.

7.6 The thermal performance of a reflective insulation has the potential to be adversely affected by materials such as dust, oil, or paint on the surfaces. These materials shall be removed during installation taking care not to damage the insulation.

⁵ CPSC "Guide to Home Wiring Hazards", available from the Consumer Product Safety Commission, 1111 Eighteenth St. N.W., Washington, D.C. 20207.

7.7 Moisture will affect the thermal performance of the reflective insulation as long as it remains on the surface. Insulation shall be free of moisture at time of installation.

7.8 It is important that reflective insulation be fitted closely around all non-heat producing components and taped to eliminate gaps or voids through which air, dust, or water vapor has the potential to pass.

7.9 *Post-Installation*—The installer must provide a signed and dated statement describing the reflective insulation

installed, the area insulated, and the R-value of the installed system. (See Trade Regulation Rule 16 CFR 460.)

NOTE 2—Large damaged areas are defined as those areas greater than 1 ft².

8. Keywords

8.1 building constructions; enclosed air space; insulation system; low emittance; metallic foil; reflective insulation; thermal insulating materials

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the ASTM website (www.astm.org/COPYRIGHT/).