



## Standard Specification for HFC-23 (Trifluoromethane, $\text{CHF}_3$ )<sup>1</sup>

This standard is issued under the fixed designation D6126/D6126M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

### 1. Scope

1.1 This specification covers the requirements for HFC-23 as a fire fighting medium.

1.2 This specification does not address the fire fighting equipment or hardware that employs HFC-23 or the conditions of employing such equipment (for example: handshields, fixed installations, etc.).

1.3 This specification does not address the storage or transportation of HFC-23. Storage handling, and transportation issues are addressed in Practice D6127.

1.4 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.

1.5 The following safety hazards caveat pertains to the test methods portion, Section 6, of this specification: *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

### 2. Referenced Documents

#### 2.1 ASTM Standards:<sup>2</sup>

D6127 Practice for Handling, Transportation, and Storage of HFC-23 (Trifluoromethane,  $\text{CHF}_3$ )

D6806 Practice for Analysis of Halogenated Organic Solvents and Their Admixtures by Gas Chromatography

<sup>1</sup> This specification is under the jurisdiction of ASTM Committee D26 on Halogenated Organic Solvents and Fire Extinguishing Agents and is the direct responsibility of Subcommittee D26.09 on Fire Extinguishing Agents.

Current edition approved June 1, 2015. Published June 2015. Originally approved in 1997. Last previous edition approved in 2011 as D6126/D6126M-11<sup>ε1</sup>. DOI: 10.1520/D6126\_D6126M-11R15.

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

#### 2.2 ISO Standards:<sup>3</sup>

ISO 3427 Gaseous Halogenated Hydrocarbons (Liquefied Gases) - Taking a Sample

#### 2.3 AHRI Standards:<sup>4</sup>

2008 Appendix C Analytical Procedures for ARI Standard 700-2006

#### 2.4 U.S. Government Standards:<sup>5</sup>

Code of Federal Regulations (CFR) Title 49, Part 172.101  
Tables of Hazardous Materials and Special Provisions  
Code of Federal Regulations (CFR) Title 49, Part 172 Sub  
D Marking Requirements of Packaging for Transportation

#### 2.5 American Society of Refrigerating Engineers:<sup>6</sup>

ASRE Standard 34, Designation of Refrigerants

### 3. Terminology

#### 3.1 Definitions of Terms Specific to This Standard:

3.1.1 *halogenated hydrocarbon*—the halogenated compound coding terminology system provides a convenient means to reference halogenated hydrocarbons, ASRE 34. Halogenated hydrocarbons are saturated hydrocarbons in which one or more of the hydrogen atoms have been replaced by atoms of the halogen series (fluorine, chlorine, bromine, and iodine). It is convention to prefix the number with an abbreviation of the compound:

CFC = chlorofluorocarbon  
HCFC = hydrochlorofluorocarbon  
HFC = hydrofluorocarbon  
FC = fluorocarbon  
R = refrigerant

3.1.1.1 *Discussion*—By definitions, the right most digit of the numbering system is the number of fluorine atoms.

3.1.1.2 *Discussion*—The second digit from the right is the number of hydrogen atoms plus one (+1).

3.1.1.3 *Discussion*—The third digit from the right is one less

<sup>3</sup> Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

<sup>4</sup> Available from Air Conditioning, Heating & Refrigeration Institute (AHRI), 2111 Wilson Blvd., Suite 500, Arlington, VA 22201, <http://www.ahrinet.org>.

<sup>5</sup> Available from U.S. Government Publishing Office, 732 N. Capitol St., NW, Washington, DC 20401-0001, <http://www.gpo.gov>.

<sup>6</sup> Available from American Society of Refrigerating Engineers, Refrigeration Engineering 65.49 (1957).

(-1) than number of carbon atoms in the compound (when this number is zero (0) it is omitted from the number.

3.1.1.4 *Discussion*—Unaccounted for valance requirements are assumed to be chlorine atoms.

3.1.1.5 *Discussion*—When the compound contains bromine or iodine, the same rules apply except the letter “B” for bromine or “I” for iodine follows the parent compound designated number and the number of the atoms is placed after the letter.

3.1.1.6 *Discussion—Example*— $\text{CHF}_3 = \text{R-23} = \text{HFC-23}$ .

3.1.2 *HFC-23*—the compound trifluoromethane;  $\text{CHF}_3$ .

## 4. Material Requirements

4.1 Nitrogen ( $\text{N}_2$ ) partial pressure is not required for this product, it is shipped neat. The saturated vapor pressure of HFC-23 is 42 bars at 21°C [610 psig at 70°F]. HFC-23 has a critical temperature of 25.9°C [78.6°F]. The filling density should be that which will not liquid fill the container at temperatures below 25.9°C [78.6°F] or exceed 5/4 the pressure rating of the container at 130°F. For example, the U.S. DOT 3AL cylinder with a minimum working pressure of 1800 psig shall not exceed 42 bar at 21°C [610 psig at 70°F] for a maximum filling density of 84.4 %. For this example the cylinder pressure is 141 bars at 54°C [2045 psig at 130°F].

4.1.1 HFC-23 shall conform to the requirements prescribed in **Table 1** when tested by the appropriate test method(s) listed in Section 6.

4.1.2 When material analysis is required, by agreement between the purchaser and the supplier, the total pressure in the HFC-23 container, the fill density of the HFC-23 within the container, and the maximum safe storage temperature shall be part of the material analysis (certification). The pressure shall be reported in bar (preferred) or pound-force per square inch gage (psig). The fill density shall be reported in kilograms per cubic metre at 21°C (preferred) or pounds per cubic foot at 70°F. The maximum safe storage temperature of the HFC-23 shall be reported in degrees Celsius (preferred) or in degrees Fahrenheit and shall conform to the applicable regulations for the HFC-23 container design and use.

4.2 By agreement between the purchaser and the supplier, analysis may be required and limits established for elements or compounds not specified in **Table 1**.

**TABLE 1 Requirements**

Property	Requirement
HFC-23 purity, %, mol/mol, max	99.0
Acidity, ppm by mass, as HCl, max	3.0
Water content, ppm by mass, max	10
Nonvolatile residue, % by weight, max	0.08
Suspended matter or sediment	none visible

4.3 *Product Requirements*—See **Table 1**.

## 5. Sampling

5.1 Samples of HFC-23, taken from the liquid phase, shall be taken from filled containers in accordance with the method specified in ISO 3427. The sampling bottle shall be capable of safely resisting the vapor pressure of the sample at the highest temperature that could be encountered.

5.2 The HFC-23 selected in accordance with 5.1 shall be tested for quality conformance in accordance with Section 6. The presence of one or more defects shall be cause for rejection.

## 6. Test Methods

6.1 *Purity*—Determine purity using the method specified in Practice **D6806**.

6.2 *Acidity*—Determine acidity using the method specified in 2008 Appendix C to ARI Standard 700-2006, part 1.

6.3 *Water Content*—Determine water content using the method specified in 2008 Appendix C to ARI Standard 700-2006, part 2.

6.4 *Nonvolatile Residue*—Determine nonvolatile residue using the method specified in 2008 Appendix C to ARI Standard 700-2006, part 3.

6.5 *Non-absorbable Gases*—Determine non-absorbable gases using the method specified in 2008 Appendix C to ARI Standard 700-2006, part 5.

6.6 *Suspended Matter or Sediment*—While performing the nonvolatile residue analysis, examine visually for any suspended matter or sediment. Observation of any suspended matter or sediment shall constitute failure of this test method.

## 7. Container, Packaging, and Package Marking

7.1 Containers used for shipping and storage of HFC-23 conforming to this specification shall be marked in the accordance with Code of Federal Regulations (CFR) Title 49, Part 172 Sub D. The proper shipping name is UN1984, trifluoromethane, "nonflammable gas" (49 CFR 172.101). In addition to DOT requirements, containers shall be marked with the following information as a minimum:

7.1.1 Supplier's name and address,

7.1.2 HFC-23 (trifluoromethane), and

7.1.3 Statement that material conforms to ASTM Specification D6126/D6126M.

## 8. Keywords

8.1  $\text{CHF}_3$ ; FE-13™; fire fighting; fire fighting agent; fire protection; fire suppressant; HFC-23; hydrofluorocarbon; trifluoromethane



## **D6126/D6126M – 11 (2015)**

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or [service@astm.org](mailto:service@astm.org) (e-mail); or through the ASTM website ([www.astm.org](http://www.astm.org)). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>*