



## Standard Practice for Determination of Dead Loads and Live Loads Associated with Vegetative (Green) Roof Systems<sup>1</sup>

This standard is issued under the fixed designation E2397/E2397M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

### 1. Scope

1.1 This practice covers a standardized procedure for predicting the system weight of a vegetative (green) roof system.

1.2 The practice addresses the loads associated with vegetative (green) roof systems. Components that are typically encountered in vegetative (green) roof systems include: membranes, non-absorptive plastic sheet components, metallic layers, fabrics, geocomposite drain layers, synthetic reinforcing layers, cover/recover boards, insulation materials, growth media, granular drainage media, and plant materials.

1.3 This practice also addresses the weight of the vegetative (green) roof system under two conditions: (1) weight under drained conditions after new water additions by rainfall or irrigation have ceased (this includes the weight of retained water and captured water), and (2) weight when rainfall or irrigation is actively occurring and the drain layer is completely filled with water. The first condition is considered the dead load of the vegetative (green) roof system. The difference in weight between the first and second conditions, approximated by the weight of transient water in the drain layer, is considered a live load.

1.4 This practice does not address point or line loads associated with architectural elements that are not essential components of a particular vegetative (green) roof system. These architectural elements may include pavement, walls, and masonry, and so forth.

1.5 This practice does not address live loads associated with construction activities.

1.6 This practice does not address loads associated with snow or wind.

1.7 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each

system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.

*1.8 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and to determine the applicability of regulatory limitations prior to use.*

### 2. Referenced Documents

2.1 *ASTM Standards:*<sup>2</sup>

E11 Specification for Woven Wire Test Sieve Cloth and Test Sieves

E631 Terminology of Building Constructions

E2114 Terminology for Sustainability Relative to the Performance of Buildings

E2396 Test Method for Saturated Water Permeability of Granular Drainage Media [Falling-Head Method] for Vegetative (Green) Roof Systems

E2398 Test Method for Water Capture and Media Retention of Geocomposite Drain Layers for Vegetative (Green) Roof Systems

E2399 Test Method for Maximum Media Density for Dead Load Analysis of Vegetative (Green) Roof Systems

### 3. Terminology

3.1 *Definitions:*

3.1.1 For terms related to building construction, refer to Terminology E631.

3.1.2 For terms related to sustainability relative to the performance of buildings, refer to Terminology E2114.

3.2 *Definitions of Terms Specific to This Standard:*

3.2.1 *captured water, n*—the quantity of water that is retained in the drain layer of a vegetative (green) roof system after new water additions have ceased and that cannot escape the roof except through evaporation or plant transpiration.

3.2.1.1 *Discussion*—Water capture is a design technique for

<sup>1</sup> This Practice is under the jurisdiction of ASTM Committee D08 on Roofing and Waterproofing and is the direct responsibility of Subcommittee D08.24 on Sustainability.

Current edition approved June 1, 2015. Published July 2015. Originally approved in 2005. Last published in 2011 as E2397 – 11. DOI: 10.1520/E2397\_E2397M-15.

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

enhancing the water holding properties of a vegetative (green) roof system. Water may be captured using a number of techniques, including reservoirs built into a geocomposite drain layer, trays, and restricting drainage in order to hold water within the drain layer. In some vegetative (green) roof systems a granular course at the bottom of the vegetative (green) roof system provides both drainage and water capture functions. In this case the captured water applies only to the thickness of the granular course for which drainage is restricted. A method for determining the captured water associated with geocomposites based on the unit water capture volume is provided in Test Method E2398. The quantity of captured water will depend on whether or not the upper surface of the geocomposite drain layer is in-filled with granular media.

3.2.2 *geocomposite drain layer, n*—a synthetic sheet, mat, or panel that is specifically designed to convey water horizontally toward the roof deck drains, gutters, or scuppers.

3.2.2.1 *Discussion*—Geocomposite drain layers include absorptive drain mats whose principle function is drainage, but which will also contribute to water retention (see *retained water*). Some geocomposite drain layers may incorporate reservoirs on their upper surfaces that will capture water (see *captured water*).

3.2.3 *maximum media density, n*—the density of a mixed media material determined after it has been subjected to a specific amount of compaction and hydrated by immersion to simulate prolonged exposure to both foot traffic and rainfall.

3.2.3.1 *Discussion*—The maximum media density applies to media in a drained condition. The measurement of the maximum media density is provided in Test Method E2399.

3.2.4 *maximum media water retention*—the quantity of water held in a media layer at the maximum media density, measured in volume percent.

3.2.4.1 *Discussion*—A procedure for measuring the maximum media water retention is provided in Test Method E2399.

3.2.5 *module, n*—modular vegetative (green) roof systems combine many functional elements of vegetative (green) roof systems in a pre-manufactured module.

3.2.5.1 *Discussion*—Independent modules are designed to be placed adjacent to one another and linked in order to tile larger surfaces.

3.2.6 *retained water, n*—water which is held for a period of hours or days but would eventually drain out given enough time in the absence of evaporation or plant transpiration.

3.2.6.1 *Discussion*—Retained water is the quantity of water that is held for a prolonged period against gravity drainage in a vegetative (green) roof system, or in one of its components, after new additions by rainfall or artificial irrigation have ceased. Neglecting the effects of capillary rise, evaporation, and plant transpiration all of this water would eventually produce runoff. However, in practice most of this water will not become runoff but will be lost to evaporation and the plant-mediated processes of transpiration. This procedure describes standardized methods for estimating the quantity of water retained in a vegetative (green) roof system.

3.2.7 *roofing system, n*—see *roofing system*.

3.2.8 *roofing system, n*—assembly of interacting components designed to weatherproof, and sometimes to insulate, the roof surface of a building. **E631**

3.2.8.1 *Discussion*—This term includes all components above the roof deck that are not part of the overlying vegetative (green) roof system. In practice this usually means the waterproofing membrane and all materials below the waterproofing membrane, down to the structural deck. It may include structural materials such as cover/recover board, insulation, protective layers, fire-suppressing materials, and waterproofing materials. The weight of these components (assumed dry) must be obtained from the manufacturer of the roofing system.

3.2.9 *transient water, n*—the quantity of water that is required to completely fill the drain layer of a vegetative (green) roof system, less the quantity of captured water.

3.2.9.1 *Discussion*—Transient water fills the open space, including pore spaces. This water can only be held for a period of minutes and drains immediately when rainfall additions end. This moisture contributes to the live load of the vegetative (green) roof system.

## 4. Summary of Practice

4.1 This practice describes a systematic procedure for estimating the dead load and transient water live load of vegetative (green) roof systems using information about the vegetative (green) roof components that are available from laboratory analysis.

## 5. Significance and Use

5.1 This practice addresses performance characteristics for vegetative (green) roof systems with respect to the dead load and transient water load of the entire vegetative (green) roof system.

5.2 Determining these performance characteristics of vegetative (green) roof systems provides information to facilitate the assessment of related engineering aspects of the facility. Such aspects may include structural design requirements, mechanical engineering and thermal design requirements, and fire and life safety requirements.

5.3 Determining these performance characteristics of vegetative (green) roof systems provides information to facilitate assessment of the performance of one vegetative (green) roof system relative to another.

## 6. Apparatus

### 6.1 Apparatus:

6.1.1 Scale, accurate to 0.005 oz [0.14 g];

6.1.2 Metal mesh with sieve opening size of U.S. #30 [0.6 mm], or larger, suspended from a drain stand;

6.1.3 Pan; and

6.1.4 Water bath.

6.2 Units of measure: lb/ft<sup>2</sup> [kg/m<sup>2</sup>].

## 7. Procedure

7.1 *Weight of All Non-Absorptive Sheet Component*—These materials include plastic or rubber membranes, closed-cell foam layers, and the rigid or semi-rigid plastic cores of

geocomposite drain layers. Also included is insulation provided as part of protected membrane roofing (PMR) installation. Absorptive drainage mats and fabrics, including fabrics integrated with geocomposite drain layers, are excluded (see 7.2 and 7.3). As needed, remove fabrics bonded to geocomposite drain layers for separate measurement according to 7.2. Weigh a 4-in. by 4-in. [10-cm by 10-cm] piece. Multiply this weight by 9 [100] to convert to unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ], and record.

**7.2 Weight of All Fabrics**—4-in. by 4-in. [10-cm by 10-cm] sample in the dry condition. Multiply this weight by 9 [100] to convert to unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ], and record. This is the dry unit weight of the fabric. Immerse the sample in a water bath for 15 min. Withdraw from the bath and drain for 15 min by laying the fabric flat on a suspended U.S. #30 [0.6 mm] wire cloth or sieve. Weigh the sample, convert to unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ], and record. This is the unit weight of the fabric. The difference between the two measurements is the unit weight of the retained water associated with the fabric,  $W_r$ .

**7.3 Weight of Absorptive Drain Mats Used as Drain Layer Components**—These materials include open-cell foam layers, porous mats fabricated from particles of plastic or rubber, and mats manufactured from coir or other organic fibers. Weigh the pan using the scale. Weigh a 4-in. by 4-in. [10-cm by 10-cm] sample in the dry condition. Multiply this weight by 9 [100] to convert to unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ], and record as the dry unit weight of the sample. Immerse the mat in the water bath for 24 hours. Withdraw the mat from the water bath and without delay place the mat into the pan. Weigh the pan and its contents. Subtract the weight of the pan and the dry weight of the mat. Multiply this weight by 9 [100] to convert to unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ], and record as the unit weight of the water contained in the mat when filled to capacity. Dry the pan. Allow the mat to drain for an additional two hours by laying the mat flat on a suspended U.S. #30 [0.6 mm] wire cloth or sieve. Return the mat to the pan. Weigh the pan and its contents. Subtract the weight of the pan. Convert to unit weight in  $\text{lb/ft}^2$ , and record. This is the unit weight of the sample. Subtract the dry unit weight of the sample, and record. This is the unit weight of the retained water,  $W_r$ , in the mat. Subtract the unit weight of the retained water from the unit weight of the water when the mat was filled to capacity. This is the unit weight of the transient water associated with the absorptive drain mat,  $W_t$ .

**7.4 Weight of Growth Media**—Use Test Method E2399 to determine the maximum media density (MMD) and dry media density,  $D_{\text{dry}}$ , both measured in  $\text{lb/ft}^3$  [ $\text{kg/m}^3$ ], and the maximum media water retention (MMWR), measured in volume percent. Multiply the maximum media density times the thickness of the media layer in feet [metres] to convert to unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ], and record. This is the unit weight of the growth media. Multiply the dry media density times the thickness of the media layer in feet to convert to unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ], and record. This is the dry unit weight of the growth media. To determine the unit weight of the retained water,  $W_r$ , multiply the MMWR by the thickness of the media layer in feet and by 0.624 [10] and record this unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ].

## 7.5 Weight of Granular Drainage Media:

**7.5.1 Drain Layers Consisting Entirely of Granular Drainage Media**—Use Test Method E2399 to determine the MMD and dry media density,  $D_{\text{dry}}$ , both measured in  $\text{lb/ft}^3$  [ $\text{kg/m}^3$ ], and the MMWR of the granular material, measured in volume percent. Multiply the MMD times the thickness of the granular drainage media in feet [metres]. Record the unit weight of the granular drainage media in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ]. Multiply the dry media density times the thickness of the media layer in feet to convert to unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ], and record. This is the dry unit weight of the granular drainage media. To determine the unit weight of the retained water,  $W_r$ , multiply the MMWR by the thickness of the layer in feet and by 0.624 [10]. Record this unit weight in  $\text{lb/ft}^2$ .

**7.5.2 Drain Layers Incorporating Geocomposite Drain Layers**—In many vegetative (green) roof systems, granular drainage media is in-filled on the upper surface of a geocomposite drain layer. In these instances, the effective thickness of the granular drainage media,  $ET$ , is the unit media retention volume,  $R_m$ , measured in  $\text{ft}^3/\text{ft}^2$  [ $\text{cm}^3/\text{cm}^2$ ], as determined using Test Method E2398, plus any supplemental thickness of granular drainage media above the geocomposite drain layer, measured in feet [metres]. Use Test Method E2399 to determine the MMD and dry media density,  $D_{\text{dry}}$ , both measured in  $\text{lb/ft}^3$  [ $\text{kg/m}^3$ ], and the MMWR of the granular material, measured in volume percent. Multiply the MMD times the effective thickness of the granular drainage media in feet and by 0.624 [10]. Record the unit weight of the granular drainage media in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ]. Multiply the dry media density times the effective thickness of the granular drainage layer in feet to convert to unit weight in  $\text{lb/ft}^2$ , and record. This is the dry unit weight of the granular drainage media. To determine the weight of the retained water,  $W_r$ , multiply the MMWR by the effective thickness of the granular drainage media layer in feet and by 0.624 [98.1]. Record this unit weight in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ].

## 7.6 Unit Weight of Captured Water:

**7.6.1 Drain Layers Consisting Entirely of Granular Drainage Media**—One strategy for capturing water in vegetative (green) roof systems is to impound water in the drain layer by restricting drainage. In these cases water will accumulate in the granular drainage media layer at the base of the vegetative (green) roof system. Use Test Method E2399 to determine the air-filled porosity (AFP) of the granular drainage media, reported in percent. Multiply AFP times the average depth of impounded water layer in feet [metres] and by 0.624 [10]. Record the unit weight of captured water,  $W_c$ , in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ].

**7.6.2 Geocomposite Drain Layers, Without Granular Drainage Media**—For vegetative (green) roof systems that incorporate geocomposite drain layers with water capture, use Test Method E2398 to determine the weight of captured water based on the unit water capture volume ( $R_w$ ). Multiply the unit water capture volume, stated in  $\text{ft}^3/\text{ft}^2$  [ $\text{cm}^3/\text{cm}^2$ ], by 62.4 [10]. Record the unit weight of captured water,  $W_c$ , in  $\text{lb/ft}^2$  [ $\text{kg/m}^2$ ].

**7.6.3 Drain Layers That Incorporate In-Filling of Granular Media on the Upper Surface of a Geocomposite Drain Layer**—Use Test Method E2399 to determine the AFP of the granular

drainage media, reported in percent. To determine the weight of captured water, multiply AFP times  $R_w$  and by 62.4 [10]. Record the unit weight of captured water,  $W_c$ , in lb/ft<sup>2</sup> [kg/m<sup>2</sup>].

### 7.7 Unit Weight of Transient Water:

**7.7.1 Drain Layers Consisting Entirely of Granular Drainage Media**—Use Test Method E2399 to determine the AFP of the granular drainage media, reported in percent. Multiply AFP times the thickness of the drain layer in feet [metres] and by 0.624 [10]. Subtract the unit weight of captured water, determined in 7.6.1. Record the unit weight of transient water,  $W_t$ , in lb/ft<sup>2</sup> [kg/m<sup>2</sup>].

**7.7.2 Drain Layers Incorporating Geocomposite Drain Layers**—For vegetative (green) roof systems using absorptive drain mats, the method for determining the weight of transient water is described in 7.3. For other geocomposite drain layers, measure the thickness of the geocomposite drain layer in feet [centimetres]. Add any supplemental thickness associated with the granular drainage media above the geocomposite drain layer. Record as the unit volume,  $UV$ , in ft<sup>3</sup>/ft<sup>2</sup> [cm<sup>3</sup>/cm<sup>2</sup>].

**7.7.2.1 Drain Layers Without Granular Drainage Media**—Multiply the unit volume by 62.4 [10]. Subtract the unit weight of captured water, determined in 7.6.2. Record the unit weight of transient water,  $W_t$ , in lb/ft<sup>2</sup> [kg/m<sup>2</sup>].

**7.7.2.2 Drain Layers Incorporating Granular Drainage Media**—Use Test Method E2399 to determine the AFP for the granular drainage media, reported in percent. Multiply AFP times the effective thickness of the granular drainage media layer, determined in 7.5.2. Add this result to the unit volume. Subtract the effective thickness. Multiply this result by 62.4 [10]. Subtract the unit weight of captured water, determined in 7.6.3. Record the resulting unit weight of transient water,  $W_t$ , in lb/ft<sup>2</sup> [kg/m<sup>2</sup>].

$$W_t = (UV - ET(1 - AFP)) * 62.4 - W_c \text{ (in. - lb)} \quad (1)$$

$$W_t = (UV - ET(1 - AFP)) * 10 - W_c \text{ (SI)}$$

where:

$W_t$  = unit weight of transient water, lb/ft<sup>3</sup> [kg/m<sup>3</sup>],  
 $UV$  = unit volume of geocomposite, ft<sup>3</sup>/ft<sup>2</sup> [cm<sup>3</sup>/cm<sup>2</sup>],  
 $ET$  = effective thickness of granular drainage media, ft<sup>3</sup>/ft<sup>2</sup> [cm<sup>3</sup>/cm<sup>2</sup>],  
 $AFP$  = air filled porosity, volume percent, and  
 $W_c$  = unit weight of captured water, lb/ft<sup>3</sup> [kg/m<sup>3</sup>].

NOTE 1—A method for measuring the effective unit volume of a geocomposite drain layer has not been introduced at this time. In the absence of a standard test method, use the full thickness of the geocom-

posite drain layer, measured in feet [centimetres] and reported as unit volume in units of ft<sup>3</sup>/ft<sup>2</sup> [cm<sup>3</sup>/cm<sup>2</sup>]. If a geocomposite drain layer has been manufactured from a non-absorbent close-cell plastic foam, or similar, deduct the average thickness of the foam material from the unit volume.

NOTE 2—When evaluating modules, set the module on a horizontal surface and measure the distance from the surface to the uppermost asperities on the textured bottom surface of the module.

**7.8 Weight of Retained Water in a Vegetative (Green) Roof System**—For purposes of comparison between vegetative (green) roof systems, the weight of the retained water in a vegetative (green) roof system shall be determined as the sum of the following unit weights:

7.8.1 Retained water in fabrics (see 7.2),

7.8.2 Retained water in absorptive drain mats (see 7.3),

7.8.3 Retained water in the growth media layer (see 7.4),

7.8.4 Retained water in the granular drainage media layer (see 7.5), and

7.8.5 Captured water (see 7.6).

**7.9 Volume of Retained Water**, reported in inches [centimetres], associated with a vegetative (green) roof system shall be the total weight of retained water, reported in lb/ft<sup>2</sup> [kg/m<sup>2</sup>], divided by 62.4 [1000], and multiplied by 12 [100].

**7.10 Weight of Transient Water Associated with a Vegetative (Green) Roof System,  $W_t$** —For purposes of comparison between vegetative (green) roof systems, the weight of the transient water in a vegetative (green) roof system shall be determined as the sum of the following unit weights:

7.10.1 Transient water in absorptive drain mats (see 7.3), and

7.10.2 Transient water in the drain layer (see 7.7).

**7.11 Volume of Transient Water**, reported in inches [centimetres], associated with a vegetative (green) roof system shall be the total weight of transient water, reported in lb/ft<sup>2</sup> [kg/m<sup>2</sup>], divided by 62.4 [1000], and multiplied by 12 [100].

## 8. Report

8.1 Use the Report Format (Annex A1) to record the unit weights determined for each vegetative (green) roof component.

## 9. Keywords

9.1 dead load; live load; sustainability; vegetative (green) roof; vegetative (green) roof system; vegetative (green) roofing system; water retention





## ANNEX

## (Mandatory Information)

## A1. REPORT FORMAT

SYSTEM DESIGNATION: \_\_\_\_\_  
 TOTAL SYSTEM THICKNESS, IN. [CM]: \_\_\_\_\_  
 VOLUME OF RETAINED WATER, IN. [CM]: \_\_\_\_\_  
 VOLUME OF CAPTURED WATER, IN. [CM]: \_\_\_\_\_

Component	Thickness, in. [cm]	Comment	Dry Unit Weight, lb/ft <sup>2</sup> [kg/m <sup>2</sup> ]	Unit Weight, lb/ft <sup>2</sup> [kg/m <sup>2</sup> ] <sup>A</sup>
<b>DEAD LOAD SUMMATION</b>				
A. Roofing System <sup>B</sup>	NA	Obtain from roofing manufacturer		
B. Non-Absorptive Components		Unit weight equals dry unit weight		
• Insulation		Protected membrane roofing (PMR) installations		
• Root-Barrier				
• Protection Layer				
• Geocomposite Drain Layer				
• Other (Describe)				
C. Fabrics				
• Protection				
• Moisture Retention				
• Separation				
• Other (Describe)				
D. Absorptive Drainage Mats				
E. Growth Media				
F. Drainage Media				
G. Captured Water	NA			
H. Extensive Plant Material	NA	Use 2 lb/ft <sup>2</sup> [96 kg/m <sup>2</sup> ]		
I. Intensive Plant Material (excluding large perennials and trees)	NA	Use 3 lb/ft <sup>2</sup> [144 kg/m <sup>2</sup> ]		
J. Other (Describe)				
<b>Total Dead Load</b>				
<b>Total Transient Water Live Load</b>				NA

<sup>A</sup> Includes weight of retained water.

<sup>B</sup> For purposes of this worksheet, waterproofing membrane and all materials below this membrane.



*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or [service@astm.org](mailto:service@astm.org) (e-mail); or through the ASTM website ([www.astm.org](http://www.astm.org)). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>*