

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 6: Equipment protection by liquid immersion "o"**

**Atmosphères explosives –
Partie 6: Protection du matériel par immersion dans le liquide "o"**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 60 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 60 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



IEC 60079-6

Edition 4.0 2015-02

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 6: Equipment protection by liquid immersion "o"**

**Atmosphères explosives –
Partie 6: Protection du matériel par immersion dans le liquide "o"**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.260.20

ISBN 978-2-8322-2251-5

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.
--

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions	7
4 Constructional requirements	8
4.1 General.....	8
4.2 Levels of protection and requirements of electrical equipment	8
4.2.1 Level of Protection	8
4.2.2 Requirements for Level of Protection “ob”	9
4.2.3 Requirements for Level of Protection “oc”	9
4.3 Switching device	9
4.4 Creepage and clearance	9
4.5 Liquid containment enclosures.....	10
4.5.1 General	10
4.5.2 Sealed enclosures	10
4.5.3 Unsealed enclosures.....	10
4.5.4 Outlet of breathing device or pressure relief device.....	10
4.5.5 Enclosures intended to be opened.....	10
4.5.6 Determination of the maximum/minimum criteria of the protective liquid	10
4.6 Immersion depth	11
4.7 Protective liquid level indication.....	11
4.7.1 General	11
4.7.2 Remote-indicating protective liquid level indicator	12
4.7.3 Safety devices for Level of Protection “ob”	12
4.8 Temperature limitations	12
4.8.1 General	12
4.8.2 Maximum Surface Temperature	12
4.8.3 Flashpoint of the protective liquid	12
4.9 Field wiring connections to liquid immersion equipment.....	12
4.10 Constructional elements of enclosures.....	12
4.10.1 Operating rods, shafts etc.	12
4.10.2 Devices for draining of liquid	13
5 Protective Liquid.....	13
5.1 Protective liquid specification	13
5.2 Detailed alternative specification	13
5.3 Group I equipment	13
5.4 Liquid contamination and gassing that may result from arcing	13
5.5 Total volume of the protective liquid.....	14
6 Verifications and tests	14
6.1 Type tests	14
6.1.1 Overpressure test on sealed enclosures	14
6.1.2 Reduced pressure test on sealed enclosures	14
6.1.3 Overpressure test on unsealed enclosures	14
6.1.4 Maximum temperature.....	14
6.1.5 Switching Tests.....	15
6.2 Routine tests.....	15

6.2.1	Sealed enclosures	15
6.2.2	Unsealed enclosures.....	15
7	Marking	15
8	Instructions.....	16
Annex A (normative) Selection and erection requirements		17
Annex B (normative) Maintenance requirements		18
Annex C (normative) Repair and Overhaul requirements.....		19
Bibliography		20
Table 1 – Working voltage.....		9
Table 2 – Depth of immersion		11
Table B.1 – Inspection requirements		18

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 6: Equipment protection by liquid immersion "o"**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-6 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This fourth edition cancels and replaces the third edition, published in 2007. This edition constitutes a technical revision.

The significant changes with respect to the previous edition are listed below:

- Edition 4 represents a major technical revision of the requirements for oil immersion "o" and should be considered as introducing all new requirements. The normal "Table of Significant Changes" has not been included for this reason. In particular:
 - The requirements for oil immersion "o" have been redefined into liquid immersion , levels of protection "ob" and "oc" as recommended by the responses to 31/715/DC
 - The ability to protect sparking contacts has been added to both "ob" and "oc"
- Additional requirements have been introduced for the protective liquid.

This part of IEC 60079 is to be used in conjunction with IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*.

The text of this standard is based on the following documents:

FDIS	Report on voting
31/1157/FDIS	31/1172/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60079 series, under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

EXPLOSIVE ATMOSPHERES –

Part 6: Equipment protection by liquid immersion "o"

1 Scope

This part of IEC 60079 specifies the requirements for the design, construction, testing and marking of Ex Equipment and Ex Components with type of protection liquid immersion "o" intended for use in explosive gas atmospheres.

Ex Equipment and Ex Components of type of protection liquid immersion "o" are either:

- Level of Protection "ob" (EPL "Mb" or "Gb")
- Level of Protection "oc" (EPL "Gc")

For Level of Protection "ob", this standard applies where the rated voltage does not exceed 11 kV r.m.s. a.c. or d.c.

For Level of Protection "oc", this standard applies where the rated voltage does not exceed 15 kV r.m.s. a.c. or d.c.

NOTE Requirements for higher voltages are under consideration.

This standard supplements and modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard takes precedence.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive Atmospheres – Part 0: Equipment – General requirements*

IEC 60156, *Insulating liquids – Determination of the breakdown voltage at power frequency – Test method*

IEC 60247, *Insulating liquids – Measurement of relative permittivity, dielectric dissipation factor ($\tan \delta$) and d.c. resistivity*

IEC 60296, *Fluids for electrotechnical applications – Unused mineral insulating oils for transformers and switchgear*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60814, *Insulating liquids – Oil impregnated paper and pressboard – Determination of water by automatic coulometric Karl Fischer titration*

IEC 60836, *Specifications for unused silicone insulating liquids for electrotechnical purposes*

IEC 61099, *Insulating liquids – Specifications for unused synthetic organic esters for electrical purposes*

IEC 61125, *Unused hydrocarbon based insulating liquids – Test methods for evaluating the oxidation stability*

IEC 62021-1, *Insulating liquids – Determination of acidity – Part 1: Automatic potentiometric titration*

IEC 62535, *Insulating liquids – Test method for detection of potentially corrosive sulphur in used and unused insulating oil*

ISO 2592, *Determination of flash and fire points – Cleveland open cup method*

ISO 2719, *Determination of flash point – Pensky-Martens closed cup method*

ISO 3016, *Petroleum oils – Determination of pour point*

ISO 3104, *Petroleum products – Transparent and opaque liquids – Determination of kinematic viscosity and calculation of dynamic viscosity*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60079-0 and the following apply.

3.1

liquid immersion "o"

type of protection in which the electrical equipment or parts of the electrical equipment are immersed in a protective liquid in such a way that an explosive gas atmosphere which may be above the liquid or outside the enclosure cannot be ignited

3.2

protective liquid

liquid which prevents the explosive atmosphere from making direct contact with potential ignition sources

3.3

sealed equipment

equipment designed and constructed in such a manner as to prevent ingress of an external atmosphere during the expansion and contraction of the internally contained liquid during normal operation, for example, by means of an expansion vessel

3.4

non-sealed equipment

equipment designed and constructed in such a manner as to allow the ingress and egress of an external atmosphere during the expansion and contraction of the internally contained fluid during normal operation

3.5

maximum permissible protective liquid level

maximum level that the protective liquid can attain in normal service, taking into account the effects of expansion from the worst-case filling condition specified by the manufacturer to the condition of full load at maximum ambient temperature for which the equipment is designed

3.6

minimum permissible protective liquid level

minimum level that the protective liquid can attain in normal service taking into account the effects of contraction from the worst-case filling condition to the condition of de-energization at minimum ambient temperature

3.7

disconnecter

mechanical switching device which provides, in the open position, an isolating distance in accordance with specified requirements

Note 1 to entry: A disconnector is capable of opening and closing a circuit when either negligible current is broken or made, or when no significant change in the voltage across the terminals of each of the poles of the disconnector occurs. It is also capable of carrying currents under normal circuit conditions and carrying for a specified time currents under abnormal conditions such as those of short circuit.

[SOURCE: IEC 60050-441:1984, 441-14-05]

3.8

switching device

device designed to make or break the current in one or more electric circuits

[SOURCE: IEC 60050-441:1984, 441-14-01]

3.9

safety device

device intended for use inside or outside explosive atmospheres but required for or contributing to the safe functioning of equipment and protective systems with respect to the risks of explosion

3.10

tap selector

device designed to carry, but not to make or break current, used in conjunction with a diverter switch to select tapping connections

[SOURCE: IEC 60050-421:1990, 421-11-02]

4 Constructional requirements

4.1 General

For Type of Protection “liquid immersion “o”, the Ex Equipment or parts of the Ex Equipment are immersed in a protective liquid in such a way that an explosive gas atmosphere, which may be above the liquid or outside the enclosure, cannot be ignited.

The Ex Equipment is constructed to ensure that the necessary amount of protective liquid is present. Dependent on the intended Equipment Protection Level, this is achieved by monitoring device(s), indicator(s) or a level control safety device with automatic switch off.

NOTE In accordance with the requirements for all electrical equipment given in IEC 60079-0, it is assumed that the relevant industrial requirements have been applied. The requirements of the IEC 60079 series of standards supplement those industrial requirements.

4.2 Levels of protection and requirements of electrical equipment

4.2.1 Level of Protection

Electrical equipment with liquid immersion “o” shall be either:

a) Level of Protection “ob” (EPL Gb or Mb); or

b) Level of Protection “oc” (EPL Gc).

The requirements of this standard shall apply to all levels of protection unless otherwise stated.

4.2.2 Requirements for Level of Protection “ob”

Electrical circuits and components, when liquid immersed in accordance with this standard, are considered to be not ignition capable in normal operation and during expected malfunctions, and shall be assigned a Level of Protection “ob” (EPL Gb or Mb).

A liquid level indication according to 4.7 is required.

Switching devices protected by liquid immersion level of protection “ob” shall comply with the following additional requirements:

- a) When a sealed enclosure is employed, the enclosure shall comply with the overpressure test in 6.1.1 using four times the prescribed pressure.
- b) Electrical equipment containing switching devices operated in the protective liquid, rated at 2 kVA per contact or less, are permitted without further test. Where the switching device is rated above 2 kVA per contact, neither pressure increases nor excessive decomposition products shall invalidate the type of protection as demonstrated by tests in accordance with 6.1.5.
- c) The equipment shall be suitable for a prospective short circuit current of 32 kA unless marked with a lower value.

Disconnectors and manual tap selectors, above 1 000 V, shall be lockable and provided with a warning according to 7 i). In addition, information on their use shall be included in the instructions.

4.2.3 Requirements for Level of Protection “oc”

Electrical circuits and components, when liquid immersed in accordance with this standard, are considered to be not ignition capable in normal operation or in the case of regular expected occurrences, and shall be assigned a Level of Protection “oc” (EPL Gc).

Ex Equipment containing switching devices operated in the protective liquid, rated at 10 kVA per contact or less, are permitted without further test. For switching devices rated above 10 kVA per contact, neither pressure increases nor excessive decomposition products shall invalidate the type of protection as demonstrated by tests in accordance with 6.1.5.

4.3 Switching device

Switching devices are only permitted for a.c. circuits where the working voltage of the switch does not exceed the values given in Table 1. Switching devices for d.c. circuits are not permitted.

Table 1 – Working voltage

Level of Protection	“ob”	“oc”
Working voltage of switching device	1 000 V r.m.s. a.c.	6,6 kV r.m.s. a.c.

4.4 Creepage and clearance

Electrical circuits and components intended to be immersed in the protective liquid shall meet the relevant industrial requirements for creepage and clearance distances in air before being immersed in the protective liquid. If the relevant industrial standard gives options for pollution degree, pollution degree 2 shall be assumed.

4.5 Liquid containment enclosures

4.5.1 General

The chemical resistance against the protective liquid shall be documented by the manufacturer.

NOTE It is not a requirement of this standard that conformity to the chemical resistance against the protective liquid be verified.

The enclosures shall be subjected to the type tests as specified in Clause 6 for sealed and unsealed enclosures respectively.

Connection bushings provided for termination of the electrical conductors shall be considered as part of the enclosure and subject to the requirements of this clause.

4.5.2 Sealed enclosures

Covers of sealed enclosures may be continuously welded to the enclosure, or sealed by means of a gasket, in which case, the cover shall be provided with special fasteners according to IEC 60079-0.

Equipment with a sealed enclosure shall be provided with a pressure-relief device. This device shall be permanently set by the manufacturer of the liquid-filled equipment to operate at a pressure of at least 10 kPa. Enclosures permanently sealed at the time of manufacture shall not be capable of being opened without leaving visible evidence that the enclosure has been opened. The enclosure shall be marked in accordance with 7 c).

NOTE Suitable techniques that can provide visible evidence of being opened are, for example, welding, soldering, cemented joints, rivets, cementing of screws, or lead-seal safety-wiring of screws.

4.5.3 Unsealed enclosures

An enclosure, which is not sealed, shall be constructed so that gas or vapour that may evolve from the protective liquid in normal service can escape through a breathing device which includes a suitable drying agent. The manufacturer shall specify the maintenance requirements for the drying agent.

4.5.4 Outlet of breathing device or pressure relief device

The outlet of the breathing device for unsealed equipment and the outlet of the pressure relief device for sealed equipment shall face down and have a degree of protection of at least IP66 as given in IEC 60529.

4.5.5 Enclosures intended to be opened

Enclosure that are designed to be opened shall incorporate sealing methods that are capable of being renewed without damage to the enclosure when the equipment is repaired, refilled and resealed. The enclosure shall be marked in accordance with 7 d).

4.5.6 Determination of the maximum/minimum criteria of the protective liquid

The following criteria shall be specified:

- a) the maximum and minimum level of the protective liquid;
- b) the maximum working angle, from the horizontal, of the equipment;

4.6 Immersion depth

Live parts of the electrical equipment shall be immersed to a depth according to Table 2 within the protective liquid, at the minimum possible liquid level no matter the orientation of the internal equipment.

Table 2 – Depth of immersion

Voltage (See ^a) $U_{r.m.s.}$ a.c. or d.c. V	Distance	
	No switching device	With a switching device (a.c. only)
≤ 50 V	3 mm	10 mm
≤ 250 V	5 mm	15 mm
≤ 1 000 V	10 mm	20 mm
≤ 6 000 V	25 mm	50 mm
≤ 10 000 V	25 mm	–
≤ 13 640 V	50 mm	–
^a When determining the required values for depth of immersion, the working voltage may be higher than the voltage in the table by a factor of 1,1 (see Note). NOTE The factor of 1,1 recognizes that at many places in a circuit, the working voltage equals the rated voltage and that there are a number of rated voltages in common use that can be accommodated by the 1,1 factor.		

4.7 Protective liquid level indication

4.7.1 General

Protective liquid level indicating device(s) complying with the following requirements shall be provided so that the liquid level of each separate liquid-filled compartment can be easily checked in service.

The maximum and the minimum protective liquid levels permissible in normal service shall be marked in accordance with 7 e), taking into account the effects of expansion and contraction resulting from operational temperature changes over the full ambient temperature range specified by the manufacturer.

The protective liquid level indicating device shall be marked in accordance with 7 f) to indicate the levels to which the electrical equipment shall be filled under the filling temperature conditions specified by the manufacturer. Alternatively, an adjacent label shall be provided which fully specifies the filling conditions.

The location of the protective liquid level indicating device shall be such that the minimum possible indicated level of the protective liquid cannot be beneath the level necessary to comply with 4.6, taking into account the effects of expansion and contraction resulting from operational temperature changes over the full ambient temperature range specified by the manufacturer.

The manufacturer shall prepare documentation to show that transparent parts will retain their mechanical and optical properties when in contact with the protective liquid.

For non-sealed equipment, a dipstick may be used provided that, in normal operation, the dipstick is secured in its measurement position and that the requirements of 4.5.1 with regard to ingress protection are maintained. An adjacent warning marking shall be provided in accordance with 7 g).

4.7.2 Remote-indicating protective liquid level indicator

If a remote-indicating protective liquid level indicator is provided, the switching element shall be lower than the sensing element by at least the dimension shown in Table 2, or it shall be protected by one of the types of protection suitable for the application. If the manufacturer does not provide the remote-indicating liquid level indicator, the certificate number shall include the "X" suffix in accordance with IEC 60079-0 and the Specific Condition of Use shall specify all necessary information required by the user to ensure conformity with the requirements of this standard.

4.7.3 Safety devices for Level of Protection "ob"

For Level of Protection "ob" with switching devices, a protective liquid level safety device shall monitor the level of the protective liquid and provide for automatic disconnection of power upon reduction of oil below the permitted minimum. The switching element of the safety device shall be lower than the sensing element of the safety device by at least the dimension shown in Table 2, or shall be protected by one of the types of protection suitable for the application. If the manufacturer does not provide the safety devices, the certificate number shall include the "X" suffix in accordance with IEC 60079-0 and the Specific Condition of Use shall specify all necessary information required by the user to ensure conformity with the requirements of this standard.

NOTE Safety devices for these applications normally have a fault tolerance of 0 and a safety integrity level SIL 1. Requirements for such safety devices are currently given in EN 50495. A project has been initiated to consider the development of an IEC standard based on EN 50495 which would provide requirements for these safety devices.

4.8 Temperature limitations

4.8.1 General

The maximum permissible temperature for equipment or parts of equipment shall be equal to the lower of the two temperatures determined by 4.8.2 or 4.8.3

4.8.2 Maximum Surface Temperature

The temperature at the free surface of the protective liquid or at any point on the surface of the electrical equipment to which an explosive gas atmosphere has access shall not exceed the limit for the assigned temperature class or assigned maximum surface temperature. In no case shall the limit exceed 200 °C.

4.8.3 Flashpoint of the protective liquid

The stated minimum flash-point (closed cup) for the protective liquid used shall be at least 25 K greater than the temperature at the free surface of the protective liquid and the temperature of the internal components immersed in the liquid.

4.9 Field wiring connections to liquid immersion equipment

Liquid immersion is not an accepted type of protection for field wiring connections. Bushings shall be used for connections through the wall of the equipment. Direct entry is not permitted.

The field wiring connections shall be protected with a type of protection suitable for the application.

4.10 Constructional elements of enclosures

4.10.1 Operating rods, shafts etc.

If the enclosure contains operating rods, shafts etc. it shall comply with the tests of 6.1.1 and 6.1.2 if a sealed enclosure and 6.1.3 if an unsealed enclosure. The tests shall be carried out

with such elements in place. Operating rods or shafts used in a sealed enclosure shall be subject to a conditioning of 500 operations prior to the tests of 6.1.1 and 6.1.2

4.10.2 Devices for draining of liquid

Devices for draining the liquid shall be secured against inadvertent removal.

5 Protective Liquid

5.1 Protective liquid specification

The protective liquid shall be a mineral oil conforming to IEC 60296, a silicone liquid conforming to IEC 60836, a synthetic organic ester liquid (Type T1) conforming to IEC 61099, or shall be a liquid conforming to the requirements of 5.2.

NOTE The future use of natural ester liquids per IEC 62770 is under consideration.

5.2 Detailed alternative specification

The specification for the alternative protective liquid shall include the following:

- a) the protective liquid shall have a fire point of not less than 300 °C determined by the test method indicated in ISO 2592;
- b) the protective liquid flash-point (closed cup) determined in accordance with ISO 2719 shall be not less than 25 K above the free surface temperature of the protective liquid (See 4.8.3);
- c) the protective liquid shall have a kinematic viscosity of not more than 100 cSt at 25 °C determined in accordance with ISO 3104;
- d) the protective liquid shall have an electrical breakdown strength of not less than 30 kV determined in accordance with IEC 60156;
- e) the protective liquid shall have a volume resistivity at 25 °C of not less than $1 \times 10^{12} \Omega \times m$ determined in accordance with IEC 60247;
- f) the pour point, determined in accordance with ISO 3016, shall be no higher than the lower of -30 °C or 10 K less than the minimum ambient temperature of the equipment;
- g) the acidity (neutralization value) shall be not more than 0,03 mg KOH/g determined in accordance with IEC 62021-1;
- h) the protective liquid shall have no adverse effect on the properties of materials with which it is in contact;
- i) the oxidation stability shall not exceed 0,15 % sludge according to IEC 61125;
- j) the sulphur content shall be confirmed as non-corrosive according to IEC 62535; and
- k) the water content shall not exceed 35 ppm according to IEC 60814.

NOTE It is not a requirement of this standard that conformity to the specification of the protective liquid be verified.

5.3 Group I equipment

For Group I equipment, mineral oils are not acceptable.

5.4 Liquid contamination and gassing that may result from arcing

Where switching devices are incorporated in the electrical equipment and may give rise to contamination of the protective liquid, suitable maintenance instructions shall be prepared. As a minimum these will include instructions for the cleaning/filtering/replacement of the protective liquid following a given number of normal switching operations and following interruption of fault currents.

5.5 Total volume of the protective liquid

The documentation prepared in accordance with IEC 60079-0 shall specify the total volume of the protective liquid, including the maximum and minimum volumes to maintain the levels required as given in 4.6.

6 Verifications and tests

6.1 Type tests

6.1.1 Overpressure test on sealed enclosures

For Level of Protection “ob” with a switching device switching more than 2 kVA per contact, a pressure equal to 4 times the pressure relief device setting, and for all other enclosures, a pressure equal to 1,5 times the pressure relief device setting shall be applied internally. In no case shall the test pressure be less than 150 kPa. The period of application of the pressure shall be at least 60 s. The pressure relief device entry shall be sealed for the duration of the test.

The test shall be considered satisfactory if, at the end of the test, the enclosure has suffered neither damage nor permanent distortion which adversely affects its ability to comply with 4.6.

NOTE A non-compressible hydraulic media is normally used for these tests. If a compressible media such as air or inert gas is used, failure of the enclosure can result in personal injury or property damage.

6.1.2 Reduced pressure test on sealed enclosures

The internal pressure of the enclosure without protective liquid shall be reduced by an amount equivalent to not less than the pressure that would result from a change in the protective liquid level from the maximum permissible level to the minimum permissible level when appropriately corrected for any ambient temperature variations specified in the documentation.

At the end of 24 h, any increase in pressure shall not exceed 5 %.

6.1.3 Overpressure test on unsealed enclosures

A pressure equal to 150 kPa, with the breather sealed, shall be applied internally. The period of application shall be at least 60 s.

The test shall be considered satisfactory if, at the end of the test, the enclosure has suffered neither damage nor permanent distortion that adversely affects its ability to comply with 4.5.3 and 4.5.5.

NOTE A non-compressible hydraulic media is normally used for these tests. If a compressible media such as air or inert gas is used, failure of the enclosure can result in personal injury or property damage.

6.1.4 Maximum temperature

A sample of “o” equipment shall be subjected to a type test to ensure that the temperature limits specified in 4.8 are not exceeded.

For “o” equipment without an external load, the test shall be carried out in accordance with the temperature measurements of IEC 60079-0.

For “o” equipment with an external load, the test shall be carried out for Level of Protection “ob” by adjusting the current to 110 % of the rated current and for Level of Protection “oc” at 100 % of the rated current in normal operation and at the maximum rated duty cycle.

NOTE Equipment with characteristics such as non-linear external loads, input power control or difficult to define failure modes introduces challenges into the determination of maximum temperatures under malfunction conditions.

6.1.5 Switching Tests

The electrical switching tests given in the relevant IEC industrial standards shall be carried out with the equipment in its design configuration. The protective liquid shall be at minimum level. At the conclusion of the tests:

- a) there shall be no release of the protective liquid nor shall the required creepage and clearance distances be compromised; and
- b) the protective liquid shall have an electrical breakdown strength of not less than 30 kV determined in accordance with IEC 60156.

6.2 Routine tests

6.2.1 Sealed enclosures

Each sealed enclosure shall be subjected to both the following tests in sequence:

- a) the overpressure test described in 6.1.1. This routine test may be omitted for other than welded enclosures, if during type testing, the equipment complies with the acceptance criteria in 6.1.1 using four times the pressure relief device setting;

NOTE A non-compressible hydraulic media is normally used for these tests. If a compressible media such as air or inert gas is used, failure of the enclosure can result in personal injury or property damage.

- b) the test described in 6.1.2 or an equivalent accelerated test using a lower pressure. In the latter case, the calculations shall be documented to demonstrate that this test will achieve the same threshold value of leakage as in the 24 h test.

6.2.2 Unsealed enclosures

Each unsealed enclosure shall be subjected to the test specified in 6.1.3. This routine test may be omitted for other than welded enclosures, if during type testing; the equipment complies with the acceptance criteria in 6.1.3 using 600 kPa.

NOTE A non-compressible hydraulic media is normally used for these tests. If a compressible media such as air or inert gas is used, failure of the enclosure can result in personal injury or property damage.

7 Marking

Ex Equipment or Ex Components of liquid immersion “o” shall be marked in accordance with IEC 60079-0, with the following additional marking:

- a) the protective liquid to be used;
- b) the pressure relief device setting (where appropriate);
- c) “This enclosure has been permanently sealed and cannot be repaired” (where appropriate);
- d) “This enclosure is factory sealed – Consult manufacturer’s instructions for repair” (where appropriate);
- e) minimum and maximum level of protective fluid;
- f) the levels to which the Ex Equipment shall be filled under the filling temperature conditions specified by the manufacturer. Alternatively, an adjacent label shall be provided which fully specifies the filling conditions;
- g) when a dipstick is employed in accordance with 4.7.1, the marking “WARNING – Replace dipstick after use”, or technically equivalent text.
- h) permitted prospective short-circuit current of the external electrical supply if the equipment is designed for a short-circuit current less than 32 kA, according to 4.2.2 c), for example “Permitted supply short-circuit current: 10 kA”;

- i) “WARNING – Operate only at NO LOAD” according to 4.2.2.

The Ex Equipment or Ex Components shall be marked as “ob” (for EPL Gb or Mb) or “oc” (for EPL Gc), as appropriate, replacing the marking “o” (for EPL Gb) shown in IEC 60079-0.

8 Instructions

All liquid-immersed “o” Ex Equipment shall be accompanied by instructions as required by IEC 60079-0, including the following additional particulars as a minimum:

- a) Details on the frequency of replacement of the protective fluid including details on the specific protective fluid to be used.
- b) Information on the use of disconnectors and tap selectors according to 4.2.2.
- c) The maintenance requirements for the drying agent for the breathing device for unsealed enclosures.
- d) Instructions for the cleaning/filtering/replacement of the protective liquid following a given number of normal switching operations and following interruption of fault currents.

Annex A

(normative)

Selection and erection requirements

Ex Equipment having type of protection “o” shall be installed in accordance with the following:

- Level of Protection “ob” equipment may be installed in locations requiring equipment suitable for EPL “Mb” “Gb” or Gc.
- Level of Protection “oc” equipment may be installed in locations requiring equipment suitable for EPL Gc.
- The field wiring connections shall be protected with a type of protection suitable for the application.
- Liquid immersion is not an accepted Type of Protection for field wiring connections. Direct entry is not permitted.

NOTE The selection and erection of the equipment requirements are found in IEC 60079-14 and are the responsibility of the user. Until IEC 60079-14 contains sufficient information, this Annex A provides information.

Annex B (normative)

Maintenance requirements

The inspection requirements of IEC 60079-17 are supplemented by those shown in Table B.1.

Table B.1 – Inspection requirements

Check that:		Grade of inspection		
		D	C	V
A	EQUIPMENT			
1	Equipment is appropriate to the EPL/Zone requirements of the location	X	X	X
2	Equipment group is correct	X	X	X
3	Equipment temperature class is correct	X	X	
4	Equipment circuit identification is correct	X	X	X
5	Equipment circuit identification is available	X	X	X
6	Enclosure, glass parts and glass-to-metal sealing gaskets and/or compounds are satisfactory	X	X	X
7	There are no unauthorized modifications	X	X	X
8	There are no visible unauthorized modifications	X	X	
9	Bolts, cable entry devices (indirect) and blanking elements are of the correct type and are complete and tight – physical check – visual check	X	X	X
10	Electrical connections are tight	X	X	X
11	Condition of enclosure gaskets is satisfactory	X	X	X
12	Breathing and draining devices are satisfactory. The manufacturer's schedule for maintenance requirements for the drying agent are documented to have been followed	X	X	X
13	Sealed enclosure pressure-relief devices are satisfactory	X	X	
14	Enclosures marked Permanently Sealed have no visible evidence that the enclosure has been opened	X	X	X
15	maximum/minimum criteria of the protective liquid a) level of the protective liquid shall be at or below the maximum and above the minimum permitted level; b) the maximum working angle to the horizontal of the equipment shall be satisfactory	X	X	X
16	Enclosures intended to be opened The level of the protective liquid in Type of Protection "o" electrical equipment designed to be opened shall be re-filled to within the required level range with the protective liquid required and re-sealed in accordance with the manufacturer's instructions	X	X	X
17	When a dipstick is provided, the dipstick is secured in its measurement position and its seal is satisfactory	X	X	X
18	remote-indicating protective liquid level indicating device operation is satisfactory	X	X	X
19	switching device schedule for cleaning/filtering/replacement of the protective liquid following a given number of normal switching operations or interruption of fault currents is documented	X	X	X

NOTE The inspection and maintenance requirements are found in IEC 60079-17 and are the responsibility of the user. Until IEC 60079-17 contains sufficient information, Annex B provides information.

Annex C (normative)

Repair and Overhaul requirements

Repair, overhaul and reclamation is not applicable to Type of Protection “o” Ex Equipment with enclosures indicated as being sealed.

Type of Protection “o” enclosures that are intended to be opened shall be subject to repair, overhaul and reclamation only as permitted by the manufacturer’s instructions.

NOTE The repair and overhaul requirements are found in IEC 60079-19 and are the responsibility of the user. Until IEC 60079-19 contains sufficient information, Annex C provides information.

Bibliography

IEC 60050-421, *International Electrotechnical Vocabulary – Chapter 421: Power transformers and reactors*

IEC 60050-441, *International Electrotechnical Vocabulary – Chapter 441: Switchgear, controlgear and fuses*

IEC 60079 (all parts), *Explosive atmospheres*

IEC 62770, *Fluids for electrotechnical applications – Unused natural esters for transformers and similar electrical equipment*

EN 50495, *Safety devices required for the safe functioning of equipment with respect to explosion risks*

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

3, rue de Varembé
PO Box 131
CH-1211 Geneva 20
Switzerland

Tel: + 41 22 919 02 11
Fax: + 41 22 919 03 00
info@iec.ch
www.iec.ch