

Reserve

NORME
INTERNATIONALE
INTERNATIONAL
STANDARD

CEI
IEC
185

1987

MODIFICATION 1
AMENDMENT 1

1990-07

สมทบ
ศูนย์ข้อมูลพลังงานแห่งประเทศไทย
สำนักงานพลังงานแห่งชาติ

- 9 พ.ย. 2533

Modification 1 à la Publication 185 (1987)

Transformateurs de courant

Amendment 1 to Publication 185 (1987)

Current transformers

© CEI 1990 Droits de reproduction réservés — Copyright — all rights reserved

Bureau Central de la Commission Electrotechnique Internationale 3, rue de Varembe Genève, Suisse



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

B

Pour prix, voir catalogue en vigueur
For price, see current catalogue

IEC

VOL. 2

PREFACE

This amendment has been prepared by IEC Technical Committee No. 38: Instrument transformers.

The text of this amendment is based on the following documents:

Six Months' Rule	Report on Voting
38(C0)82	38(C0)85

Full information on the voting for the approval of this amendment can be found in the Voting Report indicated in the above table.

Page 53

27. Limits of current error and phase displacement

Add the following note at the end of this clause:

Note.- In general the prescribed limits of current error and phase displacement are valid for any given position of an external conductor spaced at a distance in air not less than that required for insulation in air at the highest voltage for equipment (U_m).

Special conditions of application, including lower ranges of operation voltages associated with high current values, should be a matter of separate agreement between manufacturer and purchaser.