

**IEC 61892-2**  
**(Second edition – 2012)**

**Mobile and fixed offshore units – Electrical installations –**

**Part 2: System design**

**C O R R I G E N D U M 1**

**4.2.6.**

*Delete the Note.*

*Replace the existing text in this clause with the following new text:*

If main power is supplied externally, the arrangement is to be such that the requirement of 4.2.3 b) is met by a local generator, or alternatively a second independent external supply. The local generator shall not be the emergency generator.