

INTERNATIONAL STANDARD

IEC
62056-62

Second edition
2006-11

**Electricity metering –
Data exchange for meter
reading, tariff and load control –**

**Part 62:
Interface classes**



Reference number
IEC 62056-62:2006(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/online_news/justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC
62056-62

Second edition
2006-11

Electricity metering – Data exchange for meter reading, tariff and load control –

Part 62: Interface classes

© IEC 2006 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

XF

For price, see current catalogue

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms, definitions and abbreviations	8
4 Basic principles	9
4.1 General	9
4.2 Class description notation	10
4.3 Common data types	12
4.4 Data formats	13
4.5 The COSEM server model	17
4.6 COSEM logical device	18
4.7 Authentication procedures	19
5 The interface classes	20
5.1 Data (class_id: 1)	22
5.2 Register (class_id: 3)	22
5.3 Extended register (class_id: 4)	26
5.4 Demand register (class_id: 5)	27
5.5 Register activation (class_id: 6)	30
5.6 Profile generic (class_id: 7)	32
5.7 Clock (class_id: 8)	37
5.8 Script table (class_id: 9)	40
5.9 Schedule (class_id: 10)	41
5.10 Special days table (class_id: 11)	44
5.11 Activity calendar (class_id: 20)	45
5.12 Association LN (class_id: 15)	48
5.13 Association SN (class_id: 12)	53
5.14 SAP assignment (class_id: 17)	56
5.15 Register monitor (class_id: 21)	56
5.16 Utility tables (class_id: 26)	57
5.17 Single action schedule (class_id: 22)	59
5.18 Register table (class_id: 61)	60
5.19 Status mapping (class_id: 63)	62
6 Maintenance of the interface classes	63
6.1 New interface classes	63
6.2 New versions of interface classes	63
6.3 Removal of interface classes	63
Annex A (normative) Protocol related interface classes	64
Annex B (normative) Data model and protocol	84
Annex C (normative) Using short names for accessing attributes and methods	85
Annex D (normative) Relation to OBIS	94
Annex E (informative) Previous versions of interface classes	116
Bibliography	122

Index	123
Figure 1 – An interface class and its instances	10
Figure 2 – The COSEM server model.....	17
Figure 3 – Combined metering device	17
Figure 4 – Overview of the interface classes.....	21
Figure 5 – The attributes when measuring sliding demand	27
Figure 6 – The attributes when measuring current_average_value if number of periods is 1	27
Figure 7 – The attributes if the number of periods is 3	28
Figure 8 – The generalized time concept	38
Figure B.1 – The three step approach of COSEM.....	84
Table 1 – Common data types	12

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICITY METERING – DATA EXCHANGE FOR METER READING, TARIFF AND LOAD CONTROL –

Part 62: Interface classes

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this International Standard may involve the use of a maintenance service concerning the stack of protocols on which the present standard IEC 62056-62 is based.

The IEC takes no position concerning the evidence, validity and scope of this maintenance service.

The provider of the maintenance service has assured the IEC that he is willing to provide services under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the provider of the maintenance service is registered with the IEC. Information (see also 4.6.2 and Annex E) may be obtained from:

DLMS¹ User Association
Geneva / Switzerland
www.dlms.ch

¹ Device Language Message Specification.

International Standard IEC 62056-62 Ed. 2 has been prepared by IEC technical committee 13: Equipment for electrical energy measurement and load control.

This second edition cancels and replaces the first edition published in 2002 and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- the list of common data types has been amended, some new types have been added;
- formatting for floating point numbers has been added;
- new HLS mechanisms have been added;
- instance specific data types have been replaced with a well-defined set of applicable data types;
- new units have been added;
- encoding of `application_context_name` and `authentication_mechanism_name` attributes of the Association LN class has been clarified;
- new interface classes “Register table” and “Status mapping” have been added;
- a new version of the “IEC local port setup”, “Modem configuration”, “Auto connect” and “HDLC setup” interface classes have been added;
- new interface classes for setting up a TCP/IP based communication profile have been added. References to related IETF RFCs and standards, as well as related definitions have been added;
- several amendments in Annex D “Relation to OBIS” have been made.

The text of this standard is based on the following documents:

FDIS	Report on voting
13/1389/FDIS	13/1400/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of the publication may be issued at a later date.

INTRODUCTION

Driven by the need of the utilities to optimize their business processes, the meter becomes more and more part of an integrated metering and billing system. Whereas in the past the commercial value of a meter was mainly generated by its data acquisition and processing capabilities, nowadays the critical issues are system integration and interoperability.

The Companion Specification for Energy Metering (COSEM) addresses these challenges by looking at the meter as an integrated part of a commercial process, which starts with the measurement of the delivered product (energy) and ends with the revenue collection.

The meter is specified by its “behaviour” as seen from the utility's business processes. The formal specification of the behaviour is based on object modelling techniques (interface classes and objects). The specification of these objects forms a major part of COSEM.

The COSEM server model (see 4.5) represents only the externally visible elements of the meter. The client applications that support the business processes of the utilities, customers and meter manufacturers make use of this server model. The meter offers means to retrieve its structural model (the list of objects visible through the interface), and provides access to the attributes and specific methods of these objects.

The set of different interface classes form a standardized library from which the manufacturer can assemble (model) its individual products. The elements are designed so that with them the entire range of products (from residential to commercial and industrial applications) can be covered. The choice of the subset of interface classes used to build a meter, their instantiation, and their implementation are part of the product design and therefore left to the manufacturer. The concept of the standardized metering interface class library provides the different users and manufacturers with a maximum of diversity without having to sacrifice interoperability.

ELECTRICITY METERING – DATA EXCHANGE FOR METER READING, TARIFF AND LOAD CONTROL –

Part 62: Interface classes

1 Scope

This part of IEC 62056 specifies a model of a meter as it is seen through its communication interface(s). Generic building blocks are defined using object-oriented methods, in the form of interface classes to model meters from simple up to very complex functionality.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-300:2001, *International Electrotechnical Vocabulary – Electrical and electronic measurements and measuring instruments – Chapter 311: General terms relating to measurements – Chapter 312: General terms relating to electrical measurements – Chapter 313: Types of electrical measuring instruments – Chapter 314: Specific terms according to the type of instrument*

IEC 60559:1989, *Binary floating-point arithmetic for microprocessor systems*

IEC 61334-4-41:1996, *Distribution automation using distribution line carrier systems – Part 4: Data communication protocols – Section 41: Application protocols – Distribution line message specification*

IEC 62051:1999, *Electricity metering – Glossary of terms*

IEC 62051-1:2004, *Electricity metering – Data exchange for meter reading, tariff and load control – Glossary of terms – Part 1: Terms related to data exchange with metering equipment using DLMS/COSEM*

IEC 62056-21:2002, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 21: Direct local data exchange*

IEC 62056-31:1999, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 31: Using local area networks on twisted pair with carrier signalling*

IEC 62056-46:2002, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 46: Data link layer using HDLC-protocol*
Amendment 1²

IEC 62056-47:2006, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 47: COSEM transport layers for IPv4 networks*

IEC 62056-53:2006, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 53: COSEM Application layer*

² To be published.

IEC 62056-61:2006, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 61: Object identification system(OBIS)*

ANSI C12.19:1997 / IEEE 1377:1997, *Utility Industry End Device Data Tables*

STD 0005: 1981, *Internet Protocol (Also: IETF RFC 0791, RFC 0792, RFC 0919, RFC 0922, RFC 0950, RFC 1112)*

STD 0051: 1994, *The Point-to-Point Protocol (PPP) (Also: IETF RFC 1661, RFC 1662)*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-300, IEC 62051, and IEC 62051-1 apply.

3.2 Abbreviations

AARE	Application Association Response
AARQ	Application Association ReQuest
ACSE	Application Control Service Element
APDU	Application Protocol Data Unit
ASE	Application Service Element
A-XDR	Adapted eXtended Data Representation
CHAP	Challenge Handshake Authentication Protocol
COSEM	Companion Specificationfor Energy Metering
CtoS	Client to Server Challenge
DHCP	Dynamic Host Control Protocol
DLMS	Device Language Message Specification
DNS	Domain Name Server
EAP	Extensible Authentication Protocol
GMT	Greenwich Mean Time
GPS	Global Positioning System
HLS	High Level Security
IANA	Internet Assigned Numbers Authority
IC	Interface Class
IETF	Internet Engineering Task Force
IP	Internet Protocol
IPCP	Internet Protocol Control Protocol
LCP	Link Control Protocol
LLS	Low Level Security
LN	Logical Name
LSB	Least Significant Bit
m	mandatory
MD5	Message Digest Algorithm 5
MSB	Most Significant Bit
o	Optional

OBIS	OBject Identification System
PAP	Password Authentication Protocol
PDU	Protocol Data Unit
PLMN	Public Land Mobile Network
PPP	Point-to-Point Protocol
PSTN	Public Switched Telephone Network
ROHC	Robust Header Compression
SAP	Service Access Point
SHA-1	Secure Hash Algorithm
SMS	Short Message Service
SMTP	Simple Mail Transfer Protocol
SN	Short Name
StoC	Server to Client Challenge

4 Basic principles

4.1 General

This subclause describes the basic principles on which the COSEM interface classes are built. It also gives a short overview on how interface objects (instantiations of the interface classes) are used for communication purposes. Data collection systems and metering equipment from different vendors, following these specifications can exchange data in an interoperable way.


Object modelling: for specification purposes this standard uses the technique of object modelling. An object is a collection of attributes and methods.

The information of an object is organized in attributes. They represent the characteristics of an object by means of attribute values. The value of an attribute may affect the behaviour of an object. The first attribute in any object is the “logical_name”. It is one part of the identification of the object. An object may offer a number of methods to either examine or modify the values of the attributes.

Objects that share common characteristics are generalized as an interface class with a class_id. Within a specific class, the common characteristics (attributes and methods) are described once for all objects. Instantiations of an interface class are called COSEM objects.

Manufacturers may add proprietary methods or attributes to any object, using negative numbers.

Figure 1 illustrates these terms by means of an example:



IEC 305/02

Figure 1 – An interface class and its instances

The interface class “Register” is formed by combining the features necessary to model the behaviour of a generic register (containing measured or static information) as seen from the client (central unit, hand-held terminal). The contents of the register are identified by the attribute “logical_name”. The logical_name contains an OBIS identifier (see IEC 62056-61). The actual (dynamic) content of the register is carried by its “value” attribute.

Defining a specific meter means defining several specific registers. In the example of Figure 1, the meter contains two registers, i.e. two specific COSEM objects of the class “Register” are instantiated. This means that specific values are assigned to the different attributes. Through the instantiation, one COSEM object becomes a “total, positive, active energy register” whereas the other becomes a “total, positive, reactive energy register”.

REMARK The COSEM objects (instances of interface classes) represent the behaviour of the meter as seen from the “outside”. Therefore, modifying the value of an attribute must always be initiated from the outside (e.g. resetting the value of a register). Internally initiated changes of the attributes are not described in this model (e.g. updating the value of a register).

4.2 Class description notation

This subclause describes the notation used to define the interface classes.

A short text describes the functionality and application of the class. A table gives an overview of the class including the class name, the attributes, and the methods (class description template).

Class name	Cardinality	class_id, version		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. ... (...)	...			
3. ... (...)	...			
Specific method(s) (if required)	m/o			
1.			
2.			

Each attribute and method must be described in detail.

Class name	Describes the class (e.g. "Register", "Clock", "Profile generic",...)	
Cardinality	Specifies the number of instances of the class within a logical device (see 4.6).	
	<i>value</i>	The class shall be instantiated exactly "value" times.
	<i>min...max.</i>	The class shall be instantiated at least "min." times and at most "max." times. If min. is zero (0) then the class is optional, otherwise (min. > 0) "min." instantiations of the class are mandatory.
class_id	<p>Identification code of the class (range 0 to 65 535). The class_id of each object is retrieved together with the logical name by reading the object_list attribute of an "Association LN" / "Association SN" object.</p> <p>The class_id-s from 0 to 8 191 are reserved to be specified by the DLMS UA. Class_id-s from 8 192 to 32 767 are reserved for manufacturer specific interface classes. Class_id-s from 32 768 to 65 535 are reserved for user group specific interface classes. DLMS UA reserves the right to assign ranges to individual manufacturers or user groups.</p>	
Version	<p>Identification code of the version of the class. The version of each object is retrieved together with the logical name and the class_id by reading the object_list attribute of an "Association LN" / "Association SN" object.</p> <p>Within one logical device, all instances of a certain class must be of the same version.</p>	
Attribute(s)	Specifies the attribute(s) that belong to the class.	
	<i>(dyn.)</i>	Classifies an attribute that carries a process value, which is updated by the meter itself.
	<i>(static)</i>	Classifies an attribute, which is not updated by the meter itself (e.g. configuration data).
logical_name	octet-string	The logical name is always the first attribute of a class. It identifies the instantiation (COSEM object) of this class. The value of the logical_name conforms to OBIS (see IEC 62056-61).
Data type	Defines the data type of an attribute (see 4.3).	
Min.	Specifies if the attribute has a minimum value.	
	<i>x</i>	The attribute has a minimum value.
	<i><empty></i>	The attribute has no minimum value.
Max.	Defines if the attribute has a maximum value.	
	<i>x</i>	The attribute has a maximum value.
	<i><empty></i>	The attribute has no maximum value.
Def.	Specifies if the attribute has a default value. This is the value of the attribute after reset.	
	<i>x</i>	The attribute has a default value.
	<i><empty></i>	The default value is not defined by the class definition.

Specific method(s)	Provides a list of the specific methods that belong to the object.	
	<i>Method Name ()</i>	The method has to be described in the subsection "Method description".
m/o	Defines if the method is mandatory or optional.	
	<i>m (mandatory)</i>	The method is mandatory.
	<i>o (optional)</i>	The method is optional.

Attribute description

Describes each attribute with its data type (if the data type is not simple), its data format and its properties (minimum, maximum and default values).

Method description

Describes each method and the invoked behaviour of the instantiated COSEM object(s).

NOTE Services for accessing attributes or methods by the protocol are described in IEC 62056-53.

Selective access

The xDLMS services Read, Write, UnconfirmedWrite (used with SN referencing) and GET, SET (used with LN referencing) typically reference the entire attribute. However, for certain attributes selective access to just a part of the attribute may be provided. The part of the attribute is identified by specific selective access parameters. These are defined as part of the attribute specification.

4.3 Common data types

The following table contains the list of data types usable for attributes of COSEM objects.

Table 1 – Common data types

Type description	Tag ^a	Definition	Value range
--simple data types			
null-data	[0]		
boolean	[3]	boolean	TRUE or FALSE
bit-string	[4]	An ordered sequence of boolean values	
double-long	[5]	Integer32	-2 147 483 648... 2 147 483 647
double-long-unsigned	[6]	Unsigned32	0...4 294 967 295
octet-string	[9]	An ordered sequence of octets (8 bit bytes)	
visible-string	[10]	An ordered sequence of ASCII characters	
bcd	[13]	binary coded decimal	
integer	[15]	Integer8	-128...127
long	[16]	Integer16	-32 768...32 767
unsigned	[17]	Unsigned8	0...255
long-unsigned	[18]	Unsigned16	0...65 535
long64	[20]	Integer64	- 2 ⁶³ ...2 ⁶³ -1
long64-unsigned	[21]	Unsigned64	0...2 ⁶⁴ -1

Table 1 (continued)

Type description	Tag ^a	Definition	Value range
enum	[22]	The elements of the enumeration type are defined in the "Attribute description" section of a COSEM interface class specification.	
float32	[23]	OCTET STRING (SIZE(4))	For formatting, see 4.4.2.
float64	[24]	OCTET STRING (SIZE(8))	
date_time	[25]	OCTET STRING (SIZE(12))	For formatting, see 4.4.1.
date	[26]	OCTET STRING (SIZE(5))	
time	[27]	OCTET STRING (SIZE(4))	
--complex data types			
array	[1]	The elements of the array are defined in the "Attribute description" section of a COSEM interface class specification.	
structure	[2]	The elements of the structure are defined in the "Attribute description" section of a COSEM interface class specification.	
compact array	[19]	The elements of the compact array are defined in the "Attribute description" section of a COSEM interface class specification.	
--CHOICE		For some attributes of some COSEM interface objects, the data type may be chosen at COSEM object instantiation, in the implementation phase of the COSEM server. The Server always shall send back the data type and the value of each attribute, so that together with the logical name, an unambiguous interpretation is ensured. The list of possible data types is defined in the "Attribute description" section of a COSEM interface class specification.	

^a The tags are as defined in IEC 62056-53, 8.3.

4.4 Data formats

4.4.1 Date and time formats

Date and time information may be represented with data type octet-string, or using the data types *date*, *time* and *date_time*, as defined in the relevant interface class definition.

NOTE 1 In future versions of interface classes and in newly defined interface classes, only the data types *date*, *time* and *date_time* will be used.

NOTE 2 The (SIZE()) specifications do not apply if *date*, *time* or *date_time* are represented by data type octet-string.

<i>date</i>	OCTET STRING (SIZE(5)) { year highbyte, year lowbyte, month, day of month, day of week } year: interpreted as long-unsigned range 0...big 0xFFFF = not specified year highbyte and year lowbyte reference the 2 bytes of the
-------------	---

long-unsigned

month: interpreted as unsigned

range 1...12, 0xFD, 0xFE, 0xFF

1 is January

0xFD = daylight_savings_end

0xFE = daylight_savings_begin

0xFF = not specified

dayOfMonth: interpreted as unsigned

range 1...31, 0xFD, 0xFE, 0xFF

0xFD = 2nd last day of month

0xFE = last day of month

0xE0 to 0xFC = reserved

0xFF = not specified

dayOfWeek: interpreted as unsigned

range 1...7, 0xFF

1 is Monday

0xFF = not specified

For repetitive dates, the unused parts must be set to “not specified”.

The elements dayOfMonth and dayOfWeek have to be interpreted together:

- if last day of month is specified (0xFE) and day of week is wildcard, this specifies the last calendar day of the month;
- if last day of month is specified (0xFE) and an explicit day of week is specified (e.g. 7, Sunday) then it is the last occurrence of the weekday specified in the month, i.e. the last Sunday;
- if the dayOfMonth and dayOfWeek elements are both explicitly defined and they are not consistent, (for example 24th of the month is not Wednesday in the given year and month) it shall be considered as an error.

time

OCTET STRING (SIZE(4))

```
{
hour,
minute,
second,
hundredths
}
```

hour: interpreted as unsigned

range 0...23, 0xFF

0xFF = not specified,

minute: interpreted as unsigned

range 0...59, 0xFF

0xFF = not specified,

second: interpreted as unsigned

range 0...59, 0xFF

0xFF = not specified,

hundredths: interpreted as unsigned

range 0...99, 0xFF

0xFF = not specified

For repetitive times the unused parts must be set to “not specified”.

deviation long –720...720:
in minutes of local time to GMT
0x8000 = not specified

clock_status unsigned interpreted as 8 bit string

The status bits are defined as follows:

bit 0 (LSB): invalid ^a value,
bit 1: doubtful ^b value,
bit 2: different clock base ^c,
bit 3: invalid clock status ^d,
bit 4: reserved,
bit 5: reserved,
bit 6: reserved,
bit 7 (MSB): daylight saving active ^e

date_time OCTET STRING (SIZE(12))

```
{
year highbyte,
year lowbyte,
month,
day of month,
day of week,
hour,
minute,
second,
hundredths of second,
deviation highbyte,
deviation lowbyte,
clock status
}
```

Individual fields of *date_time* are encoded as defined above.
Some may be set to “not specified” as described above in *date*
and *time*.


- ^a Time could not be recovered after an incident. Detailed conditions are manufacturer specific (e.g. after the power to the clock has been interrupted).
- ^b Time could be recovered after an incident but the value cannot be guaranteed. Detailed conditions are manufacturer specific.
- ^c Bit is set if the basic timing information for the clock is at the actual moment taken from a timing source different from the source specified in *clock_base*.
- ^d This bit indicates that at least one bit of the clock status is invalid. Some bits may be correct. The exact meaning shall be explained in the manufacturer's documentation.
- ^e Flag set to true: the transmitted time contains the daylight saving deviation (summer time), Flag set to false: the transmitted time does not contain daylight saving deviation (normal time).

4.4.2 Floating point number formats

Floating point number formats are defined in IEC 60559.

NOTE: For the following, IEC 60559 is equivalent to IEEE 754.

The single format is:



where:

- s is the sign bit;
- e is the exponent; it is 8 bits wide and the exponent bias is +127;
- f is the fraction, it is 23 bits.

$$v = (-1)^s \cdot 2^{e-127} \cdot (1.f)$$

Diagram illustrating the layout of a floating-point number (likely IEEE 754 double precision):

- Bit positions: 1, 11, 52
- Fields: *s* (sign), *e* (exponent), *f* (fraction)
- Order: *msb* (most significant bit), *lsb* (least significant bit)

f is the fraction, it is 52 bits.

$$v = (-1)^s \cdot 2^{e-1023} \cdot (1.f)$$

Floating-point numbers shall be represented as a fixed length octet-string, containing the 4 bytes (float32) of the single format or 8 the bytes (float64) of the double format floating-point number as specified above, most significant byte first.

Bit 31 Sign bit 0 0: + 1: -	Bits 30-23 Exponent field 01111111 Decimal value of exponent field and exponent: $127-127 = 0$	Bits 22-0 Significand 1.0000000000000000000000 Decimal value of the significand: 1.0000000
--	---	--

Example 2: The decimal value “1” represented in double floating-point format is:

[illegible]

Example 3: The decimal value “62056” represented in single floating-point format is:

Bit 31 Sign bit 0 0: + 1: -	Bits 30-23 Exponent field 10001110 Decimal value of exponent field and exponent: 142-127 = 15	Bits 22-0 Significand 1.111001001101000000000000 Decimal value of the significand: 1.8937988
--	---	--

4.6 COSEM logical device

4.6.1 General

The COSEM logical device is a set of COSEM objects. Each physical device shall contain a “Management logical device”.

The addressing of COSEM logical devices shall be provided by the addressing scheme of the lower layers of the protocol used.

4.6.2 COSEM logical device name

The COSEM logical device can be identified by its unique COSEM logical device name. This name can be retrieved from an instance of IC “SAP assignment” (see 5.14), or of a COSEM object “COSEM logical device name” (see D.2.1.24).

This name is defined as an octet-string of up to 16 octets. The first three octets uniquely identify the manufacturer of the device ³. The manufacturer is responsible for guaranteeing the uniqueness of the octets that follow (up to 13 octets).

4.6.3 The “association view” of the logical device

In order to access COSEM objects in the server, an application association shall first be established. This characterizes the context within which the associated applications will communicate. The major parts of this context are:

- the application context;
- the authentication context;
- the xDLMS context.

This information is contained in a special COSEM object, the “Association” object. There are two types of this association object defined. One for associations using short name referencing (“Association SN”) and one for using logical name referencing (“Association LN”).

Depending on the association established between the client and the server, different access rights may be granted by the server. Access rights concern a set of COSEM objects – the visible objects – that can be accessed (‘seen’) within the given association. In addition, access to attributes and methods of these COSEM objects may also be restricted within the association (e.g. a certain type of client can only read a particular attribute of a COSEM object).

The list of the visible COSEM objects – the “association view” – can be obtained by the client by reading the “*object_list*” attribute of the appropriate association object. Additional information about the access rights (read only, write only, read and write) to the attributes and the availability of the methods (within the established association) can be found via specific attributes (logical name referencing, see 5.12) or special methods (short name referencing, see 5.13) provided by the association objects.

4.6.4 Mandatory contents of a COSEM logical device

The following objects shall be part of each COSEM logical device. They shall be accessible for GET/READ in all application associations with this logical device:

- COSEM logical device name object;
- current association (LN or SN) object.

³ Administered by the DLMS User Association

4.6.5 Management logical device

As specified in 4.6.1, the management logical device is a mandatory element of any physical device, and it has a reserved address. As defined in 6.3.4 of IEC 62056-53, it must support an application association to a public client with the lowest security level. Its role is to support revealing the internal structure of the physical device and to support notification of events in the server.

In addition to the “Association” object modelling the association with the public client, the management logical device shall contain a “SAP assignment” object, giving its SAP and the SAP of all other logical devices within the physical device. The SAP assignment object must be readable at least by the public client.

If there is only one logical device within the physical device, the “SAP assignment” object may be omitted.

4.7 Authentication procedures

4.7.1 Low Level Security (LLS) authentication

As described in IEC 62056-53 the ACSE provides the authentication services for low level security (LLS). Low level security authentication is typically used when the communication channel offers adequate security to avoid eavesdropping and message (password) replay.

For LLS, all the authentication services are provided by the ACSE. The association objects provide only the method/attribute (see 5.12, 5.13) to change the “secret” (e.g. password).

For LLS authentication the client transmits a “secret” (e.g. a password) to the server, by using the “Calling_Authentication_Value” parameter of the COSEM-OPEN.request service primitive of the client application layer. The server checks if the received “secret” corresponds to the client identification. If yes, the client is authenticated and the association can be established.

4.7.2 High Level Security (HLS) authentication

As described in IEC 62056-53, the ACSE provides part of the authentication services for high level security (HLS). High level security authentication is typically used when the communication channel offers no intrinsic security and precautions have to be taken against eavesdroppers and against message (password) replay. In this case, a 4-pass authentication protocol is foreseen. The 4-pass authentication allows the authentication of the client as well as of the server in the following way.

Pass1: The client transmits “challenge” CtoS (e.g. a random number) to the server.

Pass2: The server transmits “challenge” StoC (e.g. a random number) to the client.

The length of the challenges shall be 8 to 64 octets.

Pass3: The client processes StoC according to the rules of the HLS authentication mechanism negotiated. In case of HLS authentication_mechanism_id(2), the method of processing the challenge is secret (e.g. encrypting with a secret key) which is the HLS secret known by both the client and the server. In case of HLS authentication_mechanism_id(3), the client appends the HLS secret to the challenge StoC received during Pass2 and generates the digest using the MD5 algorithm (RFC 1321). In case of authentication_mechanism_id(4), the process is the same, but the SHA_1 algorithm is used (FIPS 180-1). The result – f(StoC) – is sent back to the server. The server checks if f(StoC) is the result of correct processing and – if correct – accepts the authentication of the client.

Pass4: If the client is authenticated, the server processes CtoS in the same way as described in Pass3. The result – f(CtoS) – is sent back to the client. The client checks if f(CtoS) is the result of the correct processing and – if correct – accepts the authentication of the server.

The HLS authentication service, supporting Pass1 is provided by the COSEM-OPEN.request service primitive of the client application layer. The parameter "Security_Mechanism_Name" carries the identifier of the HLS mechanism, and the parameter "Calling_Authentication_Value" carries the challenge CtoS.

The HLS authentication service, supporting Pass2 is provided by the COSEM-OPEN.response service primitive of the server application layer. The parameter "Security_Mechanism_Name" carries the identifier of the HLS mechanism, and the parameter "Responding_Authentication_Value" carries the challenge Stoc.

After Pass2, the association is formally established, but the access of the client is restricted to the method "reply_to_HLS_authentication" of the current "association" object.

Pass3 and Pass4 are supported by the method **reply_to_HLS_authentication** of the association object(s), (see 5.12, 5.13). If both passes are successfully executed, then full access is granted according to the current association. Otherwise, either the client or the server aborts the association.

In addition, the association object provides the method to change the HLS "secret" (e.g. the encryption key): **change_HLS_secret**.

REMARK After the client has issued the change_HLS_secret () - or change_LLS_secret () - method, it expects a response from the server acknowledging that the secret has been changed. It is possible that the server transmits the acknowledgement, but due to communication problems, the acknowledgement is not received at the client-side. Therefore, the client does not know if the secret has been changed or not. For simplicity reasons, the server does **not** offer any special support for this case; i.e. it is left to the client to cope with this situation.

5 The interface classes

The currently defined interface classes for meters and the relations between them are illustrated in Figure 4.

NOTE 1 The interface class "base" itself is not specified explicitly. It contains only one attribute "logical_name".

NOTE 2 In the description of the "Demand register", "Clock" and "Profile generic" interface classes, the 2nd attributes are labelled differently from that of the 2nd attribute of the "Data" interface class, namely "current_average_value", "time" and "buffer" vs. "value". This is to emphasize the specific nature of the "value".




Figure 4 – Overview of the interface classes

5.1 Data (class_id: 1)

A “Data” object stores data related to internal meter object(s). The meaning of the value is identified by the logical_name. The data type of the value is CHOICE. “Data” is typically used to store configuration data and parameters.

Data	0...n	class_id = 1, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static) 2. value	octet-string CHOICE			
Specific method(s)	m/o			

Attribute description

logical_name	Identifies the “Data” object instance. Identifiers are specified in Clause D.22 and in IEC 62056-61.		
value	Contains the data.		
	CHOICE		The data type depends on the instantiation defined by the “logical name” and possibly from the manufacturer. It has to be chosen so, that together with the logical name, an unambiguous interpretation is possible. Any simple and complex data types listed in 4.3 can be used, unless the choice is restricted in Annex D.
	{		
	--simple data types		
	null-data	[0],	
	boolean	[3],	
	bit-string	[4],	
	double-long	[5],	
	double-long-unsigned	[6],	
	octet-string	[9],	
	visible-string	[10],	
	bcd	[13],	
	integer	[15],	
	long	[16],	
	unsigned	[17],	
	long-unsigned	[18],	
	long64	[20],	
	long64-unsigned	[21],	
	enum	[22],	
	float32	[23],	
	float64	[24],	
	date-time	[25],	
	date	[26],	
	time	[27],	
	--complex data types		
	array	[1],	
	structure	[2],	
	compact-array	[19]	
	}		

5.2 Register (class_id: 3)

A “Register” object stores a process value or a status value with its associated unit. The register object knows the nature of the process value or of the status value. The nature of the value is described by the attribute “logical name” using the OBIS identification system (see Clause D.2 and IEC 62056-61).

Register	0...n	class_id = 3, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. value (dyn.)	CHOICE			
3. scaler_unit (static)	scal_unit_type			
Specific method(s)	m/o			
1. reset (data)	o			

Attribute description

logical_name	Identifies the “Register” object instance. Identifiers are specified in Clause D.2 and in IEC 62056-61.		
value	<p>Contains the current process or status value.</p> <p>CHOICE</p> <pre>{ --simple data types null-data [0], bit-string [4], double-long [5], double-long-unsigned [6], octet-string [9], visible-string [10], integer [15], long [16], unsigned [17], long-unsigned [18], long64 [20], long64-unsigned [21], float32 [23], float64 [24] }</pre> <p>The data type of the value depends on the instantiation defined by “logical_name” and possibly on the choice of the manufacturer. It has to be chosen so that, together with the logical_name, an unambiguous interpretation of the value is possible.</p> <p>When instead of a “Data” object a “Register” object is used, (with the scaler_unit attribute not used or with scaler = 0, unit = 255) then the data types allowed for the value attribute of the “Data” interface class are allowed.</p>		
scaler_unit	<p>Provides information on the unit and the scaler of the value.</p> <p>scal_unit_type: structure</p> <pre>{ scaler, unit }</pre> <p>scaler: integer</p> <p>unit: enum</p> <p>This is the exponent (to the base of 10) of the multiplication factor. REMARK If the value is not numerical, then the scaler shall be set to 0.</p> <p>Enumeration defining the physical unit; for details see below.</p>		

Method description

reset (data)	This method forces a reset of the object. By invoking this method, the value is set to the default value. The default value is an instance specific constant. data ::= integer(0)
---------------------	--

unit ::= enum

Code	// Unit	Quantity	Unit name	SI definition (comment)
(1)	a	// time	year	
(2)	mo	// time	month	
(3)	wk	// time	week	7*24*60*60 s
(4)	d	// time	day	24*60*60 s
(5)	h	// time	hour	60*60 s
(6)	min.	// time	min	60 s
(7)	s	// time (<i>t</i>)	second	s
(8)	°	// (phase) angle	degree	rad*180/π
(9)	°C	// temperature (<i>T</i>)	degree celsius	K-273.15
(10)	currency	// (local) currency		
(11)	m	// length (<i>l</i>)	metre	m
(12)	m/s	// speed (<i>v</i>)	metre per second	m/s
(13)	m ³	// volume (<i>V</i>) <i>r_V</i> , meter constant or pulse value (volume)	cubic metre	m ³
(14)	m ³	// corrected volume	cubic metre	m ³
(15)	m ³ /h	// volume flux	cubic metre per hour	m ³ /(60*60s)
(16)	m ³ /h	// corrected volume flux	cubic metre per hour	m ³ /(60*60s)
(17)	m ³ /d	// volume flux		m ³ /(24*60*60s)
(18)	m ³ /d	// corrected volume flux		m ³ /(24*60*60s)
(19)	l	// volume	litre	10 ⁻³ m ³
(20)	kg	// mass (<i>m</i>)	kilogram	
(21)	N	// force (<i>F</i>)	newton	
(22)	Nm	// energy	newtonmeter	J = Nm = Ws
(23)	Pa	// pressure (<i>p</i>)	pascal	N/m ²
(24)	bar	// pressure (<i>p</i>)	bar	10 ⁵ N/m ²
(25)	J	// energy	joule	J = Nm = Ws
(26)	J/h	// thermal power	joule per hour	J/(60*60s)
(27)	W	// active power (<i>P</i>)	watt	W = J/s
(28)	VA	// apparent power (<i>S</i>)	volt-ampere	
(29)	var	// reactive power (<i>Q</i>)	var	
(30)	Wh	// active energy <i>r_W</i> , active energy meter constant or pulse value	watt-hour	W*(60*60s)
(31)	VAh	// apparent energy <i>r_S</i> , apparent energy meter constant or pulse value	volt-ampere-hour	VA*(60*60s)
(32)	varh	// reactive energy <i>r_B</i> , reactive energy meter constant or pulse value	var-hour	var*(60*60s)
(33)	A	// current (<i>I</i>)	ampere	A
(34)	C	// electrical charge (<i>Q</i>)	coulomb	C = As
(35)	V	// voltage (<i>U</i>)	volt	V
(36)	V/m	// electric field strength (<i>E</i>)	volt per metre	V/m

<i>Code</i>	<i>// Unit</i>	<i>Quantity</i>	<i>Unit name</i>	<i>SI definition (comment)</i>
(37)	F	// capacitance (C)	farad	$C/V = As/V$
(38)	Ω	// resistance (R)	ohm	$\Omega = V/A$
(39)	$\Omega m^2/m$	// resistivity (ρ)		Ωm
(40)	Wb	// magnetic flux (Φ)	weber	$Wb = Vs$
(41)	T	// Magnetic flux density (B)	tesla	Wb/m^2
(42)	A/m	// magnetic field strength (H)	ampere per metre	A/m
(43)	H	// inductance (L)	henry	$H = Wb/A$
(44)	Hz	// frequency (f, ω)	hertz	1/s
(45)	1/(Wh)	// R_W , active energy meter constant or pulse value		
(46)	1/(varh)	// R_B , reactive energy meter constant or pulse value		
(47)	1/(VAh)	// R_S , apparent energy meter constant or pulse value		
(48)	V ² h	// volt-squared hour r_{U2h} , volt-squared hour meter constant or pulse value	volt-squared-hours	$V^2(60*60s)$
(49)	A ² h	// ampere-squared hour r_{I2h} , ampere-squared hour meter constant or pulse value	ampere-squared-hours	$A^2(60*60s)$
(50)	kg/s	// mass flux	kilogram per second	kg/s
(51)	S, mho	// conductance	siemens	1/ Ω
(52)	K	// temperature (T)	kelvin	
(53)	1/(V ² h)	// R_{U2h} , volt-squared hour meter constant or pulse value		
(54)	1/(A ² h)	// R_{I2h} , ampere-squared hour meter constant or pulse value		
(55)	1/m ³	// R_V , meter constant or pulse value (volume)		
(56)		// percentage	%	
(57)	Ah	// ampere-hours	Ampere-hour	
(60)	Wh/m ³	// energy per volume	$3,6*10^3 J/m^3$	
(61)	J/m ³	// calorific value, wobbe		
(62)	Mol %	// molar fraction of gas composition	mole percent	(Basic gas composition unit)
(63)	g/m ³	// mass density, quantity of material		(Gas analysis, accompanying elements)
(64)	Pa s	// dynamic viscosity	pascal second	(Characteristic of gas stream)
....				
(253)		// reserved		
(254)	other	// other unit		
(255)	count	// no unit, unitless, count		

Examples of values:

Value	Scaler	Unit	Data
263788	-3	m ³	263,788 m ³
593	3	Wh	593 kWh
3467	0	V	3467 V

5.3 Extended register (class_id: 4)

Instances of an “Extended register” class store a process value with its associated status, unit, and time information. The extended register object knows the nature of the process value. The nature of the value is described by the attribute “logical name” using the OBIS identification system.

Extended register	0...n	class_id = 4, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. value (dyn.)	CHOICE			
3. scaler_unit (static)	scal_unit_type			
4. status (dyn.)	CHOICE			
5. capture_time (dyn.)	octet-string			
Specific method(s)	m/o			
1. reset (data)	o			

Attribute description

For the definition of the attributes *value* and *scaler_unit*, see description of class "Register".

logical_name	Identifies the “Extended register” object instance. See D.2.2.1.																																												
status	<p>Provides “Extended register” specific status information. The meaning of the elements of the status shall be provided for each “Extended register” object instance.</p> <table><tr><td>CHOICE</td><td colspan="2"></td><td rowspan="10">The data type and the encoding depend on the instantiation and possibly on the choice of the manufacturer. For the interpretation, extra information from the manufacturer may be necessary.</td></tr><tr><td>{</td><td colspan="2"></td></tr><tr><td>--simple data types</td><td colspan="2"></td></tr><tr><td>null-data</td><td>[0],</td><td></td></tr><tr><td>bit-string</td><td>[4],</td><td></td></tr><tr><td>double-long-unsigned</td><td>[6],</td><td></td></tr><tr><td>octet-string</td><td>[9],</td><td></td></tr><tr><td>visible-string</td><td>[10],</td><td></td></tr><tr><td>unsigned</td><td>[17],</td><td></td></tr><tr><td>long-unsigned</td><td>[18],</td><td></td></tr><tr><td>long64-unsigned</td><td>[21]</td><td></td></tr><tr><td>}</td><td colspan="2"></td><td></td></tr><tr><td>Def.</td><td colspan="3">Depending on the status type definition.</td></tr></table>			CHOICE			The data type and the encoding depend on the instantiation and possibly on the choice of the manufacturer. For the interpretation, extra information from the manufacturer may be necessary.	{			--simple data types			null-data	[0],		bit-string	[4],		double-long-unsigned	[6],		octet-string	[9],		visible-string	[10],		unsigned	[17],		long-unsigned	[18],		long64-unsigned	[21]		}				Def.	Depending on the status type definition.		
CHOICE			The data type and the encoding depend on the instantiation and possibly on the choice of the manufacturer. For the interpretation, extra information from the manufacturer may be necessary.																																										
{																																													
--simple data types																																													
null-data	[0],																																												
bit-string	[4],																																												
double-long-unsigned	[6],																																												
octet-string	[9],																																												
visible-string	[10],																																												
unsigned	[17],																																												
long-unsigned	[18],																																												
long64-unsigned	[21]																																												
}																																													
Def.	Depending on the status type definition.																																												
capture_time	<p>Provides an “Extended register” specific date and time information showing when the value of the attribute "value" has been captured.</p> <p>octet-string, formatted as set in 4.4.1 for <i>date_time</i></p>																																												

Method description

reset (data) This method forces a reset of the object. By invoking this method, the attribute value is set to the default value. The default value is an instance specific constant.

The attribute `capture_time` is set to the time of the reset execution.

`data ::= integer(0)`

5.4 Demand register (class_id: 5)

Instances of a “Demand register” class store a demand value with its associated status, unit, and time information. The demand register measures and computes its *current_average_value* periodically. The time interval T over which the demand is measured or computed is defined by specifying “number_of_periods” and “period”.




Figure 5 – The attributes when measuring sliding demand

The demand register delivers two types of demand: the *current_average_value* and the *last_average_value* (see Figure 6 and Figure 7).

The demand register knows its type of process value, which is described in “logical name” using the OBIS identification system.




Figure 6 – The attributes when measuring current_average_value if number of periods is 1




Figure 7 – The attributes if the number of periods is 3

Attribute description

For the attribute *scaler_unit*, see description of class “Register”.

logical_name	Identifies the “Demand register” object instance. See D.2.2.1.	
current_average_value	<p>Provides the current value (running demand) of the energy accumulated since start_time divided by number_of_periods*period.</p> <p>NOTE If another <i>quantity</i> than energy is measured, other calculation methods may apply (for example for calculating average values of voltage or current).</p> <p>CHOICE</p>	<p>The data type of the value depends on the instantiation defined by “logical_name” and possibly on the choice of the manufacturer. The type has to be chosen so that, together with the logical_name, unambiguous interpretation of the value is possible.</p> <p>For data types, see “Register” class, value attribute.</p>
last_average_value	<p>Provides the value of the accumulated energy (over the last number_of_periods*period) divided by number_of_periods*period. The energy of the current (not terminated) period is not considered by the calculation.</p> <p>NOTE If another <i>quantity</i> than energy is measured, other calculation methods may apply (for example for calculating average values of voltage or current).</p> <p>CHOICE</p>	<p>For data types, see “Register” class, value attribute.</p>
status	<p>Provides “Demand register” specific status information. The data type and the encoding depend on the instantiation and possibly on the choice of the manufacturer. For the interpretation, extra information from the manufacturer may be necessary.</p> <p>CHOICE</p> <p>Def.</p>	<p>For data types, see “Extended register” class, status attribute.</p> <p>Depending on the status type definition.</p>
capture_time	<p>Provides the date and time when the last_average_value has been calculated.</p> <p>octet-string, formatted as set in 4.4.1 for <i>date_time</i></p>	
start_time_current	<p>Provides the date and time when the measurement of the current_average_value has been started.</p> <p>octet-string, formatted as set in 4.4.1 for <i>date_time</i></p>	
period	<p>Period is the interval between two successive updates of the last_average_value. (number_of_periods*period is the denominator for the calculation of the demand).</p> <p>double-long-unsigned</p> <p>The behaviour of the meter after writing a new value to this attribute shall be specified by the manufacturer.</p>	
		Measuring period in seconds

number_of_periods	The number of periods used to calculate the last_average_value. number_of_periods >= 1		
	long-unsigned		number_of_periods > 1 indicates that the last_average_value represents "sliding demand". number_of_periods = 1 indicates that the last_average_value represents "block demand".
The behaviour of the meter after writing a new value to this attribute shall be specified by the manufacturer.			

Method description

reset (data)	This method forces a reset of the object. Activating this method provokes the following actions: <ul style="list-style-type: none"> - the current period is terminated; - the current_average_value and the last_average_value are set to their default values; - the capture_time and the start_time_current are set to the time of the execution of reset(data). data ::= integer(0)			
next_period (data)	This method is used to trigger the regular termination (and restart) of a period. Closes (terminates) the current measuring period. Updates capture_time and start_time and copies current_average_value to last_average_value, sets current_average_value to its default value. Starts the next measuring period. REMARK The old last_average_value (and capture_time) can be read during the time "period". The old current_average_value is not available any more at the interface. data ::= integer(0)			

5.5 Register activation (class_id: 6)

Instances of the "Register activation" class are used to handle different tariffication structures. To each "Register activation" object, groups of "Register", "Extended register" or "Demand register" objects, modelling different kind of quantities (for example active energy, active demand, reactive energy, etc.) are assigned. Subgroups of these registers, defined by the activation_masks define different tariff structures (for example day tariff, night tariff). One of these activation masks, the active_mask, defines which subset of the registers, assigned to the "Register activation" object instance is active. Registers, which are not defined in the register_assignment attribute of any "Register activation" object, are always enabled by default.

Register activation		0...n	class_id = 6, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. register_assignment	(static)	array			
3. mask_list	(static)	array			
4. active_mask	(dyn.)	octet-string			
Specific method(s)		m/o			
1. add_register (data)		o			
2. add_mask (data)		o			
3. delete_mask (data)		o			

Attribute description

logical_name	Identifies the “Register activation” object instance. See D.2.1.9.
register_assignment	<p>Specifies an ordered list of COSEM objects assigned to the “Register activation” object. The list may contain different kinds of COSEM objects, for example “Register”, “Extended register” or “Demand register”.</p> <p>array object_definition</p> <p>object_definition ::= structure</p> <pre> { class_id: long-unsigned, logical_name: octet-string } </pre>
mask_list	<p>Specifies a list of register activation masks. Each entry (mask) is identified by its mask_name and contains an array of indices referring to the registers assigned to the mask (the first object in register_assignment is referenced by index 1, the second object by index 2, ...).</p> <p>array register_act_mask</p> <p>register_act_mask ::= structure</p> <pre> { mask_name: octet-string, index_list: index_array } </pre> <p>index_array ::= array unsigned</p> <p>mask_name has to be uniquely defined within the object.</p>
active_mask	<p>Defines the currently active mask. The mask is defined by its mask_name (see mask_list).</p> <p>octet-string This is a mask_name from the mask_list.</p> <p>The active_mask defines the registers currently enabled; all other registers listed in the register_assignment are disabled.</p>

Method description

add_register (data)	<p>Adds one more register to the attribute register_assignment. The new register is added at the end of the array; i.e. the newly added register has the highest index. The indices of the existing registers are not modified.</p> <p>data ::= structure</p> <pre> { class_id: long-unsigned, logical_name: octet-string } </pre>
----------------------------	--

add_mask (data)	Adds another mask to the attribute mask_list. If there exists already a mask with the same name, the existing mask will be overwritten by the new mask.
	data ::= register_act_mask (see above)
delete_mask (data)	Deletes a mask from the attribute mask_list. The mask is defined by its mask name.
	data ::= octet-string (mask_name)

5.6 Profile generic (class_id: 7)

The “Profile generic” class defines a generalized concept to store dynamic process values of capture objects. Capture objects are appropriate attributes or element of (an) attribute(s) of COSEM objects. The capture objects are collected periodically or occasionally.

A profile has a buffer to store the captured data. To retrieve only a part of the buffer, either a value range or an entry range may be specified, asking to retrieve all entries whose values or entry numbers fall within the given range.

The list of capture objects defines the values to be stored in the buffer (using the method *capture*). The list is defined statically to ensure homogenous buffer entries (all entries have the same size and structure). If the list of capture objects is modified, the buffer is cleared. If the buffer is captured by other “Profile generic” objects, their buffer is cleared as well, to guarantee the homogeneity of their buffer entries.

The buffer may be defined as sorted by one of the registers or by a clock, or the entries are stacked in a “last in first out” order. So for example, it is very easy to build a “maximum demand register” with a one entry deep sorted profile capturing and sorted by a demand register. It is just as simple to define a profile retaining the three largest values of some period.

The size of profile data is determined by three parameters:

- the number of entries filled. This will be zero after clearing the profile;
- the maximum number of entries to retain. If all entries are filled and a capture () request occurs, the least important entry (according to the requested sorting method) will get lost. This maximum number of entries may be specified. Upon changing it, the buffer will be adjusted;
- the physical limit for the buffer. This limit typically depends on the objects to capture. The object will reject an attempt of setting the maximum number of entries that is larger than physically possible.

Profile generic		0...n	class_id = 7, version = 1		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. buffer	(dyn.)	compact array or array			x
3. capture_objects	(static)	array			
4. capture_period	(static)	double-long-unsigned			x
5. sort_method	(static)	enum			x
6. sort_object	(static)	object_definition			x
7. entries_in_use	(dyn.)	double-long-unsigned	0		0
8. profile_entries	(static)	double-long-unsigned	1		1
Specific method(s)		m/o			
1. reset (data)		o			
2. capture (data)		o			
3. reserved from previous versions		o			
4. reserved from previous versions		o			

Attribute description

logical_name	Identifies the “Profile generic” object instance. For examples, see D.2.1.13, D.2.1.26, D.2.1.29, D.2.1.30, D.2.1.36, D.2.2.3.
buffer	<p>The buffer attribute contains a sequence of entries. Each entry contains values of the captured objects (as they would be returned to a GET or READ.request).</p> <p>compact-array or array entry</p> <p>entry ::=</p> <pre> structure { CHOICE { --simple data types null-data [0], boolean [3], bit-string [4], double-long [5], double-long-unsigned [6], octet-string [9], visible-string [10], bcd [13], integer [15], long [16], unsigned [17], long-unsigned [18], long64 [20], long64-unsigned [21], enum [22], float32 [23], float64 [24], date-time [25], date [26], time [27], --complex data types array [1], structure [2], compact-array [19] } </pre>

The number and the order of the elements of the structure holding the entries is the same as in the definition of the `capture_objects`. The buffer is filled by auto captures or by subsequent calls of the method (`capture`). The sequence of the entries within the array is ordered according to the sort method specified.

Default: The buffer is empty after reset.

REMARK 1 Reading the entire buffer delivers only those entries, which are “in use”.

REMARK 2 The value of a captured object may be replaced by “null-data” if it can be unambiguously recovered from the previous value (e.g. for time: if it can be calculated from the previous value and `capture_period`; or for a value: if it is equal to the previous value).

selective access (see 4.2) to the attribute buffer may be available (optional). The selective access parameters are as defined below.

capture_objects	<p>Specifies the list of capture objects that are assigned to the object instance. Upon a call of the <code>capture (data)</code> method or automatically in defined intervals, the selected attributes are copied into the buffer of the profile.</p> <pre>array capture_object_definition capture_object_definition ::= structure { class_id: long-unsigned, logical_name: octet-string, attribute_index: integer, data_index: long-unsigned }</pre> <ul style="list-style-type: none"> - where <code>attribute_index</code> is a pointer to the attribute within the object. <code>attribute_index 1</code> refers to the first attribute (i.e. the <code>logical_name</code>), <code>attribute_index 2</code> to the 2nd, etc.); <code>attribute_index 0</code> refers to all public attributes; - where <code>data_index</code> is a pointer selecting a specific element of the attribute. The first element in the attribute structure is identified by <code>data_index 1</code>. If the attribute is not a structure, then the <code>data_index</code> has no meaning. If the capture object is the buffer of a profile, then the <code>data_index</code> identifies the captured object of the buffer (i.e. the column) of the inner profile.
capture_period	<p><code>data_index 0</code>: references the whole attribute</p> <p><code>>= 1</code>: Automatic capturing assumed. Specifies the capturing period in seconds.</p> <p><code>0</code>: No automatic capturing; capturing is triggered externally or capture events occur asynchronously.</p>
sort_method	<p>If the profile is unsorted, it works as a “first in first out” buffer (it is hence sorted by capturing, and not necessarily by the time maintained in the clock object). If the buffer is full, the next call to <code>capture ()</code> will push out the first (oldest) entry of the buffer to make space for the new entry.</p> <p>If the profile is sorted, a call to <code>capture ()</code> will store the new entry at the appropriate position in the buffer, moving all following entries and probably losing the least interesting entry. If the new entry would enter the buffer after the last entry and if the buffer is already full, the new entry will not be retained at all.</p>

	enum	(1) fifo (first in first out), (2) lifo (last in first out), (3) largest, (4) smallest, (5) nearest_to_zero, (6) farrest_from_zero
	Def.	fifo
sort_object	If the profile is sorted, this attribute specifies the register or clock that the ordering is based upon.	
	capture_object_definition	See above.
	Def.	no object to sort by (only possible with sort_method fifo or lifo)
entries_in_use	Counts the number of entries stored in the buffer. After a call of reset (), the buffer does not contain any entries, and this value is zero. Upon each subsequent call of capture (), this value will be incremented up to the maximum number of entries that will get stored (see profile_entries).	
	double-long-unsigned	0...profile_entries
	Def.	0
profile_entries	Specifies how many entries shall be retained in the buffer.	
	double-long-unsigned	1...(limited by physical size)
	Def.	1

Parameters for selective access to the buffer attribute

Access selector value	Parameter	Comment
1	range_descriptor	Only buffer elements corresponding to the range_descriptor shall be returned in the response.
2	entry_descriptor	Only buffer elements corresponding to the entry_descriptor shall be returned in the response.

range_descriptor ::= structure

{	restricting_object	capture_object_definition	Defines the capture_object restricting the range of entries to be retrieved. Only simple data types are allowed.
	from_value	CHOICE {--simple data types double-long [5], double-long-unsigned [6], octet-string [9], visible-string [10], integer [15], long [16], unsigned [17], long-unsigned [18], long64 [20], long64-unsigned [21], float32 [23], float64 [24], date-time [25], date [26], time [27] }	Oldest or smallest entry to retrieve
	to_value	CHOICE { see above }	Newest or largest entry to retrieve
	selected_values	array capture_object_definition	List of columns to retrieve. If the array is empty (has no entries), all captured data are returned. Otherwise, only the columns specified in the array are returned. The type <i>capture_object_definition</i> is specified above (<i>capture_objects</i>)
}			

entry_descriptor ::= structure

{	from_entry	double-long-unsigned	first entry to retrieve,
	to_entry	double-long-unsigned	last entry to retrieve to_entry == 0: highest possible entry,
	from_selected_value	long-unsigned	index of first value to retrieve,
	to_selected_value	long-unsigned	index of last value to retrieve to_selected_value == 0: highest possible selected_value
}			

NOTE from_entry and to_entry identify the lines, from_selected_value to_selected_value identify the columns of the buffer to be retrieved.

Method description

reset (data)	<p>Clears the buffer. The buffer has no valid entries afterwards; entries_in_use is zero after this call. This call does not trigger any additional operations of the capture objects. Specifically, it does not reset any captured buffers or registers.</p> <p>data ::= integer(0)</p>
capture (data)	<p>Copies the values of the objects to capture into the buffer by reading each capture object. Depending on the sort_method and the actual state of the buffer this produces a new entry or a replacement for the less significant entry. As long as not all entries are already used, the entries_in_use attribute will be incremented.</p> <p>This call does not trigger any additional operations within the capture objects such as capture () or reset ().</p> <p>Note, that if more than one attributes of an object need to be captured, they have to be defined one by one on the list of capture objects. If the attribute_index = 0, all attributes are captured.</p> <p>data ::= integer(0)</p>

Behaviour of the object after modification of certain attributes

	<p>Any modification of one of the capture_objects describing the static structure of the buffer will automatically call a reset () and this call will propagate to all other profiles capturing this profile.</p> <p>If writing to profile_entries is attempted with a value too large for the buffer, it will be rejected.</p>
--	---

Restrictions

When defining the capture objects, circular reference to the profile shall be avoided.

Profile used to define a subset of preferred readout values

By setting profile_entries to 1, a “Profile generic” object can be used to define a set of preferred readout values. See also D.2.1.13.

Setting capture_period to 1 ensures that the values are updated every second.

5.7 Clock (class_id: 8)

An instance of the “Clock” interface class handles all information that is related to date and time, including leap years and the deviation of the local time to a generalized time reference (Greenwich Mean Time, GMT). The deviation from the local time to the generalized time reference can change depending on the season (e.g. summertime vs. wintertime). The interface to an external client is based on date information specified in day, month and year, time information given in hundredths of seconds, seconds, minutes and hours and the deviation from the local time to the generalized time reference.

It also handles the daylight saving function in that way; i.e. it modifies the deviation of local time to GMT depending on the attributes. The start and end point of that function is normally set once. An internal algorithm calculates the real switch point depending on these settings.




Figure 8 – The generalized time concept

Clock	0...1	class_id = 8, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. time (dyn.)	octet-string			
3. time_zone (static)	long			
4. status (dyn.)	unsigned			
5. daylight_savings_begin (static)	octet-string			
6. daylight_savings_end (static)	octet-string			
7. daylight_savings_deviation (static)	integer			
8. daylight_savings_enabled (static)	boolean			
9. clock_base (static)	enum			
Specific method(s)	m/o			
1. adjust_to_quarter (data)	o			
2. adjust_to_measuring_period (data)	o			
3. adjust_to_minute (data)	o			
4. adjust_to_preset_time (data)	o			
5. preset_adjusting_time (data)	o			
6. shift_time (data)	o			

Attribute description

logical_name	Identifies the “Clock” object instance. See D.2.1.1.
time	<p>Contains the meter’s local date and time, its deviation to GMT and the status. See 4.4.1.</p> <p>When this value is set, only specified fields of the date_time are changed. For example for setting the date without changing the time, all time relevant octets of the date_time shall be set to “not specified”. The clock_status shall always be set when writing the time.</p> <p>octet-string, formatted as set in 4.4.1 for <i>date_time</i></p>
time_zone	<p>The deviation of local, normal time to GMT in minutes.</p> <p>long</p>
status	<p>The status is equal to the status read in <i>time</i>. See 4.4.1.</p> <p>unsigned, formatted as set in 4.4.1 for <i>clock_status</i></p>

daylight_savings_begin	Defines the local switch date and time when the local time has to be deviated from the normal time. For generic definitions, wildcards are allowed. octet-string, formatted as set in 4.4.1 for <i>date_time</i>
daylight_savings_end	See above. octet-string, formatted as set in 4.4.1 for <i>date_time</i>
daylight_savings_deviation	Contains the number of minutes by which the deviation in generalized time must be corrected at daylight savings begin. integer Deviation range of up to ± 120 min
daylight_savings_enabled	TRUE enables daylight savings function. boolean
clock_base	Defines where the basic timing information comes from. enum (0) not defined, (1) internal crystal, (2) mains frequency 50 Hz, (3) mains frequency 60 Hz, (4) GPS (global positioning system), (5) radio controlled

Method description

adjust_to_quarter (data)	Sets the meter's time to the nearest (+/-) quarter of an hour value (*:00, *:15, *:30, *:45). data ::= integer (0)
adjust_to_measuring_period (data)	Sets the meter's time to the nearest (+/-) starting point of a measuring period. data ::= integer (0)
adjust_to_minute (data)	Sets the meter's time to the nearest minute. If second_counter < 30 s, so second_counter is set to 0. If second_counter \geq 30 s, so second_counter is set to 0, and minute_counter and all depending clock values are incremented if necessary. data ::= integer(0)
adjust_to_preset_time (data)	This method is used in conjunction with the preset_adjusting_time method. If the meter's time lies between validity_interval_start and validity_interval_end, then time is set to preset_time. data ::= integer(0)

preset_adjusting_time (data)	<p>Presets the time to a new value (preset_time) and defines a validity_interval within which the new time can be activated.</p> <p>data ::= structure</p> <pre> { preset_time: octet-string, validity_interval_start: octet-string, validity_interval_end: octet-string } </pre> <p>all octet-strings formatted as set in 4.4.1 for <i>date_time</i></p>
shift_time (data)	<p>Shifts the time by <i>n</i> ($-900 \leq n \leq 900$) s.</p> <p>data ::= long</p>

5.8 Script table (class_id: 9)

The IC script table provides the possibility to trigger a series of actions by executing scripts using the execute (data) method.

For that purpose, script table contains a table of script entries. Each table entry (script) consists of a script_identifier and a series of action_specifications. An action_specification activates a method of a COSEM object or modifies attributes of a COSEM object within the logical device.

A specific script may be activated by other COSEM objects within the same logical device or from the outside.

If two scripts have to be executed at the same time instance, then the one with the smaller index is executed first.

Script table	0...n	class_id = 9, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. scripts (static)	array			
Specific method(s)	m/o			
1. execute (data)	m			

Attribute description

logical_name	Identifies the "Script table" object instance. See D.2.1.5.		
scripts	Specifies the different scripts, i.e. the lists of actions.		
	array	script	
	script	<pre> structure { script_identifier: long-unsigned, actions: array action_specification } </pre> <p>The script_identifier 0 is reserved. If specified with an execute method, it results in a null script (no actions to perform).</p>	

```

action_specification    structure
                        {
                                service_id:    enum,
                                class_id:       long-unsigned,
                                logical_name:    octet-string,
                                index:           integer,
                                parameter:       service specific
                        }

```

where
 service_id: defines which action to be applied to the referenced object

- (1) write attribute,
- (2) execute specific method

index: defines (with service_id 1) which attribute of the selected object is affected or (with service_id 2) which specific method is to be executed.

The first attribute (`logical_name`) has index 1, the first specific method has index 1 as well.

NOTE The `action_specification` is limited to activate methods that do not produce any response (from the server to the client).

Method description

execute (data)	Executes the script specified in parameter data.	
	data	long-unsigned
	If data matches one of the script_identifiers in the script table, then the corresponding action specification is executed.	

5.9 Schedule (class_id: 10)

The IC “Schedule” together with an object of the IC “Special days” table handles time and date driven activities within a device. The following picture gives an overview and shows the interactions between them:

Schedule:

[illegible]

Special days table:

Index	special_day_date	day_id
12	xx-12-24	S1
33	xx-12-25	S3
77	97-03-31	S3

Schedule	0...n	class_id = 10, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. entries (static)	array			
Specific method(s)	m/o			
1. enable/disable (data)	o			
2. insert (data)	o			
3. delete (data)	o			

Attribute description

logical_name	Identifies the “Schedule” object instance. See D.2.1.7.
entries	<p>Specifies the scripts to be executed at given times. There is only one script that can be executed per entry.</p> <p>array schedule_table_entry</p> <p>schedule_table_entry structure</p> <pre> { index: long-unsigned (1..9999), enable: boolean, script_logical_name: octet-string, script_selector: long-unsigned, switch_time: octet-string, validity_window: long-unsigned, exec_weekdays: bit-string, exec_specdays: bit-string begin_date: octet-string, end_date: octet-string } </pre> <p>where:</p> <ul style="list-style-type: none"> - script_logical_name: defines the logical name of the “Script table” object; - script_selector: defines the script_identifier of the script to be executed; - switch_time accepts wildcards to define repetitive entries. The format of the octet-string follows the rules set in 4.4.1 for <i>time</i>; - validity_window defines a period in minutes, in which an entry must be processed after power fail. (time between defined switch_time and actual power_up) 0xFFFF: the script must be processed any time; - exec_weekdays defines the days of the week on which the entry is valid; - exec_specdays perform the link to the IC “Special days table”, day_ID; - begin_date and end_date define the date period in which the entry is valid (wildcards are allowed). The format follows the rules set in 4.4.1 for <i>date</i>.

Method description

enable/disable (data)	<p>Sets the disabled bit of range A entries to true and then enables the entries of range B.</p> <pre>data ::= structure { firstIndexA, lastIndexA, firstIndexB, lastIndexB }</pre> <p>firstIndexA first index of the range that is disabled long-unsigned,</p> <p>lastIndexA last index of the range that is disabled long-unsigned,</p> <p>firstIndexB first index of the range that is enabled long-unsigned,</p> <p>lastIndexB last index of the range that is enabled long-unsigned</p> <p>firstIndexA/B < lastIndexA/B: all entries of the range A/B are disabled/enabled</p> <p>firstIndexA/B == lastIndexA/B: one entry is disabled/enabled,</p> <p>firstIndexA/B > lastIndexA/B: nothing disabled/enabled,</p> <p>firstIndexA/B and lastIndexA/B > 9999: no entry is disabled/enabled</p>
insert (data)	<p>Inserts a new entry in the table. If the index of the entry exists already, the existing entry is overwritten by the new entry.</p> <p>entry schedule_table_entry</p> <p>data: corresponding to entry</p>
delete (data)	<p>Deletes a range of entries in the table.</p> <pre>data ::= structure { firstIndex, lastIndex }</pre> <p>firstIndex first index of the range that is deleted long-unsigned,</p> <p>lastIndex last index of the range that is deleted long-unsigned</p> <p>firstIndex < lastIndex: all entries of the range A/B are deleted,</p> <p>firstIndex ::= lastIndex: one entry is deleted,</p> <p>firstIndex > lastIndex: nothing deleted</p>

Remarks concerning "inconsistencies" in the table entries

- If the same script should be executed several times at a specific time instance, then it is executed only once.
- If different scripts should be executed at the same time instance, then the execution order is according to the "index". The script with the lowest "index" is executed first.

Recovery after power failure

After a power failure, the whole schedule is processed to execute all the necessary scripts that would get lost during a power failure. For this, the entries that were not executed during the power failure must be detected. Depending on the validity window attribute they are executed in the correct order (as they would have been executed in normal operation).

Handling of time changes

There are four different "actions" of time changes:

- a) time setting forward;
- b) time setting backwards;
- c) time synchronization;
- d) daylight saving action.

All these four actions need a different handling executed by the schedule in interaction with the time setting activity.

Time setting forward*

This is handled the same way as a power failure. All entries missed are executed depending on the validity window attribute. A (manufacturer specific defined) short time setting can be handled like time synchronization.

* Writing to the attribute "time" of the "Clock" object.

Time setting backward*

This results in a repetition of those entries that are activated during the repeated time. A (manufacturer specific defined) short time setting can be handled like time synchronization.

* Writing to the attribute "time" of the "Clock" object.

Time synchronization*

Time synchronization is used to correct small deviations between a master clock and the local clock. The algorithm is manufacturer specific. It shall guarantee that no entry of the schedule gets lost, or is executed twice. The validity window attribute has no effect, because all entries must be executed in normal operation.

* Using the method "adjust_to_quarter" of the "Clock" object.

Daylight saving

If the clock is put forward, then all scripts, which fall into the forwarding interval (and would therefore get lost) are executed.

If the clock is put back, re-execution of the scripts, which fall into the backwarding interval is suppressed.

5.10 Special days table (class_id: 11)

The interface class allows defining dates, which will override normal switching behaviour for special days. The interface class works in conjunction with the class "Schedule" or "Activity calendar" and the linking data item is day_id.

Special days table		0...1	class_id = 11, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. entries	(static)	array			
Specific method(s)		m/o			
1. insert (data)		o			
2. delete (data)		o			

Attribute description

logical_name	Identifies the “Special days table” object instance. See D.2.1.6.				
entries	<p>Specifies a special day identifier for a given date. The date may have wildcards for repeating special days like Christmas.</p> <p>array spec_day_entry</p> <p>spec_day_entry structure</p> <p> {</p> <p> index: long-unsigned,</p> <p> specialday_date: octet-string,</p> <p> day_id: unsigned</p> <p> }</p> <p> where:</p> <ul style="list-style-type: none"> - specialday_date formatting follows the rules set in 4.4.1 for <i>date</i>; - the range of the day_id must match the length of the bitstring exec_specdays in the related object of interface class “Schedule”. 				

Method description

insert (data)	<p>Inserts a new entry in the table.</p> <p>entry spec_day_entry</p> <p>If a special day with the same index or with the same date as an already defined day is inserted, the old entry will be overwritten.</p>				
delete (data)	<p>Deletes an entry in the table.</p> <p>index Index of the entry that shall be deleted. long-unsigned</p> <p>data ::= long-unsigned</p>				

5.11 Activity calendar (class_id: 20)

An instance of the “Activity calendar” class is typically used to handle different tariff structures. It is a definition of scheduled actions inside the meter, which follow the classical way of calendar based schedules by defining seasons, weeks... It can coexist with the more general object “Schedule” and can even overlap with it. If actions are scheduled for the same activation time in an object “Schedule” and in the object “Activity calendar”, the actions triggered by the “Schedule” object are executed first.

After a power failure, only the “last action” missed from the object “Activity calendar” is executed (delayed). This is to ensure proper tariffication after power up. If a “Schedule” object is present, then the missed “last action” of the “Activity calendar” must be executed at the correct time within the sequence of actions requested by the “Schedule” object.

The “Activity calendar” defines the activation of certain scripts, which can perform different activities inside the logical device. The interface to the object “Script table” is the same as for the object “Schedule” (see 5.9).

If an instance of the interface class “Special days table” (see 5.10) is available, relevant entries there take precedence over the “Activity calendar” object driven selection of a day profile. The day profile referenced in the “Special days table” activates the day_schedule of the day_profile_table in the “Activity calendar” object by referencing through the day_id.

Activity calendar	0...1	class_id = 20, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. calendar_name_active (static)	octet-string			
3. season_profile_active (static)	array			
4. week_profile_table_active (static)	array			
5. day_profile_table_active (static)	array			
6. calendar_name_passive (static)	octet-string			
7. season_profile_passive (static)	array			
8. week_profile_table_passive (static)	array			
9. day_profile_table_passive (static)	array			
10. activate_passive_calendar_time (static)	octet-string			
Specific method(s)	m/o			
1. activate_passive_calendar (data)	o			

Attribute description

Attributes called ..._active are currently active, attributes called ..._passive will be activated by the specific method activate_passive_calendar.

logical_name	Identifies the “Activity calendar” object instance. See D.2.1.8.
calendar_name	Typically contains an identifier, which is descriptive to the set of scripts, which are activated by the object.
season_profile	Contains a list of seasons defined by their starting date and a specific week_profile to be executed. The list is sorted according to season_start.
array	season
season ::=	structure { season_profile_name: octet-string, season_start: octet-string, week_name: octet-string } where: - season_profile_name is a user defined name identifying the current seson_profile; - season_start defines the starting time of the season, formatted as set in 4.4.1 for <i>date_time</i> . REMARK The current season is terminated by the season_start of the next season. - week_name defines the week_profile active in this season

week_profile_table	Contains an array of week_profiles to be used in the different seasons. For each week_profile, the day_profile for every day of a week is identified.
array	week_profile
week_profile ::=	<pre> structure { week_profile_name: octet-string, monday: day_id, tuesday: day_id, wednesday: day_id, thursday: day_id, friday: day_id, saturday: day_id, sunday: day_id } day_id: unsigned </pre> <p>where:</p> <ul style="list-style-type: none"> - week_profile_name is a user defined name identifying the current week_profile; - Monday defines the day_profile valid on Monday; - ... - Sunday defines the day_profile valid on Sunday.
day_profile_table	Contains an array of day_profiles, identified by their day_id. For each day_profile, a list of scheduled actions is defined by a script to be executed and the corresponding activation time (start_time). The list is sorted according to start_time.
array	day_profile
day_profile ::=	<pre> structure { day_id: unsigned, day_schedule: array day_profile_action } </pre> <p>day_profile_action ::= structure</p> <pre> { start_time: octet-string, script_logical_name: octet-string, script_selector: long-unsigned } </pre> <p>where:</p> <ul style="list-style-type: none"> - day_id is a user defined identifier, identifying the current day_profile; - start_time: defines the time when the script is to be executed (no wildcards); the format follows the rules set in 4.4.1 for <i>time</i>; - script_logical_name: defines the logical name of the "Script table" object; - script_selector: defines the script_identifier of the script to be executed.

activate_passive_calendar_time Defines the time when the object itself calls the specific method activate_passive_calendar. A definition with "not specified" notation in all fields of the attribute will deactivate this automatism. Partial "not specified" notation in just some fields of date and time are not allowed.

octet-string, formatted as set in 4.4.1 for *date_time*

Method description

activate_passive_calendar(data) This method copies all attributes called ..._passive to the corresponding attributes called ..._active,

data ::= integer(0)

5.12 Association LN (class_id: 15)

COSEM logical devices able to establish application associations within a COSEM context using logical name referencing, model the associations through instances of the "Association LN" class. A COSEM logical device has one instance of this IC for each association the device is able to support.

Association LN		0...MaxNbofAss.		class_id = 15, version = 0	
Attribute(s)		Data type		Min.	Max. Def.
1. logical_name	(static)	octet-string			
2. object_list	(static)	object_list_type			
3. associated_partners_id		associated_partners_type			
4. application_context_name		application-context-name			
5. xDLMS_context_info		xDLMS-context-type			
6. authentication_mechanism_name		mechanism-name			
7. LLS_secret		octet-string			
8. association_status		enum			
Specific method(s)		m/o			
1. reply_to_HLS_authentication (data)		o			
2. change_HLS_secret (data)		o			
3. add_object (data)		o			
4. remove_object (data)		o			

Attribute description

logical_name	Identifies the “Association LN” object instance. See D.2.1.22.
object_list	<p>Contains the list of visible COSEM objects with their class_id, version, logical name and the access rights to their attributes and methods within the given application association.</p> <pre> object_list_type ::= array object_list_element object_list_element ::= structure { class_id: long-unsigned, version: unsigned, logical_name: octet-string, access_rights: access_right } access_right ::= structure { attribute_access: attribute_access_descriptor, method_access: method_access_descriptor } attribute_access_descriptor ::= array attribute_access_item attribute_access_item ::= structure { attribute_id: integer, access_mode: enum { no_access (0), read_only (1), write_only (2), read_and_write (3) }, access_selectors ::= CHOICE { null-data, array of integer8 } } method_access_descriptor ::= array method_access_item method_access_item ::= structure { method_id: integer, access_mode: boolean } where: - the attribute_access_descriptor and the method_access_descriptor always contain all implemented attributes or methods; - access_selectors contain a list of the supported selector values. selective access (see 4.2) to the attribute object_list may be available (optional). The selective access parameters are as defined below. </pre>

associated_partners_id Contains the identifiers of the COSEM client and the COSEM server (logical device) application processes within the physical devices hosting these processes, which belong to the application association modelled by the “Association LN” object.

```
associated_partners_type ::= structure
{
    client_SAP:          integer,
    server_SAP:         long-unsigned:
}
```

The range for the client_SAP is 0...0x7F.

The range for the server_SAP is 0x000...0x3FFF.

application_context_name In the COSEM environment, it is intended that an application context pre-exists and is referenced by its name during the establishment of an application association. This attribute contains the name of the application context for that association.

The application context name is specified as OBJECT IDENTIFIER in 7.3.7.1 of IEC 62056-53.

The application_context_name attribute includes the arc labels of the OBJECT IDENTIFIER.

```
application_context_name ::= structure
{
    joint-iso-ctt-element:      unsigned,
    country-element:            unsigned,
    country-name-element:       long-unsigned,
    identified-organization-element: unsigned,
    DLMS-UA-element:            unsigned,
    application-context-element: unsigned,
    context-id-element:         unsigned
}
```

For existing implementations, the attribute may hold the value of the OBJECT IDENTIFIER encoded in BER, as an octet string. See Clause C.2 of IEC 62056-53.

```
application_context_name ::= octet-string
// holds the value of the OBJECT identifier encoded in BER
```

Example:

In case of context_id(1) the A-XDR encoding as a structure (all values are hexadecimal):

```
02 07 11 02 11 10 12 02 F4 11 05 11 08 11 01 11 01
```

The A-XDR encoding as an octet-string, holding the value of the OBJECT IDENTIFIER encoded in BER (all values are hexadecimal):

```
09 07 60 85 74 05 08 01 01
```

xDLMS_context_info Contains all the necessary information on the xDLMS context for the given association.

xDLMS-context-type ::= structure
 {

conformance: bitstring(24),
 max_receive_pdu_size: long-unsigned,
 max_send_pdu_size: long-unsigned,
 dlms_version_number: unsigned,
 quality_of_service: integer,
 cyphering_info: octet-string

}
 where

- the conformance element contains the xDLMS conformance block supported by the server;
- the max_receive_pdu_size element contains the maximum length for an xDLMS APDU, expressed in bytes that the client may send. This is the same as the server-max-receive-pdu-size parameter of the DLMS-Initiate.response pdu (see IEC 62056-53);
- the max_send_pdu_size, in an active association contains the maximum length for an xDLMS APDU, expressed in bytes that the server may send. This is the same as the client-max-receive-pdu-size parameter of the DLMS-Initiate.request pdu (see IEC 62056-53);
- the dlms_version_number element contains the DLMS version number supported by the server;
- the quality_of_service element is not used;
- the cyphering_info, in an active association, contains the dedicated key parameter of the DLMS-Initiate.request pdu (See IEC 62056-53).

authentication_mechanism_name Contains the name of the authentication mechanism for the association (see IEC 62056-53).

The authentication mechanism name is specified as an OBJECT IDENTIFIER in 7.3.7.2 of IEC 62056-53.

The authentication_mechanism_name attribute includes the arc labels of the OBJECT IDENTIFIER.

authentication_mechanism_name ::= structure

{
 joint-iso-ctt-element: unsigned,
 country-element: unsigned,
 country-name-element: long-unsigned,
 identified-organization-element: unsigned,
 DLMS-UA-element: unsigned,
 authentication-mechanism-name-element: unsigned,
 mechanism-id-element: unsigned
 }

For existing implementations, the attribute may hold the value of the OBJECT IDENTIFIER encoded in BER, as an octet string. See Clause C.2 of IEC 62056-53.

authentication_mechanism_name ::= octet-string
// holds the value of the OBJECT identifier encoded in BER

Example:

In case of mechanism_id(1) the A-XDR encoding as a structure (all values are hexadecimal):

02 07 11 02 11 10 12 02 F4 11 05 11 08 11 02 11 01

The A-XDR encoding as an octet-string, holding the value of the OBJECT IDENTIFIER encoded in BER (all values are hexadecimal):

09 07 60 85 74 05 08 02 01

LLS_secret	Contains the authentication value for the LLS authentication process.
association_status	Indicates the current status of the association, which is modelled by the object. <pre> association-status: enum { (0) non-associated, (1) association-pending, (2) associated } </pre>

A SET operation on an attribute of an association LN object becomes effective when this association object is used to establish a new association.

Parameters for selective access to the object_list attribute

- If no selective access is requested, (no Access_Selection_Parameters parameter is present in the GET.request (.indication) service invocation for the object_list attribute) the corresponding .response (.confirmation) service shall contain all object_list_elements of the object_list attribute.
- When selective access is requested to the object_list attribute (the Access_Selection_Parameters parameter is present), the response shall contain a 'filtered' list of object_list_elements, as follows:

Access selector value	Service parameters	Comment
1	NULL	All information excluding the access_rights shall be included in the response.
2	class_list	Access by class. In this case, only those object_list_elements of the object_list shall be included in the response, which have a class_id equal to one of the class_id-s of the class-list. No access_right information is included. <pre> class_list ::= array class_id class_id ::= long-unsigned </pre>
3	object_Id_list	Access by object. The full information record of object instances on the object_Id_list shall be returned. <pre> object_Id_list ::= array object_Id </pre>
4	object_Id	The full information record of the required COSEM object instance shall be returned. <pre> object_Id ::= structure { class_id: long-unsigned, logical_name: octet-string } </pre>

Method description

reply_to_HLS_authentication (data)	<p>The remote invocation of this method delivers the client's "secretly" processed "challenge StoC" (f(StoC)) back to the server as the <i>data</i> service parameter of the invoked ACTION.request service. See 4.7.2.</p> <p><i>data</i> ::= octet-string client's response to the challenge</p> <p>If the authentication is accepted, then the response (ACTION.confirm) contains Result == OK and the server's "secretly" processed "challenge CtoS" (f(CtoS)) back to the client in the <i>data</i> service parameter of the response service.</p> <p><i>data</i> ::= octet-string server's response to the challenge</p> <p>If the authentication is not accepted, then the result parameter in the response shall contain a non-OK value, and no data shall be sent back.</p>
change_HLS_secret (data)	<p>Changes the HLS secret (e.g. encryption key).</p> <p><i>data</i> ::= octet-string^a new HLS secret</p>
add_object (data)	<p>Adds the referenced object to the object_list.</p> <p><i>data</i> ::= object_list_element (see above)</p>
remove_object (data)	<p>Removes the referenced object from the object_list.</p> <p><i>data</i> ::= object_list_element (see above)</p>

^a The structure of the "new secret" depends on the security mechanism implemented. The "new secret" may contain additional check bits and it may be encrypted.

5.13 Association SN (class_id: 12)

COSEM logical devices able to establish application associations within a COSEM context using short name references, model the associations through instances of the "Association SN" class. A COSEM logical device may have one instance of this IC for each association the device is able to support.

The **short_name** of the "Association SN object itself is fixed within the COSEM context. It is given in Clause C.3 as 0xFA00.

Association SN		0...n			class_id = 12, version = 1		
Attribute(s)		Data type		Min.	Max.	Def.	
1. logical_name	(static)	octet-string					
2. object_list	(static)	objlist_type					
Specific method(s)		m/o					
1. reserved from previous versions		o					
2. reserved from previous versions		o					
3. read_by_logicalname (data)		o					
4. get_attributes&methods (data)		o					
5. change_LLS_secret (data)		o					
6. change_HLS_secret (data)		o					
7. reserved from previous versions		o					
8. reply_to_HLS_authentication (data)		o					

Attribute description

logical_name	Identifies the “Association SN” object instance. See D.2.1.22.
object_list	<p>Contains the list of all objects with their base_names (short_name), class_id, version and logical_name. The base_name is the DLMS objectName of the first attribute (logical_name).</p> <pre> objlist_type ::= array objlist_element objlist_element ::= structure { base_name: long, class_id: long-unsigned, version: unsigned, logical_name: octet-string } </pre> <p>selective access (see 4.2) to the attribute object_list may be available (optional). The selective access parameters are as defined below.</p>

Parameters for selective access to the object_list attribute

Access selector value	Parameter	Comment
1	class_id: long-unsigned	Delivers the subset of the object_list for a specific class_id. For the response: data ::= objlist_type
2	<pre> structure { class_id: long-unsigned, logical_name: octet-string } </pre>	Delivers the entry of the object_list for a specific class_id and logical_name. For the response: data ::= objlist_element

Method description

read_by_logicalname (data)	<p>Reads attributes for selected objects. The objects are specified by their class_id and their logical_name.</p> <pre> data ::= array attribute_identification attribute_identification ::= structure { class_id: long-unsigned, logical_name: octet-string, attribute_index: integer } </pre> <p>where attribute_index is a pointer (i.e. offset) to the attribute within the object.</p> <p>attribute_index 0 delivers all attributes^a, attribute_index 1 delivers the first attribute (i.e. logical_name), etc.).</p> <p>For the response: data is according to the type of the attribute.</p>
-----------------------------------	---

**get_attributes&
methods(data)**

Delivers information about the access rights to the attributes and methods within the actual association. The objects are specified by their class_id and their logical_name.

data ::= array object_identification

```
object_identification ::= structure
{
    class_id: long-unsigned,
    logical_name: octet-string
}
```

For the response

data ::= array access_description

access_description ::= structure

```
{
    read_attributes: bit-string,
    write_attributes: bit-string,
    methods: bit-string
}
```

The position in the bit-string identifies the attribute/method (first position ↔ first attribute, first position ↔ first method) and the value of the bit specifies whether the attribute/method is available (bit set) or not available (bit clear).

NOTE Depending on the implementation, some attributes or methods of some objects may not be needed. In this case, such attributes or methods may not be accessible (neither read access, nor write access to attributes, no access to methods).

**change_LLS_secret
(data)**

Changes the LLS secret (e.g. password).

data ::= octet-string new LLS secret

**change_HLS_secret
(data)**

Changes the HLS secret (e.g. encryption key).

data ::= octet-string^b new HLS secret

**reply_to_HLS_
authentication
(data)**

The remote invocation of this method delivers the client's "secretly" processed "challenge StoC" (f(StoC)) back to the server as the *data* service parameter of the invoked Write.request service (see 4.7.2).

data ::= octet-string client's response to the challenge

If the authentication is accepted, then the response (Write.confirm) contains Result == OK and the server's "secretly" processed "challenge CtoS" (f(CtoS)) back to the client in the *data* service parameter of the response service.

data ::= octet-string server's response to the challenge

If the authentication is not accepted, then the result parameter in the response shall contain a non-OK value, and no data shall be sent back.

^a If at least one attribute has no read access right under the current association, then a read_by_logicalname() to attribute index 0 reveals the error message "scope of access violation" (see IEC 61334-4-41, p. 221).

^b The structure of the "new secret" depends on the security mechanism implemented. The "new secret" may contain additional check bits and it may be encrypted.

5.14 SAP assignment (class_id: 17)

The interface class “SAP assignment” contains the information on the assignment of the logical devices to their SAP-s (see IEC 62056-53).

SAP assignment	0...1	class_id = 17, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. SAP_assignment_list (static)	asslist_type			0
Specific method(s)	m/o			
1. connect_logical_device (data)	o			

Attribute description

logical_name	Identifies the “SAP assignment” objects instance. See D.2.1.23.
SAP_assignment_list	<p>Contains the list of all logical devices and their SAP addresses within the physical device.</p> <pre> asslist_type ::= array asslist_element asslist_element ::= structure { SAP: logical_device_name: long-unsigned, octet-string } </pre> <p>REMARKS</p> <ul style="list-style-type: none"> - The actual addressing is performed by the supporting communication layers. - For the 3-layer, connection-oriented, HDLC based profile, see IEC 62056-46 and IEC 62056-53, Clause B.2. - For the TCP-UDP/IP based profile, see IEC 62056-47 and IEC 62056-53, Clause B.3.

Method description

connect_logical_device (data)	<p>Connects a logical device to a SAP. Connecting to SAP 0 will disconnect the device. More than one device cannot be connected to one SAP (exception SAP 0)</p> <p>data ::= asslist_element</p>
--------------------------------------	--

5.15 Register monitor (class_id: 21)

This interface class allows defining a set of scripts (see 5.8) that are executed when the value of an attribute of a monitored register type object “Data”, “Register”, “Extended register”, Demand register, etc. crosses a set of threshold values.

The IC “Register monitor” requires an instantiation of the IC “Script table” in the same logical device.

Register monitor	0...n	class_id = 21, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. thresholds (static)	array			
3. monitored_value (static)	value_definition			
4. actions (static)	array			
Specific method(s)	m/o			

Attribute description

logical_name	Identifies the “Register monitor” object instance. See D.2.1.11 and D.2.2.20.
thresholds	<p>Provides the threshold values to which the attribute of the referenced register is compared.</p> <pre> array threshold threshold: The threshold is of the same type as the monitored attribute of the referenced object. </pre>
monitored_value	<p>Defines which attribute of an object is to be monitored. Only values with simple data types are allowed.</p> <pre> value_definition ::= structure { class_id: long-unsigned, logical_name: octet-string, attribute_index: integer } </pre>
actions	<p>Defines the scripts to be executed when the monitored attribute of the referenced object crosses the corresponding threshold. The attribute “actions” has exactly the same number of elements as the attribute “thresholds”. The ordering of the action_items corresponds to the ordering of the thresholds (see above).</p> <pre> array action_set action_set ::= structure { action_up: action_item, action_down: action_item } where: - action_up defines the action when the attribute value of the monitored register crosses the threshold in the upwards direction; - action_down defines the action when the attribute value of the monitored register crosses the threshold in the downwards direction action_item ::= structure { script_logical_name: octet-string, script_selector: long-unsigned } </pre>

5.16 Utility tables (class_id: 26)

An instance of the “Utility tables” class encapsulates ANSI C12.19 table data.

With this interface class definition, each “table” is represented as an instance. The specific instance is identified by its logical name.

Utility tables	0...n	class_id = 26, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. table_ID (static)	long-unsigned			
3. length	double-long-unsigned			
4. buffer	octet-string			
Specific method(s)	m/o			

Attribute description

logical_name	Identifies the “Utility tables” object instance. See D.2.1.25.
table_ID	Table number. This table number is as specified in the ANSI standard and may be either a standard table or a manufacturer’s table.
length	Number of octets in table buffer.
buffer	Contents of table. Selective access (see 4.2) to the attribute buffer may be available (optional). The selective access parameters are as defined below.

Parameters for selective access to the buffer attribute

Access selector	Parameter	Comment
1	offset_access	Access to table by offset and count using offset_selector for parameter data.
2	index_access	Access to table by element id and number of elements using index_selector for parameter data.

offset_selector ::= structure

Offset	double-long-unsigned	offset in octets to the start of access area, relative to the start of the table
Count	long-unsigned	number of octets requested or transferred

index_selector ::= structure

Index	array of long-unsigned	sequence of indices to identify elements within the table’s hierarchy
Count	long-unsigned	number of elements requested or transferred. Values of count greater than 1 return up to that many elements. A value of zero, when given in the context of a request, refers to the entire sub-tree of the hierarchy starting at the selection point

}

5.17 Single action schedule (class_id: 22)

Many applications request periodic actions within a meter. These actions are not necessarily linked to tariffication (activity calendar or schedule). The IC “Single action schedule “ models such actions.

Single action schedule	0...n	class_id = 22, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. executed_script (static)	script			
3. type (static)	enum			
4. execution_time (static)	array			
Specific method(s)	m/o			

Attribute description

logical_name	Identifies the “Single action schedule” object instance. See D.2.1.10.			
executed_script	<p>Contains the logical name of the “Script table” object and the script selector of the script to be executed.</p> <pre> script structure { script_logical_name octet-string, script_selector long-unsigned } Script_logical_name and script_selector define the script to be executed.</pre>			
type	<p>enum</p> <ul style="list-style-type: none"> (1) size of execution_time = 1; wildcard in <i>date</i> allowed, (2) size of execution_time = <i>n</i>; all <i>time</i> values are the same, wildcards in <i>date</i> not allowed, (3) size of execution_time = <i>n</i>; all <i>time</i> values are the same, wildcards in <i>date</i> are allowed, (4) size of execution_time = <i>n</i>; <i>time</i> values may be different, wildcards in <i>date</i> not allowed, (5) size of execution_time = <i>n</i>; <i>time</i> values may be different, wildcards in <i>date</i> are allowed 			
execution_time	<p>Specifies the time of day the script is executed.</p> <pre> array {octet-string, octet-string} The two octet-strings contain <i>time</i> and <i>date</i>, in this order. structure { time: octet-string, date: octet-string } <i>time</i> and <i>date</i> are formatted as defined in 4.4.1. WILDCARDS in “<i>time</i>” are not allowed; seconds and hundredths of seconds must be zero.</pre>			

5.18 Register table (class_id: 61)

Instances of the “Register table” interface class store homogenous entries, identical attributes of multiple objects, which are all instances of the same interface class, and the value in value groups A to D and F of their logical name (OBIS code) is identical. The possible values in value group E are defined in IEC 62056-61 in a tabular form: the table header defines the common part of the OBIS code and each table cell defines one possible value of value group E. A “Register table” object may capture attributes of some or all of those objects.

NOTE 1 Some examples are the “UNIPED voltage dip quantities” table, see IEC 62056-61, Table 13, or the “Extended phase angle measurement” table, see IEC 62056-61, Table 11.

NOTE 2 If more complex functionality is needed, the “Profile generic” interface class can be used.

Register table	0...n	class_id = 61, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. table_cell_values (dyn.)	array			
3. table_cell_definition (static)	structure			
4. scaler_unit (static)	scaler_unit_type			
Specific method(s)	m/o			
1. reset (data)	o			
2. capture (data)	o			

Attribute description

logical_name	<p>Identifies the “Register table” object instance.</p> <p>When the format of the logical name is A.B.C.D.255.F; the values A to D and F define the common part of the logical name of the objects, the attributes of which are captured. Only one attribute of the objects concerned can be captured (for example the <i>value</i> attribute).</p> <p>When the format of the logical name is A.B.98.10.x.255, several instances of the “Register table” class can be used to capture different attributes of the objects concerned. The value group E numbers the instances.</p>
table_cell_values	<p>Holds the value of the attributes captured, as they would be returned to a GET or Read .request to the individual attributes.</p> <p>table_cell_values ::= compact array or array of table_cell_entry</p> <p>table_cell_entry</p> <p>CHOICE</p> <p>{</p> <p>--simple data types</p> <p>null-data [0],</p> <p>bit-string [4],</p> <p>double-long [5],</p> <p>double-long-unsigned [6],</p> <p>octet-string [9],</p> <p>visible-string [10],</p> <p>bcd [13],</p> <p>integer [15],</p> <p>long [16],</p> <p>unsigned [17],</p> <p>long-unsigned [18],</p> <p>long64 [20],</p> <p>long64-unsigned [21],</p> <p>float32 [23],</p>

```

float64          [24],
--complex data types
structure        [2]
}

```

If the captured attribute is attribute_0, redundant values may be replaced by “null_data”, if their value can be unambiguously recovered (for example scaler_unit).

table_cell_definition	<p>Specifies the list of attributes captured in the register table.</p> <pre> table_cell_definition ::= structure { class_id: long-unsigned, logical_name: octet_string, group_E_values: array of cell_identifier, { cell_identifier: unsigned } attribute_index integer } </pre> <p>where:</p> <ul style="list-style-type: none"> - class_id defines the common class_id of the objects the attributes of which are captured; - logical_name contains the common logical name of the objects, with E = 255 (wildcard); - group_E_values contain the list of cell identifiers, as defined in the respective table of IEC 62056-61; - attribute_index is a pointer to the attribute within the object. attribute_index 0 refers to all public attributes. <p>If the logical name of the “Register table” object is in the format A.B.C.D.255.F and the defined attribute of all objects identified in the respective table in IEC 62056-61 are captured, then attribute 3 may not be accessible. In this case:</p> <ul style="list-style-type: none"> - the class_id shall be 1 “Data”, 3 “Register” or 4 “Extended register”; - the logical name of the objects to be captured is defined by the logical name of the “Register table” object and the respective table in IEC 62056-61; - the attribute index shall be 2 (value).
scaler_unit	<p>See the description of class “Register”.</p> <p>In the case when “value” attributes of “Register” or “Extended register” objects are captured, the scaler_unit shall be common for all objects and this attribute shall hold a copy.</p> <p>If other attributes or interface classes are captured, the scaler_unit attribute has no meaning and shall be inaccessible.</p>
Method description	
reset (data)	<p>Clears the table_cell_values. It has no effect on the attributes captured.</p> <p>data ::= integer(0)</p>
capture (data)	<p>Copies the values of the attributes into the table_cell_values. If the attribute_index = 0, all attributes are captured.</p>

Behaviour of the object after modification of the table_cell_definition attribute

Any modification to this attribute will automatically call the reset(data) method and this will propagate to all other profiles capturing this object.

If writing to table_cell_definition is attempted with a value too large the buffer holding the table_cell_values attribute, it will be rejected.

5.19 Status mapping (class_id: 63)

Instances of the “Status mapping” class store status words together with the mapping of each bit in the status word to positions in a reference status table.

Status mapping		0...n		class_id = 63, version = 0	
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. status word	(dynamic)	CHOICE			
3. mapping_table	(static)	structure			
Specific method(s)		m/o			

Attribute description

logical_name	Identifies the “Status word” object instances. See D.2.1.29, D.2.1.30, D.2.1.34 and D.2.2.17.
status_word	<p>Contains the current value of the status word.</p> <p>CHOICE</p> <pre>{ [4] bit-string, [6] double-long-unsigned, [9] octet-string, [10] visible-string, [17] unsigned, [18] long-unsigned, [21] long64-unsigned }</pre> <p>The size of the status_word is n*8 bits, the maximum size is 65 536 bits.</p> <p>NOTE Manufacturers may choose any of the types listed above. However, the status word shall be always interpreted as a bit-string.</p>

mapping_table Contains the mapping of the status word to the positions in the reference table.

```

mapping_table ::= structure
{
    ref_table_id:  unsigned,
    CHOICE
    {
        first_entry    long-unsigned,
        array of table_entries
    }
}

```

table_entry long-unsigned

where:

- ref_table_id is the identifier of the reference status table

NOTE Reference status tables are maintained by the DLMS UA.

- first_entry is the entry in the reference table corresponding to bit 0 of the status word. Bit 1 corresponds to the next entry and so on, the last entry is defined by the length of the status word;
 - if the “array” choice is taken, the array of table entries maps the bits of the status word to the entries in the reference status table. The position in the array defines the position in the status word (the first position corresponds to bit 0).
-

6 Maintenance of the interface classes

Any modification of interface classes as described below in 6.2 will be recorded by moving the old or obsolete version of an interface class into Annex E.

Versions of interface classes prior to the establishment of this standard are kept by the DLMS UA only.

6.1 New interface classes

The DLMS UA reserves the right to be the exclusive administrator of interface classes.

6.2 New versions of interface classes

Any modification of an existing interface class affecting the transmission of service requests or responses results in a new version (version ::= version+1) and shall be documented accordingly. The following rules shall be followed:

- a) new attributes and methods may be added;
- b) existing attributes and methods may be invalidated BUT the indices of the invalidated attributes and methods shall not be re-used by other attributes and methods;
- c) if these rules cannot be met, then a new interface class shall be created;
- d) new versions of COSEM interface classes are administered by the DLMS UA.

6.3 Removal of interface classes

Besides one association object and the logical device name object no instantiation of an interface class is mandatory within a meter. Therefore, even unused interface classes will not be removed from the standard. They will be kept to ensure compatibility with possibly existing implementations.

Annex A (normative)

Protocol related interface classes

A.1 General

Each communication device and/or communication profile needs some setup parameters to be defined for proper operation.

A.2 IEC local port setup (class_id: 19)

Instances of this interface class define the operational parameters for communication using IEC 62056-21. Several ports can be configured.

IEC local port setup	0...n	class_id = 19, version = 1		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. default_mode (static)	enum			
3. default_baud (static)	enum			
4. prop_baud (static)	enum			
5. response_time (static)	enum			
6. device_addr (static)	octet-string			
7. pass_p1 (static)	octet-string			
8. pass_p2 (static)	octet-string			
9. pass_w5 (static)	octet-string			
Specific method(s)	m/o			

Attribute description

logical_name	Identifies the “IEC local port setup” object instance. See D.2.1.12.		
default_mode	Defines the protocol used by the meter on the port.		
	enum	(0)	protocol according to IEC 62056-21 (modes A...E),
		(1)	protocol according to IEC 62056-46. Using this enumeration value all other attributes of this class are not applicable,
		(2)	protocol not specified. Using this enumeration value, attribute 4), prop_baud is used for setting the communication speed on the port. All other attributes are not applicable.
default_baud	Defines the baud rate for the opening sequence.		
	enum	(0)	300 baud,
		(1)	600 baud,
		(2)	1 200 baud,
		(3)	2 400 baud,
		(4)	4 800 baud,
		(5)	9 600 baud,
		(6)	19 200 baud,
		(7)	38 400 baud,
		(8)	57 600 baud,
		(9)	115 200 baud

prop_baud	Defines the baud rate to be proposed by the meter.				
	enum	(0)	300 baud,		
		(1)	600 baud,		
		(2)	1 200 baud,		
		(3)	2 400 baud,		
		(4)	4 800 baud,		
		(5)	9 600 baud,		
		(6)	19 200 baud,		
		(7)	38 400 baud,		
		(8)	57 600 baud,		
		(9)	115 200 baud		
response_time	Defines the minimum time between the reception of a request (end of request telegram) and the transmission of the response (begin of response telegram).				
	enum	(0)	20 ms,		
		(1)	200 ms		
device_addr	Device address according to IEC 62056-21.				
	octet-string				
pass_p1	Password 1 according to IEC 62056-21.				
	octet-string				
pass_p2	Password 2 according to IEC 62056-21.				
	octet-string				
pass_w5	Password W5 reserved for national applications.				
	octet-string				

A.3 Modem configuration (class_id: 27)

NOTE The name of this interface class has been changed from “PSTN modem configuration” to “Modem configuration”, as it can be used not only for configuring PSTN modems, but modems of other networks, for example GSM. Otherwise, the definition remains unchanged.

An instance of the “Modem configuration” class stores data related to the initialization of modems, which are used for data transfer from/to a device. Several modems can be configured.

Modem configuration		0...n	class_id = 27, version = 1		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. comm_speed	(static)	enum	0	9	5
3. initialization_string	(static)	array			
4. modem_profile	(static)	array			
Specific method(s)		m/o			

Attribute description

logical_name	Identifies the “Modem configuration” object instance. See D.2.1.2.																				
comm_speed	<p>The communication speed between the device and the modem, not necessarily the communication speed on the WAN.</p> <p>enum:</p> <table> <tr><td>(0)</td><td>300 baud,</td></tr> <tr><td>(1)</td><td>600 baud,</td></tr> <tr><td>(2)</td><td>1 200 baud,</td></tr> <tr><td>(3)</td><td>2 400 baud,</td></tr> <tr><td>(4)</td><td>4 800 baud,</td></tr> <tr><td>(5)</td><td>9 600 baud,</td></tr> <tr><td>(6)</td><td>19 200 baud,</td></tr> <tr><td>(7)</td><td>38 400 baud,</td></tr> <tr><td>(8)</td><td>57 600 baud</td></tr> <tr><td>(9)</td><td>115 200 baud</td></tr> </table>	(0)	300 baud,	(1)	600 baud,	(2)	1 200 baud,	(3)	2 400 baud,	(4)	4 800 baud,	(5)	9 600 baud,	(6)	19 200 baud,	(7)	38 400 baud,	(8)	57 600 baud	(9)	115 200 baud
(0)	300 baud,																				
(1)	600 baud,																				
(2)	1 200 baud,																				
(3)	2 400 baud,																				
(4)	4 800 baud,																				
(5)	9 600 baud,																				
(6)	19 200 baud,																				
(7)	38 400 baud,																				
(8)	57 600 baud																				
(9)	115 200 baud																				
initialization_string	<p>Contains all the necessary initialization commands to be sent to the modem in order to configure it properly. This may include the configuration of special modem features.</p> <p>initialization_string ::= array initialization_string_element ::= structure { request: octet-string, response: octet-string, delay_after_response: long-unsigned }</p> <p>If the array contains more than one initialization_string_element, the requests are sent in a sequence. The next request is sent after the expected response matching the previous request and waiting a delay_after_response time [ms], to allow the modem to execute the request.</p> <p>REMARK: It is assumed that the modem is pre-configured so that it accepts the initialization_string. If no initialization is needed, the initialization string is empty.</p>																				
modem_profile	<p>Defines the mapping from Hayes standard commands/responses to modem specific strings.</p> <p>modem_profile ::= array { modem_profile_element: octet-string }</p> <p>The modem_profile array must contain the corresponding strings for the modem used in the following order :</p> <table> <tr><td>Element 0:</td><td>OK,</td></tr> <tr><td>Element 1:</td><td>CONNECT,</td></tr> <tr><td>Element 2:</td><td>RING,</td></tr> <tr><td>Element 3:</td><td>NO CARRIER,</td></tr> <tr><td>Element 4:</td><td>ERROR,</td></tr> <tr><td>Element 5:</td><td>CONNECT 1 200,</td></tr> <tr><td>Element 6:</td><td>NO DIAL TONE,</td></tr> <tr><td>Element 7:</td><td>BUSY,</td></tr> <tr><td>Element 8:</td><td>NO ANSWER,</td></tr> <tr><td>Element 9:</td><td>CONNECT 600,</td></tr> </table>	Element 0:	OK,	Element 1:	CONNECT,	Element 2:	RING,	Element 3:	NO CARRIER,	Element 4:	ERROR,	Element 5:	CONNECT 1 200,	Element 6:	NO DIAL TONE,	Element 7:	BUSY,	Element 8:	NO ANSWER,	Element 9:	CONNECT 600,
Element 0:	OK,																				
Element 1:	CONNECT,																				
Element 2:	RING,																				
Element 3:	NO CARRIER,																				
Element 4:	ERROR,																				
Element 5:	CONNECT 1 200,																				
Element 6:	NO DIAL TONE,																				
Element 7:	BUSY,																				
Element 8:	NO ANSWER,																				
Element 9:	CONNECT 600,																				

Element 10: CONNECT 2 400,
 Element 11: CONNECT 4 800,
 Element 12: CONNECT 9 600,
 Element 13: CONNECT 14 400,
 Element 14: CONNECT 28 800,
 Element 15: CONNECT 36 600,
 Element 16: CONNECT 56 000

A.4 Auto answer (class_id: 28)

NOTE The name of this interface class has been changed from “PSTN auto answer ” to “Auto answer”, as it can be used not only for PSTN networks, but also for other networks, for example GSM. Otherwise, the definition remains unchanged.

An instance of the “Auto answer” class stores data related to the management of data transfer between a device and a modem, which is used to answer incoming calls. Several modems can be configured.

Auto answer		0...n	class_id = 28, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. mode	(static)	enum			
3. listening_window	(static)	array			
4. status	(dyn.)	enum			
5. number_of_calls	(static)	unsigned			
6. number_of_rings	(static)	nr_rings_type			
Specific method(s)		m/o			

Attribute description

logical_name	Identifies the “Auto answer” object instance. See D.2.1.4.
mode	<p>Defines the working mode of the line when the device is auto answer.</p> <p>mode ::= enum</p> <p>(0) line dedicated to the device,</p> <p>(1) shared line management with a limited number of calls allowed. Once the number of calls is reached, the window status becomes inactive until the next start date, whatever the result of the call,</p> <p>(2) shared line management with a limited number of successful calls allowed. Once the number of successful communications is reached, the window status becomes inactive until the next start date,</p> <p>(3) currently no modem connected,</p> <p>(200...255) manufacturer specific modes</p>

listening_window	<p>Contains the start and end instant when the window becomes active (for the start instant), and inactive (for the end instant). The start_date defines implicitly the period.</p> <p>Example: when the day of month is not specified (equal to 0xFF) this means that we have a daily share line management. Daily, monthly ...window management can be defined.</p> <pre>listening_window ::= array window_element window_element ::= structure { start_time: octet-string, end_time: octet-string } start_time and end_time are formatted as set in 4.4.1 for <i>date_time</i></pre>
status	<p>Here is defined the status of the window.</p> <pre>status ::= enum (0) Inactive: the device will manage no new incoming call. This status is automatically reset to Active when the next listening window starts. (1) Active: the device can answer to the next incoming call. (2) Locked: This value can be set automatically by the device or by a specific client when this client has completed its reading session and wants to give the line back to the customer before the end of the window duration. This status is automatically reset to Active when the next listening window starts.</pre>
number_of_calls	<p>This number is the reference used in modes 1 and 2. When set to 0, this means there is no limit.</p>
number_of_rings	<p>Defines the number of rings before the meter connects the modem. Two cases are distinguished: number of rings within the window defined by attribute "listening_window" and number of rings outside the "listening_window".</p> <pre>nr_rings_type := structure { nr_rings_in_window: unsigned, (0: no connect in window) nr_rings_out_of_window: unsigned (0: no connect out of window) }</pre>

A.5 Auto connect (class_id: 29)

NOTE The name of this interface class has been changed from "PSTN auto dial" to "Auto connect", as its use has been generalized; it is not only suitable for the configuration of sending messages – generally protocol telegrams – via PSTN modems, but also sending messages of various types over various communication infrastructures.

An instance of the "Auto connect" class controls and stores data related to the management of the data transfer from the metering device to one or several destinations.

The messages to be sent, the conditions on which they shall be sent and the relation between the various modes, the calling windows and destinations are not defined here.

Depending on the mode, one or more instances of this interface class may be necessary to perform the function of sending out messages.

Auto connect		0...n	class_id = 29, version = 1		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. mode	(static)	enum			
3. repetitions	(static)	unsigned			
4. repetition_delay	(static)	long-unsigned			
5. calling_window	(static)	array			
6. destination_list	(static)	array			
Specific method(s)		m/o			

Attribute description

logical_name	Identifies the “Auto connect” object instance. See D.2.1.3.																
mode	<p>Defines the mode controlling the auto dial functionality concerning the timing, the message type to be sent and the infrastructure to be used.</p> <p>mode ::= enum</p> <table> <tr> <td>(0)</td><td>no auto dialling,</td></tr> <tr> <td>(1)</td><td>auto dialling allowed anytime,</td></tr> <tr> <td>(2)</td><td>auto dialling allowed within the validity time of the calling window, “regular”</td></tr> <tr> <td>(3)</td><td>auto dialling allowed within the validity time of the calling window; “alarm” initiated auto dialling allowed anytime,</td></tr> <tr> <td>(4)</td><td>SMS sending via Public Land Mobile Network (PLMN),</td></tr> <tr> <td>(5)</td><td>SMS sending via PSTN,</td></tr> <tr> <td>(6)</td><td>email sending,</td></tr> <tr> <td>(200..255)</td><td>manufacturer specific modes</td></tr> </table>	(0)	no auto dialling,	(1)	auto dialling allowed anytime,	(2)	auto dialling allowed within the validity time of the calling window, “regular”	(3)	auto dialling allowed within the validity time of the calling window; “alarm” initiated auto dialling allowed anytime,	(4)	SMS sending via Public Land Mobile Network (PLMN),	(5)	SMS sending via PSTN,	(6)	email sending,	(200..255)	manufacturer specific modes
(0)	no auto dialling,																
(1)	auto dialling allowed anytime,																
(2)	auto dialling allowed within the validity time of the calling window, “regular”																
(3)	auto dialling allowed within the validity time of the calling window; “alarm” initiated auto dialling allowed anytime,																
(4)	SMS sending via Public Land Mobile Network (PLMN),																
(5)	SMS sending via PSTN,																
(6)	email sending,																
(200..255)	manufacturer specific modes																
repetitions	The maximum number of trials in case of unsuccessful dialling attempts.																
repetition_delay	<p>The time delay, expressed in seconds until an unsuccessful dial attempt can be repeated.</p> <p>repetition_delay 0 means delay is not specified</p>																
calling_window	<p>Contains the start and end date/time stamp when the window becomes active (for the start instant), or inactive (for the end instant). The start_date defines implicitly the period.</p> <p>Example: when day of month is not specified (equal to 0 x FF) this means that we have a daily share line management. Daily, monthly ...window management can be defined.</p> <p>calling_window ::= array window_element window_element ::= structure { start_time: octet-string, end_time: octet-string } start_time and end_time are formatted as set in 4.4.1 for <i>date_time</i></p>																

destination_list	Contains the list of destinations (e.g. phone numbers, email addresses or their combinations) where the message(s) has(have) to be sent under certain conditions.
	The conditions and their link to the elements of the array are not defined here.
	<pre> destination_list ::= array destination { destination: octet_string } </pre>

A.6 IEC HDLC setup class (class_id: 23)

An instance of the “HDLC setup class” contains all data necessary to set up a communication channel according to IEC 62056-46. Several communication channels can be configured.

IEC HDLC setup		0...n	class_id = 23, version = 1		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. comm_speed	(static)	enum	0	9	5
3. window_size_transmit	(static)	unsigned	1	7	1
4. window_size_receive	(static)	unsigned	1	7	1
5. max_info_field_length_transmit	(static)	long-unsigned	32	2030	128
6. max_info_field_length_receive	(static)	long-unsigned	32	2030	128
7. inter_octet_time_out	(static)	long-unsigned	20	6000	25
8. inactivity_time_out	(static)	long-unsigned	0		120
9. device_address	(static)	long-unsigned	0x0010	0x3FFD	
Specific method(s)		m/o			

NOTE 1 The maximum value of the attributes max_info_field_length_transmit and max_info_field_length_receive has been increased from 128 to 2030 for efficiency reasons.

NOTE 2 In order to ensure a minimal performance, the primary station should offer at least a max_info_field_length_receive of 128 bytes.

NOTE 3 The maximum value of the inter-octet-time-out attribute has been increased from 1000 ms to 6000 ms in order to allow using communication media, where long delays may occur. The default value has been changed to 25 ms to align with 6.4.4.3.3 of IEC 62056-46.

Attribute description

logical_name	Identifies the “IEC HDLC setup” object instance. See D.2.1.14.
comm_speed	The communication speed supported by the corresponding port enum: (0) 300 baud, (1) 600 baud, (2) 1 200 baud, (3) 2 400 baud, (4) 4 800 baud, (5) 9 600 baud, (6) 19 200 baud, (7) 38 400 baud, (8) 57 600 baud, (9) 115 200 baud

This communication speed can be overridden if the HDLC mode of a device is entered through a special mode of another protocol.

window_size_transmit	The maximum number of frames that a device or system can transmit before it needs to receive an acknowledgement from a corresponding station. During logon, other values can be negotiated.																				
window_size_receive	The maximum number of frames that a device or system can receive before it needs to transmit an acknowledgement to the corresponding station. During logon, other values can be negotiated.																				
max_info_length_transmit	The maximum information field length that a device can transmit. During logon, a smaller value can be negotiated.																				
max_info_length_receive	The maximum information field length that a device can receive. During logon, a smaller value can be negotiated.																				
inter_octet_time_out	Defines the time, expressed in milliseconds, over which, when any character is received from the primary station, the device will treat the already received data as a complete frame.																				
inactivity_time_out	<p>Defines the time, expressed in seconds over which, when any frame is received from the primary station, the device will process a disconnection.</p> <p>When this value is set to 0, this means that the inactivity_time_out is not operational.</p>																				
device_address	<p>Contains the physical device address of a device.</p> <p>In the case of single byte addressing:</p> <table> <tr> <td>0x00</td><td>NO_STATION Address,</td></tr> <tr> <td>0x01...0x0F</td><td>Reserved for future use,</td></tr> <tr> <td>0x10...0x7D</td><td>Usable address space,</td></tr> <tr> <td>0x7E</td><td>'CALLING' device address,</td></tr> <tr> <td>0x7F</td><td>Broadcast address</td></tr> </table> <p>In the case of double byte addressing:</p> <table> <tr> <td>0x0000</td><td>NO_STATION address,</td></tr> <tr> <td>0x0001..0x000F</td><td>Reserved for future use,</td></tr> <tr> <td>0x0010..0x3FFD</td><td>Usable address space,</td></tr> <tr> <td>0x3FFE</td><td>'CALLING' physical device address,</td></tr> <tr> <td>0x3FFF</td><td>Broadcast address</td></tr> </table>	0x00	NO_STATION Address,	0x01...0x0F	Reserved for future use,	0x10...0x7D	Usable address space,	0x7E	'CALLING' device address,	0x7F	Broadcast address	0x0000	NO_STATION address,	0x0001..0x000F	Reserved for future use,	0x0010..0x3FFD	Usable address space,	0x3FFE	'CALLING' physical device address,	0x3FFF	Broadcast address
0x00	NO_STATION Address,																				
0x01...0x0F	Reserved for future use,																				
0x10...0x7D	Usable address space,																				
0x7E	'CALLING' device address,																				
0x7F	Broadcast address																				
0x0000	NO_STATION address,																				
0x0001..0x000F	Reserved for future use,																				
0x0010..0x3FFD	Usable address space,																				
0x3FFE	'CALLING' physical device address,																				
0x3FFF	Broadcast address																				

A.7 IEC twisted pair (1) setup (class_id: 24)

An instance of the "IEC twisted pair (1)" setup class contains all data which are necessary to set up a communication channel according to IEC 62056-31. Several communication channels can be configured.

IEC twisted pair (1) setup		0...n	class_id = 24, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. secondary_address	(static)	octet-string			
3. primary_address_list	(static)	primary_address_list_type			
4. tabi_list	(static)	tabi_list_type			
5. fatal_error	(dynamic)	enum			
Specific method(s)		m/o			

Attribute description

logical_name	Identifies the "IEC twisted pair setup" object instance. See D.2.1.15.
secondary_address	<p>Secondary_address memorizes the ADS of the secondary station (see IEC 62056-31) that corresponds to the real equipment.</p> <p>octet-string (SIZE(6))</p>
primary_address_list	<p>Primary_address_list memorizes the list of ADP or primary station physical addresses for which each logical device of the real equipment (the secondary station) has been programmed (see IEC 62056-31).</p> <pre> primary_adress_list_type ::= array { primary_address_element } primary_address_element ::= octet-string (SIZE(1)) </pre>
tabi_list	<p>tabi_list represents the list of the TAB(i) for which the real equipment (the secondary station) has been programmed in case of forgotten station call (see IEC 62056-31).</p> <p>tabi_list_type ::= array tabi_element</p> <p>tabi_element ::= integer</p>
fatal_error	<p>FatalError represents the last occurrence of one of the fatal errors of the protocols described in IEC 62056-31.</p> <p>The initial default value of this variable is "00"H. Then, each fatal error is spotted.</p> <pre> enum (0) No-error, (1) t-EP-1F, (2) t-EP-2F, (3) t-EL-4F, (4) t-EL-5F, (5) eT-1F, (6) eT-2F, (7) e-EP-3F, (8) e-EP-4F, (9) e-EP-5F, (10) e-EL-2F </pre>

A.8 TCP-UDP setup (class_id: 41)

An instance of the TCP-UDP setup class contains all data necessary to set up the TCP or UDP sub-layer of the COSEM TCP or UDP based transport layer of a TCP-UDP/IP based communication profile.

In TCP-UDP/IP based communication profiles, all application associations between a physical device hosting one or more COSEM client application processes and a physical device hosting one or more COSEM server application processes rely on a single TCP or UDP connection. The TCP or UDP entity is wrapped in the COSEM TCP-UDP based transport layer. Within a physical device, each application process – client application process or server logical device - is bound to a Wrapper Port (WPort). The binding is done with the help of the SAP Assignment object.

On the other hand, a COSEM TCP or UDP based transport layer may be capable to support more than one TCP or UDP connections, between a physical device and several peer physical devices hosting COSEM application processes.

NOTE When a COSEM physical device supports various data link layers (e.g. Ethernet and PPP), then an instance of the TCP-UDP setup object is necessary for each of them.

TCP-UDP setup		0...n	class_id = 41, version = 0		
Attribute(s)		Data type	Min.	Max.	Def
1. logical_name	(static)	octet-string			
2. TCP-UDP_port	(static)	long-unsigned			
3. IP_reference	(static)	octet-string			
4. MSS	(static)	long-unsigned	40	65,535	576
5. nb_of_sim_conn	(static)	unsigned	1		
6. inactivity_time_out		long-unsigned			180
Specific method(s)		m/o			

Attribute description

logical_name	Identifies the TCP-UDP setup object instance. See D.2.1.16.
TCP-UDP_port	Holds the TCP-UDP port number on which the physical device is listening for the DLMS/COSEM application.
IP_reference	References an IP setup object by its logical name. The referenced object contains information about the IP Address settings of the IP layer supporting the TCP-UDP layer.
MSS	<p>With the help of the Maximum Segment Size (MSS) option, a TCP can indicate the maximum receive segment size to its partner. Note, that:</p> <ul style="list-style-type: none"> - this option must only be sent in the initial connection request (i.e. in segments with the SYN control bit sent); - if this option is not present, conventionally MSS is considered as its default value, 576; - MSS is not negotiable; its value is indicated by this attribute.
nb_of_sim_conn	The maximum number of simultaneous connections the COSEM TCP-UDP based transport layer is able to support.

inactivity_time_out Defines the time, expressed in seconds over which, if no frame is received from the COSEM client, the inactive TCP connection shall be aborted.

When this value is set to 0, this means that the inactivity_time_out is not operational. In other words, a TCP connection, once established, in normal conditions – no power failure, etc. - will never be aborted by the COSEM server.

Note, that all actions related to the management of the inactivity time-out function – measuring the inactivity time, aborting the TCP connection if the time-out is over, etc. – are managed inside the TCP-UDP layer implementation.

A.9 IPv4 setup (class_id: 42)

An instance of the IPv4 setup class handles all information that is related to the IP Address settings associated to a given device and to a lower layer connection on which these settings are used.

There shall be an instance of this class in a device for each different network interface implemented. For example, if a device has two serial interfaces (and is using the TCP/IP profile on both of them), there shall be two instances of the IPv4 Setup class in that device: one for each of these interfaces.

IPv4 setup		0...n	class_id = 42, version = 0		
Attribute(s)		Data type	Min.	Max.	Def
1. logical_name	(static)	octet-string			
2. DL_reference	(static)	octet-string			
3. IP_address		double-long-unsigned			
4. multicast_IP_address		array			
5. IP_options		array			
6. subnet_mask		double-long-unsigned			
7. gateway_IP_address		double-long-unsigned			
8. use_DHCP_flag	(static)	boolean			
9. primary_DNS_address		double-long-unsigned			
10. secondary_DNS_address		double-long-unsigned			
Specific method(s)		m/o			
1. add_mc_IP_address (data)		o			
2. delete_mc_IP_address (data)		o			
3. get_nbof_mc_IP_addresses (data)		o			

Attribute description

logical_name	Identifies the IPv4 setup object instance. See D.2.1.17.
DL_reference	References a Data link layer (Ethernet or PPP) setup object by its logical name. The referenced object contains information about the specific settings of the data link layer supporting the IP layer.

IP_address	<p>Carries the value of the IP address (IPv4 address) of this physical device on the network to which the device is connected via the referenced lower layer interface.</p> <p>It can be either (static) or (dynamic). In the latter case, dynamic IP address assignment (e.g. DHCP) is used.</p> <p>If no IP address is assigned, the value is 0.</p>
multicast_IP_address	<p>Contains an array of IP addresses. IP addresses in this array must fall into the multicast group address range ("Class D" addresses, including IP addresses in the range of 224.0.0.0 to 239.255.255.255).</p> <p>When a device receives an IP datagram with one of these IP addresses in the destination IP address field, it shall consider that this datagram is addressed to it.</p> <p>multicast_IP_address ::= array double-long-unsigned</p>
IP_options	<p>Contains the necessary parameters to support the selected IP options, for example Datagram time-stamping or security services (IPSec).</p> <p>IP_options ::= array IP_options_element</p> <p>IP_options_element ::= SEQUENCE { IP-Option-Type unsigned, IP-Option-Length unsigned, IP-Option-Data octet-string }</p> <p>Allowed IP-Option-Types:</p> <ul style="list-style-type: none"> - Security - 0x82 <p>If this option is present, the device shall be allowed to send security, compartmentation, handling restrictions and TCC (closed user group) parameters within its IP Datagrams. The value of the IP-Option-Length Field must be 11, and the IP-Option-Data shall contain the value of the Security, Compartments, Handling Restrictions and Transmission Control Code values, as specified in STD 0005/RFC 791.</p> <ul style="list-style-type: none"> - Loose Source and Record Route - 0x83 <p>If this option is present, the device shall supply routing information to be used by the gateways in forwarding the datagram to the destination, and to record the route information.</p> <p>The IP-Option-length and IP-Option-Data values are specified in STD 0005/RFC 791.</p> <ul style="list-style-type: none"> - Strict Source and Record Route - 0x89 <p>If this option is present, the device shall supply routing information to be used by the gateways in forwarding the datagram to the destination, and to record the route information.</p> <p>The IP-Option-length and IP-Option-Data values are specified in STD 0005/RFC 791.</p>

- Record Route - 0x07

If this option is present, the device shall as well:

- send originated IP Datagrams with that option, providing means to record the route of these Datagrams;
- as a router, send routed IP Datagrams with the route option adjusted according to this option.

The IP-Option-length and IP-Option-Data values are specified in STD 0005/RFC 791.

- Internet Timestamp - 0x44

If this option is present, the device shall as well:

- send originated IP Datagrams with that option, providing means to time-stamp the datagram in the route to its destination;
- as a router, send routed IP Datagrams with the time-stamp option adjusted according to this option.

The IP-Option-length and IP-Option-Data values are specified in STD 0005/RFC 791.

subnet_mask

Contains the subnet mask.

When sub-networking is used in a network segment, each device concerned must behave conforming to the sub-networking rules. In order to do that, the device, besides of its IP address, needs also to know, how the IP address is structured within this sub-networked segment. The subnet_mask attribute carries this information.

With IPv4, the subnet_mask is a 32 bits word, expressed exactly in the same format as an IP Address (e.g. 255.255.255.0), but has another meaning: the '0' bits of the subnet_mask indicate the portion of the IP Address which is still used as Device_ID on a sub-networked IP Network⁴.

gateway_IP_address

Contains the IP Address of the gateway device.

In most IP implementations, there is a code in the module that handles outgoing datagrams to decide if a datagram can be sent directly to the destination on the local network or if it must be sent to a gateway. In order to be able to send non-local datagrams to the gateway, the device must know the IP address of the gateway device assigned to the given network segment.

If no IP address is assigned, the value is 0.

use_DHCP_flag

When this flag is set to TRUE, the device uses DHCP (Dynamic Host Configuration Protocol) to dynamically determine the IP_address, subnet_mask and gateway_IP_address parameters.

On the other hand, when this flag is set to FALSE, the IP_address, subnet_mask and gateway_IP_address parameters must be locally set.

⁴ See more about sub-networking in RFC 940 and RFC 950.

primary_DNS_address	The IP Address of the primary Domain Name Server (DNS). If no IP address is assigned, the value is 0.
secondary_DNS_address	The IP Address of the secondary Domain Name Server (DNS). If no IP address is assigned, the value is 0.

Method description

add_mc_IP_address (IP_Address)	Adds one multicast IP address to the multicast_IP_Address array. IP_Address ::= double-long-unsigned
delete_mc_IP_address (IP_Address)	Deletes one IP Address from the multicast_IP_Address array. The IP Address to be deleted is identified by its value. IP_Address ::= double-long-unsigned
get_nbof_mc_IP_addresses (data)	Returns the number of IP Addresses contained in the multicast_IP_Address array. data ::= unsigned

A.10 Ethernet setup (class_id: 43)

An instance of the Ethernet setup class handles all information that is related to Ethernet settings associated to a given physical device and to a lower layer connection on which these settings are used.

There shall be an instance of this class for each network interface of a physical device, using the Ethernet protocol.

Ethernet setup	0...n	class_id = 43, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. MAC_address	octet-string			
Specific method(s)	m/o			

Attribute description

logical_name	Identifies the Ethernet setup object instance. See D.2.1.18.
MAC_address	Holds the MAC address.

A.11 PPP setup (class_id: 44)

An instance of the PPP setup class handles all information that is related to PPP settings associated to a given physical device and to a lower layer connection on which these settings are used.

There shall be an instance of this class for each network interface of a physical device, using the PPP protocol.

PPP setup	0...n	Class_id = 44, version = 0		
Attribute(s)	Data type	Min.	Max.	Def.
1. logical_name (static)	octet-string			
2. PHY_reference (static)	octet-string			
3. LCP_options (static)	LCP_options_type			
4. IPCP_options (static)	IPCP_options_type			
5. PPP_authentication (static)	PPP_auth_type			
Specific method(s)	m/o			

Attribute description

logical_name	Identifies the PPP setup object instance. See D.2.1.19.
PHY_reference	References another object by its logical_name. The object referenced contains information about the specific physical layer interface, supporting the PPP layer.
LCP_options	<p>This attribute contains the parameters for the Link Control Protocol options. These options include:</p> <ul style="list-style-type: none"> - Maximum-Receive-Unit (MRU, Type 1, STD 0051/RFC 1661). This configuration option may be sent to inform the peer that the implementation can receive larger packets, or to request that peer send smaller packets. The default value is 1500 octets; - Async-Control-Character_Map (ACCM, Type 2, STD 0051/RFC 1662): This configuration option provides a method to negotiate the use of control character transparency on asynchronous links; - Authentication-Protocol (Type 3, STD 0051/RFC 1661, PAP, CHAP or EAP); This configuration option provides a method to negotiate the use of a specific protocol for authentication. By default, authentication is not required; - Magic-Number (Type 5, STD 0051/RFC 1661). This configuration option provides a method to detect looped-back links and other data link layer anomalies; - Protocol-Field-Compression (PFC, Type 7, STD 0051/RFC 1661). This configuration option provides a method to negotiate the compression of the PPP protocol field; - Address-and-Control-Field-Compression (ACFC, Type 8, STD 0051/RFC 1661). This configuration option provides a method to negotiate the compression of the data link layer address and control fields; - FCS-Alternatives (Type 9, RFC 1570). This configuration option provides a method for an implementation to specify another FCSS format to be sent by the peer, or to negotiate away the FCS altogether; - Call-back (Type 13, RFC 1570). This configuration option provides a method for an implementation to request a dial-up peer to call back. This provides enhanced security by ensuring that the remote site can connect only from a single location as defined by the call-back number.

The structure of this attribute is the following:

LCP_options ::= SEQUENCE OF LCP_options_element

LCP_options_element ::= SEQUENCE
{
LCP-option-type unsigned,
LCP-option-length unsigned,

LCP-option-data CHOICE

```

{
    MRU           [1] long-unsigned,
    ACCM          [2] double-long-unsigned,
    Auth-Prot     [3] long-unsigned,
    Mag-Num       [5] double-long-unsigned,
    ProtF-Compr   [7] boolean,
    AdCtr-Compr   [8] boolean,
    FCS-Alter     [9] unsigned,
    Callback      [13] callback-data
}

```

LCP_option_type ::= ENUMERATED

```

{
    Max-Rec-Unit           (1),
    Async-Control-Char-Map (2),
    Auth-Protocol          (3),
    Magic-Number           (5),
    Protocol-Field-Compression (7),
    Address-and-Ctr-Compression (8),
    FCS-Alternatives       (9),
    Callback               (13)
}

```

For the LCP-option-data element, the following applies:

The default value of MRU is 1500.

The value of the Auth-Prot (Authentication Protocol) element indicates the authentication protocol used on the given PPP link.

Possible values today are:

```

0x0000 - No authentication protocol is used,
0xc023 - The PAP protocol is used,
0xc223 - The CHAP protocol is used,
0xc227 - The EAP protocol is used.

```

The value of the FCS-Alter (FCS Alternatives) options field identifies the FCS used. These are assigned as follows:

```

bit 1    Null FCS,
bit 2    CCITT 16-bit FCS,
bit 3    CCITT 32-bit FCS

```

Callback-data ::= SEQUENCE

```

{
    callback-active      boolean,      // default: false,
    callback-data-length unsigned,
    callback-operation   unsigned,
    callback-message     octet-string
}

```

The callback-active member indicates whether the callback option is active on this PPP link.

```

callback-operation ::= ENUMERATED
{
    Location-is-determined-by-user-authentication    (0),
    Dialling-string                                (1),
    Location-identifier                              (2),
    E.164-number                                    (3),
    X500-distinguished-name                         (4),
    Location-is-determined-during-CBCP-negotiation  (6)
}

```

The callback-message field is zero or more octets, and its general contents are determined by the callback-operation field. The actual format of the information is site or application specific (see in RFC 1570).

NOTE 1 For more details on Link Control Protocol, please refer to RFC 1661.

NOTE 2 For latest assigned numbers, see RFC 1700.

IPCP_options

This attribute contains the parameters for the IP Control Protocol – the Network Control Protocol module of the PPP for negotiating IP parameters on the PPP link options. These options include:

- IP-Compression-Protocol (Type 2, RFC 1332). This parameter indicates the IP compression protocol supported within the PPP link described by this object;
- Preferred-Local-IP-Address (Type 3, RFC 1332). This configuration option provides a way to negotiate the IP address to be used on the local end of the link. It allows the sender of the Configure-Request to state, which IP-address is desired, or to request that the peer provide the information. The peer can provide this information by NAK-ing the option, and returning a valid IP-Address;
- Preferred-Peer-IP-Addresses. This configuration option provides a way to negotiate the IP Address to be used on the remote end of the link. When the Grant-Access-Only-to-Pref-Peer-on-List parameter is set to be TRUE, the device shall accept PPP connection only with a remote device having one of the IP Addresses on this list. When the Use-Static-IP-Pool parameter is set to TRUE, the COSEM Server device shall try to assign one of these IP Addresses to the remote device;
- Grant-Access-Only-to-Pref-Peer-on-List. (GAO) This parameter indicates whether the device can accept PPP connection only with peer devices with IP Address on the above list or not. Its default value is FALSE;
- Use-Static-IP-Pool (USIP). This parameter indicates whether the device should try to assign one of the IP Addresses of the Preferred-Peer-IP-Addresses to the remote end device during the IP Address negotiation phase or not.

The structure of this attribute is as follows:

IPCP_options ::= SEQUENCE OF IPCP_options_element

```

IPCP_options_element ::= SEQUENCE
{
    IPCP-option-type      unsigned,
    IPCP-option-length    unsigned,
    IPCP-option-data      CHOICE
    {
        IP-Comp-Prot [2] long-unsigned,
        Pref-Local-IP [3] double-long-unsigned,
        Pref-Peer-IP  [20] SEQUENCE OF double-long-unsigned,
        GAO           [21] boolean,
        USIP          [22] boolean
    }
}

```

```

    }
    IPCP-option-type ::= ENUMERATED
    {
        IP-Comp-Prot (2),
        Pref_Local-IP (3),
        Pref-Peer-IP (20),
        GAO (21),
        USIP (22)
    }

```

Possible values for the IP-Compression-Protocol (IP-Comp-Prot) parameter today are:

0x0000 – No IP Compression is used (default),
 0x002d – Van Jacobson (RFC 1232),
 0x0061 – IP Header Compression (RFC 2507, 3544)
 0x0003 – Robust Header Compression (RFC 3241)

NOTE 1 For more details on IPCP, please refer to RFC 1332.

NOTE 2 For latest assigned numbers, see RFC 1700.

PPP_ authentication

Contains the parameters required by the PPP authentication procedure used.

```

PPP_authentication ::= CHOICE {
    No-authentication: [0] NULL,
    PAP-login          [1] structure,
                        {
                            user-name          octet-string,
                            PAP-password       octet-string
                        }
    CHAP-algorithm     [2] structure,
                        {
                            user-name          octet-string
                            algorithm_id       unsigned
                            --default: 5 (MD5)
                        }
    EAP-params:        [3] supported-EAP-types
}

```

Possible values for CHAP-algorithm-id parameter today are as follows:
 0x05 – CHAP with MD5 (default),
 0x06 – SHA-1,
 0x80 – MS-CHAP,
 0x81 – MS-CHAP-2

New values can be used as become assigned.

NOTE When CHAP is used, a “secret” is also required to verify the “challenge”⁵ sent by the Client. This “secret” is not accessible in the PPP setup object.

```

supported-EAP-types ::= SEQUENCE
{
    md5-challenge          boolean,
    one-time-password      boolean,
    generic-token-card      boolean
}

```

⁵ For more details about CHAP, please refer to RFC 1994.

A.12 GPRS modem setup (class_id: 45)

A “GPRS modem setup” object stores all the necessary data for a GPRS modem management.

GPRS modem setup		0...n	class_id = 45, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. APN	(static)	octet-string			
3. PIN_code	(static)	long-unsigned			
4. quality_of_service	(static)	structure			
Specific method(s)		m/o			

Attribute description

logical_name	Identifies the “GPRS modem setup” object instance. See D.2.1.20.
APN	Defines the access point name of the network. octet-string
PIN_code	Holds the personal identification number. long-unsigned
quality_of_service	Specifies the quality of service parameters. It is a structure of 2 elements: <ul style="list-style-type: none"> - the first one defines the default or minimum characteristics of the concerned network. These parameters have to be set to best effort value; - the second element defines the requested parameters. <pre> quality_of_service ::= structure { default qos_element, requested qos_element } qos_element ::= structure { precedence unsigned, delay unsigned, reliability unsigned, peak throughput unsigned, mean throughput unsigned } </pre>

A.13 SMTP setup (Class_id: 46)

An SMTP setup object allows defining the parameters for SMTP setup.

SMTP setup		0...n	class_id = 46, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			25
2. server_port	(static)	long-unsigned			
3. user_name	(static)	octet-string			
4. login_password	(static)	octet-string			
5. server_address	(static)	octet-string			
6. sender_address	(static)	octet-string			
Specific method(s)		m/o			

Attribute description

logical_name	Identifies the “SMTP setup” object instance. See D.2.1.21.
server_port	Defines the value of the TCP-UDP port related to this protocol. By default, this value is the SMTP port Id given by IETF: 25.
user_name	Defines the user name to be used for the login to the SMTP server.
login_password	Password to be used for login. When the string is void, this means that there is no authentication.
server_address	Defines the server address as an octet string. This server address can be a name, which must be resolvable by the primary DNS or the secondary DNS. In the case when it is directly the IP address of the server, which is specified here, it shall be a string in dotted format. Example: 163.187.45.87
sender_address	Defines the sender address as an octet string. This server address can be a name. In the case when it is directly the IP address of the server, which is specified here, it will be a string in dotted format.


Annex B (normative)

Data model and protocol

The data model uses generic building blocks to define the complex functionality of the metering equipment. It provides a view of this functionality of the meter, as it is available at its interface(s). The model does not cover internal, implementation specific issues.

The communication protocol defines how the data can be accessed and exchanged.

This is illustrated in the figure below:



IEC 313/02

Figure B.1 – The three step approach of COSEM

- The COSEM specification specifies metering domain specific interface classes. The functionality of the meter is defined by the instances of these interface classes, called COSEM objects. This is defined in this standard. Logical names, (OBIS codes), identifying the COSEM objects are defined in IEC 62056-61.
- The attributes and methods of these COSEM objects can be accessed and used via the messaging services of the application layer.
- The lower layers of the protocol transport the information.

Annex C (normative)

Using short names for accessing attributes and methods

C.1 Introduction – referencing methods

Attributes and methods of COSEM objects can be referenced in two different ways:

Using COSEM logical names: In this case, the attributes and methods of a COSEM object are referenced via the identifier of the COSEM object instance to which they belong.

The reference for an attribute is:

- class_id, value of the 'logical_name' attribute, attribute_index;

The reference for a method is:

- class_id, value of the 'logical_name' attribute, method_index

where

- *attribute_index* is used as the identifier of the required attribute;
- *method_index* is used as the identifier of the required method.

Using short names: This kind of referencing is intended for use in simple devices. In this case, each attribute and method of a COSEM object is identified with a 13-bit integer. The syntax for the short name is the same as the syntax of the name of a DLMS named variable.

C.2 Guidelines for assigning short names

This clause gives guidelines for assigning short names for public attributes and methods.

Data class_id = 1, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
value	x+8	
Specific method(s)		

Register class_id = 3, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
value	x+8	
scaler_unit	x+16	
Specific method(s)		
reset (data)	x+40	

Extended register class_id = 4, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
value	x+8	
scaler_unit	x+16	
status	x+24	
capture_time	x+32	
Specific method(s)		
reset (data)	x+56	

Demand register class_id = 5, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
current_average_value	x+8	
last-average_value	x+16	
scaler_unit	x+24	
status	x+32	
capture_time	x+40	
start_time_current	x+48	
period	x+56	
number_of_periods	x+64	
Specific method(s)		
reset (data)	x+72	
next_period (data)	x+80	

Register activation class_id = 6, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
register_assignment	x+8	
mask_list	x+16	
active_mask	x+24	
Specific method(s)		
add_register (data)	x+48	
add_mask (data)	x+56	
delete_mask (data)	x+64	

Profile generic class_id = 7, version = 1	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
Buffer	x+8	Selective access to the buffer is provided using parameterized access.
capture_objects	x+16	
capture_period	x+24	
sort_method	x+32	
sort_object	x+40	
entries_in_use	x+48	
profile_entries	x+56	
Specific method(s)		
reset (data)	x+88	
capture (data)	x+96	

Clock class_id = 8, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
Time	x+8	
time_zone	x+16	
Status	x+24	
daylight_savings_begin	x+32	
daylight_savings_end	x+40	
daylight_savings_deviation	x+48	
daylight_savings_enabled	x+56	
clock_base	x+64	
Specific method(s)		
adjust_to_quarter (data)	x+96	
adjust_to_measuring_period (data)	x+104	
adjust_to_minute (data)	x+112	
adjust_to_preset_time (data)	x+120	
preset_adjusting_time (data)	x+128	
shift_time (data)	x+136	

Script table class_id = 9, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
Scripts	x+8	
Specific method(s)		
execute (data)	x+32	

Schedule class_id = 10, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
Entries	x+8	
Specific method(s)		
enable/disable (data)	x+32	
insert (data)	x+40	
delete (data)	x+48	

Special days table class_id = 11, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
Entries	x+8	
Specific method(s)		
insert (data)	x+16	
delete (data)	x+24	

Activity calendar class_id = 20, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
calendar_name_active	x+8	
season_profile_active	x+16	
week_profile_table_active	x+24	
day_profile_table_active	x+32	
calendar_name_passive	x+40	
season_profile_passive	x+48	
week_profile_table_passive	x+56	
day_profile_table_passive	x+64	
activate_passive_calendar_time	x+72	
Specific method(s)		
activate_passive_calendar (data)	x+80	

Association SN class_id = 12, version = 1	Short name	Remarks
Attribute(s)		
logical_name	x ^a	x is the base name of the object.
object_list	x+8	Selective access to the object_list is provided using parameterized access.
Specific method(s)		
read_by_logicalname (data)	x+48	With this method, the parameterized access feature can also be used.
get_attributes&methods (data)	x+56	With this method, the parameterized access feature can also be used.
change_LLS_secret (data)	x+64	
change_HLS_secret (data)	x+72	
reply_to_HLS_authentication (data)	x+88	
^a The base name of the object "Association SN" corresponding to the current association is 0xFA00.		

SAP assignment class_id = 17, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
SAP_assignment_list	x+8	
Specific method(s)		
connect_logical_device (data)	x+32	

Register monitor class_id = 21, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
Thresholds	x+8	
monitored_value	x+16	
Actions	x+24	
Specific method(s)		

Utility tables class_id = 26, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
table_ID	x+8	
Length	x+16	
Buffer	x+24	
Specific method(s)		

Single action schedule class_id = 22, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
executed_script	x+8	
Type	x+16	
execution_time	x+24	
Specific method(s)		

Register table class_id = 61, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
table_cell_values	x+8	
table_cell_definition	x+16	
scaler_unit	x+24	
Specific method(s)		
Reset	x+40	
Capture	x+48	

Status mapping class_id = 63, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
status_word	x+8	
mapping_table	x+16	
Specific method(s)		

IEC local port setup class_id = 19, version = 0 or 1	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
default_mode	x+8	
default_baud	x+16	
prop_baud	x+24	
response_time	x+32	
device_addr	x+40	
pass_p1	x+48	
pass_p2	x+56	
pass_w5	x+64	
Specific method(s)		

Modem configuration class_id = 27, version = 0 or 1	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
<input type="checkbox"/> niti_speed	x+8	
<input type="checkbox"/> nitialization_string	x+16	
modem_profile	x+24	
Specific method(s)		

Auto answer class_id = 28, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
Mode	x+8	
listening_window	x+16	
Status	x+24	
number_of_calls	x+32	
number_of_rings	x+40	
Specific method(s)		

PSTN auto dial class_id = 29, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
Mode	x+8	
Repetitions	x+16	
repetition_delay	x+24	
calling_window	x+32	
phone_list	x+40	
Specific method(s)		

Auto connect class_id = 29, version = 1	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
Mode	x+8	
Repetitions	x+16	
repetition_delay	x+24	
calling_window	x+32	
destination_list	x+40	
Specific method(s)		

IEC HDLC setup class_id = 23, version = 0 or 1	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
comm_speed	x+8	
window_size_transmit	x+16	
window_size_receive	x+24	
max_info_length_transmit	x+32	
max_info_length_receive	x+40	
inter_octet_time_out	x+48	
inactivity_time_out	x+56	
device_address	x+64	
Specific method(s)		

IEC twisted pair (1) setup class_id = 24, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
secondary_address	x+8	
primary_address_list	x+16	
tabi_list	x+24	
fatal_error	x+32	
Specific method(s)		

TCP-UDP setup class_id = 41, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
TCP-UDP_port	x+8	
IP_reference	x+16	
MSS	x+24	
nb_of_sim_conn	x+32	
inactivity_time_out	x+40	
Specific method(s)		

IPv4 setup class_id = 42, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
DL_reference	x+8	
IP_address	x+16	
multicast_IP_address	x+24	
IP_options	x+32	
subnet_mask	x+40	
gateway_IP_address	x+48	
use_DHCP_flag	x+56	
primary_DNS_address	x+64	
secondary_DNS_address	x+72	
Specific method(s)		
add_mc_IP_address	x+96	
delete_mc_IP_address	x+104	
get_nbof_mc_IP_addresses	x+112	

Ethernet setup class_id = 43, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
MAC_address	x+8	
Specific method(s)		

PPP setup class_id = 44, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
PHY_reference	x+8	
LCP_options	x+16	
IPCP_options	x+24	
PPP authentication	x+32	
Specific method(s)		

GPRS modem setup class_id = 45, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
APN	x+8	
PIN_code	x+16	
quality_of_service	x+24	
Specific method(s)		

SMTP setup class_id = 46, version = 0	Short name	Remarks
Attribute(s)		
logical_name	x	x is the base_name of the object.
server_port	x+8	
user_name	x+16	
login_password	x+24	
server_address	x+32	
sender_address	x+40	
Specific method(s)		

C.3 Reserved base_names for special COSEM objects

In order to grant access for devices offering accessing by short_names some short_names are reserved as base_names for special COSEM objects. The reserved range of names is from 0xFA00 to 0xFF8.

The following specific base_names are defined:

Base_name (objectName)	COSEM object
0x FA00	Association SN
0x FB00	Script table (instantiation: "broadcast_receiver script")
0x FC00	SAP assignment
0x FD00	"Data" or "Register" object containing the "COSEM logical device name" in the attribute "value"

Annex D (normative)

Relation to OBIS

D.1 General

The OBIS identification system serves as a basis for the COSEM logical names. The system of naming COSEM objects is defined in the basic principles (see Clause 4), the identification of real data items is specified in IEC 62056-61.

The following clauses define the usage of those definitions in the COSEM environment.

All codes, which are not explicitly listed, but outside the manufacturer specific range are reserved for future use.

D.2 Mapping of data items to COSEM objects and attributes

This clause defines the usage of OBIS identifications and their mapping to COSEM objects of certain interface classes and their attributes.

D.2.1 Abstract COSEM objects

This subclause contains definitions for data items not directly linked to an energy type.

Value group C	
Abstract objects (A = 0)	
0	General purpose COSEM objects
1	COSEM objects of IC "Clock"
2	COSEM objects IC "Modem configuration" and related ICs
10	COSEM objects of IC "Script table"
11	COSEM objects of IC "Special days table"
12	COSEM objects of IC "Schedule"
13	COSEM objects of IC "Activity calendar"
14	COSEM objects of IC "Register activation"
15	COSEM objects of IC "Single action schedule"
16	COSEM objects of IC "Register monitor"
20	COSEM objects of IC "IEC local port setup"
21	Standard readout definitions
22	COSEM objects of IC "IEC HDLC setup"
23	COSEM objects of IC "IEC twisted pair (1) setup"
25	COSEM objects of IC "TCP-UDP setup", "IPv4 setup", "Ethernet setup", "PPP setup", "GPRS modem setup", "SMTP setup".
40	COSEM objects of IC "Association SN/LN"
41	COSEM objects of IC "SAP assignment"

Value group C Abstract objects (A = 0)	
42	COSEM logical device name
65	COSEM objects of IC "Utility tables"
128 ...199	Manufacturer specific COSEM related abstract objects
All other	Reserved

D.2.1.1 Clock (class_id:8)

This COSEM object controls the system clock of the physical device. It is an instance of the interface class "Clock".

Clock	IC	OBIS identification					
		A	B	C	D	E	F
Clock object	Clock	0	x	1	0	x	255

The usage of value group E shall be:

- if just one object is instantiated, value E shall be 0;
- if more than one object is instantiated in the same physical device, the value group E shall number the instantiations from zero to the needed maximum value.

D.2.1.2 Modem configuration (class_id: 27)

This COSEM object defines and controls the behaviour of the device regarding the communication through a modem. It is an instance of the interface class "Modem configuration".

Modem configuration	IC	OBIS identification					
		A	B	C	D	E	F
Modem configuration object	Modem configuration	0	x	2	0	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the communication channel.

D.2.1.3 Auto connect (class_id: 29)

This COSEM object defines the necessary parameters for the management of sending information from the metering device to one or more destinations. It is an instance of the interface class "Auto connect".

Auto connect	IC	OBIS identification					
		A	B	C	D	E	F
Auto connect object	Auto connect	0	x	2	1	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, its value group B shall number the communication channel.

D.2.1.4 Auto answer (class_id: 28)

This COSEM object defines and controls the behaviour of the device regarding the auto answering function using a modem. It is an instance of the interface class "Auto answer".

Auto answer	IC	OBIS identification					
		A	B	C	D	E	F
Auto answer object	Auto answer	0	x	2	2	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, its value group B shall number the communication channel.

D.2.1.5 Script tables (class_id: 9)

These COSEM objects control the behaviour of the device.

Several instances of the interface class "Script table" are predefined and normally available as hidden scripts only with access to the execute() method.

The following table contains only the identifiers for the "standard" instances of the listed scripts. Implementation specific instances of these scripts should use values different from zero in value group D.

Script table objects	IC	OBIS identification					
		A	B	C	D	E	F
Global meter reset ^a	Script table	0	x	10	0	0	255
MDI reset / end of billing period ^a		0	x	10	0	1	255
Tariffication script table		0	x	10	0	100	255
Activate test mode ^a		0	x	10	0	101	255
Activate normal mode ^a		0	x	10	0	102	255
Set output signals		0	x	10	0	103	255
Switch optical test output ^{b, c}		0	x	10	0	104	255
Power quality measurement management		0	x	10	0	105	255
Broadcast script table		0	x	10	0	125	255
^a The activation of these scripts is performed by calling the execute() method to the script identifier 1 of the corresponding script object.							
^b The optical test output is switched to measuring quantity Y and the test mode is activated by calling the execute method of the script table object 0.x.10.0.104.255 using Y as parameter; where Y is given by Table 5 of IEC 62056-61 (OBIS). The default value of A is 1 (Electricity).							
Example: In case of electricity meters, A = 1, default, execute (21) switches the test output to display the active power + of phase 1.							
^c The optical test output is also switched back to its default value when this script is activated.							

The tariffication script table defines the entry point into tariffication by standardizing utility-wide how to invoke the activation of certain tariff conditions.

The broadcast script table allows standardising utility wide the entry point into regularly needed functionality.

D.2.1.6 Special days table (class_id: 11)

This COSEM object defines and controls the behaviour of the device regarding calendar functions on special days for clock control. It is an instance of the interface class "Special days table".

Special days table	IC	OBIS identification					
		A	B	C	D	E	F
Special days table object	Special days table	0	x	11	0	0	255

D.2.1.7 Schedule (class_id: 10)

This COSEM object defines and controls the behaviour of the device in a sequenced way. It is an instance of the interface class "Schedule".

Schedule	IC	OBIS identification					
		A	B	C	D	E	F
Schedule object	Schedule	0	x	12	0	x	255

The usage of value group E shall be:

- if just one object is instantiated, value E shall be 0;
- if more than one object is instantiated in the same physical device, the value group E shall number the instantiations from zero to the needed maximum value.

D.2.1.8 Activity calendar (class_id: 20)

This COSEM object defines and controls the behaviour of the device in a calendar-based way. It is an instance of the interface class "Activity calendar".

Activity calendar	IC	OBIS identification					
		A	B	C	D	E	F
Activity calendar object	Activity calendar	0	x	13	0	0	255

D.2.1.9 Register activation (class_id: 6)

This COSEM object is used to handle different tariffication structures. It is an instance of the interface class "Register activation".

Register activation	IC	OBIS identification					
		A	B	C	D	E	F
Register activation object	Register activation	0	x	14	0	x	255

The usage of value group E shall be:

- if just one object is instantiated, value E shall be 0;
- if more than one object is instantiated in the same physical device, the value group E shall number the instantiations from zero to the needed maximum value.

D.2.1.10 Single action schedule (class_id: 22)

These COSEM objects control the behaviour of the device. One instance of the interface class "Single action schedule" is predefined. Implementation specific instances of these interface classes should use values different from zero in value group D.

Single action schedule	IC	OBIS identification					
		A	B	C	D	E	F
End of billing period	Single action schedule	0	x	15	0	0	255

D.2.1.11 Register monitor (class_id: 21)

These COSEM objects control the register monitoring function of the device. They define the value to be monitored, the set of thresholds to which the value is compared, and the actions to be performed when a threshold is crossed.

In general, the following logical name(s) shall be used:

Register monitor	IC	OBIS identification					
		A	B	C	D	E	F
Register monitor object	Register monitor	0	x	16	0	x	255

The use of value group E shall be:

- if just one "Register monitor" object is instantiated the value of E shall be 0;
- if more than one object is instantiated in the same logical device, the value group E shall number the instantiations from zero to the needed maximum value.

See also D.2.2.19 and D.2.2.20.

D.2.1.12 IEC local port setup (class_id: 19)

These COSEM objects define and control the behaviour of the device regarding the communication parameters on the local port according to IEC 62056-21. They are instances of the interface class "IEC local port setup".

IEC local port setup	IC	OBIS identification					
		A	B	C	D	E	F
IEC optical port setup object	IEC local port setup	0	x	20	0	0	255
IEC electrical port setup object		0	x	20	0	1	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the communication channel.

D.2.1.13 Standard readout profile (class_id: 7)

A set of COSEM objects is defined to carry the standard readout as it would appear with IEC 62056-21 (modes A to D).

Standard readout	IC	OBIS identification					
		A	B	C	D	E	F
General local port readout	Profile generic	0	0	21	0	0	255
General display readout		0	0	21	0	1	255
Alternate display readout		0	0	21	0	2	255
Service display readout		0	0	21	0	3	255
List of configurable meter data		0	0	21	0	4	255
Additional readout profile 1		0	0	21	0	5	255
.....							
Additional readout profile <i>n</i>		0	0	21	0	N	255

For the parametrization of the standard readout “Data” objects can be used:

Standard readout parametrization	IC	OBIS identification					
		A	B	C	D	E	F
Standard readout parametrization object	Data	0	0	21	0	x	255

The usage of value group E shall be:

- if just one object is instantiated, value E shall be 0;
- if more than one object is instantiated in the same physical device, the value group E shall number the instantiations from zero to the needed maximum value.

Standard readout objects can also be related to an energy type and to a channel. See IEC 62056-61.

D.2.1.14 IEC HDLC setup (class_id: 23)

These COSEM objects define and control the behaviour of the device at the association negotiation instant using HDLC protocol. They are instances of the interface class “IEC HDLC setup”.

IEC HDLC setup	IC	OBIS identification					
		A	B	C	D	E	F
IEC HDLC setup object	IEC HDLC setup	0	x	22	0	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the communication channel.

D.2.1.15 IEC twisted pair (1) setup (class_id: 24)

These COSEM objects define and control the behaviour of the device regarding the communication parameters according to IEC 62056-31. They are instances of the interface class “IEC twisted pair (1) setup”.

IEC twisted pair (1) setup	IC	OBIS identification					
		A	B	C	D	E	F
IEC twisted pair (1) setup object	IEC twisted pair (1) setup	0	x	23	0	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the communication channel.

D.2.1.16 TCP-UDP setup (class_id: 41)

COSEM objects of the IC “TCP-UDP setup” handle all information related to the setup of the TCP and UDP layer of the Internet based communication profile(s) and point to the IPv4 setup object(s) handling the setup of the IP layer on which the TCP-UDP connection(s) is (are) used.

TCP-UDP setup	IC	OBIS identification					
		A	B	C	D	E	F
TCP-UDP setup object	TCP-UDP setup	0	x	25	0	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the communication channels used for Internet based communication.

D.2.1.17 IPv4 setup (class_id: 42)

COSEM objects of the IC “IPv4 setup” handle all information related to the setup of the IP layer of the Internet based communication profile(s) and point to the data link layer setup object(s) handling the setup of the data link layer on which the IP connection(s) is (are) used.

IPv4 setup	IC	OBIS identification					
		A	B	C	D	E	F
IPv4 setup object	IPv4 setup	0	x	25	1	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the communication channels used for internet-based communication.

D.2.1.18 Ethernet setup (class_id: 43)

COSEM objects of the IC “Ethernet setup” handle all information related to the setup of the Ethernet data link layer of the Internet based communication profile(s).

Ethernet setup	IC	OBIS identification					
		A	B	C	D	E	F
Ethernet setup object	Ethernet setup	0	x	25	2	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the communication channels used for internet-based communication.

D.2.1.19 PPP setup (class_id: 44)

COSEM object of the IC “PPP setup” handle all information related to the setup of the PPP data link layer of the Internet based communication profiles.

PPP setup	IC	OBIS identification					
		A	B	C	D	E	F
PPP setup object	PPP setup	0	x	25	3	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the communication channels used for IP connection.

D.2.1.20 GPRS modem setup (class_id: 45)

COSEM objects of the “GPRS setup” class handle all information related to the setup of the GPRS modem.

GPRS setup	IC	OBIS identification					
		A	B	C	D	E	F
GPRS modem setup object	GPRS modem setup	0	x	25	4	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the communication channels used for IP connection.

D.2.1.21 SMTP setup (class_id: 46)

COSEM objects of the “SMTP setup” class handle all information related to the setup of the SMTP service.

SMTP setup	IC	OBIS identification					
		A	B	C	D	E	F
SMTP setup object	SMTP setup	0	x	25	5	0	255

The usage of value group B shall be:

- if more than one object is instantiated in the same physical device, the value group B shall number the instances.

D.2.1.22 Association objects (class_id: 12, 15)

A series of COSEM objects are used to identify association objects within a physical device.

Association objects	IC	OBIS identification					
		A	B	C	D	E	F
Current association	Association LN/SN	0	0	40	0	0	255
Association, instance 1		0	0	40	0	1	255
.....							
Association, instance <i>n</i>		0	0	40	0	<i>n</i>	255

D.2.1.23 SAP assignment object (class_id: 17)

One COSEM object is used to inform about the SAP assignments within a physical device.

SAP assignment object	IC	OBIS identification					
		A	B	C	D	E	F
SAP assignment of current physical device	SAP assignment	0	0	41	0	0	255

D.2.1.24 COSEM logical device name

Each COSEM logical device can be identified worldwide by its logical device name.

The logical device name is held by the *value* attribute of a “Data” or “Register” object, with data type *octet-string*. For short name referencing, the base_name of the object is fixed. See Clause C.3.

COSEM logical device name	IC	OBIS identification					
		A	B	C	D	E	F
COSEM logical device name	Data ^a	0	0	42	0	0	255

^a In cases where the class “Data” is not available, the class “Register” (with scaler = 0, unit = 255) may be used.

D.2.1.25 Utility tables (class_id: 26)

The following summarizes the coding of ANSI utility tables instances using the OBIS coding of logical names.

- Value group A: use value of 0 to specify abstract object;
- Value group B: instance of table set;
- Value group C: use value 65 – signifies utility tables specific definitions;
- Value group D: table group selector;
- Value group E: table number within group;
- Value group F: use value 0xFF for data of current billing period.

Utility tables	IC	OBIS identification					
		A	B	C	D	E	F
Standard tables 0-127	Utility tables	0	x	65	0	n	255
Standard tables 128-255		0	x	65	1	n	255
...							
Standard tables 1920-2047		0	x	65	15	n	255
Manufacturer tables 0-127		0	x	65	16	n	255
Manufacturer tables 128-255		0	x	65	17	n	255
...							
Manufacturer tables 1920-2047		0	x	65	31	n	255
Std pending tables 0-127		0	x	65	32	n	255
Std pending tables 128-255		0	x	65	33	n	255
...							
Std pending tables 1920-2047		0	x	65	47	n	255
Mfg pending tables 0-127		0	x	65	48	n	255
Mfg pending tables 128-255		0	x	65	49	n	255
...							
Mfg pending tables 1920-2047		0	x	65	63	n	255

D.2.1.26 Device ID

A series of COSEM objects are used to communicate ID numbers of the device. These can be numbers defined by the manufacturer (manufacturing number) or defined by the user.

The different ID numbers are instances of the interface class "Data", with data type *octet-string*.

If more than one of those is used, it is also allowed to combine them into one instance of the interface class "Profile generic". In this case, the captured objects are the device ID "Data" objects, the capture period is 1 to have just actual values, the sort method is FIFO, the profile entries are limited to 1.

Alternatively, an instance of the "Register table" interface class can be used.

Device ID	IC	OBIS identification					
		A	B	C	D	E	F
Device ID 1 object (manufacturing number)	Data ^a	0	x	96	1	0	255
.....							
Device ID 10 object		0	x	96	1	9	255
Device ID-s object	Profile generic	0	x	96	1	255	255
Device ID-s object	Register table	0	x	96	1	255	255
^a In cases where the class "Data" is not available, the class "Register" (with scaler = 0, unit = 255) may be used.							

D.2.1.27 Metering point ID

One COSEM object is available to store a media type independent metering point ID. It is held by the *value* attribute of a "Data" interface class, with data type *octet-string*.

Metering point ID	IC	OBIS identification					
		A	B	C	D	E	F
Metering point ID	Data ^a	0	x	96	1	10	255
^a In cases where the class "Data" is not available, the class "Register" (with scaler = 0, unit = 255) may be used.							

D.2.1.28 Parameter changes

A set of simple COSEM objects describes the history of the configuration of the device. All values are modelled by instances of the interface class "Data".

Parameter changes	IC	OBIS identification					
		A	B	C	D	E	F
Number of configuration program changes object	Data ^a	0	x	96	2	0	255
Date of last configuration program change object		0	x	96	2	1	255
Date of last time switch program change object		0	x	96	2	2	255
Date of last ripple control receiver program change object		0	x	96	2	3	255
Number of protected configuration program changes ^b		0	x	96	2	10	255
Date of last protected configuration program change ^b		0	x	96	2	11	255
^a In cases where the class “Data” is not available, the class “Register” or “Extended register” (with scaler = 0, unit = 255) may be used.							
^b Protected configuration is characterized by the need to open the main meter cover to modify it.							
NOTE For a complete list, see IEC 62056-61, Table 14.							

D.2.1.29 I/O control signals

These COSEM objects define and control the status of I/O lines of the physical metering equipment.

The status is held by the value attribute of a "Data" object, with data type *octet-string* or *bit-string*.

NOTE In cases where the class "Data" is not available, the class "Register" or "Extended register" (with scaler = 0, unit = 255) may be used.

Alternatively, the status is held by a "Status mapping" object, which holds both the status word and the mapping of its bits to the reference table.

If there are several I/O control status objects used, it is allowed to combine them into an instance of the interface class "Profile generic" or "Register table", using the OBIS code of the global status word.

For OBIS codes, see IEC 62056-61, Table 14.

D.2.1.30 Status of internal control signals and internal operating status

These COSEM objects define the status of internal control signals and the internal operating status.

The status carries binary information from a bitmap, and it shall be held by the value attribute of a "Data" object, with data-type *octet-string* or *bit-string*.

NOTE In cases where the class "Data" is not available, the class "Register" or "Extended register" (with scaler = 0, unit = 255) may be used.

Alternatively, the status is held by a "Status mapping" object, which holds both the status word and the mapping of its bits to the reference table.

If there are several status of internal control signals or internal operating status objects used, it is allowed to combine them into an instance of the interface class "Profile generic" or "Register table", using the OBIS code of the global status of internal control signals or internal operating status respectively.

For OBIS codes, see IEC 62056-61, Table 14.

Internal operating status objects can also be related to an energy type. See D.2.2.17.

D.2.1.31 Battery entries

A series of COSEM objects are available for holding information relative to the battery of the device.

These objects are instances of “Data”, “Register” or “Extended register” as appropriate.

For OBIS codes, see IEC 62056-61, Table 14.

D.2.1.32 Power failure monitoring

A series of COSEM objects are available for power failure monitoring.

For simple power failure monitoring, it is possible to count the number of power failure events affecting all three phases or one of the three phases.

For advanced power failure monitoring, it is possible to record the time of occurrence of the power failure events affecting all three phases, one of the phases or any of the phases.

Further, it is possible to define a time threshold to make a distinction between short and long power failures.

If the power failure is longer than this time threshold, then the number of such long power failure events affecting all three phases, one of the three phases or any of the phases can be separately counted and their duration (time from power down to power up) can be recorded.

The number of power failure events objects are represented by instances of the IC “Data”, “Register” or “Extended register” objects with data types *unsigned*, *long-unsigned* or *double-long-unsigned*.

The power failure duration, time and time threshold data are represented by instances of the IC “Data”, “Register” or “Extended register” with appropriate data types.

If power failure duration objects are represented by instances of the IC “Data”, then the default scaler shall be 0 and the default unit shall be the *second*.

These objects may be collected in a “Power failure event log” object.

For OBIS codes, see IEC 62056-61, Table 14 and Table 21.

D.2.1.33 Operating time

A series of COSEM objects are available for holding the cumulated operating time and the various tariff registers of the device.

These objects are instances of the interface class “Data”, “Register” or “Extended register”.

The data type shall be *unsigned*, *long-unsigned* or *double-long-unsigned* with appropriate units. If the interface class “Data” is used, the unit shall be the second by default.

For OBIS codes, see IEC 62056-61, Table 14.

D.2.1.34 Status register objects

A number of objects are available to hold statuses to be captured in load profiles.

The status word carries binary information from a bitmap, and it shall be held by the value attribute of a “Data” object, with data-type *octet-string* or *bit-string*.

NOTE In cases where the class “Data” is not available, the class “Register” or “Extended register” (with scaler = 0, unit = 255) may be used.

Alternatively, the status is held by a “Status mapping” object, which holds both the status word and the mapping of its bits to the reference table.

For OBIS codes, see IEC 62056-61, Table 14.

D.2.1.35 Communication port log parameters

These COSEM objects hold various log parameters. They are represented by COSEM objects of interface class “Register”, “Extended register” or “Profile generic”.

For OBIS codes, see IEC 62056-61, Table 14.

D.2.1.36 Error values

A series of COSEM objects are used to communicate error indications of the device.

The different error values are held by the *value* attribute of “Data” objects, with data type *octet-string* or *bit-string*.

If more than one of those objects is used, it is also allowed to combine them into one instance of the interface class “Profile generic”. In this case, the captured objects are the “Data” objects, the capture period is 1 to have just actual values, the sort method is FIFO, the profile entries are limited to 1.

Alternatively, an instance of the “Register table” interface class can be used.

Error values	IC	OBIS identification					
		A	B	C	D	E	F
Error 1 object	Data ^a	0	0	97	97	0	255
.....						...	
Error 10 object		0	0	97	97	9	255
Error profile object	Profile generic	0	0	97	97	255	255
Error table object	Register table	0	0	97	97	255	255
^a In cases where the class “Data” is not available, the class “Register” or “Extended register” (with scaler = 0, unit = 255) may be used.							

Error code objects can also be related to an energy type and to a channel. See IEC 62056-61.

D.2.1.37 General list objects (class_id: 7)

These COSEM objects are used to model lists of any kind of data, for example measurement values, constants, statuses, events. They are modelled by “Profile generic” objects.

One standard object per billing period scheme is defined. See also IEC 62056-61.

General list objects	IC	OBIS identification					
		A	B	C	D	E	F
Data of billing period (with billing period scheme 1 if there are two schemes available)	Profile generic	0	x	98	1	x	255 ^a
Data of billing period (with billing period scheme 2)		0	x	98	2	x	255 ^a
^a F = 255 means a wild card here. See IEC 62056-61, Clause A.3.							

The use of value group E shall be:

- if just one “Data of billing period” object is instantiated the value of E shall be 0;
- if more than one object is instantiated in the same logical device, the value group E shall number the instantiations from zero to the needed maximum value.

D.2.2 Electricity related COSEM objects

D.2.2.1 Value group D definitions

The different values as defined by value group D are modelled in the following way:

- **cumulative values** are represented by COSEM objects which are instances of interface class "Register" or "Extended register";
- **maximum and minimum values** are represented by COSEM objects which are instances of interface class "Profile generic" with sorting method maximum or minimum, depth according to implementation and captured objects according to implementation. A single maximum value or minimum value can alternatively be represented by a COSEM object which is an instance of the interface class "Register" or "Extended register";
- **current and last average values** are the respective attributes of COSEM objects which are instances of interface class "Demand register", using the OBIS code of the current value as logical name;
- **instantaneous values** are represented by COSEM objects, which are instances of interface class "Register";
- **time integral values** are represented by COSEM objects, which are instances of interface class "Register" or "Extended register";
- **occurrence counters** are represented by COSEM objects, which are instances of interface class "Data" or "Register".

D.2.2.2 Data of previous billing periods

COSEM provides three mechanisms to represent values of historical billing periods:

- a value of a single historical billing period may be represented using the same interface class as used for representing the value of the current billing period. With F = 0...99, the billing period is identified by the value of the billing period counter VZ. F = VZ identifies the youngest value, F = VZ-1 identifies the second youngest value, etc. F = 101...125 identifies the last, second last, ...25th last billing period. (F = 255 identifies the current billing period). Simple objects can only be used to represent values of historical billing periods, if “Profile generic” objects are not implemented;
- a value of a single historical billing period may also be represented by “Profile generic” objects, which are one entry deep, and contain the historical value itself and the time stamp of the storage. With F = 0...99 the billing period is identified by the value of the billing period counter VZ. F = VZ identifies the youngest value, F = VZ-1 identifies the second youngest value, etc. F = 101 identifies the most recent billing period;

- values of multiple historical billing periods are represented with “Profile generic” objects, with suitable controlling attributes. With F = 102...125 the two last, ...25 last values can be reached. F = 126 identifies an unspecified number of historical values;
- when values of historical billing periods are represented by “Profile generic” objects, two different billing period schemes may be used. The billing period scheme is identified by the billing period counter object captured in the profile.

D.2.2.3 Electricity ID numbers

The different electricity ID numbers are instances of the interface class "Data", with data type *octet-string*.

If more than one of those is used, it is also allowed to combine them into one instance of the interface class "Profile generic". In this case, the captured objects are the electricity ID data objects, the capture period is 1 to have just actual values, the sort method is FIFO, the profile entries are limited to 1.

Alternatively, an instance of the “Register table” interface class can be used.

Electricity ID	IC	OBIS identification					
		A	B	C	D	E	F
Electricity ID 1 object	Data ^a	1	x	0	0	0	255
.....							
Electricity ID 10 object		1	x	0	0	9	255
Electricity ID-s object	Profile generic	1	x	0	0	255	255
Electricity ID-s object	Register table	1	x	0	0	255	255

^a In cases where the class “Data” is not available, the class “Register” or “Extended register” (with scaler = 0, unit = 255) may be used.

D.2.2.4 Entries related to billing periods

These values are represented by instances of the interface class "Data" with data type *unsigned* resp. *octet-string*, formatted as *date_time* in 4.4.1.

Historical data related entries	IC	OBIS identification					
		A	B	C	D	E	F
First billing period scheme (if there are two)	Data ^a						
Billing period counter object (1)		1	x	0	1	0	VZ...or 255
Number of available billing periods object (1)		1	x	0	1	1	255
Time stamp of the most recent billing period (1)		1	x	0	1	2	255
Time stamp of the billing period objects (1)		1	x	0	1	2	VZ...VZ -n
Second billing period scheme							
Billing period counter object (2)		1	x	0	1	3	VZ...VZ -n
Number of available billing periods object (2)		1	x	0	1	4	255
Time stamp of the most recent billing period (2)		1	x	0	1	5	255
Time stamp of the billing period objects (2)		1	x	0	1	5	VZ...VZ -n

^a In cases where the class "Data" is not available, the class "Register" or "Extended register" (with scaler = 0, unit = 255) may be used.

When the values of historical periods are represented by “Profile generic” objects, the time stamp of the billing period objects shall be part of the captured objects. The values can also be related to a channel.

D.2.2.5 Program entries

Those values are represented by instances of the interface class “Data” with data type *unsigned*, *long-unsigned* or *octet-string*. For “Meter connection diagram ID” objects data type *enumerated* can be used as well.

Program entries	IC	OBIS identification					
		A	B	C	D	E	F
Configuration program version number object	Data ^a	1	x	0	2	0	255
Parameter record number object		1	x	0	2	1	1
Parameter record number object (reserved for future use)		1	x	0	2	1	2... 127
Time switch program number object		1	x	0	2	2	255
RCR program number object		1	x	0	2	3	255
Meter connection diagram ID object		1	x	0	2	4	255
Passive calendar name object		1	x	0	2	7	255
^a In cases where the class “Data” are not available, the class “Register” or “Extended register” (with scaler = 0, unit = 255) may be used.							

Program entries can also be related to a channel. See also IEC 62056-61, Table 16.

D.2.2.6 Input and output pulse constants, nominal values, coefficients

These values are represented by instances of the interface class “Data”, “Register” or “Extended register” with simple data types for the value attribute.

For OBIS codes, see IEC 62056-61, Table 16.

D.2.2.7 Ratios

These values are represented by instances of the IC “Data”, “Register” or “Extended register”. For the *value* attribute, only simple data types are allowed.

For OBIS codes, see IEC 62056-61, Table 16.

D.2.2.8 Measurement period duration – Recording interval – Billing period duration values, time entries

Measurement period duration, Recording interval and Billing period duration values are represented by instances of IC “Data” “Register” or “Extended register” with the data type of the *value* attribute *unsigned*, *long-unsigned* or *double-long unsigned*.

Time entry values shall be represented by instances of IC “Data”, “Register” or “Extended register” with the data type of the *value* attribute *octet-string*, formatted as *date_time* in 4.4.1.

For OBIS codes, see IEC 62056-61, Table 16.

The clock synchronization method shall be represented by an instance of an IC “Data” with data type *enum*.

Time entries	IC	OBIS identification
--------------	----	---------------------

		A	B	C	D	E	F
Clock synchronization method object	Data ^a	1	x	0	9	10	255

^a In cases where the class “Data” is not available, the class “Register” (with scaler = 0, unit = 255) may be used.

Synchronization method: enum

- (0) no synchronization,
- (1) adjust to quarter,
- (2) adjust to measuring period,
- (3) adjust to minute,
- (4) reserved,
- (5) adjust to preset time,
- (6) shift time

D.2.2.9 Measurement algorithm for active power

These values are represented by instances of the interface class “Data”.

Measurement algorithm for active power	IC	OBIS identification					
		A	B	C	D	E	F
Measuring algorithm	Data ^a	1	x	0	11	1	255

^a In cases where the class “Data” are not available, the class “Register” (with scaler = 0, unit = 255) may be used.

Measuring algorithm: enum

- (0) not specified,
- (1) only the fundamentals of voltage and current are used,
- (2) all harmonics of voltage and current are used,
- (3) only the DC part of voltage and current is used,
- (4) all harmonics and the DC part of voltage and current are used

D.2.2.10 Measurement algorithm for active energy

These values are represented by instances of the interface class “Data”.

Measurement algorithm for active energy	IC	OBIS identification					
		A	B	C	D	E	F
Measuring algorithm	Data ^a	1	x	0	11	2	255

^a In cases where the class “Data” are not available, the class “Register” (with scaler = 0, unit = 255) may be used.

Measuring algorithm: enum

The same enumeration applies for integrated values of active power as described in D.2.2.9.

D.2.2.11 Measurement algorithm for reactive power

These values are represented by instances of the interface class “data”.

Measurement algorithm for reactive power	IC	OBIS identification					
		A	B	C	D	E	F
Measuring algorithm	Data ^a	1	x	0	11	3	255
^a In cases where the class “Data” are not available, the class “Register” (with scaler = 0, unit = 255) may be used.							

Measuring algorithm: enum

- (0) not specified,
- (1) (sum of) reactive power of each phase, calculated from the fundamental of the per phase voltage and the per phase current,
- (2) polyphase reactive power calculated from polyphase apparent power and polyphase active power,
- (3) (sum of) reactive power calculated from per phase apparent power and per phase active power.

D.2.2.12 Measurement algorithm for reactive energy

These values are represented by instances of the interface class “Data”.

Measurement algorithm for reactive energy	IC	OBIS identification					
		A	B	C	D	E	F
Measuring algorithm	Data ^a	1	x	0	11	4	255
^a In cases where the class “Data” are not available, the class “Register” (with scaler = 0, unit = 255) may be used.							

Measuring algorithm: enum

The same enumeration applies for integrated values of reactive power as described in D.2.2.11.

D.2.2.13 Measurement algorithm for apparent power

These values are represented by instances of the interface class “Data”.

Measurement algorithm for apparent power	IC	OBIS identification					
		A	B	C	D	E	F
Measuring algorithm	Data ^a	1	x	0	11	5	255
^a In cases where the class “Data” are not available, the class “Register” (with scaler = 0, unit = 255) may be used.							

Measuring algorithm: enum

- (0) not specified,
- (1) $S = U \times I$, with voltage: only fundamental, and current: only fundamental;
- (2) $S = U \times I$, with voltage: only fundamental, and current: all harmonics,
- (3) $S = U \times I$, with voltage: only fundamental, and current: all harmonics and DC part,

- (4) $S = U \times I$, with voltage: all harmonics, and current: only fundamental,
- (5) $S = U \times I$, with voltage: all harmonics, and current: all harmonics,
- (6) $S = U \times I$, with voltage: all harmonics, and current: all harmonics and DC part,
- (7) $S = U \times I$, with voltage: all harmonics and DC part, and current: only fundamental,
- (8) $S = U \times I$, with voltage: all harmonics and DC part, and current: all harmonics,
- (9) $S = U \times I$, with voltage: all harmonics and DC part, and current: all harmonics and DC part,
- (10) $S = \sqrt{P^2 + Q^2}$, with P : only fundamental in U and I , and Q : only fundamental in U and I , where P and Q are polyphase quantities,
- (11) $S = \sqrt{P^2 + Q^2}$, with P : all harmonics in U and I , and Q : only fundamental in U and I where P and Q are polyphase quantities,
- (12) $S = \sqrt{P^2 + Q^2}$, with P : all harmonics and DC part in U and I , and Q : only fundamental in U and I where P and Q are polyphase quantities;
- (13) $S = \sum \sqrt{P^2 + Q^2}$, with P : only fundamental in U and I , and Q : only fundamental in U and I where P and Q are single phase quantities,
- (14) $S = \sum \sqrt{P^2 + Q^2}$, with P : all harmonics in U and I , and Q : only fundamental in U and I where P and Q are single phase quantities,
- (15) $S = \sum \sqrt{P^2 + Q^2}$, with P : all harmonics and DC part in U and I , and Q : only fundamental in U and I where P and Q are single-phase quantities.

D.2.2.14 Measurement algorithm for apparent energy

These values are represented by instances of the interface class “Data”.

Measurement algorithm for apparent energy	IC	OBIS identification					
		A	B	C	D	E	F
Measuring algorithm	Data ^a	1	x	0	11	6	255

^a In cases where the class “Data” are not available, the class “Register” (with scaler = 0, unit = 255) may be used.

Measuring algorithm: enum

The same enumeration applies for integrated values of apparent power as described in D.2.2.13.

D.2.2.15 Measurement algorithm for power factor calculation

These values are represented by instances of the interface class “Data”.

Measurement algorithm for power factor calculation	IC	OBIS identification					
		A	B	C	D	E	F
Measuring algorithm	Data ^a	1	x	0	11	7	255

^a In cases where the class “Data” is not available, the class “Register” (with scaler = 0, unit = 255) may be used.

Measuring algorithm: enum

- (0) not specified,
- (1) displacement power factor: the displacement between fundamental voltage and current vectors, which can be calculated directly from fundamental active power and apparent power, or another appropriate algorithm,
- (2) true power factor, the power factor produced by the voltage and current including their harmonics. It may be calculated from apparent power and active power, including the harmonics.

D.2.2.16 Metering point ID (electricity related)

A series of COSEM objects are available to hold electricity related metering point IDs. They are held by the *value* attribute of a “Data” interface class, with data type *octet-string*.

If more than one of those is used, it is also allowed to combine them into one instance of the interface class “Profile generic”. In this case, the captured objects are the electricity related metering point ID data objects, the capture period is 1 to have just actual values, the sort method is FIFO, the profile entries are limited to 1.

Alternatively, an instance of the “Register table” interface class can be used.

Metering point ID	IC	OBIS identification					
		A	B	C	D	E	F
Metering point ID 1 (electricity related)	Data ^a	1	x	96	1	0	255
....							
Metering point ID 10 (electricity related)		1	x	96	1	9	255
Metering point ID-s object	Profile generic	1	x	96	1	255	255
Metering point ID-s object	Register table	1	x	96	1	255	255

^a In cases where the class “Data” is not available, the class “Register” (with scaler = 0, unit = 255) may be used.

D.2.2.17 Electricity related internal operating status

A number of electricity related objects are available to hold information about the internal operating status, the starting of the meter and the status of voltage and current circuits.

The status is held by the value attribute of a “Data” object, with data type *octet-string* or *bit-string*.

NOTE In cases where the class “Data” is not available, the class “Register” or “Extended register” (with scaler = 0, unit = 255) may be used.

Alternatively, the status is held by a “Status mapping” object, which holds both the status word and the mapping of its bits to the reference table.

If there are several electricity related internal operating status objects used, it is allowed to combine them into an instance of the interface class “Profile generic” or “Register table”, using the OBIS code of the global internal operating status.

For OBIS codes, see IEC 62056-61, Table 16.

D.2.2.18 Electricity related list objects (class_id: 7)

These COSEM objects are used to model lists of any kind of data, for example measurement values, constants, statuses, events. They are modelled by “Profile generic” objects.

One standard object per billing period scheme is defined. See also IEC 62056-61.

General list objects	IC	OBIS identification					
		A	B	C	D	E	F
Data of billing period (with billing period scheme 1 if there are two schemes available)	Profile generic	1	x	98	1	x	255 ^a
Data of billing period (with billing period scheme 2)		1	x	98	2	x	255 ^a

^a F = 255 means a wild card here. See IEC 62056-61, Clause A.3.

The use of value group E shall be:

- if just one “Data of billing period” object is instantiated, the value of E shall be 0;
- if more than one object is instantiated in the same logical device, the value group E shall number the instantiations from zero to the needed maximum value.

D.2.2.19 Threshold values

A number of objects are available for representing thresholds for instantaneous quantities. The thresholds may be “under limit”, “over limit” and “missing”. Several objects are available to represent the number of occurrences when these thresholds are exceeded, the duration of such events and the magnitude of the quantity during such events.

These values are represented by instances of IC “Data”, “Register” or “Extended register”.

For OBIS codes, see IEC 62056-61, Table 6.

All these quantities may be related to tariffs.

As defined in IEC 62056-61, 5.6.3, value group F may be used to identify multiple thresholds.

For monitoring the supply voltage, a more sophisticated functionality is also available, allowing to count the number of occurrences classified by the duration of the event and the depth of the voltage dip. For OBIS codes, see IEC 62056-61, Table 13.

D.2.2.20 Register monitor objects (class_id: 21)

Further to D.2.1.11, the following definitions apply:

For monitoring instantaneous values, the logical name of the “Register monitor” object may be the OBIS identifier of the threshold.

Register monitor	IC	OBIS identification					
		A	B	C	D	E	F
Register monitor object	Register monitor	1	x	1-80, 82, 84- 89, 91, 92	31, 35, 39	x	0-99, 255

For monitoring current average and last average values, the logical name of the “Register monitor” object may be the OBIS identifier of the demand value monitored.

Register monitor	IC	OBIS identification					
		A	B	C	D	E	F
Register monitor object	Register monitor	1	x	1-80, 82, 84- 89, 91, 92	4, 5, 14, 15, 24, 25	x	255

- The use of value group E shall be to identify the tariff rate. If the total quantity (without tariffication) is monitored, then its value shall be 0.

D.3 Coding of OBIS identifications

To identify different instances of the same interface class, their logical_name must be different. In COSEM, the logical_name is taken from the OBIS definition (see IEC 62056-61).

OBIS codes are used within the COSEM environment as an *octet-string* [6]. Each octet contains the unsigned value of the corresponding OBIS value group, coded without tags.

If a data item is identified by less than six value groups, all unused value groups must be filled with 255.

Octet 1 contains the binary coded value of A (A = 0, 1, 2, ...9) in the four rightmost bits. The four leftmost bits contain the information on the identification system. The four leftmost bits set to zero indicate that the OBIS identification system (version 1) is used as logical_name.

Identification system used	Four leftmost bits of octet 1 (MSB left)
OBIS, see IEC 62056-61.	0 0 0 0
Reserved for future use	0 0 0 1 ... 1 1 1 1

Within all value groups the usage of a certain selection is fully defined, others are reserved for future use.

If in the value groups B to F a value belonging to the manufacturer specific range (see IEC 62056-61, 4.8) is used, then the whole OBIS code shall be considered as manufacturer specific, and the value of the other groups does not necessarily carry a meaning defined by IEC 62056-61 nor this standard.

Annex E (informative)

Previous versions of interface classes

E.1 Interface class versions prior to the publication of the first edition of this standard

Prior to the publication of the first edition of this standard, previous versions of the following interface classes had been defined by and can be obtained from the DLMS User Association:

- “Profile generic” (class_id = 7, version = 0);
- “Association SN” (class_id = 12, version = 0).

E.2 IEC local port setup (class_id: 19, version 0)

Instances of this interface class define the operational parameters for communication using IEC 62056-21. Several ports can be configured. The logical_names shall be as defined in D.2.1.12.

IEC local port setup		0...n	class_id = 19, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. default_mode	(static)	enum			
3. default_baud	(static)	enum			
4. prop_baud	(static)	enum			
5. response_time	(static)	enum			
6. device_addr	(static)	octet-string			
7. pass_p1	(static)	octet-string			
8. pass_p2	(static)	octet-string			
9. pass_w5	(static)	octet-string			
Specific method(s)		m/o			

Attribute description

default_mode	Defines the protocol used by the meter on the port. enum (0) protocol according to IEC 62056-21 (modes A...E) (1) protocol according to IEC 62056-46. Using this enumeration value, all other attributes of this class are not applicable.
default_baud	Defines the baud rate for the opening sequence. enum (0) 300 baud, (1) 600 baud, (2) 1 200 baud, (3) 2 400 baud, (4) 4 800 baud, (5) 9 600 baud, (6) 19 200 baud, (7) 38 400 baud, (8) 57 600 baud, (9) 115 200 baud

prop_baud	Defines the baud rate to be proposed by the meter.
enum	(0) 300 baud, (1) 600 baud, (2) 1 200 baud, (3) 2 400 baud, (4) 4 800 baud, (5) 9 600 baud, (6) 19 200 baud, (7) 38 400 baud, (8) 57 600 baud, (9) 115 200 baud
response_time	Defines the minimum time between the reception of a request (end of request telegram) and the transmission of the response (begin of response telegram).
enum	(0) 20 ms (1) 200 ms
device_addr	Device address according to IEC 62056-21.
	octet-string
pass_p1	Password 1 according to IEC 62056-21.
	octet-string
pass_p2	Password 2 according to IEC 62056-21.
	octet-string
pass_w5	Password W5 reserved for national applications.
	octet-string

E.3 PSTN modem configuration (class_id: 27, version 0)

An instance of the “PSTN modem configuration” class stores data related to the initialization of modems, which are used for data transfer from/to a device. Several modems can be configured. The logical_names shall be as defined in D.2.1.2.

PSTN modem configuration		0...n	class_id = 27, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string	0	9	5
2. comm_speed	(static)	enum			
3. initialization_string	(static)	array			
4. modem_profile	(static)	array			
Specific method(s)		m/o			

Attribute description

comm_speed	<p>The communication speed between the device and the modem, not necessarily the communication speed on the WAN.</p> <pre>enum: (0) 300 baud, (1) 600 baud, (2) 1 200 baud, (3) 2 400 baud, (4) 4 800 baud, (5) 9 600 baud, (6) 19 200 baud, (7) 38 400 baud, (8) 57 600 baud, (9) 115 200 baud</pre>
initialization_string	<p>This data contains all the necessary initialization commands to be sent to the modem in order to configure it properly. This may include the configuration of special modem features.</p> <pre>initialization_string ::= array initialization_string_element ::= structure { request: octet-string, response: octet-string }</pre> <p>If the array contains more than one initialization string element, they are subsequently sent to the modem after receiving an answer matching the defined response.</p> <p>REMARK It is assumed that the modem is pre-configured so that it accepts the initialization_string. If no initialization is needed, the initialization string is empty.</p>
modem_profile	<p>This data defines the mapping from Hayes standard commands/responses to modem specific strings.</p> <pre>modem_profile ::= array { modem_profile_element: octet-string }</pre> <p>The modem_profile array must contain the corresponding strings for the modem used in following order:</p> <pre>Element 0: OK, Element 1: CONNECT, Element 2: RING, Element 3: NO CARRIER, Element 4: ERROR, Element 5: CONNECT 1 200, Element 6: NO DIAL TONE, Element 7: BUSY, Element 8: NO ANSWER, Element 9: CONNECT 600, Element 10: CONNECT 2 400, Element 11: CONNECT 4 800, Element 12: CONNECT 9 600, Element 13: CONNECT 14 400, Element 14: CONNECT 28 800, Element 15: CONNECT 36 600, Element 16: CONNECT 56 000</pre>

E.4 PSTN auto dial (class_id: 29, version 0)

An instance of the “PSTN auto dial” class stores data related to the management data transfer between the device and the modem to perform auto dialling. Several modems can be configured. The logical_names shall be as defined in D.2.1.3.

PSTN auto dial		0...n	class_id = 29, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. mode	(static)	enum			
3. repetitions	(static)	unsigned			
4. repetition_delay	(static)	long-unsigned			
5. calling_window	(static)	array			
6. phone_list	(static)	array			
Specific method(s)	m/o				

Attribute description

logical_name	Identifies the “PSTN auto dial” object instance.				
mode	Defines if the device can perform auto-dialling. mode ::= enum (0) no auto dialling, (1) auto dialling allowed anytime, (2) auto dialling allowed within the validity time of the calling window, (3) “regular” auto dialling allowed within the validity time of the calling window; “alarm” initiated auto dialling allowed anytime, (200...255) manufacturer specific modes				
repetitions	The maximum number of trials in case of unsuccessful dialling attempts.				
repetition_delay	The time delay, expressed in seconds until an unsuccessful dial attempt can be repeated. repetition_delay 0 means delay is not specified.				
calling_window	Contains the start and end date/time stamp when the window becomes active (for the start instant), or inactive (for the end instant). The start_date defines implicitly the period. Example: when day of month is not specified (equal to 0 x FF) this means that we have a daily share line management. Daily, monthly ...window management can be defined. calling_window ::= array window_element window_element ::= structure { start_time: octet-string, end_time: octet-string } start_time and end_time are formatted as set in 4.4.1 for <i>date_time</i>				

phone_list	Contains phone numbers, the device modem has to call under certain conditions. The link between entries in the array and the conditions are not contained in here.
	<pre> phone_list ::= array { phone_number: octet-string } </pre>

E.5 IEC HDLC setup class, (class_id:23, version 0)

An instance of the “HDLC setup class” contains all data necessary to set up a communication channel according to IEC 62056-46. Several communication channels can be configured. The logical_names shall be as defined in D.2.1.14.

IEC HDLC setup		0...n	class_id = 23, version = 0		
Attribute(s)		Data type	Min.	Max.	Def.
1. logical_name	(static)	octet-string			
2. comm_speed	(static)	enum	0	9	5
3. window_size_transmit	(static)	unsigned	1	7	1
4. window_size_receive	(static)	unsigned	1	7	1
5. max_info_field_length_transmit	(static)	unsigned	32	128	128
6. max_info_field_length_receive	(static)	unsigned	32	128	128
7. inter_octet_time_out	(static)	long-unsigned	20	1000	30
8. inactivity_time_out	(static)	long-unsigned	0		120
9. device_address	(static)	long-unsigned	16	0x3FFD	0
Specific method(s)		m/o			

Attribute description

comm_speed	<p>The communication speed supported by the corresponding port:</p> <pre> enum: (0) 300 baud, (1) 600 baud, (2) 1 200 baud, (3) 2 400 baud, (4) 4 800 baud, (5) 9 600 baud, (6) 19 200 baud, (7) 38 400 baud, (8) 57 600 baud, (9) 115 200 baud </pre> <p>This communication speed can be overridden if the HDLC mode of a device is entered through a special mode of another protocol.</p>
window_size_transmit	The maximum number of frames that a device or system can transmit before it needs to receive an acknowledgement from a corresponding station. During logon, other values can be negotiated.

window_size_receive	The maximum number of frames that a device or system can receive before it needs to transmit an acknowledgement to the corresponding station. During logon, other values can be negotiated.																				
max_info_length_transmit	The maximum information field length that a device can transmit. During logon, a smaller value can be negotiated.																				
max_info_length_receive	The maximum information field length that a device can receive. During logon, a smaller value can be negotiated.																				
Inter_octet_time_out	Defines the time, expressed in milliseconds, over which, when any character is received from the primary station, the device will treat the already received data as a complete frame.																				
inactivity_time_out	<p>Defines the time, expressed in seconds over which, when any frame is received from the primary station, the device will process a disconnection.</p> <p>When this value is set to 0, this means that the inactivity_time_out is not operational.</p>																				
device_address	<p>Contains the physical device address of a device:</p> <p>In the case of single byte addressing:</p> <table> <tr> <td>0x00</td><td>NO_STATION Address,</td></tr> <tr> <td>0x01...0x0F</td><td>Reserved for future use,</td></tr> <tr> <td>0x10...0x7D</td><td>Usable address space,</td></tr> <tr> <td>0x7E</td><td>'CALLING' device address,</td></tr> <tr> <td>0x7F</td><td>Broadcast address</td></tr> </table> <p>In the case of double byte addressing:</p> <table> <tr> <td>0x0000</td><td>NO_STATION address,</td></tr> <tr> <td>0x0001...0x000F</td><td>Reserved for future use,</td></tr> <tr> <td>0x0010...0x3FFD</td><td>Usable address space,</td></tr> <tr> <td>0x3FFE</td><td>'CALLING' physical device address,</td></tr> <tr> <td>0x3FFF</td><td>Broadcast address</td></tr> </table>	0x00	NO_STATION Address,	0x01...0x0F	Reserved for future use,	0x10...0x7D	Usable address space,	0x7E	'CALLING' device address,	0x7F	Broadcast address	0x0000	NO_STATION address,	0x0001...0x000F	Reserved for future use,	0x0010...0x3FFD	Usable address space,	0x3FFE	'CALLING' physical device address,	0x3FFF	Broadcast address
0x00	NO_STATION Address,																				
0x01...0x0F	Reserved for future use,																				
0x10...0x7D	Usable address space,																				
0x7E	'CALLING' device address,																				
0x7F	Broadcast address																				
0x0000	NO_STATION address,																				
0x0001...0x000F	Reserved for future use,																				
0x0010...0x3FFD	Usable address space,																				
0x3FFE	'CALLING' physical device address,																				
0x3FFF	Broadcast address																				

Bibliography

IEC 61334-6:2000, *Distribution automation using distribution line carrier systems – Part 6: A-XDR encoding rule*

ISO/IEC 646:1991, *Information technology – ISO 7-bit coded character set for information interchange*

ITU Recommendation X.217:1995, *Information technology – Open Systems Interconnection – Service definition for the Association Control Service Element*

ITU Recommendation X.227:1995, *Information technology – Open Systems Interconnection Connection-oriented protocol for the Association Control Service Element: Protocol specification*

IEEE 754:1985, *IEEE Standard for Binary Floating-Point Arithmetic*

RFC 0768 – *User Datagram Protocol (Also: IETF:STD 0006), 1980*

RFC 0791 – *Internet Protocol (Also: IETF STD 0005), 1981, Updated by: RFC 1349, Obsoletes: RFC 760*

RFC 0792 – *Internet Control Message Protocol (Also: IETF STD 0005), 1981, Updated by: RFC 0950, Obsoletes: RFC 0777*

RFC 0793 – *Transmission Control Protocol (Also: IETF STD 0007), 1981, Updated by: RFC 3168*

RFC 0821 – *Simple Mail Transfer Protocol (Also: IETF STD 0010), 1982*

RFC 0940 – *Toward an Internet standard scheme for subnetting, 1985*

RFC 0950 – *Internet Standard Subnetting Procedure, 1985, Updates: RFC 0792*

RFC 1321 – *The MD5 Message-Digest Algorithm, 1992*

RFC 1332 – *The PPP Internet Protocol Control Protocol (IPCP), 1992, Updated by: RFC 3241, Obsoletes: RFC 1172*

RFC 1661 – *The Point-to-Point Protocol (PPP) (Also: IETF STD 0051), 1994, Updated by: RFC 2153, Obsoletes: RFC 1548*

RFC 1662 – *PPP in HDLC-like Framing, (Also: IETF STD 0051), 1994, Obsoletes: RFC 1549*

RFC 1700 – *Assigned numbers (Also: IETF: STD 0002), 1994, Obsoletes: RFC 1340*

RFC 2507 – *IP Header Compression, 1999*

RFC 2821 – *Simple Mail Transfer Protocol, 2001, Obsoletes: RFC0821, RFC0974, RFC1869*

RFC 3241 – *Robust Header Compression (ROHC) over PPP, 2002, Updates: RFC1332*

RFC 3544 – *IP Header Compression over PPP, 2003, Obsoletes: RFC 2509*

FIPS PUB 180-1: 1995, *Secure hash standard*

FEDERAL INFORMATION PROCESSING STANDARDS PUBLICATION

U.S. DEPARTMENT OF COMMERCE/National Institute of Standards and Technology

Index

- 4-pass authentication protocol, 22
- Abstract object, 97, 105
- Access rights, 21
- ACSE, 22
- Active energy, 113
- Active power**, 113
- Activity calendar, 48, 49, 91, 97, 100
- Algorithm**, 113, 114, 115
- Apparent energy, 115
- Apparent power, 114
- Application association, 10
- Application Protocol Data Unit, 10
- Association, 21, 97, 104, 119
- Association LN, 13, 51
- Association SN, 13, 56, 92, 96, 119
- Association view, 21
- association_status**, 54
- Attribute, 11, 13, 14
- Authentication**, 22
- Auto answer, 70, 93, 99
- Auto connect, 71, 94, 98
- Auto dial, 122
- A-XDR, 125
- base_name, 56, 88, 96
- Battery, 108
- Billing period, 99, 110, 111, 117
- Billing period counter, 111
- Block demand, 33
- Broadcast, 99
- Broadcast address, 74, 124
- Buffer**, 36
- Calendar, 48
- Calling_Authentication_Value, 22
- Capture period, 106, 109, 111, 116
- capture_objects**, 37
- capture_period**, 37
- Captured object, 111, 116
- Cardinality**, 13
- Challenge, 22, 55, 58
- CHAP, 81
- Class description template, 13
- Class name, 13
- class_id, 13, 51
- client_SAP, 52
- Clock, 23, 40, 41, 47, 90, 97, 98
- Coefficients, 112
- Communication port log, 109
- Configuration, 106
- Configuration data, 13
- Configuration program, 112
- Conformance block, 53
- COSEM logical device name**, 21
- Cumulative value, 110
- Current and last average values, 110
- Current association, 21, 92
- current_average_value, 30
- Data, 23, 25, 59, 64, 88, 106, 108, 109, 110, 112, 113, 114, 115, 117
- Data format, 14, 16
- Data model, 87
- Data of previous billing periods, 110
- Data type, 13, 14, 15
- Date and time, 16
- Daylight saving, 40, 47
- Default, 14
- Demand register, 23, 30, 31, 33, 34, 59, 89, 110
- Device ID**, 106
- DHCP, 79
- DLMS User Association, 21
- DLMS version, 53
- EAP, 81
- Eavesdropping, 22
- Electrical port, 101
- Electricity, 110
- Encryption key, 23, 55, 58
- Error values, 109
- Ethernet setup, 80, 95, 103
- Extended, 110
- Extended register, 29, 32, 33, 34, 59, 64, 89, 107, 108, 109, 110, 112, 116, 117
- Fundamental, 113, 114, 116
- gateway_IP_address**, 79
- Global positioning system, 42
- GMT, 17, 40, 41
- GPRS modem setup, 85, 96, 104
- Harmonics, 113, 116
- Hayes standard, 69, 121
- HDLC mode, 73, 123
- HDLC setup, 97, 102
- HDLC setup class, 73, 123
- High Level Security**, 22
- HLS secret, 55, 58
- I/O control signals, 107
- ID numbers**, 111
- Identification system, 118
- IEC HDLC setup, 94
- IEC local port setup, 97
- IEC twisted pair (1) setup, 74, 94, 102
- Information, measured, 12
- Information, static, 12
- Instances, 13
- Instantaneous value, 110
- Instantiation, 8, 11, 12, 13, 25, 26, 59, 66
- Interface class, 11, 23
- Interface object, 11
- Internal control signals, 107
- internal operating status, 107
- Intrinsic security, 22
- IP_address, 78
- IP_options**, 78
- IPv4 setup, 77, 95, 103
- last_average_value, 30
- Leap years, 40
- Link Control Protocol, 81
- List objects**, 109, 117
- listening_window**, 71
- LLS secret, 58
- LLS_secret**, 54
- Local port setup, 67, 93, 101, 119

- Logical device, 20, 21, 51, 56, 59
- Logical device name, 96, 97, 105
- Logical name, 12, 13, 25, 88
- Logical name referencing, 21, 51
- logical_name, 11
- Low Level Security**, 22
- Maintenance, 66
- Management logical device, 21, 22
- Mandatory, 13, 14
- Mapping, 97
- Maximum, 14
- Maximum and minimum values, 110
- MDI reset, 99
- Message replay, 22
- Meter reset, 99
- Metering point ID, 106, 116
- Method, 11, 13, 14
- Minimum, 14
- Modem, 68, 69, 70, 98, 120, 121, 122
- Modem configuration, 68, 93, 97, 98, 120
- Network Control Protocol, 83
- Nominal value**, 112
- Normal mode, 99
- Notation, 13
- number_of_periods, 30
- OBIS, 12, 13, 25, 29, 30, 97, 118
- OBIS codes, 87
- Object modelling, 11
- object_list*, 21, 51, 55, 56, 57
- Occurrence counter, 110
- Operating time, 108
- Optical port, 101
- Optical test output, 99
- Optional, 13, 14
- Output signals, 99
- PAP, 81
- Parameter changes**, 106
- Parameter record, 112
- Passive calendar, 51
- Password, 22, 58
- Period, 30
- Physical device, 20, 59, 104
- Power factor, 115
- Power factor, displacement, 116
- Power factor, true, 116
- Power fail, 45
- Power failure, 47, 77
- Power failure monitoring, 108
- PPP setup, 80, 95, 103
- PPP_authentication**, 84
- Preferred readout**, 40
- primary_DNS_address**, 80
- Process value, 13, 25
- Profile entries, 106, 109, 111, 116
- Profile generic, 23, 35, 36, 90, 106, 109, 110, 111, 112, 116, 119
- Program entries**, 112
- Proprietary, 11
- Public client, 22
- Pulse constant**, 112
- Ratios, 112
- RCR, 112
- Reactive energy, 114
- Reactive power, 114
- Readout, 40, 97
- Register, 12, 25, 26, 29, 33, 34, 59, 64, 88, 107, 108, 109, 110, 112, 116, 117
- Register activation, 33, 89, 97, 100
- Register monitor, 59, 92, 101, 117, 118
- Register table, 62, 93
- register_assignment, 33
- Reserved base_names, 96
- Reset**, 27
- SAP, 59
- SAP assignment, 21, 22, 58, 92, 96, 97, 104
- scaler_unit**, 26
- Schedule, 44, 45, 48, 91, 97, 100
- Script, 43, 45, 47, 62, 92
- Script table, 43, 49, 59, 62, 90, 96, 97, 99
- Season, 40
- secondary_DNS_address**, 80
- Secret, 22, 56, 58
- Secret key, 22
- Selective access**, 14, 37, 38, 51, 55, 56, 61
- Selective access parameters, 14
- Server model, 20
- server_SAP, 52
- Shared line, 70
- Short name, 88
- Short name referencing, 21
- Single action schedule, 61, 92, 97, 101
- Sliding demand, 33
- SMTP setup, 86, 96, 104
- Sort method, 106, 109, 111, 116
- sort_method**, 37
- sort_object**, 38
- Special days, 44, 48
- Special days table**, 48, 49, 91, 97, 100
- Standard readout profile**, 101
- Status mapping, 65, 93
- Status register, 109
- Status value, 25
- subnet_mask**, 79
- Tariffication, 33, 99, 100
- TCP-UDP setup, 76, 95, 103
- TCP-UDP_port**, 76
- Test mode, 99
- Threshold values, 117
- Threshold, missing, 117
- Threshold, over limit, 117
- Threshold, under limit, 117
- Time changes, 47
- Time integral values, 110
- Time setting backward**, 47
- Time setting forward**, 47
- Time switch, 112
- Time synchronization, 47
- Twisted pair, 74
- Twisted pair setup, 97
- Unit, 27
- Utility tables, 60, 92, 97, 105
- Value, 12, 26

Value group, 62
Value group B, 98
Value group C, 97
Value group D, 110

Value group E, 98
Value group F, 117
Version, 13, 51, 66, 118, 119



Standards Survey

The IEC would like to offer you the best quality standards possible. To make sure that we continue to meet your needs, your feedback is essential. Would you please take a minute to answer the questions overleaf and fax them to us at +41 22 919 03 00 or mail them to the address below. Thank you!

Customer Service Centre (CSC)

International Electrotechnical Commission

3, rue de Varembé

1211 Genève 20

Switzerland

or

Fax to: **IEC/CSC** at +41 22 919 03 00

Thank you for your contribution to the standards-making process.

A Prioritaire

Nicht frankieren
Ne pas affranchir



Non affrancare
No stamp required

RÉPONSE PAYÉE

SUISSE

Customer Service Centre (CSC)

International Electrotechnical Commission

3, rue de Varembé

1211 GENEVA 20

Switzerland



Q1 Please report on **ONE STANDARD** and **ONE STANDARD ONLY**. Enter the exact number of the standard: (e.g. 60601-1-1)

.....

Q2 Please tell us in what capacity(ies) you bought the standard (tick all that apply). I am the/a:

- purchasing agent ☐
librarian ☐
researcher ☐
design engineer ☐
safety engineer ☐
testing engineer ☐
marketing specialist ☐
other.....

Q3 I work for/in/as a:
(tick all that apply)

- manufacturing ☐
consultant ☐
government ☐
test/certification facility ☐
public utility ☐
education ☐
military ☐
other.....

Q4 This standard will be used for:
(tick all that apply)

- general reference ☐
product research ☐
product design/development ☐
specifications ☐
tenders ☐
quality assessment ☐
certification ☐
technical documentation ☐
thesis ☐
manufacturing ☐
other.....

Q5 This standard meets my needs:
(tick one)

- not at all ☐
nearly ☐
fairly well ☐
exactly ☐

Q6 If you ticked NOT AT ALL in Question 5 the reason is: (tick all that apply)

- standard is out of date ☐
standard is incomplete ☐
standard is too academic ☐
standard is too superficial ☐
title is misleading ☐
I made the wrong choice ☐
other

Q7 Please assess the standard in the following categories, using the numbers:

- (1) unacceptable,
(2) below average,
(3) average,
(4) above average,
(5) exceptional,
(6) not applicable

- timeliness.....
quality of writing.....
technical contents.....
logic of arrangement of contents
tables, charts, graphs, figures.....
other

Q8 I read/use the: (tick one)

- French text only ☐
English text only ☐
both English and French texts ☐

Q9 Please share any comment on any aspect of the IEC that you would like us to know:

.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....



ISBN 2-8318-8895-6



9 782831 888958

ICS 91.140.50; 35.200

Typeset and printed by the IEC Central Office
GENEVA, SWITZERLAND