

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**IEC 62271-305**  
Edition 1.0 2009-11

**High-voltage switchgear and controlgear –**

**Part 305: Capacitive current switching capability of air-insulated  
Disconnectors for rated voltages above 52 kV**

### **CORRIGENDUM 1**

#### **5.6 Test circuit**

*Replace the existing second paragraph after Figure 1 by the following new paragraph:*

For each test current, the ratio  $C_S/C_L$  should be agreed between the manufacturer and the user.