

To: jeffrey Epstein[jeevacation@gmail.com]
From: Richard Barnett
Sent: Wed 12/8/2010 9:43:48 PM
Subject: FW: 9 E.71st St - Cellar Drain Piping
EpsteinCellarDrainPiping12-8-10.pdf

Mr. Epstein we had the grease trap in the basement cleaned out today to hopefully get the catering kitchen sinks in C- Level back on line. We also found a problem with the main 3" drain pipe that runs 50 feet across the SC -Level ceiling clogged solid also with grease, that connects to the grease trap . The best way to resolve this issue is to replace the piping and remove for disposal attached is a proposal for your approval for \$2,940.00 please approve so we can get all three kitchen sinks working. Thanks Richard.

Date: Wed, 8 Dec 2010 14:44:34 -0500
From: [REDACTED]
Subject: 9 E.71st St - Cellar Drain Piping
To: rbhvac@msn.com

Rich -

Please see attached estimate.

Thanks
Kevin

Kevin McCarthy
Brennan Bros. Co. Inc.
3150 Albany Crescent
Bronx, NY 10463

p [REDACTED]
f [REDACTED]