

To: [REDACTED]
Cc: Richard Barnett [REDACTED]
From: Jeffrey Epstein
Sent: Tue 9/11/2012 5:43:52 PM
Subject: Re: Clay Valve

ok

On Tue, Sep 11, 2012 at 1:39 PM, brice gordon <[REDACTED]> wrote:

FYI

As discussed, the clay valve which control water level at the main reservoir has failed.

Therefore we can not control water levels or quality at the reservoir.

This in turn affects cooling tower operation and pool water quality. It is my understanding that it has been rebuilt several times.

I have arrange JBH to replace. Cost for valve \$4000.00 this included expedited shipping.

Install should take a day.

--

Brice Gordon

USVI

Phone: [REDACTED]

New Mexico

Phone: [REDACTED]

--

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of Jeffrey Epstein

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved